

## RESULTS

Below are the results from the first round of testing of drinking water for lead that was conducted at Academy Kids Childcare on March 14, 2025. Overall, two (2) outlets were tested resulting in a total of four (4) samples being sent to the lab.

- Three (3) samples had no detectable level of lead.
- One (1) sample had a low detection of lead between 1.0 and 14.9 µg/L.
- Zero (0) samples had a high detection of lead equal to or above 15.0 µg/L.

The table below shows all sample results. Sample results are in micrograms per liter, shown as µg/L. For more information on how to read this report, please see our **Results Interpretation Fact Sheet**.

Sample ID	Outlet Description	First Draw (µg/L)	Flush (µg/L)	Remedial Action
		Initial Sampling		
Non-Detect (<1.0 µg/L)				
1-1-KIT-KF2	Kitchen faucet in facility kitchen; left side	<1.0	<1.0	N/A
Low Detection (1.0 - 14.9 µg/L)				
1-1-KIT-KF1	Kitchen faucet in facility kitchen; right side next to door	1.0	<1.0	