



OKLAHOMA DRINKING WATER

LEAD TESTING

IN PUBLIC SCHOOLS & CHILD CARE FACILITIES

District: Lindsey Asher Partnerships
School: Advance Start Learning Center
Sampling Date: 3/14/2025
Status: Remediation

RESULTS

Below are the results from the first round of testing of drinking water for lead that was conducted at Lindsey Asher Partnerships - Advance Start Learning Center on March 14, 2025. Overall, thirteen (13) outlets were tested resulting in a total of twenty-six (26) samples being sent to the lab.

- Fifteen (15) samples had no detectable level of lead.
- Eleven (11) samples had a low detection of lead between 1.0 and 14.9 µg/L.
- Zero (0) samples had a high detection of lead equal to or above 15.0 µg/L.

The table below shows all sample results. Sample results are in micrograms per liter, shown as µg/L. For more information on how to read this report, please see our **Results Interpretation Fact Sheet**.

Sample ID	Outlet Description	First Draw (µg/L)	Flush (µg/L)	Remedial Action
		Initial Sampling		
Non-Detect (<1.0 µg/L)				
1-1-LOB-WC1	Water cooler in lobby; left side	<1.0	<1.0	N/A
1-1-LOB-WC2	Water cooler in lobby; right side	<1.0	<1.0	N/A
1-1-KB-BF1	Bathroom faucet in kids' bathroom; far left side	<1.0	<1.0	N/A
1-1-KB-BF2	Bathroom faucet in kids' bathroom; left center unit	<1.0	<1.0	N/A
1-1-IR-CF1	Classroom faucet in infant room	<1.0	<1.0	N/A
Low Detection (1.0 - 14.9 µg/L)				
1-1-KIT-KF2	Kitchen faucet in facility kitchen; left of burners	1.1	<1.0	
1-1-KB-BF4	Bathroom faucet in kids' bathroom; far right side	1.2	1.1	
1-1-KB-BF3	Bathroom faucet in kids' bathroom; right center unit	<1.0	1.4	
1-1-LOB-CF1	Classroom faucet in lobby	1.7	<1.0	
1-1-KIT-KF1	Kitchen faucet in facility kitchen; traditional sink	1.7	1.4	

Sample ID	Outlet Description	First Draw ($\mu\text{g/L}$)	Flush ($\mu\text{g/L}$)	Remedial Action
		Initial Sampling		
1-1-SR-BF1	Bathroom faucet in staff restroom	1.8	<1.0	
1-1-2Y-CF1	Classroom faucet in 2-year old room	5.4	<1.0	
Borderline (10.0 – 14.9 $\mu\text{g/L}$)				
1-1-1Y-CF1	Classroom faucet in 1-year old room	11.7	1.3	