



OKLAHOMA DRINKING WATER

# LEAD TESTING

IN PUBLIC SCHOOLS & CHILD CARE FACILITIES

District: C.A.R.D. Head Starts

School: Coweta

Sampling Date: 11/26/2024

Status: Complete

## RESULTS

Below are the results from the first round of testing of drinking water for lead that was conducted at C.A.R.D. Head Starts - Coweta on November 26, 2024. Overall, six (6) outlets were tested resulting in a total of twelve (12) samples being sent to the lab.

- Twelve (12) samples had no detectable level of lead.
- Zero (0) samples had a low detection of lead between 1.0 and 14.9 µg/L.
- Zero (0) samples had a high detection of lead equal to or above 15.0 µg/L.

The table below shows all sample results. Sample results are in micrograms per liter, shown as µg/L. For more information on how to read this report, please see our **Results Interpretation Fact Sheet**.

Sample ID	Outlet Description	First Draw (µg/L)	Flush (µg/L)	Remedial Action
		Initial Sampling		
Non-Detect (<1.0 µg/L)				
1-1-KIT-KF 1	Big Sink in Kitchen	<1.0	<1.0	N/A
1-1-HALL-WC1	Water Cooler in Hall, left from entrance	<1.0	<1.0	N/A
1-1-2-CF1	Classroom ‘Coweta 2’ short sink	<1.0	<1.0	N/A
1-1-1-CF1	Classroom ‘Coweta 1’ short sink	<1.0	<1.0	N/A
1-1-BR-BF1	Bathroom between classrooms LEFT sink	<1.0	<1.0	N/A
1-1-BR-BF2	Bathroom between classrooms RIGHT sink	<1.0	<1.0	N/A