



District: Community Action Agency of Oklahoma City  
 School: New Heights Head Start  
 Sampling Date: 8/21/2024  
 Status: Complete

## RESULTS

Below are the results from the first round of testing of drinking water for lead that was conducted at Community Action Agency of Oklahoma City - New Heights Head Start on August 21, 2024. Overall, eleven (11) outlets were tested resulting in a total of twenty-two (22) samples being sent to the lab.

- Twenty-two (22) samples had no detectable level of lead.
- Zero (0) samples had a low detection of lead between 1.0 and 14.9 µg/L.
- Zero (0) samples had a high detection of lead equal to or above 15.0 µg/L.

The table below shows all sample results. Sample results are in micrograms per liter, shown as µg/L. For more information on how to read this report, please see our **Results Interpretation Fact Sheet**.

Sample ID	Comments	First Draw (µg/L)	Flush (µg/L)	Remedial Action
		Initial Sampling		
Non-Detect (<1.0 µg/L)				
1-1-C-CF1	Classroom faucet in Classroom C	<1.0	<1.0	N/A
1-1-KIT-KF1	Kitchen faucet in facility kitchen	<1.0	<1.0	N/A
1-1-HALL-WC1	Elkay water cooler in hallway near kitchen	<1.0	<1.0	N/A
1-1-HALL-IM1	Ice machine in hallway near kitchen	<1.0	<1.0	N/A
1-1-HALL-CF1	Classroom faucet in back hallway near kitchen	<1.0	<1.0	N/A
1-1-AR-BF1	Bathroom faucet in adult restroom	<1.0	<1.0	N/A
1-1-D-BF1	Bathroom faucet in Classroom D	<1.0	<1.0	N/A
1-1-BR-BF1	Bathroom faucet in boys' restroom; left side	<1.0	<1.0	N/A
1-1-BR-BF2	Bathroom faucet in boys' restroom; right side	<1.0	<1.0	N/A
1-1-GR-BF1	Bathroom faucet in girls' restroom; left side	<1.0	<1.0	N/A
1-1-GR-BF2	Bathroom faucet in girls' restroom; right side	<1.0	<1.0	N/A