



District: Community Action Agency of Oklahoma City

School: Our Spot Head Start

Sampling Date: 8/20/2024

Status: Remediation

## RESULTS

Below are the results from the first round of testing of drinking water for lead that was conducted at Community Action Agency of Oklahoma City - Our Spot Head Start on August 20, 2024.

Overall, sixteen (16) outlets were tested resulting in a total of thirty-two (32) samples being sent to the lab.

- Twenty-one (21) samples had no detectable level of lead.
- Eleven (11) samples had a low detection of lead between 1.0 and 14.9 µg/L.
- Zero (0) samples had a high detection of lead equal to or above 15.0 µg/L.

The table below shows all sample results. Sample results are in micrograms per liter, shown as µg/L. For more information on how to read this report, please see our **Results Interpretation Fact Sheet**.

Sample ID	Comments	First Draw (µg/L)	Flush (µg/L)	Remedial Action
		Initial Sampling		
<b>Non-Detect (&lt;1.0 µg/L)</b>				
1-1-2-CF2	Classroom faucet in Rm 2; middle left sink	<1.0	<1.0	N/A
1-1-2-CF4	Classroom faucet in Rm 2; far right sink	<1.0	<1.0	N/A
1-1-3-WC1	Elkay water cooler in Rm 3; not often used; flushed	<1.0	<1.0	N/A
1-1-KIT-IM1	Manitowoc ice machine in facility kitchen	<1.0	<1.0	N/A
1-1-2-WC1	Elkay water cooler in Rm 2	<1.0	<1.0	N/A
<b>Low Detection (1.0 - 14.9 µg/L)</b>				
1-1-RR-BF1	Bathroom faucet in bathroom 1	1.1	<1.0	
1-1-2-CF1	Classroom faucet in Rm 2; far left sink	1.4	<1.0	
1-1-RR-BF3	Bathroom faucet in bathroom 3; left side	1.5	<1.0	
1-1-RR-BF2	Bathroom faucet in bathroom 2	1.6	<1.0	
1-1-1-CF3	Classroom faucet in Rm 1; middle right sink	1.9	<1.0	
1-1-RR-BF4	Bathroom faucet in bathroom 3; right side	1.9	<1.0	
1-1-1-CF1	Classroom faucet in Rm 1; far left sink	2.2	<1.0	
1-1-KIT-KF1	Kitchen faucet in facility kitchen	2.2	<1.0	

Sample ID	Comments	First Draw (µg/L)	Flush (µg/L)	Remedial Action
		Initial Sampling		
1-1-1-CF4	Classroom faucet in Rm 1; far right sink	2.4	<1.0	
1-1-1-CF2	Classroom faucet in Rm 1; middle left sink	2.4	<1.0	
1-1-2-CF3	Classroom faucet in Rm 2; middle right sink	4.2	<1.0	