



OKLAHOMA DRINKING WATER

LEAD TESTING

IN PUBLIC SCHOOLS & CHILD CARE FACILITIES

District: C.A.R.D. Head StartsSchool: Catoosa I (Spunky) Head StartSampling Date: 9/17/2024Status: Remediation

RESULTS

Below are the results from the first round of testing of drinking water for lead that was conducted at C.A.R.D. Head Starts - Catoosa I (Spunky) Head Start on September 17, 2024. Overall, twelve (12) outlets were tested resulting in a total of twenty-four (24) samples being sent to the lab.

- Twenty-one (21) samples had no detectable level of lead.
- Three (3) samples had a low detection of lead between 1.0 and 14.9 µg/L.
- Zero (0) samples had a high detection of lead equal to or above 15.0 µg/L.

The table below shows all sample results. Sample results are in micrograms per liter, shown as µg/L. For more information on how to read this report, please see our **Results Interpretation Fact Sheet**.

Sample ID	Comments	First Draw (µg/L)	Flush (µg/L)	Remedial Action
		Initial Sampling		
Non-Detect (<1.0 µg/L)				
1-1-KIT -KF1	Kitchen faucet in facility kitchen; large faucet with detachable sprayer	<1.0	<1.0	N/A
1-1-KIT-IM1	Manitowoc ice machine in facility kitchen	<1.0	<1.0	N/A
1-1-TL-CF1	Classroom faucet in teachers' lounge	<1.0	<1.0	N/A
1-1-1-CF1	Classroom faucet in Rm 1	<1.0	<1.0	N/A
1-1-1-CF2	Classroom faucet in Rm 1; on left side	<1.0	<1.0	N/A
1-1-2-CF1	Classroom faucet in Head Start Rm 2; left side	<1.0	<1.0	N/A
1-1-2-CF2	Classroom faucet in Head Start Rm 2; right side	<1.0	<1.0	N/A
1-1-E1-KF1	Kitchen faucet in Early Head Start Rm 1; front sink	<1.0	<1.0	N/A
1-1-E1-CF1	Classroom faucet in Early Head Start Rm 1; middle sink	<1.0	<1.0	N/A
Low Detection (1.0 - 14.9 µg/L)				
1-1-KIT-KF1	Kitchen faucet in facility kitchen; small faucet	1.6	<1.0	

Sample ID	Comments	First Draw (µg/L)	Flush (µg/L)	Remedial Action
		Initial Sampling		
1-1-B/A-CF2	Classroom faucet in before/after care room; back sink	2.1	<1.0	
1-1-B/A-CF1	Classroom faucet in before/after care room	8.2	<1.0	