



OKLAHOMA DRINKING WATER

# LEAD TESTING

IN PUBLIC SCHOOLS & CHILD CARE FACILITIES

District: C.A.R.D. Head Starts

School: Bartlesville East II Head Start

Sampling Date: 9/18/2024

Status: Complete

## RESULTS

Below are the results from the first round of testing of drinking water for lead that was conducted at C.A.R.D. Head Starts - Bartlesville East II Head Start on September 18, 2024. Overall, five (5) outlets were tested resulting in a total of ten (10) samples being sent to the lab.

- Ten (10) samples had no detectable level of lead.
- Zero (0) sample had a low detection of lead between 1.0 and 14.9 µg/L.
- Zero (0) sample had a high detection of lead equal to or above 15.0 µg/L.

The table below shows all sample results. Sample results are in micrograms per liter, shown as µg/L. For more information on how to read this report, please see our **Results Interpretation Fact Sheet**.

Sample ID	Outlet Description	First Draw (µg/L)	Flush (µg/L)	Remedial Action
		Initial Sampling		
Non-Detect (<1.0 µg/L)				
1-1-EAST-BF1	Bathroom faucet in East bathroom; sink does not include counter	<1.0	<1.0	N/A
1-1-EAST-BF2	Bathroom faucet in secondary east bathroom	<1.0	<1.0	N/A
1-1-CR-WC1	PWII water cooler in conference room	<1.0	<1.0	N/A
1-1-KIT-KF1	Kitchen faucet in facility kitchen	<1.0	<1.0	N/A
1-1-KIT-IM1	Manitowoc ice machine in facility kitchen	<1.0	<1.0	N/A