



OKLAHOMA DRINKING WATER

# LEAD TESTING

IN PUBLIC SCHOOLS &amp; CHILD CARE FACILITIES

District: C.A.R.D. Head StartsSchool: Pryor South Head StartSampling Date: 9/18/2024Status: Remediation

## RESULTS

Below are the results from the first round of testing of drinking water for lead that was conducted at C.A.R.D. Head Starts - Pryor South Head Start on September 18, 2024. Overall, thirteen (13) outlets were tested resulting in a total of twenty-six (26) samples being sent to the lab.

- Nineteen (19) samples had no detectable level of lead.
- Seven (7) samples had a low detection of lead between 1.0 and 14.9 µg/L.
- Zero (0) samples had a high detection of lead equal to or above 15.0 µg/L.

The table below shows all sample results. Sample results are in micrograms per liter, shown as µg/L. For more information on how to read this report, please see our **Results Interpretation Fact Sheet**.

Sample ID	Outlet Description	First Draw (µg/L)	Flush (µg/L)	Remedial Action
		Initial Sampling		
Non-Detect (<1.0 µg/L)				
1-1-KIT-KF1	Kitchen faucet in facility kitchen; small sink on left	<1.0	<1.0	N/A
1-1-KIT-KF2	Kitchen faucet in facility kitchen; large sink on right	<1.0	<1.0	N/A
1-1-1-CF2	Classroom faucet in Rm 1; tall sink	<1.0	<1.0	N/A
1-1-TL-KF1	Kitchen faucet in teachers' lounge	<1.0	<1.0	N/A
1-1-HALL-WC2	Elkay water cooler in hall; at end of left hall	<1.0	<1.0	N/A
1-1-2-CF1	Classroom faucet in Rm 2; tall sink near fridge	<1.0	<1.0	N/A
1-1-2-CF2	Classroom faucet in Rm 2; short sink	<1.0	<1.0	N/A
Low Detection (1.0 - 14.9 µg/L)				
1-1-1-CF1	Classroom faucet in Rm 1; short sink; has Pur filter	1.5	<1.0	
1-1-HB-CF1	Classroom faucet in Homebase room; tall sink near fridge	1.8	<1.0	
1-1-MR-CF1	Classroom faucet in meeting room; left sink	2.3	<1.0	

Sample ID	Outlet Description	First Draw (µg/L)	Flush (µg/L)	Remedial Action
		Initial Sampling		
1-1-MR -CF1	Classroom faucet in meeting room; right sink	2.4	<1.0	
1-1-HB-CF2	Classroom faucet in Homebase room; short sink	3.6	<1.0	
1-1-HALL-WC1	Elkay water cooler in hall; near teachers' lounge	5.2	7.4	