



OKLAHOMA DRINKING WATER

# LEAD TESTING

IN PUBLIC SCHOOLS & CHILD CARE FACILITIES

District: Sunbeam Family Services

School: Emerson's Little Wonders

Sampling Date: 10/10/2024

Status: Remediation

## RESULTS

Below are the results from the first round of testing of drinking water for lead that was conducted at Sunbeam Family Services - Emerson's Little Wonders on October 10, 2024. Overall, seven (7) outlets were tested resulting in a total of fourteen (14) samples being sent to the lab.

- Thirteen (13) samples had no detectable level of lead.
- One (1) sample had a low detection of lead between 1.0 and 14.9 µg/L.
- Zero (0) samples had a high detection of lead equal to or above 15.0 µg/L.

The table below shows all sample results. Sample results are in micrograms per liter, shown as µg/L. For more information on how to read this report, please see our **Results Interpretation Fact Sheet**.

Sample ID	Outlet Description	First Draw (µg/L)	Flush (µg/L)	Remedial Action
		Initial Sampling		
Non-Detect (<1.0 µg/L)				
1-1-D112-CF1	Classroom faucet in Rm D112	<1.0	<1.0	N/A
1-1-D112-DW1	Drinking water bubbler in Rm D112	<1.0	<1.0	N/A
1-1-A-CF1	Classroom faucet in Rm A	<1.0	<1.0	N/A
1-1-A-DW1	Drinking water bubbler in Rm A	<1.0	<1.0	N/A
1-1-D113-CF1	Classroom faucet in Rm D113	<1.0	<1.0	N/A
1-1-KIT-KF1	Kitchen faucet in facility kitchen	<1.0	<1.0	N/A
Low Detection (1.0 - 14.9 µg/L)				
1-1-D113-DW1	Drinking water bubbler in Rm D113	2.2	<1.0	