



OKLAHOMA DRINKING WATER

# LEAD TESTING

IN PUBLIC SCHOOLS &amp; CHILD CARE FACILITIES

District: Enid Public SchoolsSchool: Fowler Early Childhood CenterSampling Date: 8/13/2024Status: Remediation

## RESULTS

Below are the results from the first round of testing of drinking water for lead that was conducted at Enid Public Schools - Fowler Early Childhood Center on August 13, 2024. Overall, four (4) outlets were tested resulting in a total of eight (8) samples being sent to the lab.

- Seven (7) samples had no detectable level of lead.
- One (1) samples had a low detection of lead between 1.0 and 14.9 µg/L.
- Zero (0) samples had a high detection of lead equal to or above 15.0 µg/L.

The table below shows all sample results. Sample results are in micrograms per liter, shown as µg/L. For more information on how to read this report, please see our **Results Interpretation Fact Sheet**.

Sample ID	Comments	First Draw (µg/L)	Flush (µg/L)	Remedial Action
		Initial Sampling		
Non-Detect (<1.0 µg/L)				
1-1-COM-WC1	Elkay Bottle filler in commons 11	<1.0	<1.0	N/A
1-1-COM-WC2	Elkay water cooler in Commons 11	<1.0	<1.0	N/A
1-1-KIT-KF2	Kitchen faucet in facility kitchen	<1.0	<1.0	N/A
Low Detection (1.0 - 14.9 µg/L)				
1-1-KIT-KF1	Sprayer faucet in kitchen	3.3	<1.0	