



OKLAHOMA DRINKING WATER

LEAD TESTING

IN PUBLIC SCHOOLS & CHILD CARE FACILITIES

School: Happy Hearts Academy of Early LearningSampling Date: 3/13/2025Status: Complete

RESULTS

Below are the results from the first round of testing of drinking water for lead that was conducted at Happy Hearts Academy of Early Learning on March 13, 2025. Overall, two (2) outlets were tested resulting in a total of four (4) samples being sent to the lab.

- Four (4) samples had no detectable level of lead.
- Zero (0) samples had a low detection of lead between 1.0 and 14.9 µg/L.
- Zero (0) samples had a high detection of lead equal to or above 15.0 µg/L.

The table below shows all sample results. Sample results are in micrograms per liter, shown as µg/L. For more information on how to read this report, please see our **Results Interpretation Fact Sheet**.

| Sample ID | Outlet Description | First Draw (µg/L) | Flush (µg/L) | Remedial Action |
|------------------------|--|----------------------|-----------------|-----------------|
| | | Initial Sampling | | |
| Non-Detect (<1.0 µg/L) | | | | |
| 1-1-KIT-KF1 | Kitchen faucet in facility kitchen; main sink | <1.0 | <1.0 | N/A |
| 1-1-KIT-KF2 | Kitchen faucet in facility kitchen; secondary sink | <1.0 | <1.0 | N/A |