



OKLAHOMA DRINKING WATER

LEAD TESTING

IN PUBLIC SCHOOLS & CHILD CARE FACILITIES

District: INCA Community ServicesSchool: Davis Head StartSampling Date: 8/29/2024Status: Remediation

RESULTS

Below are the results from the first round of testing of drinking water for lead that was conducted at INCA Community Services - Davis Head Start on August 29, 2024. Overall, five (5) outlets were tested resulting in a total of ten (10) samples being sent to the lab.

- Three (3) samples had no detectable level of lead.
- Four (4) samples had a low detection of lead between 1.0 and 14.9 µg/L.
- Three (3) samples had a high detection of lead equal to or above 15.0 µg/L.

The table below shows all sample results. Sample results are in micrograms per liter, shown as µg/L. For more information on how to read this report, please see our **Results Interpretation Fact Sheet**.

Sample ID	Comments	First Draw (µg/L)	Flush (µg/L)	Remedial Action
		Initial Sampling		
Non-Detect (<1.0 µg/L)				
1-1-KIT-KF2	Kitchen faucet in facility kitchen; sprayer attachment	<1.0	<1.0	N/A
Low Detection (1.0 - 14.9 µg/L)				
1-1-KIT-KF1	Kitchen faucet in facility kitchen; standard faucet	<1.0	1.6	
1-1-EHB-BF1	Bathroom faucet in Early HeadStart Bathroom	2.5	1.9	
High Detection (≥15.0 µg/L)				
1-1-EH-CF2	Classroom faucet in Early HeadStart room; sprayer attachment	57.0	14.5	
1-1-EH-CF1	Classroom faucet in Early HeadStart room; standard faucet	83.5	114.0	