



OKLAHOMA DRINKING WATER

LEAD TESTING

IN PUBLIC SCHOOLS & CHILD CARE FACILITIES

District: INCA Community ServicesSchool: INCA Milburn Head StartSampling Date: 8/30/2024Status: Remediation

RESULTS

Below are the results from the first round of testing of drinking water for lead that was conducted at INCA Community Services - INCA Milburn Head Start on August 30, 2024. Overall, five (5) outlets were tested resulting in a total of ten (10) samples being sent to the lab.

- Two (2) samples had no detectable level of lead.
- Eight (8) samples had a low detection of lead between 1.0 and 14.9 µg/L.
- Zero (0) samples had a high detection of lead equal to or above 15.0 µg/L.

The table below shows all sample results. Sample results are in micrograms per liter, shown as µg/L. For more information on how to read this report, please see our **Results Interpretation Fact Sheet**.

Sample ID	Comments	First Draw (µg/L)	Flush (µg/L)	Remedial Action
		Initial Sampling		
Non-Detect (<1.0 µg/L)				
1-1-KIT-KF1	Kitchen faucet in facility kitchen; standard faucet with Pur filter	<1.0	<1.0	N/A
Low Detection (1.0 - 14.9 µg/L)				
1-1-BR-BF2	Bathroom faucet in boys' restroom; right sink; used for brushing teeth	4.1	1.1	
1-1-BR-BF1	Bathroom faucet in boys' restroom; left sink; used for brushing teeth	4.2	1.5	
1-1-GR-BF1	Bathroom faucet in girls' restroom; left sink	4.6	1.2	
1-1-GR-BF2	Bathroom faucet in girls' restroom; right sink	4.7	1.2	