



OKLAHOMA DRINKING WATER

LEAD TESTING

IN PUBLIC SCHOOLS & CHILD CARE FACILITIES

District: INCA Community Services

School: Madill Early Head Start

Sampling Date: 8/28/2024

Status: Remediation

RESULTS

Below are the results from the first round of testing of drinking water for lead that was conducted at INCA Community Services - Madill Early Head Start on August 28, 2024. Overall, two (2) outlets were tested resulting in a total of four (4) samples being sent to the lab.

- Two (2) samples had no detectable level of lead.
- Two (2) samples had a low detection of lead between 1.0 and 14.9 µg/L.
- Zero (0) samples had a high detection of lead equal to or above 15.0 µg/L.

The table below shows all sample results. Sample results are in micrograms per liter, shown as µg/L. For more information on how to read this report, please see our **Results Interpretation Fact Sheet**.

Sample ID	Comments	First Draw (µg/L)	Flush (µg/L)	Remedial Action
		Initial Sampling		
Low Detection (1.0 - 14.9 µg/L)				
1-1-KIT-KF1	Kitchen faucet in facility kitchen	1.94	<1.0	
1-1-MC-CF1	Classroom faucet in main classroom	1.96	<1.0	