



OKLAHOMA DRINKING WATER

# LEAD TESTING

IN PUBLIC SCHOOLS & CHILD CARE FACILITIES

District: Big Five Community Services

School: Jackie Watson Child Development Center

Sampling Date: 11/25/2024

Status: Remediation

## RESULTS

Below are the results from the first round of testing of drinking water for lead that was conducted at Big Five Community Services - Jackie Watson Child Development Center on November 25, 2024. Overall, twenty-seven (27) outlets were tested resulting in a total of fifty-four (54) samples being sent to the lab.

- Forty-three (43) samples had no detectable level of lead.
- Nine (9) samples had a low detection of lead between 1.0 and 14.9 µg/L.
- Two (2) samples had a high detection of lead equal to or above 15.0 µg/L.

The table below shows all sample results. Sample results are in micrograms per liter, shown as µg/L. For more information on how to read this report, please see our **Results Interpretation Fact Sheet**.

Sample ID	Outlet Description	First Draw (µg/L)	Flush (µg/L)	Remedial Action
		Initial Sampling		
Non-Detect (<1.0 µg/L)				
1-1-OUT-OF1	Outside faucet on side of building	<1.0	<1.0	N/A
1-1-HALL-BF2	Handicap bathroom left side entrance	<1.0	<1.0	N/A
1-1-HALL-BF3	Bathroom in Hallway outside classroom (4-1) LEFT sink	<1.0	<1.0	N/A
1-1-HALL-BF4	Bathroom in Hallway outside classroom (4-1) RIGHT sink	<1.0	<1.0	N/A
1-1-KIT-KF1	Main Kitchen faucet in Kitchen	<1.0	<1.0	N/A
1-1-(3-1)-CF1	Classroom (3-1) faucet	<1.0	<1.0	N/A
1-1-(3-1)-BF1	Classroom (3-1) bathroom LEFT side	<1.0	<1.0	N/A
1-1-(3-1)-BF2	Classroom (3-1) bathroom RIGHT side	<1.0	<1.0	N/A
1-1-(3-2)-CF1	Classroom (3-2) faucet	<1.0	<1.0	N/A
1-1-(3-2)-BF1	Classroom (3-2) bathroom LEFT side	<1.0	<1.0	N/A
1-1-(3-2)-BF2	Classroom (3-2) bathroom RIGHT side	<1.0	<1.0	N/A
1-1-(3-3)-CF1	Classroom (3-3) faucet	<1.0	<1.0	N/A
1-1-(3-3)-BF1	Classroom (3-3) bathroom LEFT side	<1.0	<1.0	N/A

Sample ID	Outlet Description	First Draw (µg/L)	Flush (µg/L)	Remedial Action
		Initial Sampling		
1-1-(3-3)-BF2	Classroom (3-3) bathroom RIGHT side	<1.0	<1.0	N/A
1-1-(4-2)-BF1	Classroom (4-2) bathroom LEFT sink	<1.0	<1.0	N/A
1-1-CAFÉ-CF1	Cafeteria hand washing only sink	<1.0	<1.0	N/A
1-1-CAFÉ-KF1	Cafeteria sprayer, big sink	<1.0	<1.0	N/A
1-1-CAFÉ-KF2	Cafeteria three-compartment sink	<1.0	<1.0	N/A
1-1-CAFÉ-CF2	Cafeteria floor mop bucket filling station	<1.0	<1.0	N/A
1-1-CON-BF1	Conference room bathroom	<1.0	<1.0	N/A
<b>Low Detection (1.0 - 14.9 µg/L)</b>				
1-1-(4-2)-CF2	Classroom (4-2) RIGHT side sink	1.0	<1.0	
1-1-CON-CF1	Conference room faucet	1.3	<1.0	
1-1-KIT-KF2	Workroom, left side sink	1.4	<1.0	
1-1-HALL-BF1	Hallway public bathroom front right entrance	2.0	1.4	
1-1-KIT-KF3	Workroom, right side sink	2.8	1.9	
<b>High Detection (≥15.0 µg/L)</b>				
1-1-(4-2)-BF2	Classroom (4-2) bathroom RIGHT sink	19.2	2.7	
1-1-(4-2)-CF1	Classroom (4-2) LEFT side sink	162.0	12.6	