



OKLAHOMA DRINKING WATER

LEAD TESTING

IN PUBLIC SCHOOLS & CHILD CARE FACILITIES

District: Little Gurus STEAM Academy

School: Little Gurus STEAM Academy

Sampling Date: 2/27/2025

Status: Remediation

RESULTS

Below are the results from the first round of testing of drinking water for lead that was conducted at Little Gurus STEAM Academy - Little Gurus STEAM Academy on February 27, 2025.

Overall, one (1) outlet was tested resulting in a total of two (2) samples being sent to the lab.

- One (1) sample had no detectable level of lead.
- One (1) sample had a low detection of lead between 1.0 and 14.9 µg/L.
- Zero (0) samples had a high detection of lead equal to or above 15.0 µg/L.

The table below shows all sample results. Sample results are in micrograms per liter, shown as µg/L. For more information on how to read this report, please see our **Results Interpretation Fact Sheet**.

Sample ID	Outlet Description	First Draw (µg/L)	Flush (µg/L)	Remedial Action
		Initial Sampling		
Low Detection (1.0 - 14.9 µg/L)				
1-1-KIT-KF1	Kitchen faucet in facility kitchen	1.5	<1.0	