



OKLAHOMA DRINKING WATER

LEAD TESTING

IN PUBLIC SCHOOLS & CHILD CARE FACILITIES

District: Sunbeam Family Services

School: Positive Tomorrows Early Head Start

Sampling Date: 10/11/2024

Status: Remediation

RESULTS

Below are the results from the first round of testing of drinking water for lead that was conducted at Sunbeam Family Services - Positive Tomorrows Early Head Start on October 11, 2024.

Overall, nine (9) outlets were tested resulting in a total of eighteen (18) samples being sent to the lab.

- Thirteen (13) samples had no detectable level of lead.
- Four (4) samples had a low detection of lead between 1.0 and 14.9 µg/L.
- One (1) sample had a high detection of lead equal to or above 15.0 µg/L.

The table below shows all sample results. Sample results are in micrograms per liter, shown as µg/L. For more information on how to read this report, please see our **Results Interpretation Fact Sheet**.

Sample ID	Outlet Description	First Draw (µg/L)	Flush (µg/L)	Remedial Action
		Initial Sampling		
Non-Detect (<1.0 µg/L)				
1-1-137-BF1	Room 137 bathroom sink LEFT	<1.0	<1.0	N/A
1-1-137-BF2	Room 137 bathroom sink RIGHT	<1.0	<1.0	N/A
1-1-139-CF1	Room 139 classroom faucet	<1.0	<1.0	N/A
1-1-139-DW1	Room 139 drinking fountain	<1.0	<1.0	N/A
1-1-136-CF1	Room 136 classroom faucet	<1.0	<1.0	N/A
1-1-136-BF1	Room 136 bathroom faucet	<1.0	<1.0	N/A
Low Detection (1.0 - 14.9 µg/L)				
1-1-137-DW1	Room 137 drinking fountain	1.1	<1.0	
1-1-137-CF1	Room 137 classroom faucet	2.4	1.2	
High Detection (≥15.0 µg/L)				
1-1-136-DW1	Room 136 drinking fountain	28.7	2.3	