



District: Southwest Oklahoma Community Action Group
School: Elk City Head Start
Sampling Date: 10/29/2024
Status: Remediation

RESULTS

Below are the results from the first round of testing of drinking water for lead that was conducted at Southwest Oklahoma Community Action Group - Elk City Head Start on October 29, 2024. Overall, ten (10) outlets were tested resulting in a total of twenty (20) samples being sent to the lab.

- Nine (9) samples had no detectable level of lead.
- Eleven (11) samples had a low detection of lead between 1.0 and 14.9 µg/L.
- Zero (0) samples had a high detection of lead equal to or above 15.0 µg/L.

The table below shows all sample results. Sample results are in micrograms per liter, shown as µg/L. For more information on how to read this report, please see our **Results Interpretation Fact Sheet**.

Sample ID	Outlet Description	First Draw (µg/L)	Flush (µg/L)	Remedial Action
		Initial Sampling		
Low Detection (1.0 - 14.9 µg/L)				
2-1-2-KF1	Kitchen faucet in Rm 2; left side	1.4	<1.0	
2-1-3-BF1	Bathroom faucet in Rm 3; right side	1.5	<1.0	
1-1-1-BF2	Bathroom faucet in Rm 1; left side	1.6	<1.0	
2-1-3-KF1	Kitchen faucet in Rm 3	1.8	<1.0	
1-1-1-BF1	Bathroom faucet in Rm 1; right side	1.9	<1.0	
1-1-2-BF1	Bathroom faucet in Rm 2; right side	2.7	<1.0	
1-1-1-KF1	Kitchen faucet in Rm 1; left side	3.9	<1.0	
2-1-3-BF2	Bathroom faucet in Rm 3; left side	4.7	3.1	
1-1-1-KF2	Kitchen faucet in Rm 1; right side	5.0	<1.0	
2-1-2-KF2	Kitchen faucet in Rm 2; right side	5.0	<1.0	