



OKLAHOMA DRINKING WATER

# LEAD TESTING

IN PUBLIC SCHOOLS & CHILD CARE FACILITIES

District: Home Childcare Center

School: Smith, Hadiha

Sampling Date: 3/14/2025

Status: Remediation

## RESULTS

Below are the results from the first round of testing of drinking water for lead that was conducted at Home Childcare Center - Smith, Hadiha on March 14, 2025. Overall, three (3) outlets were tested resulting in a total of six (6) samples being sent to the lab.

- Five (5) samples had no detectable level of lead.
- One (1) samples had a low detection of lead between 1.0 and 14.9 µg/L.
- Zero (0) samples had a high detection of lead equal to or above 15.0 µg/L.

The table below shows all sample results. Sample results are in micrograms per liter, shown as µg/L. For more information on how to read this report, please see our **Results Interpretation Fact Sheet**.

Sample ID	Outlet Description	First Draw (µg/L)	Flush (µg/L)	Remedial Action
		Initial Sampling		
Non-Detect (<1.0 µg/L)				
1-1-KIT-KF1	Kitchen faucet in home kitchen; sink spigot	<1.0	<1.0	N/A
1-1-KIT-KF2	Kitchen faucet in home kitchen; spigot on refrigerator	<1.0	<1.0	N/A
Low Detection (1.0 - 14.9 µg/L)				
1-1-BATH-BF1	Bathroom faucet in daycare area bathroom	6.9	<1.0	