



OKLAHOMA DRINKING WATER

LEAD TESTING

IN PUBLIC SCHOOLS & CHILD CARE FACILITIES

District: Sunbeam Family Services
School: U.S. Grant's Little Generals
Sampling Date: 10/11/2024
Status: Complete

RESULTS

Below are the results from the first round of testing of drinking water for lead that was conducted at Sunbeam Family Services - U.S. Grant's Little Generals on October 11, 2024. Overall, four (4) outlets were tested resulting in a total of eight (8) samples being sent to the lab.

- Eight (8) samples had no detectable level of lead.
- Zero (0) samples had a low detection of lead between 1.0 and 14.9 µg/L.
- Zero (0) samples had a high detection of lead equal to or above 15.0 µg/L.

The table below shows all sample results. Sample results are in micrograms per liter, shown as µg/L. For more information on how to read this report, please see our **Results Interpretation Fact Sheet**.

Sample ID	Outlet Description	First Draw (µg/L)	Flush (µg/L)	Remedial Action
		Initial Sampling		
Non-Detect (<1.0 µg/L)				
2-1-LG-KF1	Kitchen faucet in Little Generals Room	<1.0	<1.0	N/A
1-1-T112-CF1	Classroom faucet in Rm T112	<1.0	<1.0	N/A
1-1-T110-CF1	Classroom faucet in Rm T110	<1.0	<1.0	N/A
1-1-T109-CF1	Classroom faucet in Rm T109	<1.0	<1.0	N/A