



OKLAHOMA DRINKING WATER  
**LEAD TESTING**  
 IN PUBLIC SCHOOLS & CHILD CARE FACILITIES

District: Tulsa Educare  
 School: Tulsa Educare 1 Kendall-Whittier  
 Sampling Date: 2/28/2025  
 Status: Remediation

## RESULTS

Below are the results from the first round of testing of drinking water for lead that was conducted at Tulsa Educare – Tulsa Educare 1 Kendall-Whittier on February 28, 2025. Overall, forty-one (41) outlets were tested resulting in a total of eighty-two (82) samples being sent to the lab.

- Seventy-nine (79) samples had no detectable level of lead.
- Three (3) samples had a low detection of lead between 1.0 and 14.9 µg/L.
- Zero (0) samples had a high detection of lead equal to or above 15.0 µg/L.

The table below shows all sample results. Sample results are in micrograms per liter, shown as µg/L. For more information on how to read this report, please see our **Results Interpretation Fact Sheet**.

Sample ID	Outlet Description	First Draw (µg/L)	Flush (µg/L)	Remedial Action
		Initial Sampling		
<b>Non-Detect (&lt;1.0 µg/L)</b>				
1-1-1-DW1	Drinking water bubbler on sink between Rms 1 and 3	<1.0	<1.0	N/A
1-1-1-CF1	Classroom faucet on sink between Rms 1 and 3	<1.0	<1.0	N/A
1-1-1-CF2	Classroom faucet on counter between Rms 1 and 3; left side	<1.0	<1.0	N/A
1-1-1-CF3	Classroom faucet on counter between Rms 1 and 3; right side	<1.0	<1.0	N/A
1-1-5-DW1	Drinking water bubbler on sink between Rms 5 and 7	<1.0	<1.0	N/A
1-1-5-CF1	Classroom faucet on sink between Rms 5 and 7	<1.0	<1.0	N/A
1-1-5-CF2	Classroom faucet on counter between Rms 5 and 7; left side	<1.0	<1.0	N/A
1-1-5-CF3	Classroom faucet on counter between Rms 5 and 7; right side	<1.0	<1.0	N/A
1-1-6-CF1	Classroom faucet on sink between Rms 6 and 8	<1.0	<1.0	N/A
1-1-6-CF2	Classroom faucet on counter between Rms 6 and 8; left side	<1.0	<1.0	N/A
1-1-6-CF3	Classroom faucet on counter between Rms 6 and 8; right side	<1.0	<1.0	N/A
1-1-2-DW1	Drinking water bubbler on sink between Rms 2 and 4	<1.0	<1.0	N/A

Sample ID	Outlet Description	First Draw (µg/L)	Flush (µg/L)	Remedial Action
		Initial Sampling		
1-1-2-CF1	Classroom faucet on sink between Rms 2 and 4	<1.0	<1.0	N/A
1-1-2-CF2	Classroom faucet on counter between Rms 2 and 4; left side	<1.0	<1.0	N/A
1-1-2-CF3	Classroom faucet on counter between Rms 2 and 4; right side	<1.0	<1.0	N/A
1-1-TL-WC1	Teacher's Lounge Water Cooler	<1.0	<1.0	N/A
1-1-HALL-WC1	Hallway near main entrance and 141 (fountain left)	<1.0	<1.0	N/A
1-1-HALL-WC2	Hallway near main entrance and 141 (fountain right)	<1.0	<1.0	N/A
1-1-9-CF1	Counter between 9 and 11, left	<1.0	<1.0	N/A
1-1-9-DW1	DW near CF in Classroom 11	<1.0	<1.0	N/A
1-1-9-CF2	CF near DW in Classroom 11	<1.0	<1.0	N/A
1-1-9-CF3	Used for tb. Small sink outside bathroom 11	<1.0	<1.0	N/A
1-1-13-CF1	Small sink outside bathroom 13	<1.0	<1.0	N/A
1-1-13-CF2	Counter between 13 and 15, left	<1.0	<1.0	N/A
1-1-13-DW1	DW near CF in Classroom 15	<1.0	<1.0	N/A
1-1-13-CF3	CF near DW in Classroom 15	<1.0	<1.0	N/A
1-1-13-CF4	Leaking from tap. Small sink outside bathroom 15	<1.0	<1.0	N/A
1-1-16-CF1	Small sink outside bathroom 16	<1.0	<1.0	N/A
1-1-16-CF2	Counter between 16 and 14, left	<1.0	<1.0	N/A
1-1-16-DW1	DW near CF in Classroom 14	<1.0	<1.0	N/A
1-1-16-CF3	CF near DW in Classroom 14	<1.0	<1.0	N/A
1-1-16-CF4	Small sink outside bathroom 14	<1.0	<1.0	N/A
1-1-9-CF4	Small sink in room 9	<1.0	<1.0	N/A
1-1-12-CF1	Small sink outside bathroom 12	<1.0	<1.0	N/A
1-1-12-CF2	Counter between 10 and 12, left	<1.0	<1.0	N/A
1-1-10-CF1	CF near DW in Classroom 10	<1.0	<1.0	N/A

Sample ID	Outlet Description	First Draw (µg/L)	Flush (µg/L)	Remedial Action
		Initial Sampling		
1-1-10-CF2	Small sink outside bathroom 10	<1.0	<1.0	N/A
1-1-KIT-KF2	Participant used before sampling. Directly by kitchen front door	<1.0	<1.0	N/A
<b>Low Detection (1.0 - 14.9 µg/L)</b>				
1-1-10-DW1	DW near CF in Classroom 10	2.5	<1.0	
1-1-6-DW1	Drinking water bubbler on sink between Rms 6 and 8	3.6	<1.0	
1-1-KIT-KF1	Kitchen faucet in facility kitchen	4.8	<1.0	