



OKLAHOMA DRINKING WATER  
**LEAD TESTING**  
 IN PUBLIC SCHOOLS & CHILD CARE FACILITIES

District: Tulsa Educare  
 School: MacArthur Location  
 Sampling Date: 2/28/2025  
 Status: Remediation

## RESULTS

Below are the results from the first round of testing of drinking water for lead that was conducted at Tulsa Educare - MacArthur Location on February 28, 2025. Overall, twenty-nine (29) outlets were tested resulting in a total of fifty-eight (58) samples being sent to the lab.

- Forty (40) samples had no detectable level of lead.
- Eighteen (18) samples had a low detection of lead between 1.0 and 14.9 µg/L.
- Zero (0) samples had a high detection of lead equal to or above 15.0 µg/L.

The table below shows all sample results. Sample results are in micrograms per liter, shown as µg/L. For more information on how to read this report, please see our **Results Interpretation Fact Sheet**.

Sample ID	Outlet Description	First Draw (µg/L)	Flush (µg/L)	Remedial Action
		Initial Sampling		
<b>Non-Detect (&lt;1.0 µg/L)</b>				
1-1-HALL-WC1	Water cooler in hall near restrooms; left side	<1.0	<1.0	N/A
1-1-HALL-WC2	Water cooler in hall near restrooms; middle unit	<1.0	<1.0	N/A
1-1-HALL-WC3	Water cooler in hall near restrooms; right side	<1.0	<1.0	N/A
1-1-KIT-KF2	Kitchen faucet in facility kitchen; middle unit	<1.0	<1.0	N/A
1-1-1-CF1	Classroom faucet in Rm 1; left side	<1.0	<1.0	N/A
1-1-3-CF2	Classroom faucet in Rm 3; middle unit	<1.0	<1.0	N/A
1-1-5-CF2	Classroom faucet in Rm 5; middle unit	<1.0	<1.0	N/A
1-1-7-CF1	Classroom faucet in Rm 7; left side	<1.0	<1.0	N/A
1-1-16-CF2	Classroom faucet in Rm 16; middle unit	<1.0	<1.0	N/A
1-1-16-CF3	Classroom faucet in Rm 16; right side	<1.0	<1.0	N/A
1-1-14-CF2	Classroom faucet in Rm 14; middle unit	<1.0	<1.0	N/A
1-1-14-CF3	Classroom faucet in Rm 14; right side	<1.0	<1.0	N/A
1-1-12-CF1	Classroom faucet in Rm 12; left side	<1.0	<1.0	N/A

Sample ID	Outlet Description	First Draw (µg/L)	Flush (µg/L)	Remedial Action
		Initial Sampling		
1-1-12-CF2	Classroom faucet in Rm 12; middle unit	<1.0	<1.0	N/A
1-1-10-CF3	Classroom faucet in Rm 10; right side	<1.0	<1.0	N/A
<b>Low Detection (1.0 - 14.9 µg/L)</b>				
1-1-7-CF2	Classroom faucet in Rm 7; middle unit	1.5	<1.0	
1-1-12-CF3	Classroom faucet in Rm 12; right side	1.5	<1.0	
1-1-3-CF3	Classroom faucet in Rm 3; right side	1.5	<1.0	
1-1-5-CF1	Classroom faucet in Rm 5; left side	1.5	<1.0	
1-1-3-CF1	Classroom faucet in Rm 3; left side	1.6	<1.0	
1-1-10-CF2	Classroom faucet in Rm 10; middle unit	1.9	<1.0	
1-1-KIT-KF3	Kitchen faucet in facility kitchen; pot filler	1.9	1.7	
1-1-5-CF3	Classroom faucet in Rm 5; right side	2.1	1.1	
1-1-7-CF3	Classroom faucet in Rm 7; right side	2.2	<1.0	
1-1-KIT-KF1	Kitchen faucet in facility kitchen; left side	2.5	<1.0	
1-1-1-CF2	Classroom faucet in Rm 1; middle unit	2.9	<1.0	
1-1-14-CF1	Classroom faucet in Rm 14; left side	3.0	<1.0	
1-1-16-CF1	Classroom faucet in Rm 16; left side	3.8	1.1	
1-1-1-CF3	Classroom faucet in Rm 1; right side	7.3	3.5	