



OKLAHOMA DRINKING WATER

# LEAD TESTING

IN PUBLIC SCHOOLS &amp; CHILD CARE FACILITIES

District: Tulsa EducareSchool: Celia Clinton LocationSampling Date: 3/13/2025Status: Remediation

## RESULTS

Below are the results from the first round of testing of drinking water for lead that was conducted at Tulsa Educare - Celia Clinton Location on March 13, 2025. Overall, forty-three (43) outlets were tested resulting in a total of eighty-six (86) samples being sent to the lab.

- Eighty-five (85) samples had no detectable level of lead.
- One (1) sample had a low detection of lead between 1.0 and 14.9 µg/L.
- Zero (0) samples had a high detection of lead equal to or above 15.0 µg/L.

The table below shows all sample results. Sample results are in micrograms per liter, shown as µg/L. For more information on how to read this report, please see our **Results Interpretation Fact Sheet**.

| Sample ID              | Outlet Description   | First Draw<br>(µg/L) | Flush<br>(µg/L) | Remedial Action |
|------------------------|--|----------------------|-----------------|-----------------|
|                        |  | Initial Sampling     |                 |                 |
| Non-Detect (<1.0 µg/L) |  |                      |                 |                 |
| 1-1-KIT-KF1            | Kitchen faucet in facility kitchen; near back door; left side            | <1.0                 | <1.0            | N/A             |
| 1-1-KIT-KF2            | Kitchen faucet in facility kitchen; near back door; pot filler on right  | <1.0                 | <1.0            | N/A             |
| 1-1-KIT-KF3            | Kitchen faucet in facility kitchen; central console sink                 | <1.0                 | <1.0            | N/A             |
| 1-1-KIT-KF4            | Kitchen faucet in facility kitchen; pot filler behind KF5                | <1.0                 | <1.0            | N/A             |
| 1-1-KIT-KF5            | Kitchen faucet in facility kitchen; near window                          | <1.0                 | <1.0            | N/A             |
| 1-1-KIT-KF7            | Kitchen faucet in facility kitchen; pot filler on back wall near burners | <1.0                 | <1.0            | N/A             |
| 1-1-1/2-CF1            | Classroom faucet in Rm 1/2; right side of double sink                    | <1.0                 | <1.0            | N/A             |
| 1-1-1/2-CF2            | Classroom faucet in Rm 1/2; left side of double sink                     | <1.0                 | <1.0            | N/A             |
| 1-1-1/2-CF3            | Classroom faucet in Rm 1/2; standalone sink on left side                 | <1.0                 | <1.0            | N/A             |
| 1-1-3/4-CF1            | Classroom faucet in Rm 3/4; right side of double sink                    | <1.0                 | <1.0            | N/A             |
| 1-1-3/4-CF2            | Classroom faucet in Rm 3/4; left side of double sink                     | <1.0                 | <1.0            | N/A             |
| 1-1-3/4-CF3            | Classroom faucet in Rm 3/4; standalone sink on left side                 | <1.0                 | <1.0            | N/A             |

| Sample ID     | Outlet Description   | First Draw<br>(µg/L) | Flush<br>(µg/L) | Remedial Action |
|---------------|--|----------------------|-----------------|-----------------|
|               |  | Initial Sampling     |                 |                 |
| 1-1-HALL-WC1  | Water cooler in hall; near Rms 1-4; left side              | <1.0                 | <1.0            | N/A             |
| 1-1-HALL-WC2  | Bottle filler in hall; near Rms 1-4                        | <1.0                 | <1.0            | N/A             |
| 1-1-HALL-WC3  | Water cooler in hall; near Rms 1-4; center unit            | <1.0                 | <1.0            | N/A             |
| 1-1-5/6-CF1   | Classroom faucet in Rm 5/6; right side of double sink      | <1.0                 | <1.0            | N/A             |
| 1-1-5/6-CF2   | Classroom faucet in Rm 5/6; left side of double sink       | <1.0                 | <1.0            | N/A             |
| 1-1-5/6-CF3   | Classroom faucet in Rm 5/6; standalone sink on left side   | <1.0                 | <1.0            | N/A             |
| 1-1-7/8-CF1   | Classroom faucet in Rm 7/8; right side of double sink      | <1.0                 | <1.0            | N/A             |
| 1-1-7/8-CF2   | Classroom faucet in Rm 7/8; left side of double sink       | <1.0                 | <1.0            | N/A             |
| 1-1-7/8-CF3   | Classroom faucet in Rm 7/8; standalone sink on left side   | <1.0                 | <1.0            | N/A             |
| 1-1-9/10-CF1  | Classroom faucet in Rm 9/10; right side of double sink     | <1.0                 | <1.0            | N/A             |
| 1-1-9/10-CF2  | Classroom faucet in Rm 9/10; left side of double sink      | <1.0                 | <1.0            | N/A             |
| 1-1-9/10-CF3  | Classroom faucet in Rm 9/10; standalone sink on left side  | <1.0                 | <1.0            | N/A             |
| 1-1-11/12-CF1 | Classroom faucet in Rm 11/12; right side of double sink    | <1.0                 | <1.0            | N/A             |
| 1-1-11/12-CF2 | Classroom faucet in Rm 11/12; left side of double sink     | <1.0                 | <1.0            | N/A             |
| 1-1-11/12-CF3 | Classroom faucet in Rm 11/12; standalone sink on left side | <1.0                 | <1.0            | N/A             |
| 1-1-HALL-WC4  | Water cooler in hall; near Rms 13-16; left side            | <1.0                 | <1.0            | N/A             |
| 1-1-HALL-WC5  | Bottle filler in hall; near Rms 13-16                      | <1.0                 | <1.0            | N/A             |
| 1-1-HALL-WC6  | Water cooler in hall; near Rms 13-16; center unit          | <1.0                 | <1.0            | N/A             |
| 1-1-HALL-WC7  | Water cooler in hall; near Rms 13-16; right side           | <1.0                 | <1.0            | N/A             |
| 1-1-TL-CF1    | Classroom faucet in teachers' lounge                       | <1.0                 | <1.0            | N/A             |
| 1-1-TL-IM1    | Ice machine in teachers' lounge                            | <1.0                 | <1.0            | N/A             |

| Sample ID                              | Outlet Description  | First Draw<br>(µg/L) | Flush<br>(µg/L) | Remedial Action |
|--|---|----------------------|-----------------|-----------------|
|  |   | Initial Sampling     |                 |                 |
| 1-1-13/14-CF1                          | Classroom faucet in Rm 13/14; right side of double sink     | <1.0                 | <1.0            | N/A             |
| 1-1-13/14-CF2                          | Classroom faucet in Rm 13/14; left side of double sink      | <1.0                 | <1.0            | N/A             |
| 1-1-13/14-CF3                          | Classroom faucet in Rm 13/14; standalone sink on left side  | <1.0                 | <1.0            | N/A             |
| 1-1-15/16-CF1                          | Classroom faucet in Rm 15/16; right side of double sink     | <1.0                 | <1.0            | N/A             |
| 1-1-15/16-CF2                          | Classroom faucet in Rm 15/16; left side of double sink      | <1.0                 | <1.0            | N/A             |
| 1-1-15/16-CF3                          | Classroom faucet in Rm 15/16; standalone sink on left side  | <1.0                 | <1.0            | N/A             |
| 1-1-HALL-WC8                           | Water cooler in hall behind facility kitchen; left side     | <1.0                 | <1.0            | N/A             |
| 1-1-HALL-WC9                           | Bottle filler in hall behind kitchen                        | <1.0                 | <1.0            | N/A             |
| 1-1-HALL-WC10                          | Water cooler in hall behind kitchen; right side             | <1.0                 | <1.0            | N/A             |
| <b>Low Detection (1.0 - 14.9 µg/L)</b> |   |                      |                 |                 |
| 1-1-KIT-KF6                            | Kitchen faucet in facility kitchen; pot filler on back wall | 1.9                  | <1.0            |                 |