



OKLAHOMA DRINKING WATER

LEAD TESTING

IN PUBLIC SCHOOLS & CHILD CARE FACILITIES

District: Washita Valley Community Action CenterSchool: Chickasha Early Head StartSampling Date: 10/22/2024Status: Remediation

RESULTS

Below are the results from the first round of testing of drinking water for lead that was conducted at Washita Valley Community Action Center - Chickasha Early Head Start on October 22, 2024. Overall, eleven (11) outlets were tested resulting in a total of twenty-two (22) samples being sent to the lab.

- Fourteen (14) samples had no detectable level of lead.
- Seven (7) samples had a low detection of lead between 1.0 and 14.9 µg/L.
- One (1) sample had a high detection of lead equal to or above 15.0 µg/L.

The table below shows all sample results. Sample results are in micrograms per liter, shown as µg/L. For more information on how to read this report, please see our **Results Interpretation Fact Sheet**.

Sample ID	Outlet Description	First Draw (µg/L)	Flush (µg/L)	Remedial Action
		Initial Sampling		
Non-Detect (<1.0 µg/L)				
1-1-1-CF2	Classroom faucet in Rm 1; middle sink	<1.0	<1.0	N/A
1-1-11-CF1	Classroom faucet in Rm 11; left side	<1.0	<1.0	N/A
1-1-2-CF2	Classroom faucet in Rm 2; right side	<1.0	<1.0	N/A
1-1-10-CF1	Classroom faucet in Rm 10; left side	<1.0	<1.0	N/A
Low Detection (1.0 - 14.9 µg/L)				
1-1-11-CF2	Classroom faucet in Rm 11; right side	1.0	<1.0	
1-1-10-CF2	Classroom faucet in Rm 10; right side	1.3	<1.0	
1-1-2-CF1	Classroom faucet in Rm 2; left side	1.3	<1.0	
1-1-1-CF3	Classroom faucet in Rm 1; right side	1.9	<1.0	
1-1-8-CF1	Classroom faucet in Rm 8	1.1	2.3	
1-1-1-CF1	Classroom faucet in Rm 1; left side	3.6	<1.0	
High Detection (≥15.0 µg/L)				
1-1-3-CF1	Classroom faucet in Rm 3	16.7	<1.0	