



OKLAHOMA DRINKING WATER

LEAD TESTING

IN PUBLIC SCHOOLS & CHILD CARE FACILITIES

District: Washita Valley Community Action CenterSchool: Ft. Cobb Early Head StartSampling Date: 10/23/2024Status: Remediation

RESULTS

Below are the results from the first round of testing of drinking water for lead that was conducted at Washita Valley Community Action Center - Ft. Cobb Early Head Start on October 23, 2024. Overall, ten (10) outlets were tested resulting in a total of twenty (20) samples being sent to the lab.

- Fourteen (14) samples had no detectable level of lead.
- Six (6) samples had a low detection of lead between 1.0 and 14.9 µg/L.
- Zero (0) samples had a high detection of lead equal to or above 15.0 µg/L.

The table below shows all sample results. Sample results are in micrograms per liter, shown as µg/L. For more information on how to read this report, please see our **Results Interpretation Fact Sheet**.

Sample ID	Outlet Description	First Draw (µg/L)	Flush (µg/L)	Remedial Action
		Initial Sampling		
Non-Detect (<1.0 µg/L)				
1-1-HALL-WC1	Elkay bottle filler in hall near Rm 716	<1.0	<1.0	N/A
1-1-HALL-WC2	Elkay water cooler with bottle filler in hall near Rm 716; left side	<1.0	<1.0	N/A
1-1-KIT-IM1	Ice machine in facility kitchen	<1.0	<1.0	N/A
1-1-720-CF1	Classroom faucet in Rm 720	<1.0	<1.0	N/A
1-1-714B-BF1	Bathroom faucet in bathroom attached to Rm 714; left side	<1.0	<1.0	N/A
1-1-IR-CF1	Classroom faucet in Infant Room	<1.0	<1.0	N/A
Low Detection (1.0 - 14.9 µg/L)				
1-1-714B-BF2	Bathroom faucet in bathroom attached to Rm 714; right side	1.1	<1.0	
1-1-KIT-KF1	Kitchen faucet in facility kitchen	1.4	1.1	
1-1-721-CF1	Classroom faucet in Rm 721	1.5	<1.0	
1-1-HALL-WC3	Elkay water cooler in hall near Rm 716; right side	5.0	3.5	