



**Clean Harbors Environmental Services, LLC  
Lone Mountain Facility  
Waynoka, Oklahoma**

**RCRA/HSWA  
Permit Renewal  
Application**

**Volume 7**

**October 1, 2020**



# VOLUME 7

## CONTENTS IN THIS VOLUME:

SECTION EF2  
SECTION EF3  
SECTION EF4 (OUT OF SERVICE)  
SECTION EO1  
SECTION FT1



# SECTION EF2




EVAPORATOR FEED TANK NO. 2 (EF2)  
ASSESSMENT

LONE MOUNTAIN FACILITY

WAYNOKA, OKLAHOMA



APRIL 2016



CA1960  
6-30-2016

015493



## TABLE OF CONTENTS

1.	TANK SYSTEM DESCRIPTION.....	1.
2.	TANK SYSTEM ASSESSMENT.....	1.
2.1	General Description of Evaporator Feed Tank No. 2 (EF2).....	1.
2.2	Design Standard(s) .....	1.
2.3	Hazardous Characteristics of Managed Waste(s).....	1.
2.4	Existing Corrosion Protection.....	2.
2.5	Documented Age of Tank .....	2.
2.6	Results of Leak Test.....	2.
2.7	Existing Data Obtained.....	2.
2.8	Calculation of Foundation Loading.....	2.
2.9	Required Structural Calculation .....	2.
2.10	Comparison of Actual Structural to Theoretical Values .....	2.
2.10.1	Wall Thickness Comparison .....	3.
2.10.2	Bottom Thickness Comparison .....	4.
2.10.3	Foundation Integrity.....	4.
3.	SECONDARY CONTAINMENT SYSTEM.....	5.
3.1	General Description of Secondary Containment .....	5.
3.2	Design Standards .....	5.
3.3	Hazardous Characteristics of Wastes Stored.....	5.
3.4	Existing Corrosion Protection.....	6.
3.5	Documented Age of the Containment System.....	6.
3.6	Results of Leak Test.....	6.
3.7	Existing Data Obtained.....	6.
3.8	Calculation of Existing Capacity .....	6.
3.9	Required Volume.....	7.
3.10	Comparison of Available Volume to Required Volume.....	7.
4.	CONCLUSIONS .....	7.
4.1	Primary Tank Vessel .....	7.
4.2	Secondary Containment.....	7.
5.	RECOMMENDATIONS.....	8.
5.1	Primary Tank.....	8.
5.2	Secondary Containment.....	8.
5.3	Routine Inspections.....	8.
6.	CERTIFICATION.....	8.
TABLE 2.1	EF2 TANK DATA	
TABLE 2.2	COMPARISON OF ACTUAL STRUCTURAL TO THEORETICAL VALUES FOR THE EF2 TANK	
TABLE 3.1	SECONDARY CONTAINMENT AREA DATA	
FIGURE 1.	EF2 TANK DETAILS	



---

FIGURE 1a.	EF2 MEASURED PLATE THICKNESS
FIGURE 2.	EF2 TANK SURVEY POINTS SCHEMATIC
FIGURE 3.	EF2 TANK HISTORICAL FOUNDATION SURVEY DATA
FIGURE 4.	EF2 SECONDARY CONTAINMENT SYSTEM
FIGURE 5.	EF2 TANK SECONDARY CONTAINMENT SECTION A-A
APPENDIX A.	PRIMARY TANK VOLUME CALCULATION - NOVEMBER 2000 SUBMITTAL
APPENDIX B.	PRIMARY TANK WALL THICKNESS - NOVEMBER 2000 SUBMITTAL
APPENDIX C.	SEISMIC CALCULATIONS - NOVEMBER 2000 SUBMITTAL
APPENDIX D.	WIND LOAD CALCULATIONS - NOVEMBER 2000 SUBMITTAL
APPENDIX E.	FOUNDATION INTEGRITY MONITORING DOCUMENT - JANUARY 2011 SUBMITTAL
APPENDIX F.	LAW ENGINEERING GEOTECHNICAL REPORT - NOVEMBER 2000 SUBMITTAL
APPENDIX G.	FOUNDATION DESIGN ANALYSIS - NOVEMBER 2000 SUBMITTAL
APPENDIX H.	CHEMPROOF PERMACOAT 3000 DOCUMENTATION
APPENDIX I.	SECONDARY CONTAINMENT CALCULATIONS - NOVEMBER 2000 SUBMITTAL

---



## 1. TANK SYSTEM DESCRIPTION



Clean Harbors Environmental Services, Inc., retained ENVIROTECH ENGINEERING & CONSULTING, INC., to conduct the required 5-year assessment of Evaporator Feed Tank No. 2 (EF2), as outlined in the previous January 2011 assessment. A visual inspection of Tank EF2 was conducted by Envirotech on November 25, 2015. This report is a continuation of previous five-year assessments and references the original design data developed for this tank. Evaporator Feed Tank No. 2 (EF2) is a 60-ft.-dia. circular-steel aboveground open-top wastewater storage and treatment tank installed in July 1987. The 360,000-gal. (nominal) tank is utilized for storage and incidental treatment of pre-treated wastewater. Certain wastewater not requiring pretreatment may also be stored in the tank (i.e., contaminated rainwater, landfill leachates, etc.) After storage, the wastewater is transferred for final treatment and/or disposal. The tank (along with a similar Tank EF1 and a tank holding reagent-grade bleach) is located immediately east of the pretreatment area in a common-lined concrete secondary containment system. Tank volume calculations are included in *Appendix A*. An "As-Built" drawing depicting the tank details is included as *Figure 1*.

## 2. TANK SYSTEM ASSESSMENT


- 2.1 General Description of Evaporator Feed Tank No. 2 (EF2).** Evaporator Feed Tank No. 2 (EF2) is a vertical circular carbon-steel tank with a nominal 60-ft.-dia. sitting on an 8-in. channel that rests upon a concrete ring wall foundation. A sand base and high-density polyethylene (HDPE) liner leak detection system is located directly under the primary tank floor with detector pipes extending through the ring wall and liner for positive leak identification.
- 2.2 Design Standard(s).** The tank was constructed in 1987 and appears to be field-designed and constructed. Although the tank appears to be a modified design, for purposes of this assessment, structural calculations were prepared to compare the existing tank and supports to those applicable sections in the *American Petroleum Institute Standard 653 - 1995 2<sup>ND</sup> Edition (API-653)* and the *American Institute of Steel Construction (AISC) Manual of Steel Construction - 8<sup>TH</sup> Edition*. These calculations are included in *Appendices B thru D*. The actual steel specifications by which the tanks are constructed are not known, but have been assumed to be A36 (carbon steel).
- 2.3 Hazardous Characteristics of Managed Waste(s).** The wastes managed in this tank are both characteristic and listed waste, as summarized in *40 CFR Part 261, Subparts C and D*. This tank is a storage tank where aqueous-based waste materials that required oxidation, neutralization, filtration, or settling (among other physical/chemical treatment methods) were stored prior to evaporation or shipment off-site. Currently, the only material placed in the tank is treated wastewater. According to Clean Harbors, the waste managed in this tank has the following general characteristics:

- $4 < \text{pH} < 13$ ;
- $N > 1$ ;






North View




West View



LONE MOUNTAIN FACILITY  
WAYNOKA, OKLAHOMA

# Evaporator Feed Storage Tank No. 2 Tank Details



Date:	April 6, 2016
Scale:	n.t.a.
Designed by:	R. ERDMAN
Drawn by:	R. UNGER
Checked By:	R. ERDMAN
Project No.	015493-00
Fig. 1	



- Temperature = Ambient; and
- Low-Solvent Constituents.

The tank is lined with coal tar that is resistant to most constituents-of-concern. The coal tar liner has survived well in this working environment.

With regards to the potential for corrosion, it was determined that the pH and normality levels of the waste are the primary areas-of-concern. This was to determine the applicability of a corrosion allowance for the tank material type and thickness.

- 2.4 **Existing Corrosion Protection.** The tank is isolated from soil and water by a ring wall, below which is a leak detection system. This system is comprised of an HDPE liner below a layer of sand on a concrete mat foundation. The HDPE liner and concrete mat foundation isolate the sand from the underlying soil. Water may be entrained in the sand when placed prior to construction of the tank bottom, but the secondary containment system is designed to drain entrained fluids to one of the leak detection drains that penetrate the ring wall. For further protection, a coal tar liner is employed on the bottom and sidewalls of the tank interior. In addition, the tank has an exterior epoxy paint layer.
- 2.5 **Documented Age of Tank.** Tank EF2 was erected and installed in July 1987 and is 28-years old as of this assessment conducted in November 2015.
- 2.6 **Results of Leak Test.** On November 25, 2015, a visual inspection of the tank system was conducted to satisfy the requirements of a leak test. No evidence of leakage from the welds, seams, flanged connections, valves and threaded connections was observed. The leak detector pipes that extend through the ring wall foundation showed no indication of tank bottom leakage.
- 2.7 **Existing Data Obtained.** The existing data associated with the referenced tank is summarized in *Table 2.1*.
- 2.8 **Calculation of Foundation Loading.** The total weight of the tank and its contents equals 1,968-ton. Detailed calculations reflecting the minimum required foundation thickness and steel reinforcement are included herein as *Appendix G*.
- 2.9 **Required Structural Calculation.** The calculated required wall thickness for this tank is 0.2363-in. This thickness includes 0.0625-in. added for corrosion allowance. This corrosion allowance is based on a "best-engineering" estimate, considering the materials being treated and a 20-yr. design life. Detailed calculations required for wall thickness and structural analysis of the tank support system are included herein as *Appendices B thru D*.



- 2.10 Comparison of Actual Structural to Theoretical Values.** The comparison of actual structural to theoretical values is summarized in *Table 2.2*. Some minor variance of instrument readings can be attributed partially to the idiosyncrasies of the testing equipment such as density of "couplant" and roughness of tank surface at each test point.

TABLE 2.1 EF2 TANK DATA	
Tank Diameter	60-ft.
Tank Height	16.9-ft.
Maximum Operating Level	15.9-ft.
Material	A36 (Assumed)
Wall Thickness (See Appendix B)	0.25-in.
Specific Gravity	1.3
Operating Temperature	Ambient
Maximum Volume	47,785-cf
Seismic Zone	1

TABLE 2.2 COMPARISON OF ACTUAL STRUCTURAL TO THEORETICAL VALUES FOR THE EF2 TANK	
WALL THICKNESS COMPARISON	
Calculated Required Wall Thickness	0.2363-in.
Minimum Required Wall Thickness by API 653 (2.3.3.1)	0.1738-in.
Original Plate Thickness	0.25-in.
Measured Wall Thickness w/Coating (minimum)	0.279-in.
BOTTOM THICKNESS COMPARISON	
Minimum Required Bottom Thickness by API 653	0.10-in.
Original Plate Thickness	0.24-in.
Measured Bottom Thickness w/Coating (minimum)	0.243-in.

- 2.10.1 Wall Thickness Comparison.** During the November 2015 assessment, a visual inspection and an ultrasonic thickness corrosion survey were conducted on the tank walls. Wall thickness measurements of the interior protective surface ranging from



0.270-in. to 0.314-in. exceeded the minimum required wall thickness of 0.2363-in. and 0.1738-in., as graphically depicted on *Figure 1a*. The interior wall coating appeared sound and intact, with no pitting or corrosion. Separate readings indicating that the coating thickness varies are most likely the result of normal wear and tear. Furthermore, the difference in values does not indicate a reduction that would adversely impact the minimum thickness requirement.


**2.10.2 Bottom Thickness Comparison.** During the November 2015 assessment, a visual inspection was conducted on the tank bottom. Floor thickness measurements of the interior protective surface, ranging from 0.270- to 0.391-in., exceeded the minimum required floor thickness of 0.10-in., as graphically depicted on *Figure 1a*. The floor coating appeared sound and intact, with not pitting or corrosion. Separate readings indicating that the coating thickness varies are most likely the result of normal use. Furthermore, the difference in values does not indicate a reduction that would adversely impact the minimum thickness requirement.

**2.10.3 Foundation Integrity.** Evaporator Feed Tank No. 2 (EF2) is situated on a concrete ring foundation with a sand base. The sand base rests on a concrete slab that is tied to the foundation ring. Indications of insignificant minor cracks in the foundation ring have been coated with an impermeable coating. On the top of the foundation ring is a steel channel to which the tank is attached.

In September 1993, USPCI (former facility owner) retained Law Engineering to conduct an investigation that would yield site-specific subsurface data in the vicinity of Tank EF2. Law drilled four (4) geotechnical borings as part of this investigation. In general, the soil profile consisted of 1- to 2-ft. of gravel followed by 15- to 20-ft. of soft-to-hard, reddish-brown silty clay. A review of the data within the Law report, including the boring logs, indicates the soil strengths should be adequate to support the tank and associated ring foundation. The applicable portion of the Law report is included herein as *Appendix F*. In addition, a foundation design analysis is included in *Appendix G*.

To quantify foundation settlement since October 2001, Jividen Surveying shot nine (9) points around the perimeter of the tank on several occasions, as indicated in the monitoring documents included in *Appendix E*. The survey points are graphically depicted on the drawing included herein as *Figure 2*. These existing foundation elevations were compared with previous surveys of the same points. A graphic representation of the historical foundation data is included herein as *Figure 3*. The most recent survey data indicates that minor foundation movement continues to occur at a reasonably uniform rate excepting point No. 89 which demonstrated an 0.11 ft. difference in 2014 but returned to its normal level in 2015. It was determined this was due to a measurement recording error. Foundation movement appears uniform without generating a concern for structural or containment failure. Generally, the tank in its entirety has demonstrated a minor cyclical rise and fall in





**Clean Harbors**  
ENVIRONMENTAL SERVICES, INC.

**LONE MOUNTAIN FACILITY  
WAYNOKA, OKLAHOMA**



Evaporator Feed Storage Tank No. 2  
Measured Plate Thickness

Date:	April 6, 2016
Scale:	n.t.s.
Designed by:	R. ERDIN
Drawn by:	R. UNGER
Checked By:	R. ERDIN
Project No.	015493-

Fig. 1a







 ENVIRONMENTAL SERVICES, INC.	LONE MOUNTAIN FACILITY WAYNOKA, OKLAHOMA	
	Evaporator Feed Storage Tank No. 2 Survey Points Schematic	
		
	Date: April 6, 2016	
	Scale: NTS	
Designed by: R. ERDMAN		
Drawn by: R. UNGER		
Checked By: R. ERDMAN		
Project No. 015493-00		
Fig. 2		



# EVAPORATOR FEED TANK NO. 2 FOUNDATION SURVEY DATA




Figure 3.



elevation over time that is attributed to normally-occurring groundwater table fluctuations and which has not resulted in any known tank damage.

### 3. SECONDARY CONTAINMENT SYSTEM

- 3.1 General Description of Secondary Containment.** The secondary containment system is designed and operated to prevent migration of wastes or liquids out of the system. Evaporator Feed Tank Nos. 1 and 2 are located in a reinforced-concrete-base floor area with vertical concrete sidewalls. This area is inspected on a daily basis.


A previously-reported visual inspection prior to October 2001 showed apparent stress cracks or other conditions that would indicate an insufficiency in the foundation design. The previously-referenced geotechnical investigation has addressed these issues. It was determined that this apparent failure in the concrete was due to the lack of proper steel reinforcement and/or differential settlement (consolidation) in the subgrade. The subgrade appeared to be comprised of fill material. The possibility that the subgrade was not properly compacted before the concrete was poured was suspected. It was determined that the concrete under the primary tank was in fair condition. The ground surrounding the secondary containment system is sloped to shed rainfall runoff to aid in preventing saturated soil. The containment system is walled-off and receives no direct vehicular traffic. The foundation walls and base are mass-poured in-place.

During this assessment, the concrete secondary containment area appeared to be in satisfactory condition. The walls and floor have a uniform sealant coating and an ongoing maintenance program repairs cracks on a continual basis. The ground surrounding the secondary containment system is sloped to shed rainfall runoff to aid in preventing saturation of the foundation soil.

The containment area and tanks are visually monitored on a daily basis for leaks. The floor is sloped to collect any drainage or spills. Any released tank contents or surface runoff will drain on top of the sloped concrete to the sump area. The accumulated liquids are then withdrawn within a specified time period. The secondary containment system is graphically depicted in the drawings included herein as *Figures 4 and 5*.

- 3.2 Design Standards.** "As-Built" drawings for this area were obtained and utilized as a reference. The structural capacity of the foundation and walls were compared to those applicable sections in the *API 653-95* and the *American Concrete Institute (ACI 318/89/318r-89)*. These calculations were used as a guide to verify the ability of the system to contain hazardous waste.
- 3.3 Hazardous Characteristics of Wastes Stored.** The wastes managed in the primary tank are both characteristic and listed waste, as found in *40 CFR Part 261, Subparts C and D*. This tank is a storage tank where aqueous-based waste materials that required oxidation, neutralization, filtration, or settling (among other physical/chemical treatment methods) were






**CleanHarbors**  
ENVIRONMENTAL SERVICES, INC.



LONE MOUNTAIN FACILITY  
WAYNOKA, OKLAHOMA

Evaporator Feed Storage Tank No. 2  
Secondary Containment System



Date:	April 6, 2016
Scale:	n.t.s.
Designed by:	R. ERDMAN
Drawn by:	R. UNGER
Checked By:	R. ERDMAN
Project No.	015493-00
Fig.	4





Liner Detail

Containment Section Details  
Scale = N.T.S.



LONE MOUNTAIN FACILITY  
WAYNOKA, OKLAHOMA

Evaporator Feed Storage Tank No. 2  
Secondary Containment Section A-A



Date:	April 6, 2016
Scale:	n.t.s.
Designed by:	R. ERDMAN
Drawn by:	R. UNGER
Checked By:	R. ERDMAN
Project No.	015493-00
Fig. 5	



stored prior to evaporation or shipment off-site. Currently, the only material placed in the tank is treated wastewater. The waste managed in this tank has the following general characteristics:

- $4 < \text{pH} < 13$ ;
- $N > 1$ ;
- Temperature = Ambient; and
- Low-Solvent Constituents.

The hazardous characteristics of the waste treated in the primary tank were examined. It was determined that the pH and normality levels of the waste are the primary areas-of-concern.

**3.4 Existing Corrosion Protection.** The entire secondary containment area has been coated with Dudick, Inc. Protecto-Coat 200.

**3.5 Documented Age of the Containment System.** The secondary containment system was constructed and installed in 1987, thus making the system 28-years old at the time of this assessment. The system has undergone significant upgrading since it was initially installed to include the following.

- A coating was applied in June 2012. The secondary containment surface coating Chemproof Polymers-Permacoat 3000 on horizontal surfaces and Chemproof Polymers-Permacoat 3000V on vertical surfaces. Equivalent or superior coating materials are used during any necessary repairs to the coating. Information regarding Chemproof Polymers-Permacoat is included herein as *Appendix H*.
- Potential cross-connections were eliminated in 1993. The main lines from the primary treatment and storage areas exited the containment area through the floor of the secondary containment area down to the final treatment area, thereby potentially allowing material from a tank failure to migrate into the secondary containment area within the final treatment area. Elimination of this potential cross-connection acts to segregate the secondary containment area for EF1 and EF2 from any other.

**3.6 Results of Leak Test.** A visual inspection of the containment area was conducted to satisfy the requirements of a leak test. No evidence of leakage from the manways or signs of penetration of the tank or containment area was observed. Based on this inspection, this area appears to be adequate to contain any leaks or spills.

**3.7 Existing Data Obtained.** The collected data associated with the secondary containment area is summarized in *Table 3.1*.

**3.8 Calculation of Existing Capacity.** The volume containment capacity available (CCA) calculation is:



$$CCA = \text{Gross Volume} - \text{Volume of Items in Containment} - \text{Volume of Rainfall}$$

Detailed calculations of the available containment volume are included in *Appendix I*. The containment capacity available equals 59,487-cf.

TABLE 3.1 SECONDARY CONTAINMENT AREA DATA	
Area	14,589-ft. <sup>2</sup>
Available Wall Height	5.5-ft.
Material	Concrete
Gross Volume	80,240-ft. <sup>3</sup>

**3.9 Required Volume.** The containment capacity required (CCR) is calculated as follows:

$$CCR = \text{Volume of Largest Tank in Secondary Containment} = (EF2) = 47,785\text{-cf}$$

**3.10 Comparison of Available Volume to Required Volume.** The containment capacity comparison is calculated as follows:

$$\begin{aligned}\text{Containment Capacity Required} &= 47,785\text{-cf} \\ \text{Secondary Containment Volume Available} &= 59,487\text{-cf} \\ \text{Excess Containment Volume} &= 11,702\text{-cf} \\ \text{Safety Factor} &= 1.24\end{aligned}$$

$CCA > CCR$ . Adequate capacity (under normal operating conditions) is available.

## 4. CONCLUSIONS

**4.1 Primary Tank Vessel.** The tank vessel at the time of inspection is appropriate for use with the present waste stream at given densities, chemical, and physical characteristics, as verified by Clean Harbors. While the useful life of the steel tank was originally estimated at 5-years, interim inspections have revealed satisfactory service conditions. Therefore, it appears that the life may be extended up to an additional 5-years, provided an annual tank foundation survey is conducted at the points previously identified in *Figure 2* to ensure that the annual maximum settlement does not exceed 1-in.

In the event the tank foundation settles more than 1-in/yr., ENVIROTECH ENGINEERING & CONSULTING, INC. requests that a new tank assessment be conducted immediately.

**4.2 Secondary Containment.** The secondary containment area at the time of inspection is appropriate for use with the present waste stream at given densities, chemical, and physical



- 4.2 **Secondary Containment.** The secondary containment area at the time of inspection is appropriate for use with the present waste stream at given densities, chemical, and physical characteristics. While the useful life of the secondary containment was originally estimated at 5-years, interim inspections have revealed satisfactory service conditions. Therefore, it appears that the life may be extended up to an additional 5-years, provided the constraint addressed in Section 4.1 is complied with.

## 5. RECOMMENDATIONS

- 5.1 **Primary Tank.** Clean Harbors should continually ensure compatibility with the waste and densities stored. Daily inspections should be continued to detect any visual corrosion or defects. Due to the known history and pattern of movement, inspection in terms of collecting and evaluating the foundation survey for settlement shall be performed between one (1) to three (3) years.
- 5.2 **Secondary Containment.** The secondary containment should be visually inspected periodically for any deterioration as well as structural integrity.
- 5.3 **Routine Inspections.** When routine and preventive measures are to be implemented, the tank should be cleaned and internally inspected to determine any interior defects or corrosion. Continued routine painting and coating of tanks on the interior and exterior, as well as routine inspections, is recommended.

## 6. CERTIFICATION

*"I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to ensure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for collecting the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment, for knowing violations."*

DATED this \_\_\_\_\_ day of April, 2016.

Ron Erdman, P.E.  
ENVIROTECH ENGINEERING & CONSULTING, INC.

C.A. 1960 - Expiration 06/30/2016



## APPENDIX A.

### PRIMARY TANK VOLUME CALCULATIONS



## PRIMARY TANK VOLUME CALCULATIONS

### ☐ DIMENSIONS

Geometry ..... Cylindrical  
Diameter ..... 60.00-ft.  
Height ..... 16.90-ft.  
Operating Height ..... 15.50-ft.  
Bottom ..... Flat

### ☐ TANK VOLUME

Maximum Volume ..... 47,785.26-cf = 357,458.57-gal.  
Operating Volume ..... 43,826.72-cf = 327,846.63-gal.

Total Primary Tank Volume ..... 47,785.26-cf = 357,458.57-gal.

### ☐ WEIGHT ON FOUNDATION

Contents S.G. .... 1.3  
Density ..... 81.12-lb/cf

### ☐ SURFACE AREA CALCULATION

Tank Top ..... n/a  
Tank Bottom ..... 2,827.53-sf  
Tank Wall ..... 3,185.68-sf

Total Surface Area ..... 6,013.21-sf

Steel Thickness - Sidewalls ..... 0.250-in.  
Steel Thickness - Bottom ..... 0.240-in.  
Volume of Steel - Sidewalls ..... 66.37-cf  
Volume of Steel - Bottom ..... 56.55-cf  
Density of Steel ..... 490-lb/cf  
Weight of Steel (Tank) ..... 30.12-ton = 60,230.32-lb.

Weight of Tank Contents ..... 1,938-ton = 3,876,340-lb.

Total Weight of Tank and Contents ..... 1,968-ton = 3,936,570-lb.



## APPENDIX B.

---

### PRIMARY TANK WALL THICKNESS

---



## PRIMARY TANK WALL THICKNESS

### ☐ DIMENSIONS

Geometry ..... Cylindrical  
Diameter ..... 60.00-ft.  
Height ..... 16.90-ft.  
Specific Gravity ..... 1.30  
Normal Operating Temperature ..... Ambient

### ☐ STEEL THICKNESS CALCULATIONS

Thickness (t) .....  $(2.6 * H * D * S.G.) / (s * E) + CA$   
s (Allowable Design Stress) ..... 23,200.00-psi  
E (Joint Efficiency) ..... 85.00%  
Thickness (t) ..... 0.1738-in.  
Corrosion Allowance ..... 0.0625-in.  
  
*Calculated Minimum Wall Thickness* ..... 0.2363-in.



## APPENDIX C.

### SEISMIC CALCULATIONS



## SEISMIC CALCULATIONS

### ☐ DIMENSIONS

Diameter ..... 60.00-ft.  
Height ..... 16.90-ft.  
Weight of Tank (Steel) ..... 75,817.00-lb.  
Weight of Maximum Contents ..... 3,876,340.00-lb.  
Tank Shell Thickness ..... 0.25-in.  
Tank Bottom Thickness ..... 0.240-in.

### ☐ STRESS IN TANK SHELL FROM SEISMIC FORCES

Max. weight of tank contents that may be used to resist shell overturning moment ..... WI  
WI .....  $7.9 * tb * (Fby * G * H)^{.5}$   
Fby (Minimum Yield Strength in Bottom Plate) ..... 36,000.00  
tb (Thickness of Tank Bottom) ..... 0.240  
G (Design Specific Gravity of Liquid) ..... 1.3  
WI ..... 1,686.18  
Note: WI Shall Not Exceed  $1.25 * G * H * D$  ..... 1,647.75-lb/ft. of Shell Circumference  
Density of Tank Shell Material ..... 490.00-lb/cf  
WT (Weight of Tank Shell) ..... 172.52-lb/ft. of Shell Circumference  
 $M/[D^2(WT + WI)]$  ..... 0.1071  
Maximum Longitudinal Compressive Force at the Bottom of Tank Shell ..... b  
b .....  $WT + 1.273 * M/D^2$   
b ..... 420.63-lb/ft. of Shell  
 $G * H * D^2/t^2$  ..... 1,265,472  
Fa ( $10^6 * t/D$ ) ..... 4,167-psi

OR

Fa ( $.5 * Fty$ ) ..... 18,000-psi  
Use Minimum Value for Fa ..... 4,167-psi  
 $b/12 * t$  ..... 140.21-psi

Note:  $b/12t$  Cannot Exceed Fa for a Stable Tank

### ☐ OVERTURNING MOMENT

Overturning Moment (M) .....  $Z * I * (C1 * Ws * Xs + C1 * W1 * X1 + C2 * W2 * X2)$   
Zone Coefficient (Z) ..... 0.1875  
Essential Facilities Factor (I) ..... 1.000



Lateral Earthquake Force Coefficient (C1) .....	0.240
D/H .....	3.55
k Factor (@ D/H = 3.55) .....	0.680
Site Amplification Factor (S) .....	1.5
Natural Period of First Sloshing Mode (T) .....	5.11
Lateral Earthquake Force Coefficient (C2) .....	0.07755
Weight of Tank (Ws) .....	60,230.32
Weight of Tank Contents (Wt) .....	3,876,340.00
W1 / Wt (@ D/H = 3.55) .....	0.32
W2 / Wt (@ D/H = 3.55) .....	0.60
Weight of Effective Mass (W1) .....	1,240,428.80
Weight of Effective Mass (W2) .....	2,325,804.00
Height from Bottom of Shell to Center of Shell (Xs) .....	8.45
X1/H .....	0.38
Height from Bottom of Center of Lateral Seismic Force (X1) .....	6.422
X2/H .....	0.55
Height from Bottom of Center of Lateral Seismic Force (X2) .....	9.295
Overtopping Moment (M) .....	695,718-ft/lb.
Opposing Moment (M*) .....	118,097,110-ft/lb.



## APPENDIX D.

### WIND LOAD CALCULATIONS



## WIND LOAD CALCULATIONS

### ☐ DIMENSIONS

Diameter ..... 60.00-ft.  
Height ..... 16.90-ft.  
Weight of Tank (Steel) ..... 60,230.32-lb.  
Weight of Max. Contents ..... 3,876,340.00-lb.  
Tank Shell Thickness ..... 0.25-in.  
Tank Bottom Thickness ..... 0.240-in.

### ☐ OVERTURNING MOMENT FROM WIND LOADS

M ..... Overturning Moment Due to Wind Loading  
M .....  $P_w * A_p * H_c$   
Pw (Wind Pressure - Assume 18-psi for 100-MPH Wind on Cylinders) ..... 18.00-psi  
Ap (Projected Frontal Area of Tank (H\*D) .....  $1,014\text{-Ft}^2$   
H1 (Height from Ground to Centroid of Tank) ..... 8.45-ft.  
M .....  $154,229.40\text{-ft-lb.}$   
M Max .....  $.66 * (WD) / 2$   
W (Weight of Tank) ..... 60,230.32-lb.  
M Max .....  $1,192,560\text{-ft-lb.}$   
*M Must Be Less Than M Max*



## APPENDIX E.

### FOUNDATION INTEGRITY MONITORING DOCUMENTS



## Annual Tank In-Service Inspection Checklist

Tank Name: EF-2 Tank Number: 2  
 Tank Location: WSWPT Date: 10-23-2014  
 Inspected By: \_\_\_\_\_ Signature: \_\_\_\_\_  
 Date of Last Inspection: \_\_\_\_\_

### I. Foundation

- A. Measure foundation levelness and bottom elevations (8 points for EF-1 and 9 points for EF-2).  
 Note: No other tanks require foundation levelness and elevation survey.

#### EF-1:

37 _____	47 _____	55 _____	263 _____
271 _____	278 _____	293 _____	303 _____

#### EF-2:

65 <u>1425.85</u>	73 <u>1425.94</u>	81 <u>1426.02</u>	89 <u>1425.92</u>	191 <u>1425.70</u>
205 <u>1425.62</u>	211 <u>1425.70</u>	219 <u>1425.79</u>	227 <u>1425.70</u>	

- B. Has the yearly maximum settlement exceeded 1 inch? (EF-1 and EF-2 only)

#### EF-1:

#### EF-2:

Yes \_\_\_\_\_ No \_\_\_\_\_ Yes \_\_\_\_\_ No \_\_\_\_\_

- C. Check 8 inch annular channel for deflection of more than 2 degrees from its correct position. (EF-1 only)

Deflection \_\_\_\_\_

Comments:

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_



## Annual Tank In-Service Inspection Checklist

Tank Name: EF-2 Tank Number: #2  
 Tank Location: WWPT Date: \_\_\_\_\_  
 Inspected By: \_\_\_\_\_ Signature: \_\_\_\_\_  
 Date of Last Inspection: 12-03-2015

### I. Foundation

- A. Measure foundation levelness and bottom elevations (8 points for EF-1 and 9 points for EF-2).  
 Note: No other tanks require foundation levelness and elevation survey.

#### EF-1:

37 \_\_\_\_\_ 47 \_\_\_\_\_ 55 \_\_\_\_\_ 263 \_\_\_\_\_  
 271 \_\_\_\_\_ 279 \_\_\_\_\_ 293 \_\_\_\_\_ 303 \_\_\_\_\_

#### EF-2:

65 1425.84 73 1425.95 81 1426.03 89 1425.88 191 1425.70  
 205 1425.62 211 1425.70 219 1425.79 227 1425.79

- B. Has the yearly maximum settlement exceeded 1 inch? (EF-1 and EF-2 only)

#### EF-1:

Yes \_\_\_\_\_

No \_\_\_\_\_

#### EF-2:

Yes \_\_\_\_\_

No \_\_\_\_\_

- C. Check 8 inch annular channel for deflection of more than 2 degrees from its correct position. (EF-1 only)

Deflection \_\_\_\_\_

Comments:

\_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_



## APPENDIX F.

---

### LAW ENGINEERING GEOTECHNICAL REPORT

---



November 22, 1993



LAW

ENGINEERING AND ENVIRONMENTAL SERVICES

Mr. Walter Sonne, P.E.  
USPCI, Inc.  
515 West Greens Road, Suite 500  
Houston, Texas 77067

SUBJECT: REVISED REPORT OF GEOTECHNICAL EXPLORATION  
Expansion of Wastewater Treatment Facilities--  
Lone Mountain Facility, Major County, Oklahoma  
Law Engineering Projects No. 392-01406-01


Law Engineering, Inc. has completed the geotechnical exploration at the subject site. Our services were provided in accordance with our Revised Proposal for Geotechnical Exploration Services No. HP-8173-93G, dated September 22, 1993; and a Request for Change Order letter dated October 12, 1993. This report briefly discusses our understanding of the project information, describes our exploratory procedures and findings, and presents our recommendations and conclusions. The data obtained during the field exploration and from the laboratory testing program is presented in the appendices.

We will be happy to discuss our recommendations with you and would welcome the opportunity to provide the additional studies or construction testing services necessary to complete this project. We look forward to serving as your geotechnical engineer on the remainder of this project and on future projects.


If you have any questions, or if you require additional information, please do not hesitate to contact us.

Sincerely,


LAW ENGINEERING, INC.



Fernando Pons, E.I.  
Project Geotechnical Engineer



Michael W. Palmer, P.E.  
Principal Geotechnical Engineer  
USPCI - Client Manager



Michael H. Homan, P.E.  
Principal Geotechnical Engineer  
Oklahoma Registration No. 15777


Distribution Copies:

Walter Sonne (2) - USPCI

Larry Marr (1) - USPCI

LAW COMPANIES GROUP, INC.





LAW ENGINEERING

---

REVISED REPORT OF GEOTECHNICAL EXPLORATION

---

EXPANSION  
OF WASTEWATER TREATMENT FACILITIES

LONE MOUNTAIN FACILITY  
MAJOR COUNTY, OKLAHOMA

prepared for  
USPCI, Inc.  
HOUSTON, TEXAS

LAW ENGINEERING PROJECT NO. 392-1406-01

NOVEMBER 1993



Expansion of Wastewater Facilities  
USPCI, Inc.  
Law Eng. Proj. No. 392-01406-01

## 1.0 PURPOSE OF EXPLORATION

The purpose of this exploration was to obtain specific subsurface data at the site and to provide recommendations and opinions for:

- ~~o General geotechnical design and construction criteria for the Expansion of Wastewater Final Treatment Facilities (WWFT): Phase I (Expansion of the WWFT Building) and Phase II (Leachate Storage Tanks).~~
- ~~o Site preparation and construction of compacted fills for the WWFT Phase I, and the WWFT Phase II.~~
- o Soil stratigraphy at the Wastewater Pretreatment Facilities (WWPT): Phase III tanks.

It should be noted that it was not the purpose of this study to directly assess or to address any environmental conditions at the site, i.e., the presence of contaminants or other substances in the soil, rock, or ground water. An additional study should be undertaken if USPCI decides to specifically address environmental conditions.



## Expansion of Wastewater Facilities

USPCI, Inc.

Law Eng. Proj. No. 392-01406-01

### ~~2.2 LEACHATE STORAGE TANKS~~

~~We understand that USPCI plans to construct three tanks within a containment area. The proposed site of construction is south of Cell 4. The proposed tanks will include a 60-foot diameter, 16-foot tall, 300,000 gallon tank; and two 33-foot diameter, 16-foot tall, 100,000 gallon tanks.~~

The proposed tanks, containing leachate with a specific gravity of 1.3, will be located within a concrete containment structure with walls on the order of 7 feet in height.

~~We understand that the preferred foundation system at the present time is a drilled pier underground system, 18-inch diameter, straight-sided drilled piers founded at 8-feet on centers. In turn, these drilled piers will support the containment wall and a 10-inch thick concrete slab on 6 inches of sand and 24 inches of structural fill.~~

### 2.3 WASTEWATER PRETREATMENT (WWPT) BUILDING

We understand that two existing on-line 300,000 storage tanks structures within the Wastewater Pretreatment (WWPT) Building are experiencing foundation distress. We further understand that these two tanks and the containment area are supported on shallow footings.



#### 4.1.3 Wastewater Pretreatment (WWPT) Building

Exploration borings L-5, L-6, L-6A, and L-7 were drilled in this area. The measured surface elevation of these borings were 1418.35, 1428.62, 1428.48, and 1430.23 feet MSL, respectively, as provided by USPCI. The subsurface conditions for this area are generalized as follows:

#### AREA C

#### WASTEWATER PRETREATMENT BUILDING

(Borings L-5, L-6, L-6A, and L-7)

STRATUM	DEPTH (ft)	DESCRIPTION	USCS CLASSIFICATION <sup>2</sup>
I C	0 to 2	FILL: GRAVEL	Unclassified
II C	1 to 22.5	FILL: Soft to hard, reddish brown with gray, silty CLAY, with gypsum fragments and gravel.	CL
III C	15.5 to 20.5	Very stiff to hard, reddish brown with gray, silty CLAY, with gypsum fragments and gray silt streaks.	CL
IV C	18.5 to TOB <sup>1</sup>	Gray silty CLAYSTONE to reddish brown silty CLAYSTONE.	Unclassified

<sup>1</sup> Termination of Boring

<sup>2</sup> Unified Soil Classification System



With reference to the Soil Stratum Summary, the TEST BORING RECORDS, Soil Profiles and the Laboratory Test Results, our discussion of the soil conditions for Area C is as follows:

Stratum IC consists of GRAVEL to gravelly fill soils encountered in all borings from existing surface to approximately 2 feet below existing grade.

Stratum IIC consists of fill soils of soft to hard, reddish brown with gray, silty CLAY with pumice fragments and gravel. Law personnel performed continuous sampling with Shelby tubes, and utilized on-site extruding techniques to better identify the extent of this fill stratum. These fill soils were encountered from a depth of 1 foot from existing surface to 22.5 feet below grade. Organic odor and wet seams were identified in the lower two feet of this formation in Borings L-6 and L-7. Plasticity for this stratum was medium with plasticity index values ranging from 17 to 21. Liquid limit values range from 43 to 45 percent and plastic limit values range from 24 percent to 26 percent. Stratum IIC soils were generally moist with occasional wet seams. Natural moisture contents ranged from 24 to 30 percent, and were from 0 to 2 percent above corresponding PL values.

Pocket penetrometer tests and laboratory unconfined compression tests, on relatively undisturbed samples, indicated shear strength values that varied erratically throughout the fill depth in Boring L-5 (easternmost boring). Shear strength values in Borings L-6 and L-7 were similar throughout the same depths of the fill stratum. There was a similar uniform decrease of shear strength values with depth in Borings L-6 and L-7 to a depth approximately 12.5 feet. (See TEST BORING RECORDS L-6 and L-7).

Stratum IIIC consists of very stiff to hard, reddish brown with gray, silty CLAY with pumice fragments and gray silt streaks. These soils were encountered in all borings, except Boring L-5, from 15.5 feet from existing surface to a depth of 20.5 feet below grade. One Standard Penetration Test N-value was 40 blows per foot (bpf) at a depth of 17 feet in Boring L-6A. Plasticity for this stratum was medium with a plasticity index value of 13, a LL value of 32 percent, and a PL value of 19 percent. One natural moisture content was 24 percent. Based on this natural moisture content and corresponding Atterberg Limit tests, the soil was very moist with a moisture content 5 percent above the corresponding PL value. Pocket penetrometer tests resulted in cohesion values ranging from 3,750 psf to an excess of 4,500 psf.



Stratum IV consists of gray silty CLAYSTONE to reddish brown silty CLAYSTONE. This formation was encountered from a depth of 18.5 feet below existing surface to termination depth. Standard Penetration Test N-values resulted in refusal values ranging from 6 inches per 50 blows to 4.5 inches per 50 blows. One natural moisture content was 21 percent. All pocket penetrometer tests resulted in cohesion values in excess of 4,500 psf.

#### 4.2 WATER LEVEL CONDITIONS

~~Water level observations were made in the boreholes during drilling operations and 24 hours after completion of drilling to investigate the short term ground water levels.~~

~~Ground water was identified during our subsurface exploration at depths of 7 feet and 5.5 feet in Borings L-1 and L-2A, respectively (24 hour readings). Ground water was encountered 1.5-feet to 1-foot above the top of the claystone formation in these borings.~~

~~Borings L-3 and L-4 were dry at the time of drilling and 24 hours thereafter.~~

Water was identified during drilling at a depth of 24 feet below existing ground surface in Boring L-5. Boring L-6 was dry to termination depth during drilling operations and 24 hours thereafter. Ground water was not identified in Borings L-6A and L-7 during and immediately following drilling operations. Law personnel could not obtain 24 hour water level readings at L-5, L-6A, or L-7, due to caving soils in L-5 at 15.8 feet, and surficial cuttings that obstructing the boreholes at L-6A and L-7.

Fluctuations in rainfall, evaporation, construction activity, surface runoff, and other site specific factors could cause ground water conditions at the time of construction to vary from that observed during our field exploration.



#### ~~5.4.3 Settlement~~

~~Predicted settlements for the drilled piers will be relatively small and are expected to be limited to the elastic compression of the founding claystone formation. The maximum total settlement of any drilled shaft under the anticipated sustained loading conditions is predicted to be less than 0.25 inch.~~

#### ~~5.5 CONSTRUCTION CONSIDERATIONS~~

~~Once a foundation excavation is completed, the setting of reinforcing steel and placement of concrete should proceed expeditiously to reduce exposure of the bearing stratum and possible disturbance of the material. Should the bottom of an excavation become disturbed due to ponding of water or desiccation, the disturbed soils should be removed before concrete is placed.~~

~~We recommend that the geotechnical engineer, or their representative, observe the footing excavations immediately prior to placing concrete. The engineer should compare the soils exposed with those encountered in the soil test borings and document the results. Any significant differences should be brought to the attention of the Owner's representatives along with appropriate recommendations. The foundation bearing area should be level or suitably benched. It should also be free of loose soil, ponded water and debris prior to the inspection.~~

#### ~~5.6 WASTEWATER PRETREATMENT BUILDING STRATIGRAPHY~~

~~We understand that two existing on-line 300,000 storage tanks structures within the Wastewater Pretreatment (WWPT) Building are experiencing foundation distress. We further understand that these two tanks and the containment area are supported on shallow footings, which are currently bearing in fill soils consisting of soft to hard, reddish brown with gray, silty CLAY with gypsum fragments and gravel (Stratum IIC).~~




As discussed previously in this report, the soil stratigraphy encountered in the WWPT area generally consists of silty fill soils to a maximum depth of 22.5 feet underlain by silty clay soils which grade into claystone. Law personnel performed continuous sampling in borings L-5, L-6, and L-7 and utilized Shelby tubes and on-site extruding techniques to better identify the extent of this fill stratum.

The properties of the soils, deemed significant in the evaluation of distress of the structures, are the following:

- (a) the moist condition of the silty clay fill soils (Stratum IIC) at the site;
- (b) the medium shrink-swell potential of the silty clay matrix within the zone of major seasonal moisture change;
- (c) the erratic variation in consistency of the fill soils encountered in Boring L-5;
- (d) the similar uniform decrease in shear strength in Borings L-6 and L-7 to a minimum at approximately 13 feet from existing ground level;
- (e) the presence of wet seams, organics, and organic odor in the fill soils of Boring L-6 and Boring L-5;
- (f) the presence of ground water in Boring L-5 at a depth of 24.5 feet;







DESCRIPTION OF MATERIAL	DEPTH (ft)	ELEVATION	SAMPLES / TESTS				Plastic Limit(%)    NM (%)    Liquid Limit(%) + - - - - + △ ⊗ ⊕ COHESION (100 psf) ⊙ PENETRATION (bpf)												
			Sample Type	No.	Dry density (pcf)	% Fines													
							10	20	30	40	50	60	70	80	90				
SURF. EL: 1430.23 ft. MSL																			
LEVEL																			
to hard, reddish-brown with some LAY with gypsum fragments and				3.0	1										⊗				
	5	1425.2		5.0	2										⊗				
				7.0	3										⊗				
	10	1420.2		9.0	4	102.9					⊗	⊕	⊙		+				
				11.0	5						⊗								
				13.0	6						⊗								
	15	1415.2		15.0	7								⊗						
to hard, reddish-brown with gray, silty				17.0	8										⊗				
gray silty CLAY with gypsum very moist				19.0	9							+	⊙	+					
CLAYSTONE	20	1410.2		21.0	10														
own silty CLAYSTONE																			
Boring terminated at 25 feet	25	1405.2			11														

KS:  
 NOTES: N10920.34 E9182.90. Borehole advanced  
 5 truck-mounted drill rig using 3 1/4" I.D. hollow

Arnold Caesar

Ando Pons

SEE KEY SHEET FOR EXPLANATION OF  
 SYMBOLS AND ABBREVIATIONS USED ABOVE

TEST BORING RECORD	
BORING NUMBER	L-7
DATES DRILLED	Start: October 1, 1993 Complete: October 1, 1993
PROJECT NUMBER	392-01406-01
PROJECT	Expansion of WWT Facilities
PAGE 1 OF 1	
LAW ENGINEERING Tulsa, Oklahoma	



DESCRIPTION OF MATERIAL	DEPTH (ft)	ELEVATION	SAMPLES / TESTS				Plastic Limit(%)    NM (%)    Liquid Limit(%)																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																
			DEPTH (ft)	Sample		Test	+---+---+---+---+---+---+---+---+---+---+																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																
				Type	No.		Dry density (pcf)	% Fines	△ ⊗ ⊕ COHESION (100 psf) ⊗ PENETRATION (bpf)																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																														
SURF. EL: 1428.48 R. MSL																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																							</

ES: N10829.08 E9253.23. Borehole advanced  
truck-mounted drill rig using 3 1/4" I.D. hollow  
Soil classification from 0 to 16 feet is based on

old Caesar  
Pando Pons.

SEE KEY SHEET FOR EXPLANATION OF  
MBOLS AND ABBREVIATIONS USED ABOVE

TEST BORING RECORD	
BORING NUMBER	L-6A
DATES DRILLED	Start: October 1, 1993 Complete: October 1, 1993
PROJECT NUMBER	392-01406-01
PROJECT	Expansion of WWT Facilities
PAGE 1 OF 1	
LAW ENGINEERING Tulsa, Oklahoma	



SEE KEY SHEET FOR EXPLANATION OF  
SYMBOLS AND ABBREVIATIONS USED ABOVE



# DESCRIPTION OF MATERIAL

SURF. EL: 1418.35 ft. MSL

LEVEL

Soft to hard, reddish brown with gray, silty  
with some gravel

DEPTH  
(ft)

ELEVATION

## SAMPLES / TESTS

Sample Test  
Dry density (pcf) % Fines

Plastic Limit(%) NM (%) Liquid Limit(%)  
+ - - - - +  
△ ⊗ ⊕ COHESION (100 psf)  
⊗ PENETRATION (bpf)

10 20 30 40 50 60 70 80 90

5 1413.4

10 1408.4

15 1403.4

20 1398.4

25 1393.4

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13

96.7

with organics and organic odor at 22

wet seam with some gravel

rown silty CLAYSTONE

pipe refusal at 23 feet

Boring terminated at 23 feet

NOTES: N10939.63 E9409.49. Borehole advanced  
3 truck-mounted drill rig using 3 1/4" I.D. HSAs.  
drilled immediately following drilling operations.  
hole at 15.8' identified on 10/2/93.

Arnold Caesar  
Rando Pons

SEE KEY SHEET FOR EXPLANATION OF  
SYMBOLS AND ABBREVIATIONS USED ABOVE

## BEST BORING RECORD

BORING NUMBER L-5  
DATES DRILLED Start: October 1, 1993  
Complete: October 1, 1993  
PROJECT NUMBER 392-01406-01  
PROJECT Expansion of WWT Facilities  
PAGE 1 OF 1

LAW ENGINEERING  
Tulsa, Oklahoma



## APPENDIX G.

---

### FOUNDATION DESIGN ANALYSIS



## FOUNDATION DESIGN ANALYSIS

### ☐ DIMENSIONS

Diameter ..... 60.00-ft.  
Height ..... 16.90-ft.  
Weight of Tank (Steel) ..... 60,230.32-lb.  
Weight of Max. Contents ..... 3,876,340.00-lb.  
Tank Shell Thickness ..... 0.25-in.  
Tank Bottom Thickness ..... 0.240-in.

### ☐ CONCRETE FOUNDATION DESIGN

Assumed Footing Depth ..... 48-in.  
Assumed Footing Width ..... 12-in.  
Assumed Effective Soil Pressure - (Based on Law Engineering Investigation) ..... 1,500-psf  
Max. Bottom Shell Compression - (Based on Seismic Analysis) b ..... 420.63-lb/ft. of circ.  
Footing Width ..... 1.00-ft.  
Actual Applied Loading ..... 420.63-psf


*The actual applied loading is significantly less than the assumed effective soil pressure and therefore, the foundation should be stable.*



## APPENDIX H.

### CHEMPROOF, PERMACOAT 3000 DOCUMENTATION





# Chemproof Polymer Flooring

Home

Heavy Duty

Medium Duty

PermaCoat 2000

PermaCoat 2000 SL

PermaCoat 3000

PermaCoat 4000

PermaCoat 5000

PermaCoat 6000

PermaCoat 6500

Construction Details

Application Guidelines

System Specifications

About Us

Contact Us

**PERMACOAT 3000**  
Epoxy Floor Coating

**DESCRIPTION**

PERMACOAT 3000 is a 100% solids floor coating. PERMACOAT 3000 can be utilized as a glaze coat for the PERMATEC high build floors, or as a two coat floor or containment system (30-80 mils). When applied as a two coat floor or containment system, a silica broadcast is used between coats.

The PERMACOAT 3000 consists of two components, resin and hardener, in both the horizontal and vertical formulations. Its application is accomplished with rubber squeegees and short nap paint rollers.

**FUNCTION**

PERMACOAT 3000 is designed as a medium duty (30-80 mils) floor coating and/or secondary containment system where moderate mechanical abuse and chemical exposure are anticipated, so you may use the Chemical Resistant Flooring. PERMACOAT 3000 can be installed over most sound floors, including new or old concrete, steel and wood, providing a cost effective alternative to high-build floor toppings.

**TYPICAL APPLICATIONS**

- Food processing plants
- Chemical processing plants
- Breweries
- Laboratories
- Pulp and paper mills

**TYPICAL PROPERTIES**

Solids, by Volume	100%
Hardness Shore D ASTM D2240	82-85
Taber Abrasion ASTM D4060 CS 17 Wheels	Loss/1000 cycles = 25mg
Compressive Strength ASTM C579	14,400 psi
Flexural Strength ASTM D790	16,500 psi
Tensile Strength ASTM D307	11,000 psi
Bond Strength to Concrete ASTM D4541	Exceeds tensile strength of concrete. Failure in concrete

**PACKAGING & COVERAGE**

PERMACOAT 3000 is packaged in one and three gallon units. Each unit consists of premeasured components, Part A (Resin) and Part B (Hardener).

Application thickness may vary from 30 to 80 mils, depending on the expected service conditions. Factors to consider are 1) length of chemical exposure; 2)mechanical abuses; and 3) substrate texture.



- Processing area in general where chemicals are used
- Any area that requires a safe, non-slip floor

### FEATURES

PERMACOAT 3000 allows for fast, easy application. It also offers chemical resistance and physical performance much higher than those found in paints and other thin mil coatings.

Note: At 30-50 mils, PERMACOAT 3000 provides excellent chemical resistance for splash and spill exposures. In addition, when applied at 50-80 mils, it can often be recommended for containment service. (For specific recommendations refer to PERMACOAT 3000 "Chemical Resistance Guide" and your local distributor.)

### OTHER FEATURES INCLUDE:

- Rapid cure resulting in minimal "downtime"
- Odor-free
- Nonskid safety finish optional

### MIXING

Prior to application, the PERMACOAT 3000 (Resin, Hardener, and Silica) and the substrate should be between 70 degrees and 95 degrees F.

Premix the Resin (Part A) for 30 seconds using a Jiffler mixer blade attached to a 500-750 RPM drill. Add the Hardener (Part B) only when the batch is ready to be applied. Mix for approx. 90-120 seconds. After mixing pour immediately onto floor.

### APPLICATION

Use a rubber squeegee to spread

### CURE TIME

The cure time of PERMACOAT 3000 and other resinous systems are very dependent upon the temperature of the substrate. The chart below represents the approximate times for the respective service conditions, following the last coat:

Service (hours)	70°F	80°F	90°F
Foot traffic	10	8	6
Light Chemical	14	12	10
Fork Lift	20	16	12

### CLEAN-UP

All mixing and application equipment should be cleaned immediately after use. If this is done, soap and water, or biodegradable cleaners can be used. If the material has begun to set, more aggressive solvents may be necessary. Before using solvents, refer to their respective MSDS for handling considerations.

### MAINTENANCE

For systems designed for splash and spill exposures, routine washdowns are recommended to reduce the length of chemical exposure. This step is not necessary where the product is recommended for containment service.

### WARRANTY

For product warranty see ChemProof Polymers, Inc. "Standard Limited Warranty." If one is not included with this literature contact your local distributor or ChemProof Polymers, Inc. for a copy.

### STORAGE & SHELF LIFE

PERMACOAT 3000 should be stored at 50-90°F out of direct sunlight. All containers should



the resin over the pre-measured area to be covered. Immediately back roll the PERMACOAT 3000 with a short nap (1/8 inches) wool or mohair roller. At this point several pre-specified readings should be made with a wet mil gauge to assure uniform coverage. After the coating has been back rolled and uniform thickness verified, the surface should be saturated with a silica broadcast.

After the first coat supports foot traffic, the excess silica can be removed. Within 24 hours a second coat of PERMACOAT 3000 should be applied using the same procedure, minus the silica broadcast.

Note: Additional broadcasts and roll coats can be utilized to increase floor thickness.

### **SAFETY**

PERMACOAT 3000 contains blended Epoxies as the resin and blended Amines as the hardener. Protective clothing and gloves are recommended to prevent sensitization to these materials. In case of ingestion or eye contact, contact a physician immediately. MSDS are available for this product upon request.

remain unopened until ready for use. If stored as set out above, PERMACOAT 3000 has a minimum shelf life of one year.

**WHERE PERMACOAT 3000 SHOULD NOT BE INSTALLED**  
**PERMACOAT 3000 should not be applied over substrates:**

- which are wet during the application
- subject to hydrostatic pressure
- which are unsound
- which are contaminated and cannot be cleaned
- at temperatures below 70°F  
(consult ChemProof Polymers)

---

[Home](#) | [About Us](#) | [Contact Us](#)

©2001 ChemProof. All rights reserved.

[Tulsa Web Design by Ambitious Web](#)



# APPENDIX I.

## SECONDARY CONTAINMENT CALCULATIONS



## SECONDARY CONTAINMENT CALCULATIONS

### ☐ DIMENSIONS

EF Tank Diameter ..... 60.00-ft.  
PCL Tank Diameter ..... 12.00-ft.  
Secondary Containment Height - Hsc ..... 5.50  
Secondary Containment Surface Area - Asc ..... 14,589.00-sf  
Gross Volume of Secondary Containment ..... 80,239.50-cf

### ☐ DISPLACEMENT VOLUMES

EF Tank Base ( $\pi \cdot D^2/4 \cdot Hsc$ ) ..... 15,551.42-cf  
PCL Tank Base ( $\pi \cdot D^2/4 \cdot Hsc$ ) ..... 622.06-cf

*Note: Displacement volumes include only one of the EF tanks. It is assumed that a failed tank would not displace available secondary containment.*

Displacement Volume ..... 16,173.47-cf

### ☐ RAINFALL VOLUMES

Depth of Rainfall ..... 6.150-in.  
Impacted Area ..... 8,934.00-sf  
Rainfall Volume ..... 4,578.68-cf

### ☐ CONTAINMENT CAPACITY AVAILABLE

CCA ..... Gross Volume - Displacement Volume - Rainfall Volume

CCA ..... 59,487-cf

Volume of Largest Tank (EF1) ..... 47,785.26-cf


Excess Containment Volume ..... 11,702-cf

Safety Factor ..... 1.24



# SECTION EF3





ENGINEERING  
FOR  
TODAY'S  
CHANGING  
WORLD



June 14, 1993



Mr. Don Dillie  
Project Engineer  
USPCI, Inc.  
Lone Mountain Facility  
Route 2, Box 180A  
Waynoka, Oklahoma 73860


Re: Evaporator Feed Tank No. 3 (EF3)  
Tank Installation

Dear Mr. Dillie:

At the time of our inspection of Evaporator Feed Tank No. 3 (EF3) at the Lone Mountain Facility, there were no visual apparent weld breaks, punctures, scrapes of protective coatings, cracks, corrosion or damage due to construction or installation. This is to certify that Evaporator Feed Tank No. 3 was installed in such a manner which did not produce any structurally adverse conditions in accordance with 40 CFR 264.192(b).

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment of knowing violations.

If you have any questions please feel free to call us at 405-755-5325.




cc: Larry Oden  
Jim Williams  
Dennis Dodd

FILE INSTRUCTIONS	
Unit	Final Treatment
Project	EF3 Tank Assessment
Section	Tank Certification
Rcvd. by: L. J. ODEN	
ROUTE	COPY
File	<del>File</del> D.D.D.D

(TANK  
INSTALL)





ENGINEERING  
FOR  
TODAY'S  
CHANGING  
WORLD

Mr. Don Dillie  
Project Engineer  
USPCI, Inc.  
Lone Mountain Facility  
Route 2, Box 180A  
Waynoka, Oklahoma 73860


Re: Evaporator Feed Tank No. 3 (EF3)  
Tank Leak Test

Dear Mr. Dillie:


Evaporator Feed Tank No. 3 (EF3) was tested for leaks by the tank manufacturer before shipping. Once the tank was installed, and before it was put into service, it was filled with water and allowed to remain in hydraulic static equilibrium for a period of several hours. The tank did not leak during this period in accordance with 40 CFR 264.192 (d).

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment of knowing violations.

If you have any questions please feel free to call us at 405-755-5325.



cc: Larry Oden  
Jim Williams  
Dennis Dodd



June 14, 1993



FILE INSTRUCTIONS	
Unit	Final Treatment
Project	EF3 Tank Assessment
Section	Tank Certification
Rcvd. by: L. J. ODEN	
ROUTE	COPY
FILE	B. Conner
	D. Dodd

(LEAK TEST)



**SECTION 301**  
**ASSESSMENT OF EVAPORATOR FEED STORAGE TANK No. 3 (EF3)**  
**LONE MOUNTAIN HAZARDOUS WASTE FACILITY**  
**U.S.P.C.I.**  
**WAYNOKA, OKLAHOMA**

**A. TANK SYSTEM DESCRIPTION**

The Evaporator Feed Storage Tank No. 3 (EF3) is a new cylindrical carbon steel aboveground vertical tank located in the wastewater treatment building of the Lone Mountain Hazardous Waste Facility. The Evaporator Feed Storage Tank No. 3 and its ancillary equipment are located together in a concrete curbed containment area.

**B. PRIMARY TANK VESSEL**

**1. General Description**

The Evaporator Feed Storage Tank No. 3 is being assessed to determine if the unit is adequately designed with sufficient structural strength, and compatibility with the waste to be treated. The Evaporator Feed Storage Tank No. 3 will be used to store treated wastes prior to entrance into the exchanger units. The tank is vertical in position, aboveground and cylindrical in shape. The tank is supported by a skirted base. The Feed Tank has a slightly elevated temperature due to the return waste line from the Flash Tank.

**2. Design Standards.**

Structure calculations were performed to compare the existing tank and supports to those sections that are applicable in the American Petroleum Institute Standard 650 - 1988 edition (API-650) and the American Institute of Steel Construction (AISC) Manual of Steel Construction (8th Edition). These calculations can be found in the Appendix of this report. The tank was built to API-650 Standards and the steel specifications and mill test reports will be located in Appendix F. Appendix A and M were utilized from API-650 due to the small diameter and elevated temperature.

**3. Hazardous Characteristics of Wastes Treated**

The wastes which are treated in this tank have the following characteristics:

Treated wastes

pH (4-12)

N < 6

Temperature = < 245°F



The hazardous characteristics of the waste treated in this tank were examined. It was determined that the pH and normality levels of the waste are the primary areas of concern. This was to determine the applicability of a corrosion allowance for the tank material type and thickness.

#### **4. Existing Corrosion Protection**

The tank is coated on the inside with Sherwin Williams Hi-Mil Sher Tar Epoxy. The exterior is painted with Glidden Epoxy Primer No. 5466. It should be noted that when thickness calculations were compared, a 1/8" corrosion allowance was used.

#### **5. Documented Age of Tank**

The tank was manufactured by Delta Tanks of Houston Texas in March of 1993. The tank was installed in April, 1993.

#### **6. Result of Leak Tests**

A leak test was performed by the manufacturer and witnessed by an inspector prior to shipment. An inplace leak was performed and no leaks were found.

#### **7. Existing Data Obtained**

Diameter of Tank	6'-4"
Height	12'
(Normal Operating Level)	11'
Material	Carbon Steel (ASTM A-36)
Wall Thickness	0.375"
Specific Gravity	1.5
Operating Temperature	245°
Maximum Volume	1625 Gal.
Normal Operating Volume	1389 Gal.
Seismic Zone	1

#### **8. Calculation of Foundation Loading**

Total Weight of Tank and Contents = 11.42 tons

Detailed calculations reflecting the volume and weight of the tank are found in appendix A. The minimum required foundation thickness and steel reinforcement are included in appendix E of this assessment.



## 9. Required Structural Calculation

The calculated required wall thickness for this tank is 0.1448 inches. 0.125 inches is added for corrosion allowance. This corrosion allowance is based on a best engineering estimate taking into account the materials being treated and a 20 year design life. (See appendix B of this assessment for detailed calculations or required wall thickness and structural analysis of the tank support system.) The API-650 standard and Appendix A and M were used in determining the maximum allowable stress. The maximum allowable stress for this tank will be 17,600 psi.

## 10. Comparison of Actual Structure to Theoretical Values

### Wall Thickness Comparison

Calculated Required Wall Thickness	0.1448"
Minimum Required Wall Thickness By API 650-88	0.1875"
Measured Wall Thickness	0.375"

## C. SECONDARY CONTAINMENT SYSTEM

### 1. General Description of Secondary Containment

The secondary containment system is designed and operated to prevent any migration of wastes or liquids out of the system. (See appendix G for layout of secondary containment area.) The Evaporator Feed Storage Tank No. 3 is located inside the wastewater final treatment building within a concrete containment area. All associated piping is aboveground and a portion of the associated piping is contained in this area. The area is inspected on a daily basis.

Design or construction details were not available for detailed structural analysis of the concrete curb and floor. The minimum required foundation thickness and steel reinforcement were calculated and are included in the appendix E of this assessment. See appendix G for detailed drawings of the containment area. The section through the containment area is based on concrete cores taken in this area. The size and spacing of the steel reinforcement is not known, however, it would be acceptable to assume No. 3 bars spaced at 12" center to center in each direction. The concrete slab is resting on a sand base. The thickness of the slab in this area is no less than 6". The compressive strength determined from the concrete removed in the coring procedure was found to be approximately 7000 psi. For calculation purposes a compressive strength of 4000 psi was used.



The containment area and tanks are routinely visually monitored on a daily basis for leaks. A sump pump and drain are located in the containment area. The floor is sloped to the low area to collect any drainage or spills. Any released tank contents or surface runoff will drain on top of the sloped concrete to the sump area. The accumulated liquids are then removed and pumped to the wastewater pretreatment area within a maximum of 24 hours, as a permit condition.

## **2. Design Standards**

The structural capacity of the foundation and walls were compared to those sections that are applicable in the API 650-88 and the American Concrete Institute (ACI 318-89/318r-89) and these calculations were used as a guide in verifying the ability of the system to contain hazardous waste. No design drawings or standards were found.

## **3. Hazardous Characteristics of Wastes Treated**

The wastes which are treated in the primary tank have the following characteristics:

Treated Wastes  
pH Level (4-12)  
N < 6  
Temperature < 245°

The hazardous characteristics of the waste treated in the primary tank were examined. It was determined that the pH and normality levels of the waste were the primary areas of concern. This was to determine the applicability of a corrosion allowance for the containment system material type and thickness.

## **4. Existing Corrosion Protection**

The entire secondary containment area floor and walls have been coated with an impermeable coating (Overcrete Plus by Concrete Protection Systems, Inc. and Sentry Polymers, Semstone 805). The coating is compatible with the present waste stream as verified by USPCI.

## **5. Documented Age of the Containment Area**

The secondary containment system was constructed and installed in 1987 thus making the containment system 5 years old.



## 6. Result of Leak Tests

A visual inspection of the containment area was performed and from this inspection there were no cracks or breaks in the impermeable coating, therefore it would be adequate to contain any leaks or spills. The area is inspected daily on a routine basis checking for leaks from the primary tank.

## 7. Existing Data Obtained

Area	2396 s.f.
Wall Height	0.46 ft. (Lowest point)
Material	Concrete

See Appendix G of this assessment for detailed drawings of the containment area.

## 8. Calculation of Existing Capacity

### Containment Capacity Available (CCA)

$CCA = \text{Gross Volume} - \text{Volume of items in the containment} - \text{Volume of rainfall.}$

See Appendix D of this assessment for detailed calculations of the available containment volume. The containment capacity available = 1186.60 c.f.

## 9. Required Volume

Containment Capacity Required (CCR)

$CCR = \text{Volume of Largest Tank in the secondary containment}$

Volume of Largest Tank = 315.24 c.f. (FT3 Section 303)

## 10. Comparison of Available Volume to Required Volume

### Containment Capacity Comparison

Containment Capacity Required =	315.24 c.f.
Secondary Containment Volume Available =	1186.60 c.f.
Excess Containment Volume =	871.36 c.f.

$CCA > CCR$  Adequate Capacity (under normal operating conditions) is available.



## **D. CONCLUSIONS**

### **1. Primary Tank System**

The tank vessel at the time of inspection was fit for use with the present waste stream at given densities, chemical and physical characteristics as verified by USPCI. The useful life of the steel tank would be estimated at 20 years if the current waste stream is maintained. This useful life was determined by using a design life of 20 years less the period that the tank has been in use at the USPCI Lone Mountain Facility.

### **2. Secondary Containment System**

The secondary containment area at the time of inspection was fit for use, if the present waste stream at given densities and chemical and physical characteristics as verified by USPCI were released from the primary tank. The useful life of the concrete containment area is estimated at 15 years. This useful life was determined by using a design life of 20 years less the period that the tank has been in use at the USPCI Lone Mountain Facility. There did not seem to be any extensive corrosion or deterioration of the secondary containment area.

## **E. RECOMMENDATIONS**

The following repairs or modifications should be made:

### **1 Primary Tank**

The tank should be cleaned and internally inspected periodically for corrosion. The tank should be checked periodically with ultrasonic testing procedures to establish a verified limit of corrosion. USPCI should continually insure compatibility with the waste and densities stored. Daily inspections should be continued to detect any visual corrosion or defects.

### **2 Secondary Containment System**

The secondary containment should be checked periodically for any deterioration and structural integrity.


### **3 Routine Inspections**

When routine and preventative measures are to be completed, the tank should be cleaned and internally inspected to determine any interior defects or corrosion. Continued routine painting and coating of tanks on the interior and exterior, and routine inspection is recommended.



## F. CERTIFICATION

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.





## SECTION 301 - APPENDIX A

### EF3, Evaporator Feed Tank No.3

#### PRIMARY TANK VOLUME

##### DIMENSIONS:

Geometry:	CYLINDRICAL	
Diameter:	6.33 FEET	
Max Height:	6.00 FEET	
Normal Operating Height:	5.00 FEET	
Cone Height:	2.50 FEET	
Bottom Cone Diameter	0.50 FEET	
Cone Length	4.03 FEET	
Cone Volume:	28.46 C.F. or	212.88 Gal.

##### VOLUME CALCULATIONS

Max. Volume :	217.28 C.F. or	1625.26 Gal.
Normal Operating Volume	185.81 C.F. or	1389.86 Gal.

MAXIMUM OPERATING TANK VOLUME =	217.28 C.F.
	OR 1,625.26 GAL

##### WEIGHT ON FOUNDATION

CONTENTS S.G.:	1.50
DENSITY:	93.60 LB/C.F.

##### SURFACE AREA CALCULATION

Tank Top =	31.47 S.F.
Tank Bottom Cone =	68.66 S.F.
Tank Wall= $Cir \times h$	119.32 S.F.

TOTAL SURFACE AREA WALL AND TOP	219.44 S.F.
---------------------------------	-------------

Steel Thickness=	
Sidewalls and Top	0.25 INCHES
Cone	0.31 INCHES
Volume of Steel =	
Sidewalls	2.49 C.F.
Top and bottom	2.61 C.F.
Density of Steel =	490.00 LB/C.F.
Weight of Steel =	1.25 TONS

WEIGHT OF TANK CONTENTS =	10.17 TONS
---------------------------	------------

TOTAL WEIGHT OF TANK AND CONTENTS =	11.42 TONS
-------------------------------------	------------



## SECTION 301 - APPENDIX B

EF3, Evaporator Feed Tank No.3

### PRIMARY TANK WALL THICKNESS

#### DIMENSIONS:

Geometry:	CYLINDRICAL	
Diameter:	6.33	FEET
Height :	12.00	FEET
Specific Gravity:	1.50	
Normal Operating Temperature =	ambient	

#### STEEL THICKNESS CALCULATIONS @ BOTTOM RING

$$\text{Thickness (t)} = (2.6 * H * D * \text{S.G.}) / (s * E) + \text{CA}$$

$$s = \text{Allowable Design Stress} = 17600.00 \text{ PSI ***}$$

$$E = \text{Joint Efficiency} = 85.00\%$$

$$\text{Thickness (t)} = 0.0198 \text{ INCHES}$$

$$\text{Corrosion Allowance} = 0.1250 \text{ INCHES}$$

$$\text{Calculated Req'd Wall thk.} = 0.1448 \text{ INCHES}$$

\*\*\* THIS DESIGN STRESS IS OBTAINED FROM API-650-88 WITH THE USE OF APPENDIX A.

#### CONE WALL THICKNESS CALCULATION

$$\text{Cosine Alpha} = \cos(67.6594) = 0.3801$$

$$P1 = \text{Internal Pressure} =$$

$$= \text{Density} * \text{s.g.} * (x + D/6 * \cot(\alpha)) = 3263.83 \text{ psi}$$

$$P2 = H * \text{density} * \text{s.g.} = 33 * 62.4 * 1.5 = 3182.40 \text{ psi}$$

$$Tc = \text{top cone radius} = 6.36 \text{ inches}$$

$$Fb = \text{Allowable stress} = 17600 \text{ psi}$$

The required wall thickness of the cone will be the greater of the following Formulas.

$$1. Ts = P1 * Tc / 2 * \cos(\alpha) * Fb = 0.098 + 1/8 \text{ C.A.} = 0.223 \text{ in.}$$

$$2. Ts = P2 * D / \cos(\alpha) * Fb = 0.125 + 1/8 \text{ C.A.} = 0.250 \text{ in.}$$



## SECTION 301 - APPENDIX C

### EF3, Evaporator Feed Tank

#### STRUCTURAL SUPPORT CALCULATIONS

GIVEN:

Tank Diameter =	6.33 feet
Total Height =	12.00 feet
Weight of Tank =	2500.00 lbs
Weight of Max. Contents =	22840.00 lbs
Tank Nominal Thickness =	0.375 in

---SEISMIC DESIGN CHECK---

ZONE COEFFICIENT (Z):	0.1875
ESSENTIAL FACILITIES FACTOR (I):	1.000
LATERAL EARTHQUAKE FORCE COEFF. (C1):	0.240
D/H:	0.528
k factor:	0.590
SITE AMPLIFICATION FACTOR (S):	1.500
NATURAL PERIOD OF FIRST SLOSHING (T):	1.485
LATERAL EARTHQUAKE FORCE COEFF. (C2):	0.311
WEIGHT OF TANK SHELL (Ws):	2500.000 LBS
TOTAL WEIGHT OF TANK CONTENTS (Wt):	22840.000 LBS
W1/Wt:	0.950
W2/Wt:	0.100
WEIGHT OF EFFECTIVE MASS OF CONTENTS MOVES IN UNISON WITH THE TANK SHELL (W	21698.000 LBS
WEIGHT OF EFFECTIVE MASS IN FIRST SLOS	2284.000 LBS
HT FROM BTM OF SHELL TO CENT. OF SHELL	8.000 FEET



X1/H:	0.500
HT FROM BTM TO CENT. OF LAT. SEISMIC FO	8.000 FEET
X2/H:	0.900
HT FROM BTM TO CENT. OF LAT. SEISMIC FO	10.800 FEET
OVERTURNING MOMENT (M) = $Z \cdot I \cdot (C1 \cdot Ws \cdot Xs + C1 \cdot W1 \cdot X1 + C2 \cdot W2 \cdot X2)$	
OVERTURNING MOMENT (M):	10149.686 FT-LBS

Note: All of the above calculations are based on API-650-88 Seismic Design Procedure (Appendix E).

#### CHECK STRESS IN TANK SHELL FROM SEISMIC FORCES:

WI = MAXIMUM WEIGHT OF TANK CONTENTS THAT MAY BE USED  
TO RESIST THE SHELL OVERTURNING MOMENT

$$WI = 7.9 \cdot tb \cdot (Fby \cdot G \cdot H)^{.5}$$

tb = THK. OF BTM. PLATE UNDER SHELL:	0.375 IN
--------------------------------------	----------

Fby = MINIMUM YIELD STRENGTH OF BOTTOM PLATE:	9000.000 PSI
--	--------------

G = DESIGN SPECIFIC GRAV. OF LIQUID:	1.50
--------------------------------------	------

WI =	1192.38 LBS/FT OF SHELL CIRCUMFERENCE
------	--

DENSITY OF TANK SHELL MATERIAL:	490.00 LBS/CF
---------------------------------	---------------

WT = WEIGHT OF TANK SHELL AND THE PORTION OF FIXED ROOF SUPPORTED BY TANK SHELL:	183.75 LBS/FT OF SHELL CIRCUMFERENCE
--	---

$M/[D^2(WT+WI)]:$	0.1839
-------------------	--------

b = MAXIMUM LONGITUDINAL COMPRESSIVE  
FORCE AT THE BTM. OF TANK SHELL

$$b = WT + 1.273 \cdot M/D^2$$

b:	505.90 LBS/FT OF SHELL
----	------------------------



$G \cdot H \cdot D^2 / 1^2$ :	5133.68
$F_a$ = MINIMUM OF $10 \cdot 6 \cdot D$ or $F_{ly} / 2$ :	4500.00 PSI
$F_{ly}$ = MINIMUM YIELD STRENGTH OF BTM. PLATE:	9000.00 PSI
MAX. LONGITUDINAL COMPRESSIVE STRESS IN THE TANK SHELL = $b / 12t$ =	112.42 PSI

#### CHECK OVERTURNING MOMENT FROM WIND PRESSURE

M must be Less Than or Equal To  $.66 \cdot (WD) / 2$   
 If M is Greater Than  $.66 \cdot (WD) / 2$  Anchor Bolts  
 Would Be Required

Where:

W = Shell Weight Available To Resist Uplift (lbs)

D = Tank Diameter (feet)

M = Overturning Moment

$M = P_w \cdot \text{Projected Area} \cdot H_1$

$H_1$  = Height from ground to centroid of tank shell

$P_w$  = Wind Pressure (18 psf for 100 MPH Wind on cylinders)

$.66 \cdot (WD) / 2$ :	5224.73 FT-LBS
------------------------	----------------

M:	8207.57 FT-LBS
----	----------------

$M > .66 \cdot (WD) / 2$  therefore anchor bolts are required

Number of Anchors:	8.00
--------------------	------

Anchor Diameter:	0.75 inches
------------------	-------------

Dia. of Anchor Circle:	6.66 feet
------------------------	-----------

$tB$  = design tension load per anchor

$tB$ :	303.41 pounds
--------	---------------

Allowable Load/ Anchor:	8835.73 pounds
-------------------------	----------------



SECTION 301 - APPENDIX D

Wastewater Final Treatment

SECONDARY CONTAINMENT VOLUME CALCULATIONS

AREA 13-1

Area No.13-1-1	
Length =	50.33 feet
Width =	29.00 feet
Height =	0.46 feet
Surface Area =	1459.66 S.F.
Volume =	671.44 C.F.

Area No.13-1-2	
Length =	15.00 feet
Width =	13.25 feet
Height =	0.41 feet
Surface Area =	198.75 S.F.
Volume =	81.49 C.F.

Area No.13-1 Sump (Trench)	
Length =	49.17 feet
Width =	1.25 feet
Height =	0.83 feet
Surface Area =	61.46 S.F.
Volume =	51.22 C.F.

Area No.13-1 Sump (Trench)	
Length =	22.00 feet
Width =	1.25 feet
Height =	0.33 feet
Surface Area =	27.50 S.F.
Volume =	9.17 C.F.

Gross Area =	Summ of Area 1 and 2	1658.41 S.F
Gross Volume =	Area * Height + Sumps	813.31 C.F.



Volumes of Items of Displacement \*\* Area 13-1

1. DU Tank pad =	$19 \times 12 \times 2 / 12 =$	38.00 C.F.
2. BB1 Tank Skirt =	$2 \times \pi \times r \times \text{thk.} \times 0.46 =$	0.24 C.F.
3. BB1 pump base =	$4 \times 1.333 \times 0.46 =$	2.45 C.F.
4. Filter Base =	0.15 c.f.	0.15 C.F.
5. Channel supports for LF2 =	$5 \times .46 \times 3.83 / 144 =$	0.06 C.F.
6. Walkway support legs =	$4 \times 0.0875 \times 0.46 =$	0.16 C.F.
7. Building supports =	$8 \times (19.7 / 144) \times 0.46 =$	0.50 C.F.
8. DU Pumps =	$8 \times 1.333 \times 0.5 \times 0.25 =$	1.33 C.F.
9. EV3 support legs	$4 \times 0.46 \times 7.34 / 144 =$	0.09 C.F.
10. EB1 Support Legs =	$4 \times 2 \times 19.7 / 144 =$	1.09 C.F.
11. Sump for pipes =	$6 \times 4 \times .46 =$	11.04 C.F.
12. Small Base DU units	$\pi \times D \times (.5 / 12) \times .46$	0.15 C.F.
13. Large Base DU units	$\pi \times D \times (.5 / 12) \times .46$	0.10 C.F.

Total volume to deduct for items in containment area = 55.38 C.F.

Subtraction for volume of rainfall

This entire area is covered and will not receive any rain

TOTAL AVAILABLE VOLUME = Gross Volume - Subtractions =	813.31 C.F.
Items of displacement	-55.38 C.F.
Volume of rainfall	0.00 C.F.

TOTAL AVAILABLE VOLUME AREA 13-1 757.93 C.F.

AREA 13-2

Area No.13-2

Length =	41.00 feet
Width =	18.00 feet
Height =	0.46 feet
Surface Area =	738.00 S.F.
Volume =	339.48 C.F.

Area No.13-2 Sump

Length =	2.00 feet
----------	-----------



Width =	3.00 feet
Height =	2.54 feet
Surface Area =	6.00 S.F.
Volume =	15.25 C.F.

Area No.13-2 Sump (Cont.)	
Length =	4.00 feet
Width =	4.00 feet
Height =	4.92 feet
Surface Area =	16.00 S.F.
Volume =	78.67 C.F.

Gross Area =	Area 1	738.00 S.F
Gross Volume =	Area * Height + Sumps	433.40 C.F.

Volumes of Items of Displacement **		
1. Bearing Pads	$12 * (1.5 * 1 * 2 / 12) =$	3.00 C.F.
2. Pump Base (5" high steel) =	$5 * 1.5 * 3.5' =$	0.30 C.F.
3. Hydraulic unit support legs	$4 * 0.0064 * .64 =$	0.02 C.F.
4. Steps and supports, ladder supports =		0.50 C.F.
5. 8" Tank support legs =	$12 * (17.2 / 144) * 0.64 =$	0.92 C.F.
Total volume to deduct for items in containment area =		4.73 C.F.

Subtraction for volume of rainfall  
This entire area is covered and will not receive any rain

TOTAL AVAILABLE VOLUME = Gross Volume - Subtractions =	433.40 C.F.
Items of displacement	-4.73 C.F
Volume of rainfall	0.00 C.F

TOTAL AVAILABLE VOLUME AREA 13-2	428.67 C.F
----------------------------------	------------

	1186.60 C.F.
	OR
TOTAL AVAILABLE VOLUME AREA 13	8875.77 GAL



## SECTION 301 - APPENDIX E

EF3, Evaporator Feed Tank No.3

### FOUNDATION DESIGN ANALYSIS

#### ASSUMPTIONS:

$f'_c$ =	4.00 KSI
$f_y$ =	60.00 KSI
Allowable Soil Press. =	2.20 KSI
Structural Steel =	A36

#### GIVEN:

Tank Diameter =	6.33 feet
Sidewall Height =	12.00 feet
Weight of Tank (Shell)	2500.00 lbs
Weight of Max. Contents =	20340.00 lbs

Tank is Resting on a concrete foundation.

---

#### CHECK CONCRETE FOUNDATION DESIGN:

Assume Footing Depth =	6.00 inches
Assume Footing Width =	12.00 inches
Assumed Effective Soil Press. =	1925.00 psf

Look at what is resisting overturning moment from seismic load:

$b$  = 506.00 lb/ft of circ.

Where  $b$  is the maximum shell compression at the bottom of the shell.

If the footing is	12.00 inches wide
then the actual applied pressure to the subgrade is	506.00 lb/sf


This is less than the effective soil pressure.



GENERAL DATA	
DESIGN STANDARD	AS-400
DESIGN PRESSURE	0.5 PSIG
DESIGN TEMPERATURE	200 DEG F
OPERATING PRESSURE	ATMOSPHERIC
SEAL LUBE	1
WIND VELOCITY	80 MPH
SEAL AND GASKET TYPE	NYLON
DESIGNER'S SIGNATURE	YES
HYDROSTATIC TESTING	YES
VOLUME	100 GALL
SECT. GRAVITY	1.0


#### GENERAL NOTES

1. PROPOSED TANK SHALL BE DESIGNED, FABRICATED, AND ERECTED IN STRICT ACCORDANCE WITH AMERICAN PETROLEUM INSTITUTE STANDARD 600 AND EDITION 1970-1971. HOWEVER, THE NOZZLES AND MANWAYS SHALL BE FABRICATED WITH 50% PLACES WITH BLIND FLANGES PROVIDED.
2. THE SEAL AND GASKET SHALL BE 3/4" NYLON THICKNESS. THE CONTRACTOR SHALL VERIFY THAT THE MANUFACTURER'S INSTRUCTIONS FOR CORROSION ALLOWANCE AND MEETS THE THICKNESS REQUIREMENTS OF API-650.
3. THE FABRICATOR SHALL PROVIDE A SPECIAL REPORTING AND FOR A 1" OPENING IN THE SHEET, THIS OPENING SHALL BE FIELD LOCATED.
4. THE INTERIOR SHALL BE SAND BLASTED AND COATED (SEE NOTE NO. 5 & 6) TO SAND BLASTED. THE VESSEL SHALL BE LEAK TESTED AT THE TIME OF THE OWNER'S REPRESENTATIVE'S INSPECTION FROM THE COATING OF THE INTERIOR OR EXTERIOR.
5. THE FABRICATOR SHALL PROVIDE FULLY DIMENSIONED SHOP DRAWINGS FOR APPROVAL FROM THE CONTRACTOR'S FABRICATOR.
6. ALL SHEET MANWAYS SHALL BE PROVIDED WITH DAMPERS.
7. THE BASE RING SHALL BE DESIGNED TO LIFT THE LOAD TRANSFERRED TO THE CONCRETE SLAB TO LESS THAN 2500 POUNDS.
8. PLAT TOP ROOF SHALL BE USED AS A WINDWARD PLATE. ROOF LOADS SHALL BE PROVIDED FOR ROOF TRAFFIC SAFETY. LIVE LOAD = 50 PS. DEAD LOAD = 25 PS.
9. THE INTERIOR SHALL BE COATED WITH "EPOXY VALUING HALL 9-5-74" EPOXY. THIS COATING SHALL BE APPLIED IN STRICT ACCORDANCE WITH THE MANUFACTURER'S INSTRUCTIONS WITH 2 COATS APPLIED AT THE RATE OF 1 GALS PER SQ YD. THE EXTERIOR SHALL BE 50% PRIMERED WITH ALUMINUM EPOXY PRIMER NO. 5000 APPLIED AT 1/4 GALS PER SQ YD.




#### ROOF NOZZLE ORIENTATION

NOZZLE NO.	SIZE	LOCATION	ANGLE	TYPE	USE
1	8"	ROOF	270°	2'-0"	FLASH TANK OVERFLOW
2	5"	ROOF	90°	2'-0"	FUTURE USE
3	5"	ROOF	90°	2'-0"	LEVEL GAUGE
4	3/4"	ROOF	0°	1'-0"	MANWAY
5	24"	SEEWALL	90°	8'-0"	MANWAY
6	5"	SEEWALL	45°	7'-6"	FL
7	5"	SEEWALL	30°	7'-6"	FL
8	5"	SEEWALL	2025°	8'-6"	OVERFLOW
9	5"	SEEWALL	67.5°	7'-6"	FUTURE USE
10	5"	SEEWALL	90°	8'-6"	SHOT GLASS
11	5"	SEEWALL	90°	8'-6"	SHOT GLASS
12	6"	CONC	BOTTOM	CENTER	PUMP SUCTION
13	6"	ROOF	90°	1'-0"	VENT
14	5"	ROOF	225°	2'-0"	OVERFLOW



#### SIDE NOZZLE ORIENTATION



#### ELEVATION VIEW LOOKING NORTH

#### RECORD DRAWING

**USPCI**  
A Subsidiary of  
Union Pacific Corporation


**USPCI**  
LONE MOUNTAIN FACILITY  
WAYNOKA, OKLAHOMA

**Myers**  
ENGINEERING CORPORATION  
1102 N. Street, Suite 3400  
Oklahoma City, Oklahoma 73120  
(405) 758-6336


**EF3 CONSTRUCTION PLANS**  
WASTE WATER TREATMENT AREA

JOB NO. 5150  
SCALE: GRASMAIS  
DATE: 12/30/82  
DRAWN: 2  
OF: 4





14 ..... CONTAINMENT AREA NUMBER



DASHED LINE DENOTES TANK ON  
SUPPORTS NOT ON FLOOR

RECORD DRAWING

**USPCI**  
A Subsidiary of  
Union Pacific Corporation


USPCI  
LONE MOUNTAIN FACILITY  
WAYNOKA, OKLAHOMA

**Myers**  
ENGINEERING CORPORATION  
7102 N. Steadford Dr. Suite 8400  
Oklahoma City, Oklahoma 73120  
(405) 755-6325

WASTEWATER FINAL TREATMENT PLANT  
PLAN VIEW

JOB NO.	5111
SCALE	GRS
DATE	9-17-92
DRAWN	
CHECK	





14 ..... CONTAINMENT AREA NUMBER

..... DASHED LINE DENOTES TANK ON  
SUPPORTS NOT ON FLOOR

RECORD DRAWING

REVISIONS

NO.	DATE	DESCRIPTION
1	10/1/92	ISSUED FOR PERMIT
2	10/1/92	ISSUED FOR PERMIT
3	10/1/92	ISSUED FOR PERMIT
4	10/1/92	ISSUED FOR PERMIT
5	10/1/92	ISSUED FOR PERMIT
6	10/1/92	ISSUED FOR PERMIT
7	10/1/92	ISSUED FOR PERMIT
8	10/1/92	ISSUED FOR PERMIT
9	10/1/92	ISSUED FOR PERMIT
10	10/1/92	ISSUED FOR PERMIT

**USPCI**  
A Subsidiary of  
Union Pacific Corporation


**USPCI**  
LONE MOUNTAIN FACILITY  
WAYNOKA, OKLAHOMA

**Myers**  
ENGINEERING CORPORATION  
1102 N. Stirlford Dr., Suite 8400  
Oklahoma City, Oklahoma 73120  
(405) 755-5325

ELEVATIONS OF  
WASTEWATER FINAL TREATMENT AREA

JOB NO.	5111
SCALE	1"=10'
DRAWN	JTC
DATE	9-16-92
CHECKED	
BY	





NOTE: THE ACTUAL STEEL CONFIGURATION IS NOT KNOWN HOWEVER, STEEL WAS ENCOUNTERED DURING CORING OPERATIONS.

SECTION C - C  
NOT TO SCALE



RECORD DRAWING

REVISIONS	
NO.	DATE
1	10/1/80
2	10/1/80
3	10/1/80
4	10/1/80
5	10/1/80
6	10/1/80
7	10/1/80
8	10/1/80
9	10/1/80
10	10/1/80
USPCI A Subsidiary of Union Pacific Corporation	
USPCI LONE MOUNTAIN FACILITY WAYNOKA, OKLAHOMA	
Myers ENGINEERING CORPORATION 1702 N. Stratford Dr. Suite 8400 Oklahoma City, Oklahoma 73120 (405) 753-5325	
Section C-C Containment Area Section Detail Containment Area 19	
JOB NO. 1111	SCALE 1/4" = 1'-0"
DRAWN 1/1	DATE 1/1/80
SHEET 1 OF 1	



NOTE: THE ACTUAL STEEL CONFIGURATION IS NOT KNOWN, HOWEVER STEEL WAS ENCOUNTERED DURING CONNO OPERATIONS.

CONNO TESTS			
CORE NO.	DEPTH	COMPRESSIVE STRENGTH	
4	6"	7200 PSI	
5	6"	7100 PSI	



RECORD DRAWING

REVISIONS	
NO.	DESCRIPTION

**USPCI**  
A Subsidiary of  
Union Pacific Corporation

USPCI  
LONE MOUNTAIN FACILITY  
WAYNOKA, OKLAHOMA

**Myers**  
ENGINEERING CORPORATION  
1102 N. Stamford Dr., Suite 8400  
Oklahoma City, Oklahoma 73120  
(405) 755-5335

Containment Area Section Detail  
Containment Area 13B

JOB NO.	5111
SCALE	N.T.S.
DRAWN	CRS
DATE	2-2-92
CHECK	
OFF	



# SECTION EF4

## (OUT OF SERVICE)



**ASSESSMENT OF EVAPORATOR FEED TANK NO. 4 (EF4)  
LONE MOUNTAIN HAZARDOUS WASTE FACILITY  
U.S.P.C.I./LAIDLAW  
WAYNOKA, OKLAHOMA**

**A TANK SYSTEM DESCRIPTION**

Evaporator Feed Tank No. 4 (EF4) is a new replacement welded above-ground wastewater storage and treatment tank to be installed as a part of the final wastewater treatment plant at the Lone Mountain Facility. Evaporator Feed Tank #4 (EF4) is located within the Wastewater Final Treatment building on the first mezzanine level of the support structure. The tank system consists of Evaporator Feed Tank #4 (EF4), Circulating Pump (P76), Circulating Pump (P79), Heat Exchanger #4 (EU4), and associated piping and instruments.

**B PRIMARY TANK VESSEL**

**1. General Description**

Evaporator Feed Tank No. 4 (EF4) is a circular steel tank with an outside diameter of 6'4" and a height of 12'0". The tank proper has a skirt that is anchored to the support structure, and it has a closed flat top that is vented to the atmosphere. The bottom of the tank is cone shaped. Flash Tank No. 4 is being assessed to determine if the unit is adequately designed with sufficient structural strength and compatibility with the waste to be stored.

**2. Design Standards**

The tank is designed and constructed to those sections that are applicable in the American Petroleum Institute Standard 650-1993 edition (API-650).

**3. Hazardous Characteristics of Wastes Stored**

The wastes which are stored in this tank are treated and untreated brine solutions. Representative samples of both the treated and the untreated wastes were sent for analysis. The results of those analyses are included in Appendix G of this assessment. In addition, the following characteristics of the wastes were verified:

Ignitability - Flash Point > 240° F

Corrosiveness

7 < pH < 12

2 < N < 7



Reactivity - None

Temp < 300° F

From the examination of the hazardous characteristics of the waste to be stored in this tank, it was determined that the pH and normality levels (Corrosiveness) of the waste are the primary areas of concern. This is to determine the applicability of a corrosion allowance for the tank material type and thickness.

4. Corrosion Protection

The interior of the tank is coated with two layers of Sherwin Williams Hi-Mil Sher-Tar Epoxy. Each layer is applied at a dry film thickness of not less than 7.0 mils. The exterior coating consists of one layer of Glid-Guard Corrosion Resistant HS Epoxy No. 5466 series, at a dry film thickness of not less than 3.0 mils. Appendix F contains manufacturer's information on both the interior and the exterior corrosion protection systems.

5. Documented Age of Tank

This tank was manufactured by Lide Tank Company of Mexia, Texas in November 1994 and installed in February of 1995.

6. Result of Leak Tests

The manufacturer conducted a hydrostatic leak test of the tank before shipping. A description of that test is included in Appendix D of this assessment. In addition, a visual inspection was performed of the interior and exterior of the tank after installation. This inspection was conducted specifically to detect the presence of any of the following items:

- a) Weld break
- b) Punctures
- c) Scrapes of protective coatings
- d) Cracks
- e) Corrosion
- f) Other structural damage or inadequacies of construction and/or installation

The tank hydrostatic test after installation is included in Appendix D of this Assessment. A description of that procedure is also included in Appendix D of this assessment. From these tests it was determined that the primary tank was not leaking.



## 7. Existing Data Obtained

a. Diameter of Tank	6'4"
b. Nominal Height of Tank	12'0"
c. Maximum Capacity	1625 gal.
d. Overflow Liquid level	11'6"
e. Overflow Volume	1504 gal.
f. Design Specific Gravity	1.5
g. Maximum Bottom Pressure	5.9 psi
h. Maximum Operating Temperature	250° F
i. Material of Construction	
i) Shell, Root & Bottom	ASTM A36
ii) Reinforcing Pads	ASTM A36
iii) Structural Supports	ASTM A36
iv) Steel Pipe	ASTM SA106, Grade B
v) Bolts	ASTM SA193, B7
vi) Flanges, Blinds, Couplings & Plugs	ASTM SA105
j. Wall Thickness	0.375"
k. Operating Pressure	Atmospheric
l. Seismic Zone	1

## 8. Calculation of Existing Foundation Loading

Total Weight of Tank and Contents 27,350 lbs.

Detailed calculations reflecting the volume and weight of the tank are included in Appendix A of this assessment.

## 9. Required Structural Calculation

Calculations for the required wall thickness for this tank are shown in Appendix B. Metallurgical information on the materials used is included in Appendix E of this assessment. The minimum required thickness in accordance with API 650, is 0.148 inches. A corrosion allowance of 0.125 is provided for. The measured wall thickness is 0.375 inches.

Design calculations for the support structure are included in Appendix C of this assessment. These calculations were done in accordance with BOCA National Building Code 1990 Edition.

Structural analysis of the foundation is included in Appendix C of this assessment.



# 10. Comparison of Actual to Theoretical Structural Values

## Wall Thickness Comparison

Calculated Required Wall Thickness	0.1875"
Minimum Required Wall Thickness By API 650	0.148"
Measured Wall Thickness	0.375"

## Bottom Thickness Comparison

Calculated Required Bottom Thickness	0.150"
Minimum required Bottom Thickness by API 650	0.250"
Measured Bottom Thickness	0.375"

## Support Structure Comparison

See Appendix C of this assessment for complete comparison of the loads and support information for vertical columns, horizontal beams and diagonal bracing.

## Foundation Integrity Comparison

Maximum Calculated Load (6" Slab)	17.6 Kips
Calculated Foundation Support (6" Slab)	26.7 Kips
Maximum Calculated Load (17" Slab)	62.9 Kips
Calculated Foundation Support (17" Slab)	127.7 Kips

## C ANCILLARY EQUIPMENT

### 1. General Description

The ancillary equipment for the Evaporator Feed Tank No. 4 (EF4) system includes the following:

- a) Circulating Pump (P76) - a centrifugal pump designed to pump 80 GPM at 50 feet of discharge head with a suction head of 5 feet.
- b) Circulation Pump (P79) -- a centrifugal pump designed to pump 80 gpm at 50 ft. discharge head with a suction head of 5 ft.
- c) Heat Exchanger (EU4) - a plate and frame unit of stainless steel construction designed to operate at a pressure of 150 PSIG and a temperature of 300°F. Manufacturer's design information is included in Appendix B of this assessment.
- d) Associated piping, valves and instruments - all piping is Schedule 40 carbon steel fitted with 150 psi flanges. All piping with an inside



diameter of 2" or smaller is socket-welded using, at a minimum, 3000# connections. All piping with an inside diameter greater than 2" is butt-welded. All valves, fittings & instruments are rated for 150 psi or higher.

2. Design Standards

All piping is to be installed according to ASME/ANSI Code section B31.3. Metallurgical information on the materials used is included in Appendix E of this assessment.

3. Corrosion Protection

The exterior of all waste piping will be coated with two layers of Kem-Kromik Universal Metal Primer - B50Z Series. Each layer is applied at a dry film thickness of not less than 5 mils. Detailed information on the coating is included in Appendix F of this assessment.

4. Documented Age of Piping System

The piping and other ancillary equipment was purchased during a period of time between December 1994 and January 1995. It will be installed in April 1995.

5. Result of Leak Tests

A Hydrostatic leak test was performed in accordance with ASME/ANSI. B31.3 Chapter VI paragraph 345.5 using paragraph 345.4.2 to determine the pressure requirements of the test. A description of this testing procedure, along with the results of that test, are inserted in Appendix D of this assessment.

6. Data Obtained

Included in Appendix H of this assessment is a Piping and Flow Diagram of the treatment process. This Piping and Flow Diagram reflects data such as valves, blowoffs, vents, level controls and the overall flow pattern of the treatment process.

7. Piping Support System

A visual inspection of the pipe support system will be conducted. This inspection will include a look at such things as materials of construction, welds, and construction methods. From this inspection a determination will



be made as to the adequacy of the piping support system.

## **D SECONDARY CONTAINMENT SYSTEM**

### **1. General Description of Secondary Containment**

The secondary containment system was originally designed and operated to prevent any migration of wastes or liquids out of the system. Evaporator Flash Tank No. 1, Evaporator Flash Tank No. 2, Evaporator Flash Tank No. 3, Evaporator Blowdown Tank No. 2, and Evaporator Feed Tank No. 4 are located on a reinforced concrete base floor area with vertical concrete sidewalls. All associated piping is above ground and located within the secondary containment system. The area is inspected daily on a routine basis.

At the time of inspection the concrete area was withstanding daily operations, and routine climatic conditions. No cracks from compression or uplift were visually apparent.

Any released tank contents are removed and pumped to an appropriate storage area within the maximum time allowed as a permit condition.

### **2. Design Standards**

Coring of the concrete in the existing containment area were taken and tested for comprehensive strength. A copy of the report generated from those tests is included in Appendix C of this assessment. The structural capacity of the foundation was compared to those sections that are applicable in the API-650 and the ACI-318, and these calculations were used as a guide in verifying the ability of the system to contain hazardous waste.

### **3. Corrosion Protection**

There is an impermeable coating applied to the entire concrete floor and curbs. Appendix F of this assessment contains detailed information on the coating(s) employed.

### **4. Documented Age of the Containment Area**

The secondary containment system was constructed and installed in 1987.

### **5. Result of Leak Tests**

A visual inspection of the containment area was performed and from this inspection there were no cracks or breaks in the impermeable coating, therefore it appears to be adequate to contain any leaks or spills.



## 6. Calculation of Capacity Available (CCA)

Area	2738 s.f.
Curb Height	0.25 ft.
Material	Concrete
Gross Volume	685 c.f.

See Appendix H for detailed drawings of this containment area. Appendix A of this assessment contains detailed calculations of the available containment volume. The containment capacity available = 685 c.f.

## 7. Required Volume

### Containment Capacity Required (CCR)

CCR=Volume of Largest Tank in the secondary containment

Volume of Largest Tank = (FT1)= 401 c.f.

## 8. Comparison of Available Volume to Required Volume

### Containment Capacity

Containment Capacity Required =	401 c.f.
Secondary Containment Volume Available =	685 c.f.
Excess Containment Volume =	284 c.f.

CCA>CCR Adequate Capacity (under normal operating conditions is available)

## E CONCLUSIONS

1. The foundation, structural support beams, connections, and controls for the Evaporator Feed Tank No. 4 (EF4) System have been adequately designed.
2. The Evaporator Feed Tank No. 4 (EF4) system has sufficient structural strength, is compatible with the wastes to be stored and treated, and has adequate corrosion protection to ensure that it will not collapse, rupture or fail.
3. The Evaporator Feed Tank No. 4 (EF4) system was inspected on 3/1/95 for weld breaks, punctures scrapes of protective coating, cracks, leaks, corrosion, and other structural damage or inadequacies of construction/installation.
4. The Evaporator Feed Tank No. 4 (EF4) was tightness tested on 3/1/95, and it was found that the tank test positive for tightness.
5. The Secondary Containment for the Evaporator Feed Tank No. 4 (EF4) system is

(Feed Tank EF4)  
((09/18/96 )




of sufficient structural strength and of sufficient volume to meet the requirements set forth in 40 CFR 264.193.

6. All ancillary equipment associated with the Evaporator Feed Tank No. 4 (EF4) system is properly supported and protected against physical damage and excessive stress due to settlement, vibration, expansion, or contraction.
7. The Evaporator Feed Tank No. 4 (EF4) system associated ancillary equipment have been tightness tested in accordance with ASME/ANSI B31.

#### F CERTIFICATION

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to be the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

  
Date 09/18/96



## Primary Tank Volume Calculations




## EF4 Volume Calculations

$$\begin{aligned}\text{Shell Volume} &= \pi r^2 L \\ &= 3.14 \times 3.17\text{ft} \times 3.17\text{ft} \times 6\text{ft} \\ &\approx 189.5 \text{ ft}^3\end{aligned}$$

$$\begin{aligned}\text{Cone Volume} &= \frac{1}{3} \pi r^2 L \\ &= 0.33 \times 3.14 \times 3.17\text{ft} \times 3.17\text{ft} \times 3\text{ft} \\ &\approx 31.25 \text{ ft}^3\end{aligned}$$

$$\begin{aligned}\text{Total Volume} &= \text{Shell Volume} + \text{Cone Volume} \\ &= 189.5 \text{ ft}^3 + 31.25 \text{ ft}^3 \\ &= 220.75 \text{ ft}^3\end{aligned}$$





## Secondary Containment Volume Calculations



## SECONDARY CONTAINMENT VOLUME CALCULATIONS

### A. DIMENSIONS

1.	Length	64' 9"
2.	Width	44' 0"
3.	Height	3" min

B. VOLUME (Before encroachments)  $64.75' \times 44' \times .25' = 712.25 \text{ft}^3$

### C. ENCROACHMENTS

1.	Posts	16 @ 10" x 10" x 3"
2.	Posts	9 @ 12" x 10" x 3"
3.	Posts	1 @ 14" x 15" x 3"
4.	Posts	1 @ 24" x 8" x 3"
5.	Posts	2 @ 12" x 12" x 3"
6.	Posts	2 @ 32" x 12" x 3"
7.	Posts	1 @ 24" x 24" x 3"
8.	Ramps	4 @ 14' x 30" x 3"
9.	Ramps	1 @ 16' x 32" x 3"
10.	Heat Exchangers	2 @ 2' x 51" x 3"
11.	Pumps	4 @ 5' x 20" x 3"
12.	Pumps	4 @ 3' x 1' x 3"

### D. ENCROACHMENT VOLUME CALCULATIONS

1.	$16 \times 0.83 \text{ ft} \times 0.83 \text{ ft} \times 0.25 \text{ ft} =$	$2.75 \text{ ft}^3$
2.	$9 \times 1 \text{ ft} \times 0.83 \text{ ft} \times 0.25 \text{ ft} =$	$1.87 \text{ ft}^3$
3.	$1 \times 1.17 \text{ ft} \times 1.25 \text{ ft} \times 0.25 \text{ ft} =$	$0.37 \text{ ft}^3$
4.	$1 \times 2 \text{ ft} \times 0.67 \text{ ft} \times 0.25 \text{ ft} =$	$0.34 \text{ ft}^3$
5.	$2 \times 1 \text{ ft} \times 1 \text{ ft} \times 0.25 \text{ ft} =$	$0.5 \text{ ft}^3$
6.	$2 \times 2.67 \text{ ft} \times 1 \text{ ft} \times 0.25 \text{ ft} =$	$1.34 \text{ ft}^3$
7.	$1 \times 2 \text{ ft} \times 2 \text{ ft} \times 0.25 \text{ ft} =$	$1.0 \text{ ft}^3$
8.	$4 \times 1.17 \text{ ft} \times 2.5 \text{ ft} \times 0.25 \text{ ft} =$	$2.93 \text{ ft}^3$
9.	$1 \times 1.33 \text{ ft} \times 2.67 \text{ ft} \times 0.25 \text{ ft} =$	$0.89 \text{ ft}^3$
10.	$2 \times 2 \text{ ft} \times 4.25 \text{ ft} \times 0.25 \text{ ft} =$	$4.25 \text{ ft}^3$
11.	$4 \times 5 \text{ ft} \times 1.67 \text{ ft} \times 0.25 \text{ ft} =$	$8.35 \text{ ft}^3$
12.	$4 \times 3 \text{ ft} \times 1 \text{ ft} \times 0.25 \text{ ft} =$	$3 \text{ ft}^3$

TOTAL ENCROACHMENT VOLUME  $27.59 \text{ FT}^3$

AVAILABLE CONTAINMENT VOLUME  $684.66 \text{ FT}^3$

LARGEST TANK VOLUME (FT 1)  $401 \text{ FT}^3$

EXCESS CONTAINMENT  $283.66 \text{ FT}^3$



# Manufacturers Design Information



USPCL  
item # EB2  
\*EF4

QW-482 SUGGESTED FORMAT FOR WELDING PROCEDURE SPECIFICATION (WPS)  
(See QW-200.1, Section IX, ASME Boiler and Pressure Vessel Code)

Company Name LIDE VESSELS INC. By: EVAN LEMON  
Welding Procedure Specification No. BB01 Date 6-1-82 Supporting PQR No.(s) BB01  
Revision No. 1 Date 5-1-90  
Welding Process(es) SMAW Type(s) MANUAL  
(Automatic, Manual, Machine, or Semi-Auto.)

JOINTS (QW-402)

Details

Joint Design SEE PRODUCTION DRAWINGS  
Backing (Yes) F4 (No) F3  
Backing Material (Type) WELD METAL OR BASE METAL  
(Refer to both backing and retainers.)

☐ Metal ☐ Nonfusing Metal RETAINERS NOT USED  
☐ Nonmetallic ☐ Other

Sketches, Production Drawings, Weld Symbols or Written Description should show the general arrangement of the parts to be welded. Where applicable, the root spacing and the details of weld groove may be specified.

(At the option of the Mfr., sketches may be attached to illustrate joint design, weld layers and bead sequence, e.g. for notch toughness procedures, for multiple process procedures, etc.)

BASE METALS (QW-403)

to 1 Group No. 1&2 to P-No. 1 Group No. 1&2

OR

Specification type and grade ---

to Specification type and grade ---

OR

Chem. Analysis and Mechn. Prop. ---

to Chem. Analysis and Mech. Prop. ---

Thickness Range:

Base Metal: Groove .1875 - 1.500 \* Fillet ALL  
Pipe Dia. Range: Groove ALL Fillet ALL  
Other \* PROCEDURE LIMITED TO 1.500 DUE TO NO PWHT

\*FILLER METALS (QW-404)

Spec. No. (SFA)	<u>5.1</u>	<u>5.1</u>
AWS No. (Class)	<u>E6010</u>	<u>E7018</u>
F-No.	<u>3</u>	<u>4</u>
A-No.	<u>1</u>	<u>1</u>
Size of Filler Metals	<u>1/8" - 5/32"</u>	<u>1/8" - 5/32"</u>
Deposited Weld Metal	<u>.250</u>	<u>.614</u>
Thickness Range:	<u>---</u>	<u>---</u>
Groove	<u>.500</u>	<u>1.228</u>
Fillet	<u>ALL</u>	<u>ALL</u>
Electrode-Flux (Class)	<u>---</u>	<u>---</u>
Flux Trade Name	<u>---</u>	<u>---</u>
Consumable Insert	<u>---</u>	<u>---</u>
Other	<u>---</u>	<u>---</u>

Each base metal-filler metal combination should be recorded individually.



QW-482 (Back)

WPS No. BB01Rev. 1

<b>POSITIONS (QW-405)</b> Position(s) of Groove <u>ALL</u> Welding Progression: Up <u>F4</u> Down <u>F3</u> Position(s) of Fillet <u>ALL</u>	<b>POSTWELD HEAT TREATMENT (QW-407)</b> Temperature Range <u>NA</u> Time Range <u>---</u>																
<b>PREHEAT (QW-406)</b> Preheat Temp. Min. <u>50°F **</u> Interpass Temp. Max. <u>600°F</u> Preheat Maintenance <u>NA</u> (Continuous or special heating where applicable should be recorded)	<b>GAS (QW-408)</b> <table style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th style="text-align: center;">Gas(es)</th> <th style="text-align: center;">Percent Composition (Mixture)</th> <th style="text-align: center;">Flow Rate</th> </tr> </thead> <tbody> <tr> <td>Shielding</td> <td style="text-align: center;">---</td> <td style="text-align: center;">---</td> <td style="text-align: center;">---</td> </tr> <tr> <td>Trailing</td> <td style="text-align: center;">---</td> <td style="text-align: center;">---</td> <td style="text-align: center;">---</td> </tr> <tr> <td>Backing</td> <td style="text-align: center;">---</td> <td style="text-align: center;">---</td> <td style="text-align: center;">---</td> </tr> </tbody> </table>		Gas(es)	Percent Composition (Mixture)	Flow Rate	Shielding	---	---	---	Trailing	---	---	---	Backing	---	---	---
	Gas(es)	Percent Composition (Mixture)	Flow Rate														
Shielding	---	---	---														
Trailing	---	---	---														
Backing	---	---	---														

**ELECTRICAL CHARACTERISTICS (QW-409)**

Current AC or DC DC Polarity REV  
 Amps (Range) SEE BELOW Volts (Range) SEE BELOW

(Amps and volts range should be recorded for each electrode size, position, and thickness, etc. This information may be listed in a tabular form similar to that shown below.)

Tungsten Electrode Size and Type --- (Pure Tungsten, 2% Thoriated, etc.)

Mode of Metal Transfer for GMAW --- (Spray arc, short circuiting arc, etc.)

Electrode Wire feed speed range ---

**TECHNIQUE (QW-410)**

String or Weave Bead STRING

Orifice or Gas Cup Size ---

Initial and Interpass Cleaning (Brushing, Grinding, etc.) BRUSH, GRIND, OR CHIP AS NEEDED

Method of Back Gouging AIR ARC OR GRIND AS NEEDED

Oscillation ---

Contact Tube to Work Distance ---

Multiple or Single Pass (per side) MULTIPLE

Multiple or Single Electrodes SINGLE

Travel Speed (Range) ---

Peening NONE

Other NO SINGLE PASS TO EXCEED 1/2" IN THICKNESS

\*\* 200°F MINIMUM PREHEAT FOR THICKNESSES OVER 1.25"  
AND THROUGH 1.5"

Weld Layer(s)	Process	Filler Metal		Current		Volt Range	Travel Speed Range	Other (e.g., Remarks, Comments, Hot Wire Addition, Technique, Torch Angle, Etc.)
		Class	Dia.	Type Polar.	Amp. Range			
1&2	SMAW	E6010	1/8"	REV	75-125	18-24	NA	
"	"	"	5/32"	"	110-170	20-26	"	
REM	SMAW	E7018	1/8"	"	115-165	20-26	"	
"	"	"	5/32"	"	150-220	21-27	"	



**QW-483 SUGGESTED FORMAT FOR PROCEDURE QUALIFICATION RECORD (PQR)**  
 (See QW-200.2, Section IX, ASME Boiler and Pressure Vessel Code)  
 Record Actual Conditions Used to Weld Test Coupon.

Company Name LIDE VESSELS INC.

Procedure Qualification Record No. BBO1


Date 5-26-82

WPS No. BBO1

Welding Processes SMAW

Types (Manual, Automatic, Semi-Auto.) MANUAL

**JOINTS (QW-402)**



Groove Design of Test Coupon

(For combination qualifications, the deposited weld metal thickness shall be recorded for each filler metal or process used.)

**BASE METALS (QW-403)**

Material Spec. SA-106

Plate or Grade B

Thickness of Test Coupon .864 to P-No. 1

Diameter of Test Coupon 6-5/8" OD

Other ---

**POSTWELD HEAT TREATMENT (QW-407)**

Temperature NA

Time ---

Other ---

**GAS (QW-408)**

**Percent Composition**

	Gas(es)	(Mixture)	Flow Rate
Shielding	<u>---</u>	<u>---</u>	<u>---</u>
Trailing	<u>---</u>	<u>---</u>	<u>---</u>
Backing	<u>---</u>	<u>---</u>	<u>---</u>

**FILLER METALS (QW-404)**

SFA Specification 5.1 5.1

AWS Classification E6010 E7018

Filler Metal F-No. 3 4

Weld Metal Analysis A-No. 1 1

Size of Filler Metal 1/8" 1/8"

Other ---

Deposited Weld Metal .250 .614

**ELECTRICAL CHARACTERISTICS (QW-409)**

Current DC

Polarity REV

Amps F3-120, F4-120 Volts F3-20, F4-24

Tungsten Electrode Size NA

Other ---

**POSITION (QW-405)**

Position of Groove 6G

Weld Progression (Uphill, Downhill) F3-DOWN, F4-UP

Other ---

**TECHNIQUE (QW-410)**

Travel Speed NOT RECORDED

String or Weave Bead STRING

Oscillation NONE

Multipass or Single Pass (per side) MULTIPLE

Single or Multiple Electrodes SINGLE

Other ---

**PREHEAT (QW-406)**

Preheat Temp. 70°F

Interpass Temp. 500°F


Other ---



**QW-483 SUGGESTED FORMAT FOR PROCEDURE QUALIFICATION RECORD (PQR)**  
 (See QW-200.2, Section IX, ASME Boiler and Pressure Vessel Code)  
 Record Actual Conditions Used to Weld Test Coupon.

Company Name LIDE VESSELS INC.  
 Procedure Qualification Record No. BB02 Date 5-26-82  
 WPS No. BB02  
 Welding Processes SMAW  
 Types (Manual, Automatic, Semi-Auto.) MANUAL

**JOINTS (QW-402)**



Groove Design of Test Coupon

(For combination qualifications, the deposited weld metal thickness shall be recorded for each filler metal or process used.)

**BASE METALS (QW-403)**

Material Spec. SA-36  
 Type or Grade ---  
 Thickness of Test Coupon .750  
 Diameter of Test Coupon ---  
 Other PLATE

**POSTWELD HEAT TREATMENT (QW-407)**

Temperature NA  
 Time ---  
 Other ---

**FILLER METALS (QW-404)**

SFA Specification <u>5.1</u>	<u>5.1</u>
AWS Classification <u>E6010</u>	<u>E7024</u>
Filler Metal F-No. <u>3</u>	<u>1</u>
Weld Metal Analysis A-No. <u>1</u>	<u>1</u>
Size of Filler Metal <u>1/8"</u>	<u>3/16"</u>
Other <u>---</u>	
Deposited Weld Metal <u>.250"</u>	<u>.500"</u>

**GAS (QW-408)**

	Gas(es)	Percent Composition (Mixture)	Flow Rate
Shielding	<u>---</u>	<u>---</u>	<u>---</u>
Trailing	<u>---</u>	<u>---</u>	<u>---</u>
Backing	<u>---</u>	<u>---</u>	<u>---</u>

**ELECTRICAL CHARACTERISTICS (QW-409)**

Current DC  
 Polarity REV  
 Amps. F3-110, F1-250 Volts F3-20, F1-22  
 Tungsten Electrode Size ---  
 Other ---

**POSITION (QW-405)**

Position of Groove 1G  
 Weld Progression (Uphill, Downhill) FLAT  
 Other ---

**TECHNIQUE (QW-410)**

Travel Speed NOT RECORDED  
 String or Weave Bead STRING  
 Oscillation ---  
 Multipass or Single Pass (per side) MULTIPLE  
 Single or Multiple Electrodes SINGLE  
 Other ---

**HEAT (QW-406)**

Heat Temp. 70°F  
 Interpass Temp. 500°F  
 Other ---



**QW-482 SUGGESTED FORMAT FOR WELDING PROCEDURE SPECIFICATION (WPS)**  
 (See QW-200.1, Section IX, ASME Boiler and Pressure Vessel Code)

Company Name LIDE VESSELS INC. By: EVAN LEMON  
 Welding Procedure Specification No. BB02 Date 5-28-82 Supporting PQR No.(s) BB02  
 Revision No. 1 Date 3-7-89  
 Welding Process(es) SMAW Type(s) MANUAL  
 (Automatic, Manual, Machine, or Semi-Auto.)

**JOINTS (QW-402)**

Details

Joint Design SEE PRODUCTION DRAWINGS  
 Backing (Yes) XX (No) XX  
 Backing Material (Type) WELD METAL OR BASE METAL  
 (Refer to both backing and retainers.)

☐ Metal ☐ Nonfusing Metal **NO RETAINERS USED**  
☐ Nonmetallic ☐ Other

Sketches, Production Drawings, Weld Symbols or Written Description should show the general arrangement of the parts to be welded. Where applicable, the root spacing and the details of weld groove may be specified.

(At the option of the Mfr., sketches may be attached to illustrate joint design, weld layers and bead sequence, e.g. for notch toughness procedures, for multiple process procedures, etc.)

**BASE METALS (QW-403)**

No. 1 Group No. 1&2 to P-No. 1 Group No. 1&2

OR

Specification type and grade ---

to Specification type and grade ---

OR

Chem. Analysis and Mech. Prop. ---

to Chem. Analysis and Mech. Prop. ---

Thickness Range:

Base Metal: Groove .1875" - 1.5" Fillet ALL

Pipe Dia. Range: Groove ALL Fillet ALL

Other ---

**\*FILLER METALS (QW-404)**

Spec. No. (SFA)	<u>5.1</u>	<u>5.1</u>
AWS No. (Class)	<u>E6010</u>	<u>E7024</u>
F-No.	<u>3</u>	<u>1</u>
A-No.	<u>1</u>	<u>1</u>
Size of Filler Metals	<u>1/8", 5/32"</u>	<u>1/8", 5/32", 3/16"</u>
Deposited Weld Metal	<u>.250</u>	<u>.500</u>
Thickness Range:	<u>---</u>	<u>---</u>
Groove	<u>.500</u>	<u>1.00</u>
Fillet	<u>ALL</u>	<u>ALL</u>
Electrode-Flux (Class)	<u>---</u>	<u>---</u>
Flux Trade Name	<u>---</u>	<u>---</u>
Consumable Insert	<u>---</u>	<u>---</u>
Other	<u>---</u>	<u>---</u>

\*Each base metal-filler metal combination should be recorded individually.



<b>POSITIONS (QW-405)</b> Position(s) of Groove <u>F3-ALL. F1-FLAT</u> Welding Progression: Up <u>F3</u> Down _____ Position(s) of Fillet <u>ALL</u>	<b>POSTWELD HEAT TREATMENT (QW-407)</b> Temperature Range <u>NA</u> Time Range _____																
<b>PREHEAT (QW-406)</b> Preheat Temp. Min. <u>50 °F ±</u> Interpass Temp. Max. <u>600 °F</u> Preheat Maintenance <u>NONE</u> (Continuous or special heating where applicable should be recorded)	<b>GAS (QW-408)</b> <table style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th style="text-align: center;">Gas(es)</th> <th style="text-align: center;">Percent Composition (Mixture)</th> <th style="text-align: center;">Flow Rate</th> </tr> </thead> <tbody> <tr> <td>Shielding</td> <td style="text-align: center;">---</td> <td style="text-align: center;">---</td> <td style="text-align: center;">---</td> </tr> <tr> <td>Trailing</td> <td style="text-align: center;">---</td> <td style="text-align: center;">---</td> <td style="text-align: center;">---</td> </tr> <tr> <td>Backing</td> <td style="text-align: center;">---</td> <td style="text-align: center;">---</td> <td style="text-align: center;">---</td> </tr> </tbody> </table>		Gas(es)	Percent Composition (Mixture)	Flow Rate	Shielding	---	---	---	Trailing	---	---	---	Backing	---	---	---
	Gas(es)	Percent Composition (Mixture)	Flow Rate														
Shielding	---	---	---														
Trailing	---	---	---														
Backing	---	---	---														

**ELECTRICAL CHARACTERISTICS (QW-409)**

Current AC or DC DC Polarity REV  
 Amps (Range) SEE BELOW Volts (Range) SEE BELOW

(Amps and volts range should be recorded for each electrode size, position, and thickness, etc. This information may be listed in a tabular form similar to that shown below.)

Tungsten Electrode Size and Type \_\_\_\_\_  
 (Pure Tungsten, 2% Thoriated, etc.)

Mode of Metal Transfer for GMAW \_\_\_\_\_  
 (Spray arc, short circuiting arc, etc.)

Electrode Wire feed speed range \_\_\_\_\_

**TECHNIQUE (QW-410)**

String or Weave Bead STRING  
 Orifice or Gas Cup Size \_\_\_\_\_  
 Initial and Interpass Cleaning (Brushing, Grinding, etc.) BRUSH, GRIND, OR CHIP AS NEEDED  
 Method of Back Gouging AIR ARC OR GRIND AS NEEDED  
 Oscillation \_\_\_\_\_  
 Contact Tube to Work Distance \_\_\_\_\_  
 Multiple or Single Pass (per side) MULTIPLE  
 Multiple or Single Electrodes SINGLE  
 Travel Speed (Range) \_\_\_\_\_  
 Peening NONE  
 Other NO SINGLE PASS TO EXCEED 1/2" IN THICKNESS  
± 200 °F MINIMUM PREHEAT FOR THICKNESSES OVER 1.25"  
AND INCLUDING 1.5"

Weld Layer(s)	Process	Filler Metal		Current		Volt Range	Travel Speed Range	Other (e.g., Remarks, Comments, Hot Wire Addition, Technique, Torch Angle, Etc.)
		Class	Dis.	Type Polar.	Amp. Range			
1&2	SMAW	E6010	1/8"	REV	75-125	18-24	NA	
"	"	"	5/32"	"	110-170	20-26	"	
REM	"	E7024	1/8"	"	140-190	18-24	"	
"	"	"	5/32"	"	180-250	20-26	"	
"	"	"	3/16	"	230-305	21-27	"	



USPCI

APPENDIX	1	1993
EDITION	8 TH	REVISION NUMBER A
	5	NOMINAL HEIGHT 12
DESIGN PRESSURE	2.38616	PARTIAL STRESS
MANUFACTURER'S SERIAL NO.	7955	PURCHASER'S TANK NO. E B 2
	LODE TANKS CO	
	LODE TANK CO	
SHELL COURSE	SA 36	
2 - 318"		



USPCI

API STANDARD 650			
		1993	
		0	
NOMINAL DIAMETER	6' 4"	NOMINAL HEIGHT	12'
NOMINAL CAPACITY	1,625 GAL	DESIGN LIQUID LEVEL	
DESIGN COEFFICIENT	0.5		
	2.3 ft/s		2.1
	2.3		2.5
FABRICATED BY	LIDE TANK CO.		
ERECTED BY	LIDE TANK CO.		
2-3.8'		34 36	



QW-483 (Back)

PQR No. 9802

## Tensile Test (QW-150)

Specimen No.	Width	Thickness	Area	Ultimate Total Load lb	Ultimate Unit Stress psi	Type of Failure & Location
1	.505	DIA.	.200	14120	70600	WLD DUCT
2	.506	DIA.	.201	13740	68400	BM DUCT

## Guided-Bend Tests (QW-160)

Type and Figure No.	Result
SIDE BEND QW-462.2	ACCEPTABLE
SIDE BEND QW-462.2	ACCEPTABLE
SIDE BEND QW-462.2	ACCEPTABLE
SIDE BEND QW-462.2	ACCEPTABLE

## Toughness Tests (QW-170)

Specimen No.	Notch Location	Notch Type	Test Temp.	Impact Values	Lateral Exp.		Drop Weight	
					% Shear	Mils	Break	No Break

## Fillet-Weld Test (QW-180)

Result — Satisfactory: Yes --- No --- Penetration into Parent Metal: Yes --- No ---  
 Macro—Results -----

## Other Tests

Type of Test ---  
 Deposit Analysis ---  
 Other -----

Welder's Name BILLY LIDE Clock No. --- Stamp No. L  
 Tests conducted by: SOUTHWESTERN LABORATORIES Laboratory Test No. D9-8220-1

We certify that the statements in this record are correct, and that the test welds were prepared, welded, and tested in accordance with the requirements of Section IX of the ASME Code.

Manufacturer LIDE VESSELS INC.

Date 9-11-90

By Evan Linder

(Detail of record of tests are illustrative only and may be modified to conform to the type and number of tests required by the Code.)



QW-483 (Back)

Tensile Test (QW-150)

PQR No. SB01

Specimen No.	Width	Thickness	Area	Ultimate Total Load lb	Ultimate Unit Stress psi	Type of Failure & Location
1	.506	DIA	.201	15800	78600	BM DUCT
2	.506	DIA	.201	15600	77600	BM DUCT

Guided-Bend Tests (QW-160)

Type and Figure No.	Result
SIDE BEND QW-462.2	ACCEPTABLE
SIDE BEND QW-462.2	ACCEPTABLE
SIDE BEND QW-462.2	ACCEPTABLE
SIDE BEND QW-462.2	ACCEPTABLE

Toughness Tests (QW-170)

Specimen No.	Notch Location	Notch Type	Test Temp.	Impact Values	Lateral Exp.		Drop Weight	
					% Shear	Mils	Break	No Break

Fillet-Weld Test (QW-180)

Result — Satisfactory: Yes \_\_\_\_\_ No \_\_\_\_\_ Penetration into Parent Metal: Yes \_\_\_\_\_ No \_\_\_\_\_  
Macro-Results \_\_\_\_\_

Other Tests

Type of Test BNH F3 WELD-174 HAZ-179, F4 WELD-179 HAZ-182 & 185  
Deposit Analysis \_\_\_\_\_  
Other \_\_\_\_\_

Welder's Name JOHN MCKINNEY Clock No. 114 Stamp No. M  
Tests conducted by: SOUTHWESTERN LAB Laboratory Test No. 09-8220-2

We certify that the statements in this record are correct and that the test welds were prepared, welded, and tested in accordance with the requirements of Section IX of the ASME Code.

Manufacturer LIDE VESSELS INC.

Date 6-2-82 By Erin P...

Detail of record of tests are illustrative only and may be modified to conform to the type and number of tests required by the Code.)




# Tank Wall Thickness



## Secondary Containment Drawings







### CHECK SEISMIC

$$D/H = 5.0/12.0 = .42$$

$$\begin{aligned} \text{TANK SHELL} &= 3360 \text{ lbs} \\ \text{TANK ROOF} &= 400 \text{ lbs} \\ \text{TANK CONTENTS} &= 14,700 \text{ lbs} \end{aligned}$$

FIND EFFECTIVE MBS  $W_1$  &  $W_2$

FROM APP. E FIG. E-2 FOR  $D/H = .42$

$$z = .1875 \text{ FOR ZONE 1} \\ I = 1.0$$

$$\frac{W_1}{W_T} = .1 \quad \frac{W_2}{W_T} = .9$$

$$W_1 = 1470 \text{ lbs}$$

$$W_2 = 13,230 \text{ lbs}$$

FIND  $X_1$  &  $X_2$  FROM FIG. E-3

$$X_1/H = .43$$

$$X_2/H = .85$$

$$X_1 = 5.2 \text{ FT}$$

$$X_2 = 10.2 \text{ FT}$$

NATURAL PERIOD  $T = K\sqrt{D}$  WHERE  $K = .59$  FOR FIG. E-4

$$T = .59\sqrt{5} = 1.32 \Rightarrow C_1 = .24 \quad C_2 = \frac{.305}{T} = \frac{.30(1.5)}{1.32}$$

$C_2 = .34$  FOR  $S = 1.5$  UNKNOWN SOIL CONDITION

$$M = \sum I \left( \underset{\text{shell}}{C_1 W_s X_s} + \underset{\text{roof}}{C_1 W_r H_r} + \underset{\text{TANK SLOSHING}}{C_1 W_1 X_1} + C_2 W_2 X_2 \right)$$

$$M = .1875(1.0) \left[ .24(3360)9.0 + .24(400)12 + .24(1470)5.2 + .34(13,230)10.2 \right] =$$

$$M = 10,524 \text{ ft-lb}$$

FOR ANCHORED TANK CHECK STRAIN COMP. STRESS  $b$

$$b = \frac{4200 \text{ lb}}{5.0(\pi)} + \frac{1.273(10,524)}{(5.0)^2} = .803 \text{ lbs/ft}^2 \text{ at CIRC}$$

$$\text{Stress} = \frac{803}{12(.725)} = 270 \text{ psi} \quad \text{OK}$$

$$\text{Allow. Compressive} = .5045 = .5(3)$$



KSL ENGINEERING & DESIGN INC.  
306 RIDGECREST  
TYLER, TEXAS 75701

L. WEINBRENNER  
Pg. 2 of 3

SHELL DESIGN

$$t_s = \frac{2.6 D(H-1) G}{E (21,000)} + CA$$

$$t_s = \frac{2.6 (5) 6 (1.5)}{.7 (21000)} + \frac{1}{8} \Rightarrow .008' + \frac{1}{8}'' = .133''$$

$\frac{3}{8}''$  SHELL IS OK

HEAD DESIGN

BTM CONE

$$t_c = \frac{t_s}{\cos \alpha} = \frac{.008}{\cos 42.7} = .0109 + \frac{1}{8}'' = .136''$$

$\frac{3}{8}''$  CONE OK

TOP HEAD: FLAT PLATE DESIGN

LOADING IS 50% (DEAD + LOOPS) LIVE LOAD

$$150 \text{ lb} / 144 = 1.04 \text{ PLF}$$

$$t_h = D \sqrt{\frac{CP}{S}} + \frac{1}{8}''$$

C = .25 FOR WELDED CORNER JOINT

$$t_h = 60'' \sqrt{\frac{.25 (1.04)}{21,000}} + \frac{1}{8}''$$

$$.21 + \frac{1}{8}'' = .336''$$

$\frac{3}{8}''$  HEAD PLATE OK

CHECK WIND

ASSUME: TANIC EM/TM,  
EFF DIA = 6'  
SHAPE FACTOR = .80

$$\text{WIND PRESS. } 1.00256 (100)^2 = 26 \text{ psf}$$

$$\text{WIND FORCE } 26 \text{ psf} (.8) (6') (12') = 1500 \text{ lb}$$

$$\text{MOMENT} = 1500 \text{ lb} (12'/2) - 4200 \text{ lb} (5.3'/2) = -2130 \text{ ft-lb}$$

NO UPLIFT



KSL ENGINEERING & DESIGN INC.  
306 RIDGECREST  
TYLER, TEXAS 75701

L. WEINGARTNER  
Pg. 1 of 3

### STRUCTURAL DESIGN

5'-0" I.D. x 12'-0" TALL

DESIGN CONDITIONS: ATMOSPHERIC TANK

DESIGN TEMP 250°F :

WIND VELOCITY 100 MPH SEISMIC ZONE 1

S.G. = 1.5


CORROSION ALLOW. = 1/8"

SHELL & HEAD 3/8" THK

CONE ANGLE  $\alpha = 42.7^\circ$

TANK EMPTY 4200'

TANK FULL 17,200'



STRESS CORRECTION FOR 250°F = .904<sub>s</sub>

.90(36000) = 32,400 psi ALLOWABLE = 2/3 Y<sub>s</sub> = 2/3(32,400)

ALLOWABLE = 21,600 psi




# Heat Exchanger




Designed, Constructed and National Board Stamped in Accordance with latest  
1992 A.S.M.E. Code and Addendum.




Side




Front



Footing



Section AA



B= 42 5/16" (1075) A= See Plate Spec Documentation Dimensions in ( ) are millimeters (mm)

LOC	Function	Fluid	Material	Size	Rating	Type
S1	Hotside Inlet	30.7 psig Steam	SS	6"	150#	STUD
S2	Hotside Outlet	30.7 psig Steam	SS	6"	150#	STUD
S3	Coldside Inlet	Solution	SS	6"	150#	STUD
S4	Coldside Outlet	Solution	SS	6"	150#	STUD

Notes: Carboline 134 1.5 mils DFT (Alfa Laval Blue)

CERTIFIED  
APPROVED FOR FABRICATION  
BY [Signature] DATE 12/29/91

Customer Name : USPCI  
P.O. Number : 20572  
Item : # 2 Heat Exchangers  
Order Number : 942005  
A/L Serial#(s) : 30101-96638 thru 96639

Design Press/Temp.: 150 PSI / 300 °F  
Plate/Gasket Mat'l: AISI 316 / EPDM  
Plates Actual/Max.: 39 / 64 (0.5mm)  
Weight Dry/Flooded: 2350 lb / 2607 lb  
Length CBar/TBolt.: 900 mm / 750 mm

M15-FFG  
Plate Heat Exchanger

Alfa Laval Thermal Inc.

Manufactured in Richmond, Virginia

rev.	description	by	date
A	Revised Stud Bolt, Foot Dimension & Foot Print	TC	11/91
by	date	check	date
MG	11/91	AV	11/91
date	approval	date	
	TC		11/91

Rev: A ( )



Alfa Laval Thermal Inc.  
5400 International Trade Drive  
Richmond, VA 23231

Plate Heat Exchanger  
Bill of Materials

Implementation Date: 2/28/94  
Revision: 1



Page 1 of 1

Subject: M15-FFD

QA03138

BACKGROUND


Given are standard ASME/ASTM materials of construction.

No.	Item	Quantity	Material	Notes	Dimensions
1.	Frame Plate	1	SA516-70	1	
2.	Pressure Plate	1	SA516-70	1	
3a.	Carrying Bar	1	Aluminum		900 mm
3b.	T-Profile Cladding	2	SA240,304SS		900 mm
4.	Guide Bar	1	SA479,304SS		750 mm
5.	Tightening Bolt	8	SA193,B7		2" - 4 1/2 UNC
6.	Tightening Nut	8	SA194,2H2		2" - 4 1/2 UNC
7.	Support Column	1	Aluminum	1	
8.	Support Foot	1	SA36	1	
9.	Frame Foot	2	SA36	2	
10.	Stud Bolt	48	SA193,B7		
11.	Connection Liner	4	SA240,316SS		
12.	N/A				
13.	Channel Plate Gasket	40	EPDM		Electropolished
14.	Channel Plate	39	SA240,316SS		

Not Shown  
OSHA Shroud 1 Aluminum 3

Notes: (1)Painted. (2)Zinc Plated. (3)Not Shown

*Drawing is not an accurate depiction, see certified print.*



USPCI  
P.O. #: 20572  
TAG: #2 HEAT EXCHANGERS  
A/L ORDER #: 942005  
A/L SERIAL #: 30101-96638  
30101-96639

CERTIFIED  
APPROVED FOR FABRICATION  
BY [Signature] DATE 6/23/94



# ALFA - LAVAL THERMAL

## PLATE HEAT EXCHANGER Specification Sheet

CUSTOMER: USPCI  
Supplier: Alfa Laval Thermal Inc.  
Agent: Charles Martin, Thermal Engineering Co

P.O.#: 20572  
Order#: 942005  
Tag#: # 2 Heat Exchangers

Quantity: 2  
Serial#: 30101-96638 thru 96639

PHE Model Type: M15-FFG

HOT SIDE  
-1-

COLD SIDE  
=2=

Fluids	:	30.7 psig Steam	Solution
Flow rates	lb/hr	10349	312000
Inlet temperature	F	275.0	180.0
Outlet temperature	F	272.2	230.0
Pressure drops	psi	2.0	8.9
Total Surface Area	:	260 sq ft	
Flow regimen fluids	:	counterflow	
Connection locations in	:	S1	S3
out	:	S2	S4
Material in connections	:	SS	SS
Total number of plates	:	39	
Plates material	:	AISI 316	
thickness	:	0.5mm	
Gasket material	:	EPDM Clip-on	
Design pressure	:	150 PSI	
Design temperature	:	300 F	
Liquid volumes	US gallon	13	13
Total unit dry weight	:	2300 lb	

CERTIFIED  
APPROVED FOR FABRICATION  
BY                      DATE 9/24/94



Document

Date 06/22/94

CUSTOMER: USPCI

P.O.#: 20572

=====

ALFA-LAVAL THERMAL PLATE HEAT EXCHANGER

=====

Model Type M15-FFG  
 Quantity 2  
 Serial#: 30101-96638 thru 96639  
 Supplier: Alfa Laval Thermal Inc. Order#: 942005  
 Agent: Charles Martin, Thermal Engineering Co Tag#: # 2 Heat Exchangers

Gasket sides of the plates are facing the frame plate.  
 Plates with parallel flow.

Plates material AISI 316  
 thickness 0.5mm  
 Gasket material EPDM Clip-on  
 A - Dimension (See Drawing) 174 mm  
 Total number of plates 39  
 Total unit dry weight 2300 lb  
 Extra/Inspection port location Side 1: Side 2:

-----SAMPLE FLOW DIAGRAMS-----

Sample SINGLEPASS Flow Diagram

121	End Plt1 76A	H	====<=====			
120	Chan Plt 03B	L	O U--<---O-----U			
119	Chan Plt 03A	L	O U O U			
			) ) ) )		S	
			( ( ( (			
3	Chan Plt 03A	H	U==<===O=====U		A	D
2	Chan Plt 03B	H	O U--<---O-----U			
1	End Plt2 83A	H	O O O O		M	I
			-S4-----S3-----S2-----S1-		P	A

Sample MULTIPASS Flow Diagram

			-----T3-----T2-----			
121	Tran Plt 43A	H	O O O O		L	G
120	Turn Plt 04B	H	O U--<---		E	R
119	Chan Plt 03A	L	U==<===U O O			
			) ) ) )			A
			( ( ( (			
71	Chan Plt 03B	H	O O U--<---U		F	M
70	Chan Plt 03A	L	U==<===U O O			
69	Turn Plt 11B	H	O ---->--U		L	S
68	Chan Plt 03A	L	U===>==U O O			
			) ) ) )		O	
			( ( ( (			
4	Chan Plt 03A	L	O O O O		W	
3	Chan Plt 03B	H	O O U--->--U			
2	Chan Plt 03A	L	U===>==U O O			
1	End Plt2 84B	H	O O			
			-----S3-----S2-----			

See following page for Flow Diagram Discriptions.  
 \*\*\* SEE PAGE 1 FOR YOUR FLOW DIAGRAM. \*\*\*



Date 06/22/94

Document

=====FLOW DIAGRAM DESCRIPTIONS=====

Singlepass....Plate heat exchanger with connections on frame plate  
(stationary cover) only.  
Multipass....Plate heat exchanger with both frame plate and pressure  
plate (movable cover) connections.  
S1,S2,S3,S4...Frame plate connection designations.  
T1,T2,T3,T4...Pressure plate connection designations.  
(See drawing for locations of T and S ports.)

-----PLATE DESCRIPTIONS-----


1 to 121...Plate position starting from frame plate.  
Chan Plt...Channel Plate. Standard 4-port channel plate. Gasketed so  
that flow from two ports opens to the channel plate center.  
End Plt2...End Plate 2. Channel plate adjacent to frame plate. With  
port holes fully gasketed so that flow does not go between  
this plate and the frame plate.  
End Plt1...End Plate 1. Channel plate adjacent to pressure plate  
on single pass unit.  
Turn Plt...Turning Plate. Redirects flow with port locations which are  
not punched (no U or O) on multipass units.  
In Plt...Transition Plate. Channel plate adjacent to both pressure  
plate and partition plates on multipass unit.  
Part Plt...Partition Plate. Thicker steel plate required on some  
multipass units.  
Twin Plt...Twin plate. Channel plate type used on welded units only.  
76,03,83...Plate hole punching description. A-L internal use only.

-----PORT PUNCHING-----

O.....Port surrounded by ring gasket. Fluid in this port  
U.....Flow opening port. Fluid flows into this channel.  
No O or U..If no U or O is shown then this port location is not punched  
and fluid does not flow through this port.

-----PLATE ORIENTATION-----

A,B.....Plate orientation, as seen from gasketed side of plates:

A Plate =>  <= B Plate  
(Channel plate arrangements alternate between A and B plates)

.....High Theata channel plate. Chevrons at angle greater than  
90 degrees.  
.....Low Theata channel plate. Chevrons at angle less than 90  
degrees.  
(Channel plate arrangements can have all Highs, all Lows or  
a mixture of Highs and Lows.)



2\*M15-F CH\_\_ AISI\_316 0.5mm EPDM\_Clip-on

06/22/94

```
1*19 L S1->S2 30.7 psig Steam
1*19 L S4<=S3 Solution
```

```
1*19 L   S4<=S3   Solution
```

Line	Text	Code	U	U	U	U
39	End Plt1 16B	H				
38	Chan Plt.03A	L	U==<==U		O	O
37	Chan Plt.03B	L	O	O	U	U
36	Chan Plt.03A	L	U	U	O	O
35	Chan Plt.03B	L	O	O	U	U
			)	)	)	)
			(	(	(	(
6	Chan Plt.03A	L	U	U	O	O
5	Chan Plt.03B	L	O	O	U	U
4	Chan Plt.03A	L	U	U	O	O
3	Chan Plt.03B	L	O	O	U--<--U	U
2	Chan Plt.03A	L	U==<==U		O	O
1	End Plt2 83B	H	O	O	O	O
			-S4----	-S3-----	-S2-----	-S1-



Plates: M15-F CH AISI 316 0.5mm EPDM Clip-on  
74 37 Chan Plt.03 L Channel plate  
2 1 End Plt1 16B H End plate 1 0.6mm  
2 1 End Plt2 83B H End plate 2

Gaskets: EPDM Clip-on  
74 37 32330-1804-3 Channel plate gasket  
2 1 32330-1804-3 Channel plate gasket  
2 1 End plate gasket II consists of:  
4 2 32330-1804-3 2 Channel plate gaskets



# Structural Support Calculations



COLUMN LOADS

A-1 - 3.6 k  
B-1 - 14.3 k  
C-1 - 14.1 k  
D-1 - 19.0 k  
E-1 - 14.2 k  
A-2 - 4.5 k  
B-2 - 36.3 k  
D-2 - 62.9 k  
E-2 - 34.1 k  
A-3 - 8.4 k  
B-3 - 27.9 k  
C-3 - 28.8 k  
D-3 - 19.9 k  
E-3 - 14.4 k  
A-5 - 9.8 k  
B-5 - 17.6 k  
A-7 - 4.8 k  
B-7 - 8.5 k  
C-7 - 11.5 k  
F-7 - 12.1 k  
C-6 - 24.8 k  
F-6 - 24.2 k  
C-4 - 28.1 k  
F-4 - 24.2 k  
F-3.1 - 12.0 k

EXCEPT @ GRID F. ALL COLUMNS  
WILL BE 14.8-24.


WITH KL 13.0 ALLOWABLE  
COL LOAD IS 93.0 k.

THIS SATISFIES ALL CONDITIONS





# HORZ. FORCES @ GRID F'



$$\frac{3.26}{4} = .8150 \text{ KIPS PER COL.}$$

$$.8150 \times 11.6 = 9.37 \text{ K' MOMENT}$$

$$\frac{9.37 \times 12 \times 1000}{21600} = 5.2 \text{ REQD SZ}$$

$$148.31 \times 27.5 = 5.2 \text{ COLUMNS OK}$$






HORZ. FORCES & DIAG. BRACING.

7.26 KIPS @ C-7 TO F-7

12.23 @ E-2 TO E-3

6.10 @ A-1 TO A-2

14.64 @ D.1-1 TO E-1



COL. UPLIFT  
21.65 K  
NEGLECTING  
DEAD LOAD

DIAG BRACE.  $R 4 \times 3 \times 1.5 \text{ in}$   $\frac{26.13}{1.5} = 17.42 \text{ ksi} < 24$   
BRACE O.K.

COLUMN UPLIFT 21.65 w/  $4 \times 3 \times 1.5 \text{ in}$  EPOXY ANCHORS:

PULLOUT TEST ON  $3 \times 4 \text{ in}$  EPOXY ANCH. w/  $6 \times 12 \text{ in}$  INCREASMENT IS

24.2 KIPS. WITH A SAFETY FACTOR OF 4 TO 1

6 KIPS PER ANCHOR

$6 \text{ k} \times 4 = 24 > 21.65$  O.K.





DESIGN LOADS (1990 BOCA NATIONAL BUILD CODE)

LIVE LOAD ... 100 PSF. (LIGHT MANUFACTURING - PAGE 246)  
DEAD LOAD ... 20 PSF.  
TOTAL ... 120 PSF.

TANKS FT1, FT2, & FT3 47,300 LBS. EACH (FILLED).  
TANK ET4 25,300 LBS (FILLED).

LATERAL FORCES FOR EARTHQUAKE LOADS

$V = 2.5 A_v I K C S W$  (PAGE 272)  
 $A_v = .1$  (ZONE 1) (PAGE 273)  
 $I = 1.0$  (TABLE 1113.1, PAGE 275)  
 $K = 1.0$  (TABLE 1113.4.3, PAGE 278)  
 $C = .12$  (PAGE 279)  
 $S = 1.5$  (TABLE 1113.4.6, PAGE 281)  
 $W = \text{WEIGHT}$

$V = 2.5 \times .1 \times 1.0 \times 1.0 \times .12 \times 1.5 \times W$   
 $V = .045 W$






BEAM GRID A-1 TO B-1

(12/2.14)

UNBRACED LEN. 3'-1"




$$M_{\text{at } \textcircled{1}} = \text{at } \textcircled{2} = 24 \times 3.08 = 7.4$$

FROM ASD 2.174 ALLOWABLE  $M = 27.3 > 7.4$

BEAM GRID A-2 TO B-2

(12/2.14)

UNBRACED LEN. 3'-1"



$$M_{\text{at } \textcircled{1}} = 3.3 \times 3.08 = 10.2$$

$$M_{\text{at } \textcircled{2}} = 3.3 \times 4.50 = 2.4 \times 1.42 = 11.4$$

$$M_{\text{at } \textcircled{3}} = 4.3 \times 3.08 = 1.9 \times 1.71 = 11.9$$

$$M_{\text{at } \textcircled{4}} = 4.3 \times 2.37 = 10.2$$

FROM ASD 2.174 ALLOWABLE  $M = 27.3 > 11.9$



Otis A Clark PE.


TEL NO. 405 878-0338

Mar 29, 95 9:09 P.11  
PAGE 9

BEAM - GRID B-2 TO D-2

(W12, 35)

UNTRACED LATH 2'-11"



$$M @ ① \quad 21.0 \times 2.21 = 46.4$$

$$M @ ② \quad 21.0 \times 5.13 - 20.4 \times 2.92 = 48.2$$


$$M @ ③ \quad 21.0 \times 2.21 = 46.4$$

FROM ASD 2.172 ALLOWABLE  $M = 91.2 > 48.2$

BEAM - GRID D-2 TO E-2

(W12, 26)

UNTRACED LATH 2'-11"



$$M @ ① \quad 26.4 \times 2.21 = 58.3$$

$$M @ ② \quad 26.4 \times 5.13 - 25.8 \times 2.92 = 60.1$$

$$M @ ③ \quad 26.4 \times 2.21 = 58.3$$

FROM ASD 2.173 ALLOWABLE  $M = 66.8 > 60.1$




Otis A Clark PE.

TEL NO. 405 878-0338

Mar 29, 95

9:10 P.12  
PAGE 10

BEAM & GRID D1-1 TO E-1 & D1-3 TO E-3 (W12x6)  
(UNBROKEN LETH 24.1)




$$M = ① 15.4 \times 6.7 = 10.3$$

$$M = ② 15.4 \times 3.59 - 12.9 \times 2.92 = 17.6$$

$$M = ③ 11.2 \times 2.21 = 24.3$$

FROM ASD 2-173 ALLOWABLE  $M = 66.4 > 24.3$

BEAM & GRID B-1 TO C-1 (W12x19)  
(UNBROKEN LETH 24.1)




$$M = ① 6.4 \times 2.21 = 14.1$$

$$M = ② 6.4 \times 5.13 - 7.5 \times 2.92 = 10.9$$

$$M = ③ 9.2 \times 6.7 = 6.2$$

FROM ASD 2-174 ALLOWABLE  $M = 42.5 > 14.1$





(11/12/14)

UNBRACED LETH 3/0

$$M_{\text{①}} = 4.4 \times 1.5 = 6.6$$

$$M_{\text{②}} = 4.4 \times 3.75 - 1.5 \times 3.00 = 12.15$$

$$M_{\text{③}} = 3.7 \times 5.14 - 1.9 \times 2.37 = 15.85$$


$$M_{\text{④}} = 3.7 \times 2.37 = 8.77$$

FROM ASD 2.174 ALLOWABLE  $M = 27.3 >$

BEAM - GRID A-5 TO A-7

(11/12/16)

UNBRACED LETH 3/10



$$M_{\text{①}} = 6.1 \times 3.35 = 20.4$$

$$M_{\text{②}} = 6.1 \times 7.17 - 3.1 \times 3.82 = 31.9$$

$$M_{\text{③}} = 6.2 \times 6.24 - 2.7 \times 3.35 = 29.6$$

$$M_{\text{④}} = 6.2 \times 2.89 = 17.9$$


FROM ASD 2.172 ALLOWABLE  $M = 76.2 > 31.9$



BEAM @ GRID A-3 TO A-5

W12x8

UNBRIDGED LETH 410




$$\begin{aligned}
 M @ 1 &= 4.2 \times 3.31 &= 13.9 \\
 M @ 2 &= 4.2 \times 6.62 - 1.8 \times 3.31 &= 22.0 \\
 M @ 3 &= 4.0 \times 7.96 - 2.2 \times 3.98 &= 23.4 \\
 M @ 4 &= 4.0 \times 3.98 &= 15.9
 \end{aligned}$$

FROM ASD 2-17C ALLOWABLE  $M = 76.2 > 23.4$ BEAM @ GRID B-3 TO B-5

(W12x16)

UNBRIDGED LETH 410




$$\begin{aligned}
 M @ 1 &= 7.6 \times 3.31 &= 25.1 \\
 M @ 2 &= 7.6 \times 6.62 - 3.3 \times 3.31 &= 39.3 \\
 M @ 3 &= 7.1 \times 7.96 - 3.9 \times 3.98 &= 41.2 \\
 M @ 4 &= 7.1 \times 3.98 &= 28.4
 \end{aligned}$$

FROM ASD 2-17C ALLOWABLE  $M = 76.2 > 41.2$



BEAM &amp; GRID B-5 TO B-7




$$\begin{aligned}
 M @ 1 &= 6.9 \times 3.35 = 23.1 \\
 M @ 2 &= 6.9 \times 7.17 - 3.5 \times 3.82 = 36.1 \\
 M @ 3 &= 7.0 \times 6.24 - 3.21 \times 3.35 = 33.3 \\
 M @ 4 &= 7.0 \times 2.89 = 20.2
 \end{aligned}$$

FROM ASD 2-172 ALLOWABLE  $M = 76.2 > 33.3$ 

CROSS BEAM UNDER FT 1, 2, 3 (6 PLACES) 5/10 SPAN (W8-18)

UNBRACED LETH 16




$$\begin{aligned}
 M @ 1 &= 7.0 \times 1.42 = 9.9 \\
 M @ 2 &= 7.0 \times 2.92 - 6.7 \times 1.50 = 10.4 \\
 M @ 3 &= 7.0 \times 1.42 = 9.9
 \end{aligned}$$

FROM ASD 2-174 ALLOWABLE  $M = 30.3 > 10.4$



## BEAM - GRID C-3 TO C-4

(W12.35)



$$M @ ① = 13.7 \times 1.87$$

$$= 25.6$$

$$M @ ② = 13.7 \times 3.35 - 1.6 \times 1.48$$

$$= 43.5$$

$$M @ ③ = 13.7 \times 5.27 - 1.6 \times 4.0 - 8.4 \times 2.52 = 52.9$$

$$M @ ④ = 11.1 \times 6.19 - 3.3 \times 3.19 - 1.7 \times 2.21 = 54.4$$


$$M @ ⑤ = 11.1 \times 3.78 - 3.3 \times .98 = 40.9$$

$$M @ ⑥ = 11.1 \times 3.00 = 33.3$$

FROM ASD 2-172 ALLOWABLE  $M = 91.2 > 54.4$

BEAM - GRID F-3 TO F-4, F-4 TO F6  
# F6 TO F-7

(W12.26)



$$M @ ① = 9.2 \times 3.35 = 30.8$$

$$M @ ② = 9.2 \times 3.35 = 30.8$$


FROM ASD 2-172 ALLOWABLE  $M = 66.8 > 30.8$



BEAM &amp; GRID C-6 TO C-7

(W12x26)

UNBRACED LGTH 31.44



$$M_1 \textcircled{1} = 9.0 \times 3.35 = 30.2$$

$$M_2 \textcircled{2} = 9.0 \times 7.17 - 8.4 \times 3.82 = 32.4$$


$$M_3 \textcircled{3} = 9.4 \times 3.35 = 31.5$$

FROM ASD 2.173 ALLOWABLE  $M = 66.8 > 32.4$ 

BEAM &amp; GRID C-4 TO C-6

(W12x26)

UNBRACED LGTH 31.44



$$M_1 \textcircled{1} = 10.2 \times 3.35 = 34.2$$

$$M_2 \textcircled{2} = 10.2 \times 6.25 - 9.8 \times 2.90 = 35.3$$

$$M_3 \textcircled{3} = 10.8 \times 3.35 - 1.5 \times 1.43 = 34.0$$

$$M_4 \textcircled{4} = 10.8 \times 1.5 = 16.2$$

FROM ASD 2.173 ALLOWABLE  $M = 66.8 > 35.3$




Otis A Clark PE.

TEL NO. 405 878-0338

Mar 29, 95 9:14 P.18

BEAM UNDER EP 4 (2 PLACES) (V12.26)  
UNBRACED LGTH 54'0 3/4"




$$M @ ① \& ④ = 8.1 \times 3.55 = 28.8$$

$$M @ ② \& ③ = 8.1 \times 4.63 - 49 \times 1.08 = 32.2$$

FROM ADS 2-173 ALLOWABLE  $M = 66.8 > 32.2$

BEAM @ GRID B-3 TO C-3 (V12.35)



$$M @ ① = 12.8 \times 2.21 = 28.3$$

$$M @ ② = 12.8 \times 5.13 - 12.9 \times 2.92 = 28.0$$

$$M @ ③ = 25.5 \times 1.46 - 13.7 \times .79 = 26.4$$

$$M @ ④ = 25.5 \times .67 = 17.1$$

FROM ADS 2-172 ALLOWABLE  $M = 91.2 > 28.3$




Otis A Clark PE.

TEL NO. 405 878-0338

Mar 29, 95

9:15 P.19  
PAGE 11

CROSS BENT UNDER RF 4 (2 PLACES) 5'10" SPAN (48'18")  
UNBRACED LETH 116



$$M = \textcircled{1} 4.3 \times 1.42 = 6.1$$

$$M = \textcircled{2} 4.3 \times 2.92 - 4.0 \times 1.50 = 6.6$$


$$M = \textcircled{3} 4.3 \times 1.42 = 6.1$$

FROM ASD 2-174 ALLOWABLE  $M = 30.3 > 6.6$

BENT UNDER FLASH TANKS (2 PLACES)

(412'26")

UNBRACED LETH 5103



$$M = \textcircled{1} \& \textcircled{4} = 12.9 \times 3.55 = 45.8$$

$$M = \textcircled{2} \& \textcircled{3} = 12.9 \times 4.63 - 7.0 \times 1.08 = 52.2$$

FROM ASD 2-173 ALLOWABLE  $M = 66.8 > 52.2$



BEAM - GRID E-2 TO E-3

(W8.24)

UNBRACED LTH 12.4

$$M = \frac{1.8 \times 12.33}{8} = 2.8 \text{ k'}$$

FROM ASD 2-174 ALLOWABLE  $M = 38.3 > 2.8$ 

BEAM - GRID B-2 TO B-3

(W8.24)

UNBRACED LTH 12.4

$$M = \frac{3.6 \times 12.33}{8} = 5.5 \text{ k'}$$

FROM ASD 2-174 ALLOWABLE  $M = 38.3 > 5.5$ 

BEAM - GRID B-1 TO B-2

(W8.24)

UNBRACED LTH 12.4

$$M = \frac{4.2 \times 12.33}{8} = 6.5 \text{ k'}$$

FROM ASD 2-174 ALLOWABLE  $M = 38.3 > 6.5$ 

BEAM - GRID A-1 TO A-2

(W8.24)

UNBRACED LTH 12.4

$$M = \frac{2.4 \times 12.33}{8} = 3.7 \text{ k'}$$

FROM ASD 2-174 ALLOWABLE  $M = 38.2 > 3.7$ 

BEAM - GRID A-5 TO B-5

(W8.24)

UNBRACED LTH 9.3

$$M = \frac{3.4 \times 9.25}{8} = 3.9 \text{ k'}$$

FROM ASD 2-174 ALLOWABLE  $M = 38.3 > 3.9$



BEAM  $7\frac{1}{8}$  SOUTH OF GRID B-7 TO C-7

(W8x10)

UNBRACED LGTH  $7\frac{1}{3}$

$$M = \frac{3.2 \times 7.25}{8} = 2.9 \text{ K'}$$

FROM ASD PAGE 2-175 ALLOWABLE  $M = 11.5 > 2.9$

BEAM  $6\frac{1}{3}$  NORTH OF GRID B-5 TO C-5

(W8x10)

UNBRACED LGTH  $7\frac{1}{3}$

$$M = \frac{3.2 \times 7.25}{8} = 2.9 \text{ K'}$$

FROM ASD 2-175 ALLOWABLE  $M = 11.5 > 2.9$

BEAM  $2\frac{1}{4}$  NORTH OF GRID B-5 TO C-5

(W8x10)

UNBRACED LGTH  $7\frac{1}{3}$

$$M = \frac{2.8 \times 7.25}{8} = 2.5 \text{ K'}$$

FROM ASD 2-175 ALLOWABLE  $M = 11.5 > 2.5$

BEAM  $3\frac{1}{4}$  SOUTH OF GRID B-5 TO C-5

(W8x10)

UNBRACED LGTH  $7\frac{1}{3}$

$$M = \frac{3.0 \times 7.25}{8} = 2.7 \text{ K'}$$

FROM ASD 2-175 ALLOWABLE  $M = 11.5 > 2.7$

BEAM  $6\frac{1}{2}$  SOUTH OF GRID B-5 TO C-5

(W8x10)

UNBRACED LGTH  $7\frac{1}{3}$

$$M = \frac{3.2 \times 7.25}{8} = 2.9 \text{ K'}$$

FROM ASD 2-175 ALLOWABLE  $M = 11.5 > 2.9$



BEAM 2<sup>1</sup>/<sub>8</sub> NORTH OF GRID A-5 TO B-5 (W8x10)

UNBRACED LETH 9'3"

$$M = \frac{3.4 \times 9.25}{8} = 3.9 \text{ K'}$$

FROM ADS 2-175 ALLOWABLE  $M = 9.0 > 3.9$

BEAM 6<sup>1</sup>/<sub>8</sub> NORTH OF GRID A-5 TO B-5 (W8x10)

UNBRACED LETH 9'3"

$$M = \frac{4.0 \times 9.25}{8} = 4.6 \text{ K'}$$

FROM ADS 2-175 ALLOWABLE  $M = 9.0 > 4.6$

BEAM 7<sup>1</sup>/<sub>8</sub> SOUTH OF GRID A-7 TO B-7 (W8x10)

UNBRACED LETH 9'3"

$$M = \frac{4.2 \times 9.25}{8} = 4.9 \text{ K'}$$

FROM ADS 2-175 ALLOWABLE  $M = 9.0 > 4.9$

BEAM 3<sup>1</sup>/<sub>4</sub> SOUTH OF GRID A-7 TO B-7 (W8x10)

$$M = \frac{4.0 \times 9.25}{8} = 4.6 \text{ K'}$$

FROM ADS 2-175 ALLOWABLE  $M = 9.0 > 4.6$

BEAM 3<sup>1</sup>/<sub>4</sub> SOUTH OF GRID B-5 TO C-5 (W8x10)

UNBRACED LETH 7'3"

$$M = \frac{3.2 \times 7.25}{8} = 2.9 \text{ K'}$$

FROM ADS 2-175 ALLOWABLE  $M = 11.5 > 2.9$



BEAM @ GRID D-2 TO D-3

(W12x14)

UNBRACED LTH 11'10"

$$M = \frac{3.8 \cdot 11.83}{8} = 4.7 \text{ K'}$$

FROM ASD 2.175 ALLOWABLE  $M = 20.75 > 4.7$ BEAM @ GRID D-1 TO D-2

(W12x19)

UNBRACED LTH 17'6"

$$M = \frac{3.2 \cdot 12.5}{8} = 5.0 \text{ K'}$$

FROM ASD 2.175 ALLOWABLE  $M = 17.0 > 5.0$ BEAM  $3\frac{1}{4}$  NORTH OF GRID A-3 TO B-3

(W8x10)

UNBRACED LTH 9'3"

$$M = \frac{4.4 \cdot 9.25}{8} = 5.1 \text{ K'}$$

FROM ASD 2.175 ALLOWABLE  $M = 9.0 > 5.1$ BEAM  $6\frac{1}{2}$  SOUTH OF GRID A-5 TO B-5

(W8x10)

UNBRACED LTH 9'3"

$$M = \frac{4.0 \cdot 9.25}{8} = 4.6$$

FROM ASD 2.175 ALLOWABLE  $M = 9.0 > 4.6$ BEAM  $3\frac{3}{4}$  SOUTH OF GRID A-5 TO B-5

(W8x10)

UNBRACED LTH 9'3"

$$M = \frac{3.6 \cdot 9.25}{8} = 4.2$$

FROM ASD 2.175 ALLOWABLE  $M = 9.0 > 4.2$



BEAM 3-1 & 6-2 WEST OF GRID B-1 TO B-2 (2 PLACES)

(W8.15) UNBROKEN LATH 13'0"

$$M = \frac{4.8 \times 13}{8} = 7.8 \text{ K'}$$

FROM ASD 2.175 ALLOWABLE  $M = 12.1 > 7.8$

BEAM 2-4 & 5-6 WEST OF GRID B-2 TO B-3 (W8.15)

UNBROKEN LATH 13'0"

$$M = \frac{3.8 \times 13}{8} = 6.2 \text{ K'}$$

FROM ASD FACTOR 2.175 ALLOWABLE  $M = 12.1 > 6.2$

BEAM UNDER TANKS (8 PLACES) (W8.10)

UNBROKEN LATH 11'

$$M = \frac{1.6 \times 5.9}{8} = 1.2 \text{ K'}$$

FROM ASD 2.175 ALLOWABLE  $M = 15.6 > 1.2$

BEAM @ TANKS 3'6" SPAN (8 PLACES) (W8.10)

UNBROKEN LATH 3'6"

$$M = \frac{1.2 \times 3.55}{8} = .5 \text{ K'}$$

FROM ASD 2.175 ALLOWABLE  $M = 15.6 > .5$



BEAM - GRID A-7 TO B-7

(W8.24)

UNBRACED LETH 9'3"

$$M = \frac{1.8 \times 9.25}{8} = 2.1 \text{ k'}$$

FROM ASD 2.174 ALLOWABLE  $M = 38.3 > 2.1$ 

BEAM - GRID B-7 TO C-7

(W8.24)

UNBRACED LETH 7'3"

$$M = \frac{1.4 \times 7.25}{8} = 1.3$$

FROM ASD 2.174 ALLOWABLE  $M = 38.3 > 1.3$ 

BEAM - GRID B-5 TO C-5

(W8.24)

UNBRACED LETH 7'3"

$$M = \frac{2.6 \times 7.25}{8} = 2.4 \text{ k'}$$

FROM ASD 2.174 ALLOWABLE  $M = 38.3 > 2.4$ 

BEAM - GRID C-7 TO F-7

(W12.26)

UNBRACED LETH 18'0"

$$M = \frac{3.6 \times 18.0}{8} = 8.1 \text{ k'}$$

$$M = \text{CONT. END} = \frac{12.0 \times 5.45^2}{2} = 3.0 \text{ k'}$$

FROM ASD 2.174 ALLOWABLE  $M = 31.4 > 8.1$



BEAM @ GRID C-6 TO F-6 & C-4 TO F-4 (W 12.26)  
UNBRACED LETH 18'0"

$$M = \frac{7.2 \times 18.04}{8} = 16.2 \text{ k'}$$

$$M @ \text{CONT.} = \frac{.40 \times 5.45^2}{2} = 5.9 \text{ k'}$$

FROM ASD 2.174 ALLOWABLE  $M = 31.4 > 16.2$

BEAM @ GRID C-31 TO F-31 (W 12.26)  
UNBRACED LETH 18'0"

$$M = \frac{6.6 \times 18.04}{8} = 14.9 \text{ k'}$$

$$M @ \text{CONT.} = \frac{2.0 \times 5.45^2}{2} = 3.0 \text{ k'}$$

FROM ASD 2.174 ALLOWABLE  $M = 31.4 > 14.9$

BEAM - FILTER PRESSURE GRID C TO F (6 PLACES) (W 12.26)  
UNBRACED LETH 18'0"

$$M = \frac{3.6 \times 18.04}{8} = 8.1 \text{ k'}$$

$$M @ \text{CONT.} = \frac{.46 \times 5.45^2}{2} = 6.8 \text{ k'}$$

FROM ASD 2.174 ALLOWABLE  $M = 31.4 > 8.1$



BEAM 411/2 # 34 1/4 NORTH OF GRID. B-3 TO C-3 (W8.10)

UNBRACED LETH 7.3

$$M = \frac{34 \times 7.25}{8} = 3.1 \text{ k}$$

FROM ASD 2.175 ALLOWABLE  $M = 11.5 > 3.1$

BEAM @ GRID E-1 TO E-2

(W8.10)

UNBRACED LETH 12.4

$$M = \frac{1.8 \times 11.33}{8} = 2.5$$

FROM ASD 2.175 ALLOWABLE  $M = 5.2 > 2.5$

BEAM 416 EAST OF GRID. A-3 TO A-2

(W8.10)

UNBRACED LETH 13.0

$$M = \frac{1.8 \times 13}{8} = 2.9 \text{ k}$$


FROM ASD 2.175 ALLOWABLE  $M = 4.8 > 2.9$



MEZZ BEAM - GRID B-1 TO C9-1

(W18x15)

UNBRACED LTH. 410



$$M = \textcircled{1} = 2.1 \times 3.12 = 6.6$$


$$M = \textcircled{2} = 2.8 \times 1.58 = 4.4$$

FROM ASD 2.175 ALLOWABLE  $M = 23.6 > 6.6$

MEZZ BEAM - GRID B-2 TO D-2

(W18x14)

UNBRACED LTH 210



$$M = \textcircled{1} = 5.2 \times 1.54 = 8.0$$

$$M = \textcircled{2} = 5.2 \times 3.12 = 16.2$$

$$M = \textcircled{3} = 5.2 \times 5.12 = 26.6$$


$$M = \textcircled{4} = 6.7 \times 3.12 = 20.9$$

$$M = \textcircled{5} = 6.7 \times 1.54 = 10.3$$

FROM ASD 2.174 ALLOWABLE  $M = 29.8 > 14.4$




MEZZ BEAM B-3 TO C-3 & D-1-3 TO E-3 (WE-15)  
& E-1 TO D-1-1 UNBRACED LGTH 31.7



M @ ①  $1.9 \times 1.54 = 2.9 \text{ k}$   
M @ ②  $0.7 \times 3.58 = 2.5 \text{ k}$

FROM ASD 2-175 ALLOWABLE M = 23.6 > 2.9

MEZZ BEAM @ GRID D-2 TO E-2 (WE-14)  
UNBRACED LGTH 31.7



M @ ①  $5.6 \times 1.54 = 8.6$   
M @ ②  $5.6 \times 5.12 - 5.2 \times 3.58 = 10.1$   
M @ ③  $4.7 \times 1.54 = 7.2$

FROM ASD 2-114 ALLOWABLE M = 27.6 > 10.1



MEZZ BEAM C9-1 TO C9-2

(W8x15)

(UNBRACED LGTH = 10'1")

$$M = \frac{3.6 \times 1267}{8} = 5.7 \text{ k'}$$

FROM ADS 2.175 ALLOWABLE  $M = 14.0 > 5.7$ MEZZ BEAM D1-1 TO D1-2

(W8x15)

(UNBRACED LGTH = 7'2")

$$M = \frac{5.2 \times 1267}{8} = 8.2 \text{ k'}$$

FROM ADS 2.175 ALLOWABLE  $M = 21.0 > 8.2$ MEZZ BEAM 1 1/2 WEST OF C9-1 TO C9-2

(W8x15)

(UNBRACED LGTH 4'6")

$$M = \frac{4.2 \times 13}{8} = 6.8 \text{ k'}$$

FROM ADS 2.175 ALLOWABLE  $M = 21.25 > 6.8$ MEZZ BEAM 3 1/2 EAST OF B-1 TO B-2

(W8x15)

(4'6" UNBRACED LGTH)

$$M = \frac{5.6 \times 13}{8} = 9.1$$

FROM ADS 2.175 ALLOWABLE  $M = 21.25 > 9.1$ MEZZ BEAM 1 1/2 EAST OF B2 TO B3

(W8x15)

(UNBRACED LGTH 7'2")

$$M = \frac{4.9 \times 13}{8} = 6.5$$

FROM ADS 2.175 ALLOWABLE  $M = 21.0 > 6.5$



MEZZ BEAM @ GRID E-1 TO E-2 (W8.10)  
B2 TO B3 & E2 TO E3

$M = \frac{1.2 + 1.3}{8} \cdot 1.95 \text{ k}' \quad (\text{UNBRACED LTH } 15'0")$

FROM ADS 2.175 ALLOWABLE  $M = 4.0 > 1.95$

MEZZ BEAM @ GRID B1 TO B2 (W8.10)

(UNBRACED LTH 6'8")

$M = \frac{2.6 + 1.3}{8} \cdot 4.2 \text{ k}'$

FROM ADS PAGE 2.175 ALLOWABLE  $M = 12.2 >$

MEZZ BEAM @ GRID C-9-3 TO C-9-2 & D-1-3 TO D-1-2

(W8.15) (UNBRACED LTH 7'2")

$M = \frac{5.2 + 1.3}{8} \cdot 8.5 \text{ k}'$

FROM ADS 2.175 ALLOW.  $M = 21.2 > 8.5$

MEZZ BEAM 1/2 W. OF E1 TO E2 & E2 TO E3 (W8.15)

(UNBRACED LTH 7'2")

$M = \frac{4.0 + 1.3}{8} \cdot 6.5 \text{ k}'$

FROM ADS 2.175 ALLOWABLE  $M = 21.2 > 6.5$



MEZZ BEAM 2-11 SPAN, 6 PLACES, 12.8x10

(211 UNBRACED LETH)

$$M = \frac{1.2 \times 2.92}{2} = 4.1'$$

FROM ADS 2-175 ALLOWABLE  $M = 16.0 > 4$

MEZZ BEAM - TANK OPENINGS (6 PLACES) (12.8x10)

(UNBRACED LETH 2/14)

$$M = \frac{.6 \times 7.16}{4} = 1.1' K'$$

FROM ADS 2-175 ALLOWABLE  $M = 16.0 > 1.1$





(REVISED)


COLUMNS ON 6" SLABS

Max. Cal. Load Is At B.S - 17.6 kips

6" SLAB, 4000 PSI CONC w/ #4 @ 12 IN. &amp; STR.

ALLOWABLE M PER FT. OF SLAB

$$As f_s d = .20 \times 14000 \times .85 \times 3 \times 12,240 \text{ " LBS.}$$



CHECK OF 2 WAY (PUNCHING) SHEAR

$$4 \times 16" \times 6" \times 1.1 \sqrt{4000} = 26.7 \text{ k} > 17.6 \text{ k O.K.}$$

REQUIRED MOMENT PER FT OF SLAB

$$\frac{2500 \times 11.5}{12} \times 11.5 = 9184 \text{ " LBS} < 12,240 \text{ " LBS. O.K.}$$

FROM ASD PAGE 2.302 BEAM DIAG. #20




Otis A Clark PE.

TEL NO. 405 878-0338

Apr 03, 95 13:36 P.03

(REVISED)

# HORZ. FORCES & GRID



$$\frac{3.26}{4} = .8150 \text{ KIPS PER COL.}$$

4

$$.8150 \times 11.5 = 9.37 \text{ K' MOMENT}$$


$$\frac{9.37 \times 12 \times 1000}{21600} = 5.2 \text{ K/IN S.F.}$$

$$148.31 \times 27.5 = 4078.5 \text{ COLUMNS OK}$$

## COMBINED LOADS:

$$\frac{5.2}{27.5} + \frac{24.2}{149} = .3515 < 1 \text{ Cols. O.K.}$$

FROM 405-331





Otis A Clark PE.

TEL NO. 405 878-0338

Apr 03, 95 13:37 P.04

PAGE 32

HORIZ FORCES @ MECH Horiz Col Load @ B2 = 7.1 k  
D2 = 12.3 k  
E2 = 5.9 k

HORIZ FORCE @ GRID 2 =  $(7.1 + 12.3 + 5.9) \times .045 = 1.14$  k

$\frac{1.14}{3} = .38$  k HORIZ FORCE PER COL

M K' WSK AISC OF COL =  $.38 \times 12.25 = 4.66$  k'

RESN S2 =  $\frac{4.66 \times 12}{21.6} = 2.59 < 5.63$  OK


COMBINED LOADING

$\frac{2.59}{5.63} + \frac{12.3}{95} = .46 + .13 = .59 < 1$

COLS. OK



MOMENT CONN @ COL CAP PLATES, Cals. F3, F4, F5, F7



CAP PL. @ Cals. F3, F4, F5, F7

FROM PAGE 5 MOMENT IN 9.37 k

$$\text{FORCES @ FUS. } \frac{9.37 \times 12}{(8 - 1.435)} = 14.86 \text{ k}$$

WELD @ FLANGES  $70 \times 4 \times 8 = 22.4 > 14.86 \text{ O.K.}$

$$\text{Max TSH @ BOLTS. } \frac{9.37 \times 12}{6.75} = 16.66 \text{ k}$$

$$\frac{16.66}{2} = 8.33 \text{ PER BOLT} < 9.3 \text{ O.K.}$$



# Foundation Design Analysis



Otis A Clark PE.

TEL NO.405 878-0338

Mar 29,95 9:02 P.02

OTIS A. CLARK PE.

Phone  
(405) 878-0338

130 Bdwy. Bldg.  
Suite 202  
Shawnee, OK. 74801

To: USPCI  
Lone Mountain Facility  
Route 2, Box 180A  
Waynoka, Okla. 73806

Attn: Lawson Fenton

March 28, 1995

The following is an investigation for the foundation support for the mezzanine platforms for the Wastewater Final Treatment Facility, and the calculations for the design of the beams, columns, and bracing for the structure. The design loads are per the 1990 BOCA National Building Code and are shown on page #7 of the following submittal.

COLUMN	LOAD, KIPS	FOUNDATION CONDITION	REMARKS
A-1	3.6	17" floor slab	OK (see page #2)
A-2	4.5		
A-3	8.4		
A-5	9.8	6" floor slab	OK (see page #1)
A-7	4.8		
B-1	14.3	17" floor slab	OK (see page #2)
B-2	36.3		
B-3	27.9		
B-5	17.6	6" floor slab	OK (see page #1)
B-7	8.5		
C-4	28.1	24" x 36" cont.ftg.	Ok (see page #3)



C-6	24.8	24" x 36" cont.ftg.	Ok (see page #3)
C-7	11.5	6" floor slab	OK (see page #1)
C.9-1	14.1	17" floor slab	OK (see page #2)
C.9-3	28.8		
D-2	62.9		
D.1-1	19.0		
D.1-3	19.9		
E-1	14.2		
E-2	34.1		
E-3	14.4		
F-3.1	12.0	6" floor slab	OK (see page #1)
F-4	24.2	24" x 36" cont. ftg.	OK (see page #3)
F-6	24.2		
F-7	12.1	6" floor slab	OK (see page #1)






COLUMNS ON 6" SLABS

Max. Cal. Load Is AT B.S - 17.6 KIP.

6" SLAB, 4,000 PSI CONC. w/ #4 @ 12 IN. CTR.

ALLOWABLE M PER FT. OF SLAB

$$As_{reqd} = .20 \times 24000 \times .85 \times 3 = 12,240 \text{ " LBS.}$$



CHECK OF 2 WAY (PUNCHING) SHEAR

$$4 \times 16" \times 6" \times 1.1 \sqrt{4000} = 26.7 \text{ K.} > 17.6 \text{ K. O.K.}$$

REQUIRED MOMENT PER FT. OF SLAB

$$\frac{2500 \times 11.5}{12} \times 11.5 = 6,888 \text{ " LBS.} < 12,240 \text{ " LBS. O.K.}$$

4



COLUMNS ON 17" SLAB w/ #6 @ 12" E.D. T & B

Max. Col. Load Is At Grid D-2 = 62.9 KIPS

ALLOWABLE MOMENT IN SLAB

$$.44 \times 24000 \times 12 = 126,720 \text{ LB} = 10.56 \text{ K'}$$

ALLOWABLE SOIL BEG. = 2500 \* SWA WT 180 = 2320

$$\frac{62.9}{2.32} = 27.11 \text{ sq ft reqd. area} = 5.3 \text{ SQUARES}$$

$$2 \text{ WAY (PUNCHING) SHEAR } 4 \times 27 \times 17 \times 1.1 \sqrt{4000} \\ = 127.7 \text{ K} > 62.9 \text{ K} \quad \text{O.K.}$$

REQD MOMENT IN GRADE BEAM

$$\frac{2.25 \times 2.32}{4} = 1.31 \text{ K' } < 10.56 \text{ K'}$$

O.K.



COLUMNS ON 24" x 36" GRADE BEAM

MAX COL LOAD IS AT COL C-4 - 28.1 KIPS.

GRADE BEAM HAS 2 #6 @ TOP, CTR & BOT  
(ACCORDING TO LAWSON FENTON)

ALLOWABLE MOMENT IN GRADE BEAM (FIGURING T & B REINF.)

As f'd =  $1.88 \times 24000 \times 30 = 632,640$  "LB. OR 52.8 K"

ALLOWABLE SOIL BRG 2500 - GB WEIGHT 360 = 2140


$\frac{28,100}{2} \times 6' - 8$  LENGTH OF GRADE BEAM TO SUPPORT SOIL  
2140 + 2

REQD MOMENT IN GRADE BEAM

$\frac{21.8 \text{ K} \times 6.67}{2} = 18.2 \text{ K} < 52.8 \text{ K} \quad \text{O.K.}$







## CORE PLUG DETAIL

CORE PLUG DETAIL FOR  
USPCI, LONE MOUNTAIN FACILITY  
WAYNOKA, OKLAHOMA

Myers

ENGINEERING CORPORATION  
Oklahoma City Oklahoma

JOB NO. 511  
SCALE NTS  
DRAWN DMC  
DATE 6/23/97

1 OF 1



<u>Specimen</u>	<u>Diameter, in.</u>	<u>Drilled Length, in.</u>	<u>Capped Length, in.</u>	<u>Crushing Load, lbs.</u>	<u>L/D Correction Factor</u>	<u>Compressive Strength, psi</u>
PHT-1	3.75	5.5	5.7	32,440	0.96	2,810
PHT-2	3.75	5.5	4.9	47,200	0.93	3,980
PHT-3	3.75	6.5	4.5	41,400	0.93	3,490
PHT-4	3.75	7.5	4.6	60,700	0.93	5,110
PHT-5	3.75	7.0	7.1	43,000	0.99	3,860
PHT-6	3.75	6.5	4.1	57,100	0.88	4,550
PHT-7	3.75	7.0	5.8	43,800	0.96	3,810
PHT-8	3.75	6.0	5.8	74,800	0.96	6,480
PHT-9	3.75	5.0	5.5	33,900	0.96	2,950
PHT-10	3.75	6.0	4.7	72,500	0.93	6,100
PHT-11	3.75	6.0	5.6	55,720	0.96	4,840
PHT-12	3.75	6.0	6.6	65,600	0.98	5,800
PHT-13	3.75	5.0	5.3	68,700	0.94	5,850
PHT-14	3.75	5.0	5.3	80,200	0.95	6,900
PHT-15	3.75	6.0	5.1	60,200	0.97	5,290
FHT-1A	3.75	6.0	4.7	53,800	0.93	4,530
FHT-1B	3.75	13.0	6.0	50,800	0.97	4,460
FHT-2	3.75	22.0	7.0	30,740	0.99	2,760
*FHT-3	3.75	15.0	-	-	-	-
FHT-4	3.75	6.0	7.0	81,600	0.99	7,320
FHT-5	3.75	6.0	5.8	81,700	0.96	7,100
*FHT-6	3.75	19.0	-	-	-	-
*FHT-7	3.75	14.5	-	-	-	-
FHT-9	3.75	7.0	7.0	53,200	0.99	4,770

PHT - Pre-Water Treatment  
FHT - Final Water Treatment

\* Samples which we were not able to pull out of the hole.



4


**MERS**  
MERS-INDICATING CONTINUALLY  
IMPROVED COTTON BLEND

JOE MO. 911  
SCALE 031341  
DRAWING 6-17-53



(14) — CONTAINMENT AREA NUMBER

.....LOCATION OF CORE



FWT: Final Water Treatment

LAYOUT OF WASTE WATER TREATMENT  
BUILDING USED LONE MOUNTAIN HAZARDOUS  
WASTE FACILITY VAINONA, OKLAHOMA

MOS

WASTE WATER TREATMENT

WASTE WATER TREATMENT





March 27, 1995

Mr. Jim Richenbaugh  
Black & Veatch Waste Science  
4717 Grand Avenue, Suite 500  
Kansas City, MO 64112

Re: USPCI Lone Mountain Facility  
Subject: Waste Water Treatment Floor Structural Design

The concrete floors in the area where the mezzanine has been erected were poured as part of two different building expansions. The first expansion was poured in the spring of 1987 and was designed to be eighteen inches thick with two layers of 3/4 inch reinforcement bars tied on one foot centers and separated by twelve inches between the top and bottom mats. All reinforcement bars were kept within three inches of the slab's surfaces and were supported by concrete brick on a two inch layer of sand. This slab underlies the area that supports the Flash Tanks and EF4 and extends to the south edge of the filter press mezzanine.

The second expansion attaches to the north side of the first slab and was poured in November of 1987. It was poured around four existing boiler foundations that were 2 feet wide, 3 feet deep, and 24 feet long. The floor slab was poured six inches thick and used a layer of 1/2 inch reinforcement bars tied on one foot centers, supported on a concrete brick and a 2 inch layer of sand. This slab underlies the area supporting the filter presses.

Both slabs were poured using a 4000 psi concrete strength mix as verified by the core sample tested by Meyers Engineering of which a report has been sent to you earlier this week.

I hope this will provide the information you needed for the certification work now in progress.

Sincerely,

Lawson Fenton  
Project Manager

2, Box 170  
Waynoka, Oklahoma 73860-9622

Tel: 405/697-3500  
Fax: 405/697-3596

**Our Mission:**

Provide the highest quality waste and by-product management services that consistently meet or exceed customer needs and regulatory requirements at competitive cost while enhancing shareholder value.



## FF4 Tank Loading

Tank Volume = 1625 gal.

Fluid Sp. Gr = 1.5 maximum

Fluid weight(max) = 1625 gal.  $\times$  8.35 lb/gal(water)  $\times$  1.5 sp. gr. = 20,350 lb


Tank Weight  $\approx$  7000 lb.

Weight of tank + contents = 7000 lb + 20,350 lb = 27,350 lb

Weight distribution to base plate.  
 Base plate Area =  $\pi R^2 - \pi r^2 = \pi(R^2 - r^2)$   
 $= 3.14 [(3'5")^2 - (2'11")^2]$   
 $= 10 \text{ ft}^2$

Loading =  $\frac{\text{wt. (tank + contents)}}{A}$

$L = \frac{27350 \text{ lb}}{10 \text{ ft}^2} = 2735 \text{ lb/ft}^2$



Tank Base Plate



# Tank Leak Tests



Hydrostatic Test Record

Customer: USPCI - Lone Mt. Facility

Project: Evaporation Feed Tank No. 4

Location: Waynoke, OK

Test Start Date 3/1/95 Test Start Time 7:45 a.m.

Test Finish Date 3/1/95 Test Finish Time 11:45 a.m.

Test Procedure:

Fill evaporator feed tank to the top mtd. nozzle with water.

Results:

All tank nozzles were flanged off below the test water level. There was no change in water level inside the feed tank. Visual inspection of tank and tank nozzles indicated no water leaks.

Witness

Bay Pries

Date: 3/1/95



FROM : DUB GREER

PHONE NO. : 903 764 5764

Feb. 15 1995 02:38PM P2

## WISco, INC.

11811 North Fwy., Suite 670  
Houston, Texas 77060  
(713) 820-8066

Page 1 of 1  
Report Date 11/19/93  
Report No. 001

Customer USPCI Attn: Bruce Patterson  
Order No. 12418-30-46 Dated \_\_\_\_\_ Rev. \_\_\_\_\_ Dated \_\_\_\_\_  
Mat'l Destination Lone Mt. Facility, Waynoka, OK Req. Date \_\_\_\_\_  
Shipment Date is now 11/24/93 As of 11/19/93 Changed from \_\_\_\_\_  
Inspector estimated shipment date 11/24/93 Order is 85 percent completed  
Vendor Lide Tank Co. Order No. \_\_\_\_\_ Dated \_\_\_\_\_  
Manufacturer Lide Tank Co. Phone 817-562-5526  
Shop Location Mexia, TX Shop Order TKEB2 & TKEF4  
Inspector's Contact Mr. Billy Lide Position Customer Contact  
Report is: ☒ Interim ☐ Final Regarding: ☒ Inspection ☐ Expediting ☐ Status  
MATERIAL DESCRIPTION:

Two (2) tanks - one 6' 4" OD x 12' 0" high; one 5' 0" OD x 12' 0" high  
To specifications of USPCI and API 650

STATUS OF ORDER: Engineering, Materials, Fabrication, Inspection, Completion

The following was performed on each item:

Dimensional checks covering elevation, orientation, projection of all nozzles and manways. All of which were noted to be acceptable and as noted on shop approved drawings.

Fit-up of material: seams, junctions and welding of same was found to be very good. Visual inspection on nozzle fit-up and welding was noted as very good.

Review of two (2) spot x-rays (one on each item) was found to be satisfactory.

Leak test on each item was performed and noted as acceptable. Vessels were filled for over twelve (12) hours. Visual inspection disclosed no leaks or seeps.

Inspection of blasting and painting is scheduled for Wednesday, 11/24/93.

Rec  
12-4-93  
Dub

INSPECTOR: Dub Greer  
INSPECTION ORDER: 12418-30-46



# Piping Leak Tests



## Piping Pressure Test

Customer: USPCI - Lone Mt. Facility

Project: Discharge piping from Evaporation Feed Pumps P76 and P79 to

- (1) the block valve located just before suction side of Pump P75.
- (2) the block valves located on either side of Preheat Exchanger EU-4.
- (3) the check valves located between the normally closed (NC) valves and the TEEs connecting to the suction side of Filter Press Pumps P77, P80, and P83 (including by-pass lines).
- (4) the flange located on suction side of Pump P-5.

Location: Waynoka, OK

Test Start Date: 8/5/96

Test Start Time: 3:55 p.m.

Test Finish Date: 8/5/96

Test Finish Time: 5:55 p.m.

### Test Procedure:

Fill piping section between Pumps P76 and P79 discharge to valves described above. Apply water pressure to system up to 105 psig by hydro pump and hold this pressure for minimum 2 hours.

### Results:

Piping section was isolated from Pumps P76, P79, and P-5 by flange and Pump P75, EU-4, and Pump P83 by valve. System was pressured up to 105 psig and held this pressure for 2 hours. No change in pressure gauge reading was observed.



Signature

Geoffrey E. Brueggemann  
Geoffrey E. Brueggemann, P.E.  
Envirotech Services, Inc.

Date: Aug. 20, 1996



# Tank Metallurgy



ACCEPTANCE STANDARD API 650 ITEM DESCRIPTION TK. EF4  
RADIOGRAPHIC REQUIREMENTS RT-3

SOURCE: TYPE Ir 192 EXPOSURE: S. TO F. DISTANCE 16" VIEWING: SINGLE ☒  
SIZE .1 MAT'L THICKNESS .375 COMPOSITE ☐  
STRENGTH 41 ci. TIME 1 min 45 sec SINGLE WALL ☐

FILM: MFG Kodak SIZE 17 SCREENS: FRONT .005  
TYPE I SHIM THICKNESS .003 BACK .010  
SIZE 4 1/2 x 10" SOURCE SIDE yes  
FILM SIDE \_\_\_\_\_

[illegible]

RADIOGRAPHER D. Stanley LEVEL II Q.C. MGR. Evan Lemon DATE 11-18-93  
 AUTHORIZED INSPECTOR Reviewed Dale Starn DATE \_\_\_\_\_  
 COMMENTS: 11-19-93 WISCO INC.



PTANCE STANDARD API 650 ITEM DESCRIPTION TK. EB 2  
 BIOGRAPHIC REQUIREMENTS RT-3

SOURCE: TYPE Ir 192 EXPOSURE: S. TO F. DISTANCE 16" VIEWING: SINGLE ☒  
SIZE .1 MAT'L THICKNESS .375 COMPOSITE \_\_\_\_\_  
STRENGTH 41 ci. TIME 1 min 45 sec SINGLE WALL \_\_\_\_\_  
DOUBLE WALL \_\_\_\_\_

-M: PENETRATOR: 17 SCREENS: FRONT .005  
MFG Kodak SHIM THICKNESS .003  
TYPE T SOURCE SIDE yes  
SIZE 4 1/2 x 10" FILM SIDE BACK .010

[illegible]

ADIOGRAPHER D. Stanley LEVEL II ✓ Q.C. MGR. Evan Lemon DATE 11-18-93  
 UTHORIZED INSPECTOR Reviewed Duke Smith DATE \_\_\_\_\_  
 OMMENTS: 11-19-93 WISCO INC.





Test Report

THIS IS TO CERTIFY THAT THE PRODUCT DESCRIBED HEREIN WAS MANUFACTURED, SAMPLED, TESTED AND/OR INSPECTED IN ACCORDANCE WITH THE SPECIFICATION AND FULFILLS REQUIREMENTS IN SUCH RESPECTS.

*Edward J. Bigalle*  
CORPORATE DIRECTOR, QUALITY  
DATE 09-23-93

GENEVA STEEL P.O. BOX 2500 PROVO, UTAH 84603	MANNESSMANN PIPE&STEEL CORP 1990 POST OAK BLVD HOUSTON TX 77056-3811	ONEAL STEEL INC 10848 LUNA ROAD DALLAS TEXAS	S H I P T O
P.O. DATE 06/09/93		PURCHASE ORDER NO. 60-0641/X-53625	
SHIPPERS NO. GC625400		MILL ORDER NO. EA66015	TALLY NO. GC625400
VEHICLE IDENTITY SP 595603			

H.R. SHEET C.25 MAX P.040 MAX S.050 MAX HR36S058 Y/P 36 KSI MIN  
T/S 58 KSI MIN DRY NO OIL (FOR CONVERSION TO ASTM A-36)

01 MILL RA/SN CERTIFIED T/R

ITEM NO.	MATERIAL DESCRIPTION			QUAN-TITY	WEIGHT	HEAT NO.	TEST OR PIECE IDENTITY	YIELD PT. PSI	TENSILE STR. PSI	ELONGATION %		% RED. OF AREA
	THICKNESS OR SECTION	WIDTH, DIA. OR FL. WT.	LENGTH							IN 8"	IN 2"	
3	.3650"	72.0000"	COIL 655782	1	48630#	103294	.3610" .3680" ***END OF DATA***	43000 46700	62500 64900	27.0 24.0		

HEAT NO.	TYPE	C	AN	P	S	SI	CU	NI	CR	MO	SN	AL	N	V	B	TI	CB	CO
103294	HEAT 24	79	011	019	06													
'GENEVA STEEL COMPANY CERTIFIES ALL SMELTING AND MANUFACTURING PROCESSES OCCURRED IN THE USA.'																		
***END OF DATA***																		



JOB, CONTRACT NO. 2		P.O. DATE		PURCHASE ORDER NO.		THIS IS TO CERTIFY THAT THE PRODUCT DESCRIBED HEREIN WAS MANUFACTURED, SAMPLED, TESTED AND/OR INSPECTED IN ACCORDANCE WITH THE SPECIFICATION AND FULFILLS REQUIREMENTS IN SUCH RESPECTS.	
GENEVA STEEL		10/16/92		60-8349/23-3878-92		MANAGER - QUALITY ASSURANCE	
P.O. BOX 2500		SHIPPERS NO.		MILL ORDER NO.		DATE 12-08-92	
PRQVO, UTAH 84603		GC508408		EA54100			
		VEHICLE IDENTITY		RG 310945			
MANNESMANN PIPE&STEEL CORP		FERRO UNION		SHIP TO			
1990 POST OAK BLVD		7400 MESA ROAD					
HOUSTON TX 77056-3811		SP SPIN#243093					
		HOUSTON, TEXAS					

H.R. SHEET C.25MAX P.040MAX S.050MAX HR36SD58 Y/P 36 KSI MIN T/S  
58 KSI MIN DRY NO OIL

01 MILL RA/SN	CERTIFIED T/R ANALYSIS	REPORT TEST RESULTS PER PROD
SPECN CAPTION		

ITEM NO.	MATERIAL DESCRIPTION			QUANTITY	WEIGHT	HEAT NO.	TEST OR PIECE IDENTITY	YIELD PT. PSI	TENSILE STR. PSI	ELONGATION %		% RED. OF AREA
	THICKNESS OR SECTION	WIDTH, DIA. OR FT. WT.	LENGTH							IN 8"	IN 2"	
1	.3600"	72.0000"	COIL 566534	1	43230#	1C3269	.3600" .3600" ***END OF DATA***	46600 51100 DATA***	70600 72000	20.0 23.0		
<div style="text-align: center; font-size: 2em; margin-bottom: 10px;">3/8</div>												

HEAT NO.	TYPE	C	AN	P	S	SI	CU	NI	CR	MO	SN	AL	N	V	B	TI	CB	CO
C3269	HEAT	23	86	011	022	03												
GENEVA STEEL COMPANY CERTIFIES ALL SMELTING, MELTING AND MANUFACTURING PROCESSES OCCURRED IN THE USA. ***END OF DATA***																		



# Piping Metallurgy



MTT-14-1993 14:02 FROM QUINCY BLD 403 865-9750 TO 17137958701 P.03

# BELLVILLE TUBE CORP

P.O. Box 220  
Bellville, Texas 77418

## MILL CERTIFICATION

S.O.# : 001363 CUSTOMER ORDER #: 74454 DATE: 5-13-93 SOLID : 20142

S:		SI:	
01	Texas Pipe & Supply	01	Texas Pipe & Supply
L:	2330 Holmes Rd.	L:	2330 Holmes Rd.
D:	Houston, Texas	D:	Houston, Texas
	77051		
T:		T:	
01		01	

SIZE:	WALL	GRADE:	TYPE	LENGTH	QUANTITY
3.500"	216"	15L Gr B/X42	ERW	SEE	
		A53 Gr B		BELOW	1,305 Pcs.

SPECIAL INSTRUCTIONS: 2S  
BEVELED FOR WELDING

LOT	HEAT	C	Mn	P	S	Si	ULT.	YIELD	%EL.
DE009	25963	.20	.99	.010	.006	.22	72,710	51,254	45.7
DE010	25965	.21	.98	.010	.004	.21	72,510	50,313	45.7
DE011	25965	.21	.98	.010	.004	.21	72,903	51,479	44.7
DE012	25965	.21	.98	.010	.004	.21	72,054	48,330	45.3
DE013	25962	.20	1.00	.011	.005	.20	71,971	49,872	45.4
DE014	25962	.20	1.00	.011	.005	.20	75,206	53,979	43.8
DE015	25962	.20	1.00	.011	.005	.20	74,687	54,291	42.1
DE016	25965	.21	.98	.010	.004	.21	71,451	48,730	45.1

All material has passed API flattening tests,  
and Hydrostatic tests.

Notwithstanding any other provision in this contract, B.T.C. makes no warranty as to the suitability or fitness of this product for upgrading by Quench and Temper or any other process, unless B.T.C. shall be consulted in advance and give its approval in writing.

We hereby certify that the above information is true and correct as contained  
in the records of this division.

2. 11 1.1.00





# HACKNEY, INC.

A DIVISION OF TRINITY INDUSTRIES  
P.O. Box 568887 • 2525 Stemmons Freeway  
Dallas, Texas 75356-8887 • (214) 634-2850

YOUR ORDER NUMBER	REFERENCE	CUSTOMER NO.	INVOICE NO.	INVOICE DATE	DATE SHIPPED
DARRELL ANDERSON		454634			

SOLD TO: K & K SUPPLY CO  
PO BOX 548  
DUNCAN OK 75533

SHIP TO:

## CERTIFIED TEST REPORT

ITEM	QUANTITY	DESCRIPTION/SPECIFICATION	HEAT CODE
		6 STD LR 90 A106B 09 / U60907 A234-92A/SA234 WPB STRESS RELIEVED AT 1200 F	C66W

CODE	C	Mn	P	S	SI	Cr	Mo	Cu	NI	V	Nb	CE.
5W	.17	.77	.011	.007	.23	.02	.00	.01	.01	.00	.00	.30

HEAT CODE	TENSILE * KSI	YIELD KSI	% Elong. IN 2"	Hard- ness HB	Size MM x 10 mm	Temp. °F	FOOT POUNDS	LATERAL EXPANSION	% SHEAR
C66W	65.9 L	41.9	33.0	126					

\* LONGITUDINAL, T = TRANSVERSE

C66W CONFORMS TO THE REQUIREMENTS OF NACE MR0175-92

These items were heat treated in accordance with the requirements of the specification to which they were manufactured.

At the products covered by this report comply with the applicable requirements of ASTM and/or ASME specifications, as noted for each item.  
We certify that the above figures are correct, as contained in the records of the Company.

*Shirley L. L. L.*





# HACKNEY, INC.

A DIVISION OF TRINITY INDUSTRIES  
P.O. Box 568887 • 2525 Stemmons Freeway  
Dallas, Texas 75356-8887 • (214) 634-2850

YOUR ORDER NUMBER	REFERENCE	CUSTOMER NO.	INVOICE NO.	INVOICE DATE	DATE SHIPPED
0099-001186	C121252	454634	982719	01/20/94	01/20/94

OLD TO: M & M SUPPLY CO  
PO BOX 548  
DUNCAN OK 75533

SHIP TO: M&M SUPPLY CO  
2512 NO. 4TH STREET  
ENID, OK 73701

## CERTIFIED TEST REPORT

RI 414 (R 8/91)

ITEM	QUANTITY	DESCRIPTION/SPECIFICATION		HEAT CODE
1	8	6 150 RF WN STD	A105-92 / SA105	1293LB
		A105 01 / DJB	AS FORGED	
10	8	8 STD LR 90	A234-92A/SA234 WPB	C67R
		A106B 09 / X63386	STRESS RELIEVED AT 1200 F	

CHEMICAL ANALYSIS													
CODE	C	Mn	P	S	Si	Cr	Mo	Cu	Ni	V	Nb		C.E.
1293LB	.19	1.02	.012	.022	.25	.07	.01	.17	.06	.02	.00		.40
C67R	.18	.84	.008	.005	.25	.02	.01	.01	.02	.00	.00		.33

PHYSICAL PROPERTIES							CHARPY RESULTS			
HEAT CODE	TENSILE * KSI	YIELD KSI	% Elong. IN 2"	Hard- ness HB	Size MM x 10 mm	Temp. °F	FOOT POUNDS		LATERAL EXPANSION	
1293LB	88.8	58.4	30.6	187						
C67R	X P.A. 71.1 L	=63.4 46.6	MAX 37.0	153						

\* L - LONGITUDINAL, T - TRANSVERSE

1293LB C67R CONFORM TO THE REQUIREMENTS OF NACE MR0175-92

The items were heat treated in accordance with the requirements of the specification to which they were manufactured.

We certify that the products covered by this report comply with the applicable requirements of ASTM and/or ASME specifications, as noted for each item.

We hereby certify that the above figures are correct, as contained in the records of the Company.

By:

*Shirley L. Hester*



MILL TEST REPORTS FURNISHED BY  
TEXAS PIPE & SUPPLY CO., INC.

CUSTOMER

**NORTH STAR STEEL**

Seamless Tubular Products

CUSTOMER CERTIFIED TEST REPORT

□ 9

HEAT NO.: SLN 8Y0167

PRODUCT DESCRIPTION: 6-23 OD 0.280 WALL 18.97

LBS/FT PE DRL

CUSTOMER ORDER NO.: 7773

NS&H W/O NO.:

GRADE: API 5L X42/B

CUSTOMER SPEC.:

NS&H LOT NO.:

NS&H MILL ORDER NO.: 0-0017155-0

**MECHANICAL PROPERTIES: LONGITUDINAL**

SPECIMEN CROSS SECTION	ACTUAL LOAD (KIPB)	STRENGTH (KSI)	ELONGATION
YIELD (IN) : 100K (IN) : 100K (IN) : 100K (IN)	YIELD : 100K (IN) : 100K (IN) : 100K (IN)	YIELD : 100K (IN) : 100K (IN) : 100K (IN)	ELONGATION : 100K (IN) : 100K (IN) : 100K (IN)
1.479 : 0.273 : 0.4038 : 20.4	31.0 : 32.9	50.5 : 52.3	76.8 : 77.9 : 2.0 : 2.0
1.472 : 0.287 : 0.4225 : 22.1			

**COMMENTS**

This material is also manufactured by  
ASTM A106 Rev. 1966  
ASTM A106 Rev. 71  
ASME SA106-2 Rev. 1965  
ASME SA106-2 Rev. 71

**CHEMICAL ANALYSIS: MS61**

	C	Mn	P	S	Si	CU	NI	CR	MO	BN	CB	V	AL	CA	Fe	N	CE
HEAT	0.21	0.71	0.007	0.007	0.25	0.25	0.11	0.07	0.03	0.013	0.001	0.001	0.001	0.001	0.014	0.01	0.01
PRODUCT #1	0.21	0.71	0.008	0.007	0.24	0.24	0.11	0.07	0.03	0.015	0.001	0.001	0.001	0.001	0.012	0.01	0.01
PRODUCT #2	0.21	0.71	0.008	0.007	0.25	0.25	0.11	0.07	0.03	0.015	0.001	0.001	0.001	0.001	0.012	0.01	0.01
PRODUCT #3	0.21	0.71	0.007	0.007	0.25	0.25	0.11	0.07	0.03	0.015	0.001	0.001	0.001	0.001	0.012	0.01	0.01
PRODUCT #4	0.21	0.71	0.007	0.007	0.25	0.25	0.11	0.07	0.03	0.015	0.001	0.001	0.001	0.001	0.012	0.01	0.01

**HYDROSTATIC TEST (psi): 2660**

**SUPPLEMENTAL REQUIREMENTS: YES: NO:**

REMARKS

HARTNESS : X : : FB AVE 25

CHARPY IMPACT TEST : : :

FLATTENING TEST: X : : PASSED

MADE TEST : : :

JOINTLY HARDEN : : :

GRAIN SIZE : : :

OTHER : : :

Satisfies NACE MR-01-75

This material is not to be used in applications where the  
hydrostatic test is required unless authorized by  
the manufacturer of the equipment to be tested. The  
hydrostatic test is required for the purpose of  
determining the ability of the material to withstand  
the internal pressure of the equipment to be tested.  
The hydrostatic test is required for the purpose of  
determining the ability of the material to withstand  
the internal pressure of the equipment to be tested.

DATE: 2-2-94  
BY: [Signature]  
FOR: [Signature]

NAME: [Signature]

MY CERTIFICATE EXPIRES:

THIS CERTIFICATE IS NOT VALID UNLESS  
THESE REQUIREMENTS ARE MET





WELDED PIPE SECTION  
REPORT OF CHEMICAL ANALYSIS AND PHYSICAL TESTS

NINTH & LOWELL STREETS - NEWPORT, KY. 41072  
606-222-0000

TEXAS PIPE & SUPPLY, INC.  
2330 HOLMES ROAD  
HOUSTON 77051  
TX

Date 12/18/92  
Customer Number C18071  
TUBULAR WALL THICKNESS 15694  
DATE 12/16/92  
BILL OF LADING NUMBER B25404  
VEHICLE NO. C&O 356426  
MADE AND MANUFACTURED IN U.S.A.

TEXAS PIPE & SUPPLY INC.  
SP DELIVERY PIERCE JCT. TRACK  
SPIN 774190  
HOUSTON, TEXAS.

API-5L X42 GRADE

.237 4-1/2"

HEAT		C0643		C0607		A6017		B4882		A6021	
LOT		121592D		121592D		121592D		121592D		121592D	
C.	.1800	.1800	.1700	.1700	.1700	.1800	.1900	.1900	.1900	.1900	.1900
Mn.	.5200	.5300	.5100	.5400	.5800	.5600	.5000	.4900	.5000	.4900	.4900
P.	.0060	.0060	.0070	.0070	.0070	.0070	.0050	.0040	.0070	.0080	.0080
S.	.0040	.0060	.0100	.0120	.0070	.0090	.0040	.0070	.0070	.0080	.0080
SL.	.1600	.1500	.1500	.1600	.1700	.1800	.1500	.1600	.1700	.1600	.1600
Cu.	.2000	.2000	.1000	.1000	.1700	.1600	.0900	.3100	.3100	.3000	.3000
NI.	.0600	.0700	.0400	.0400	.0600	.0600	.0300	.0600	.0700	.0700	.0700
Cr.	.1000	.1000	.0500	.0500	.0700	.0700	.0400	.0900	.0900	.0900	.0900
Mo.	.0200	.0200	.0100	.0100	.0200	.0200	.0100	.0300	.0300	.0300	.0300
Al.	.0290	.0310	.0370	.0360	.0340	.0350	.0340	.0310	.0330	.0350	.0350
V.	.0010	.0010	.0010	.0010	.0010	.0010	.0010	.0010	.0010	.0010	.0010
Ca.	.0040	.0040	.0020	.0010	.0034	.0040	.0054	.0043	.0042	.0027	.0027
TENSILE		64200		64900		65500		65900		80500	
YIELD		53300		53200		56800		55000		65900	
ELC		39		37		37		38		32	
TEST PRESS		2650		2650		2650		2650		2650	
FLAT		OK		OK		OK		OK		OK	

CERTIFICATION STATEMENT  
This is to certify that the product described on this report was produced in accordance with the specifications and all analyses were performed by the laboratory of this company. The analyses were performed by the laboratory of this company. The analyses were performed by the laboratory of this company.

12/18/95



KOPPEL DIVISION  
AMBRIDGE DIVISION  
PHONE: 412-843-7100  
FAX: 412-847-4071



TUBULAR  
TEST REPORT

ORDER NO: T3234

SOLD TO:  
TEXAS PIPE & SUPPLY CO., INC.  
ATTN: PURCHASING DEPARTMENT  
2330 HOLMES ROAD  
HOUSTON, TX 77051

SHIP TO:  
TEXAS PIPE & SUPPLY CO., INC.  
HOUSTON, TX SPIN 774190  
S. PIERCE JUNCTION TEAM  
TRACK

CURT P.O.  
79335 H

SPECIFICATION (#) ASTM A53-93 SA/A106-93 API 5L GR B/X42

O.D.	WALL	WT/FT	GRADE	QUALITY
3.5000	.216	7.58	1023K	SEAMLESS HOT FINISH

CONDITION (SPECIAL):

HEAT #	C	Mn	P	S	Si	Cr	Ni	Mo	Cu	Al	SN	CB	V	CA
414640 L	.19	.51	.013	.010	.24	.12	.10	.02	.19	.022			.003	
P	.19	.51	.014	.010	.24	.12	.10	.02	.19	.024			.003	
V	.19	.51	.013	.009	.24	.12	.10	.02	.19	.022			.003	
P	.19	.51	.013	.010	.24	.12	.10	.02	.19	.022			.003	
P	.19	.51	.012	.009	.24	.12	.10	.02	.19	.022			.003	

LOT #	SPECIMEN	YIELD KSI	TENSILE KSI	ELONG 2"	R/A	BHN	ROCK WELL	GRAIN SIZE	WGT LOSS F S
	.750" STR	48.8 49.6	71.2 72.3	36 36				7	

MATERIAL MELTED AND MANUFACTURED IN USA

OTHER

HYDRO - 3000 PSI. 5 SEC HOLD  
FLATS - OK  
CERTIFIED NACE MR0175

MILL TEST REPORTS FURNISHED BY  
TEXAS PIPE & SUPPLY CO. INC.

CUSTOMER

CUSTOMER PO#

DATE

QUALITY ASSURANCE

MATERIAL WAS NOT EXPOSED TO MERCURY DURING PROCESSING.

NO WELDING OR WELD REPAIR PERFORMED ON THIS MATERIAL.

TEST REPORT

Koppel Steel Corporation

Ambridge Tube Operations  
P.O. Box 410  
Ambridge, PA 15003

Koppel Steel Operations/General Office  
P.O. Box 770  
Beaver Falls, PA 15004  
Phone 412-843-7100, Fax 412-847-6122

FROM 412-847-6256

07-26-94 10:00 AM




MILL TEST REPORTS FURNISHED BY  
TEXAS PIPE & SUPPLY CO., INC.

CUSTOMER \_\_\_\_\_

CUSTOMER PO # \_\_\_\_\_

KOPPEL DIVISION  
AMBRIDGE DIVISION  
PHONE: 412-843-7100  
FAX: 412-847-4071



A Subsidiary of KSI Group Inc.

TUBULAR  
TEST REPORT

ORDER NO: T1561

SOLD TO:  
TEXAS PIPE & SUPPLY CO., INC.  
ATTN: PURCHASING DEPARTMENT  
2330 HOLMES ROAD  
HOUSTON, TX 77051

SHIP TO:  
TEXAS PIPE & SUPPLY CO., INC.  
RAIL SPIN NO. 774190  
HOUSTON, TX

CUST P.O.  
80477H

SPECIFICATION (B): ASTM A53-93A SA/A106-93/API 5L GR B/X42  
CERTIFIED NACE MR0175

O.D.	WALL	WT/FT	GRADE	QUALITY
3.5000	.216	7.58	1023K	SEAMLESS HOT FINISH

CONDITION (SPECIAL):

HEAT #	C	Mn	S	P	SI	Cr	Ni	Mo	Cu	Al	BN	CS	V	CA
416412	.20	.31	.011	.006	.26	.07	.07	.01	.15	.021			.001	
L	.19	.49	.009	.006	.25	.08	.07	.01	.15	.020			.001	
P	.18	.49	.010	.006	.25	.08	.07	.01	.15	.020			.001	
P	.19	.50	.009	.006	.26	.07	.08	.01	.15	.020			.001	
P	.18	.49	.010	.006	.25	.07	.07	.01	.14	.019			.001	

LOT #	SPECIMEN	YIELD KSI	TENSILE KSI	ELONG 2"	R/A	BHN	ROCK WELL	GRAIN SIZE	MAGNAFLUX F B
	.750 " HTR	51.8 52.7	72.3 73.3	36 34				7	

MATERIAL MELTED AND MANUFACTURED IN USA

OTHER

HYDRO - 3000 PSI 5 SEC HOLD  
FLATS - OK

1b

DATE

10-11-94

*Lauri R. Bissette*

QUALITY ASSURANCE

MATERIAL WAS NOT EXPOSED TO MERCURY DURING PROCESSING.  
NO WELDING OR WELD REPAIR PERFORMED ON THIS MATERIAL.

TEST REPORT

Koppel Steel Corporation

Ambridge Tube Operations  
P.O. Box 410  
Ambridge, PA 16003

Koppel Steel Operations/General Offices  
P.O. Box 753  
Beaver Falls, PA 15010  
Phone 412-843-7100, Fax 412-847-4335



ALL INFORMATION TEST REPORT

48M 10-41-54

THIS IS TO CERTIFY THAT THE PRODUCT DESCRIBED HEREIN WAS MFG., SAMPLED, TESTED, AND/OR INSPD. IN ACCORDANCE WITH THE SPECIFICATION AND FULFILL REQUIREMENTS IN SUCH RESPECTS. APPROVED BY OFFICE OF: U.S. DABKOWSKI MGR. MET. & C.A. USS TUBULAR PRODUCTS

P.O. DATE	PURCHASE ORDER NO.	INVOICE NO.
SHIPMENTS NO.	WILL ORDER NO.	
R13523	D589600-01	1
VEHICLE IDENT	L12240	

USS TUBULAR PRODUCTS

DATE 02/23/93

WALL TEST REPORTS FURNISHED BY TEXAS PIPE & SUPPLY CO., INC. CUSTOMER MPM CUSIO: ER PO # DTF-100213

O.	SIZE	MATERIAL DESCRIPTION		WALL	SPECIFICATION & GRADE	WALL	YIELD STRENGTH	TENSILE STRENGTH	ELONGATION	GRADE	FLAT	BEND
		MIN	MAX									
1	3/8	154	106	ASTM A53-70 GR. B ASME SA53 GR. B 89ED. 91 ADD ASTM A106 GR. B 91 GR. B ASME SA106 GR. B 89ED. 91 ADD. API 5L GR. B/X42 10TH ED. 11/92	BML	NC6003	3000	74400	35.0	3/4		OK
		104	107	ASTM A53-70 GR. B ASME SA53 GR. B 89ED. 91 ADD ASTM A106 GR. B 91 GR. B ASME SA106 GR. B 89ED. 91 ADD. API 5L GR. B/X42 10TH ED. 11/92	BML	NC6011	3000	75700	32.0	3/4		OK

HEAT NO.	TYPE	C	MIN	P	S	SI	CU	NI	CR	MO	BM	AL	N	V	B	TH	CB	CO	CE	HRB
NG6003	HEAT	18	106	012	005	28	02	01	04	01				001					36	76.0
NG6003	PROD	19	107	008	007	25	01	01	06	01				001					35	73.0
NG6011	HEAT	17	103	011	011	26	02	01	05	01				001					35	73.0
NG6011	PROD	17	106	007	012	25	02	01	05	01				001					35	73.0

END OF DATA THIS SHEET \*\*\*



MILL TEST REPORTS FURNISHED BY  
TEXAS PIPE & SUPPLY CO., INC.

CUSTOMER \_\_\_\_\_

CUSTOMER PO # \_\_\_\_\_

KOPPEL DIVISION  
AMBRIDGE DIVISION  
PHONE: 412-343-7100  
FAX: 412-847-4071

TUBULAR

TEST REPORT

A Subsidiary of KSC Group Inc.

ORDER NO: T3554

SOLD TO:  
TEXAS PIPE & SUPPLY CO., INC.  
ATM: PURCHASING DEPARTMENT  
2330 HOLMES ROAD  
HOUSTON, TX 77051

SHIP TO:  
TEXAS PIPE & SUPPLY CO., INC.  
RAIL SPIN 774190  
HOUSTON, TX

CUST P.O.  
90477H

SPECIFICATION(S): ASTM A536 SA/A53-93a/SA/A106-93/API 5L GR B/X42

O.D. 2.3750	WALL .154	WT/FT 3.65	GRADE 1023H	QUALITY SEAMLESS HOT FINISH
----------------	--------------	---------------	----------------	--------------------------------

CONDITION (SPECIAL):

HEAT #	C	Mn	S	P	Si	Cr	Ni	Mo	Cu	Al	SN	CB	V	CA
418527	.19	.52	.009	.006	.25	.09	.09	.02	.18	.018				
L	.19	.52	.010	.006	.28	.10	.09	.02	.18	.020				
P	.19	.53	.010	.006	.27	.09	.09	.02	.19	.019				
P	.18	.53	.010	.006	.27	.09	.09	.02	.18	.018				
P	.19	.52	.010	.006	.28	.09	.09	.02	.18	.020				

LOT #	SPECIMEN	YIELD KSI	TENSILE KSI	ELONG 2"	R/A	BHN	ROCK WELL	GRAIN SIZE	HAZARDOUS FLUX
	.750 " BTR	54.9 54.4	73.8 73.1	33 38				7	

MATERIAL MELTED AND MANUFACTURED IN USA

OTHER

HYDRO - 3000 PSI 5 SEC HOLD  
BENDS - OK  
CERTIFIED NACE MR0175  
MILL TEST REPORTS FURNISHED BY  
TEXAS PIPE & SUPPLY CO. INC.  
CUSTOMER \_\_\_\_\_  
CUSTOMER PO# \_\_\_\_\_

DATE

QUALITY ASSURANCE

9-21-94 *Laurie R. Bennett*

MATERIAL HAS NOT EXPOSED TO MERCURY DURING PROCESSING.  
NO WELDING OR WELD REPAIR PERFORMED ON THIS MATERIAL.

TEST REPORT

Koppel Steel Corporation

Ambridge Tube Operations  
P.O. Box 410  
Ambridge, PA 15003  
Phone 412-343-7100

Koppel Steel Operations/Corporate Office  
P.O. Box 780  
Beverly Hills, PA 15010

TOTAL P.02





# HACKNEY, INC.

A DIVISION OF TRINITY INDUSTRIES  
P.O. Box 568887 • 2525 Stemmons Freeway  
Dallas, Texas 75356-8887 • (214) 634-2850

YOUR ORDER NUMBER	REFERENCE	CUSTOMER NO.	INVOICE NO.	INVOICE DATE	DATE SHIPPED
0099-002979	C139654	454634	819873	12/02/94	12/02/94

SOLD TO: M & M SUPPLY CO  
PO BOX 548  
DUNCAN OK 75533

SHIP TO: M & M SUPPLY  
3923 OKLAHOMA AVE  
HODDWARD, OK 73801

## CERTIFIED TEST REPORT

ITEM	QUANTITY	DESCRIPTION/SPECIFICATION	HEAT CODE
30		3X1 STD CONC. A234-92A/SA234 WPB	XGJ
31	12	A106B 09 / N69975 3X2 STD CONC A234-92A/SA234 WPB	LYH1
32	6	A106B 09 / L82128 4X2 STD CONC A234-92A/SA234 WPB	MAL1
33	12	A106B 09 / C86737 4X3 STD CONC A234-92A/SA234 WPB	MAL1
		A106B 09 / C86737 STRESS RELIEVED AT 1200 F	

ITEM CODE	C	Mn	P	S	Si	Cr	Mo	Cu	Ni	V	Nb	CE
XGJ	.18	.82	.010	.009	.26	.06	.01	.01	.02	.00	.00	.33
LYH1	.18	.83	.011	.004	.26	.06	.02	.03	.02	.00	.00	.34
MAL1	.18	.78	.010	.010	.24	.03	.01	.01	.00	.00	.00	.32
MAL1	.18	.78	.010	.010	.24	.03	.01	.01	.00	.00	.00	.32

PHYSICAL PROPERTIES					CHARPY RESULTS				
HEAT CODE	TENSILE * KSI	YIELD KSI	% Elong. IN 2"	Hard- ness HB	Size MM x 10 mm	Temp. °F	FOOT POUNDS	LATERAL EXPANSION	% SHEAR
XGJ	70.0 L	45.3	37.0	197					
LYH1	62.1 L	42.5	26.0	125					
MAL1	67.80L	47.7	31.0	121					
MAL1	67.80L	47.7	31.0	121					

\*L = LONGITUDINAL, T = TRANSVERSE, R = ROUND, S = STRIP

HACKNEY is a domestic manufacturer, and these items conform to the following specifications as they apply:

FITTINGS: ASTM A234 WPB, ASME SA234 WPB, ANSI B16.9, B16.28, AND NACE MR01-75.

FLANGES: ASTM A105 AND A516-70, ASME SA105, ANSI B16.5, and NACE MR01-75.

These items were heat treated as required by the applicable specification. They also conform to the requirements of Parts 192 and 195, Title 49, Code of Federal Regulations. All welded fittings are welded by certified welders to ASME Section X, and 100% radiographically examined per Article 2, ASME Section V. All fittings conform with the requirements of Paragraph UG-11, Section VII, Division 1 of the ASME code. Hackney weld caps meet ASME Division 1, Section VIII Pressure Vessel Code Requirements, Paragraph UCS-79d. We certify these flanges and fittings capable of passing a hydrostatic test compatible with their rating, and the above figures are correct as contained in the records of the Company. Hardness testing and stamping are per NACE MR01-75.





# HACKNEY, INC.

A DIVISION OF TRINITY INDUSTRIES  
P.O. Box 568887 • 2525 Stemmons Freeway  
Dallas, Texas 75356-8887 • (214) 634-2850

YOUR ORDER NUMBER	REFERENCE	CUSTOMER NO.	INVOICE NO.	INVOICE DATE	DATE SHIPPED
0099-002979	C139654	454634	819873	12/02/94	12/02/94

SOLD TO: M & M SUPPLY CO  
PO BOX 548  
DUNCAN OK 75533

SHIP TO: M & M SUPPLY  
3923 OKLAHOMA AVE  
HODDWARD, OK 73801

## CERTIFIED TEST REPORT

TRI 414 (R 12/93)

ITEM	QUANTITY	DESCRIPTION/SPECIFICATION	HEAT CODE
28	7	8 STD WC A234-92A/SA234 WPB A516-70 TUSCL 5B92016	AZKD
29	3	10 STD WC A234-92A/SA234 WPB A516-70 TUSCL 5B92016	AZJH
30	8	3X1 STD CONCL A234-92A/SA234 WPB A106B 09 / N76276	XCV
30		3X1 STD CONCL A234-92A/SA234 WPB A106B 15 / 76406	XCC

### CHEMICAL ANALYSIS

CODE	C	Mn	P	S	Si	Cr	Mo	Cu	Ni	V	Nb	CE
AZKD	.24	1.07	.020	.009	.22	.03	.00	.03	.02	.00	.00	.43
AZJH	.24	1.07	.020	.009	.22	.03	.00	.03	.02	.00	.00	.43
XCV	.17	1.03	.004	.003	.22	.04	.01	.02	.02	.00	.00	.36
XCC	.19	1.00	.026	.009	.29	.01	.01	.01	.00	.00	.00	.36

### PHYSICAL PROPERTIES

### CHARPY RESULTS

HEAT CODE	TENSILE * KSI	YIELD KSI	% Elong. IN 2"	Hard- ness HB	Size MM x 10 mm	Temp. °F	FOOT POUNDS	LATERAL EXPANSION	% SHEAR
AZKD	80.1 T	55.7	33.0	197 MAX					
AZJH	85.0 T	58.6	32.0	197 MAX					
XCV	74.4 L	48.1	35.0	197 MAX					
XCC	75.4 L	51.5	31.0	197 MAX					

\*L = LONGITUDINAL, T = TRANSVERSE, R = ROUND, S = STRIP

HACKNEY is a domestic manufacturer, and these items conform to the following specifications as they apply:

FITTINGS: ASTM A234 WPB, ASME SA234 WPB, ANSI B16.9, B16.28, AND NACE MR01-75.  
FLANGES: ASTM A105 AND A516-70, ASME SA105, ANSI B16.5, and NACE MR01-75.

were heat treated as required by the applicable specification. They also conform to the requirements of Parts 192 and 195, Title 49, Code of Federal Regulations. All welded fittings are welded by certified welders to ASME Section X, and 100% radiographically examined per Article 2, ASME Section V. All are in accordance with the requirements of Paragraph UG-11, Section VII, Division 1 of the ASME code. Hackney weld caps meet ASME Division 1, Section VIII Pressure Vessel Code Requirements, Paragraph UCS-79d. We certify these flanges and fittings capable of passing a hydrostatic test compatible with their rating, and that above figures are correct as contained in the records of the Company. Hardness testing and stamping are per NACE MR01-75.





# HACKNEY, INC.

A DIVISION OF TRINITY INDUSTRIES  
P.O. Box 568887 • 2525 Stemmons Freeway  
Dallas, Texas 75356-8887 • (214) 634-2850

YOUR ORDER NUMBER	REFERENCE	CUSTOMER NO.	INVOICE NO.	INVOICE DATE	DATE SHIPPED
0099-002979	C139654	454634	819873	12/02/94	12/02/94

OLD TO: H & M SUPPLY CO  
PO BOX 548  
DUNCAN OK 75533

SHIP TO: H & M SUPPLY  
3923 OKLAHOMA AVE  
HOODWARD, OK 73801

## CERTIFIED TEST REPORT

ITEM	QUANTITY	DESCRIPTION/SPECIFICATION	HEAT CODE
24	6	3 600 RF. BLIND A105-93B/SA105 A105-04 / HD787 NORMALIZED AT 1650 F	0894CE
25	6	2 STD WC A234-92A/SA234 WPB A516-70 40 / J3543	AZFD
26	5	3 STD WC A234-92A/SA234 WPB A516-70 40 / K0848	AZHP
27	5	6 STD W/C A234-92A/SA234 WPB A516-70 TUSCL 88551000	AZJH

CHEMICAL ANALYSIS													
CODE	C	Mn	P	S	SI	Cr	Mo	Cu	Ni	V	Nb		CE
0894CE	.25	1.04	.015	.027	.26	.08	.03	.28	.08	.00	.00		.47
AZFD	.17	1.01	.027	.010	.27	.09	.00	.03	.11	.02	.00		.37
AZHP	.15	1.08	.010	.009	.31	.06	.01	.03	.09	.01	.00		.35
AZJH	.26	1.19	.013	.014	.22	.01	.01	.02	.02	.00	.00		.46

PHYSICAL PROPERTIES							CHARPY RESULTS			
HEAT CODE	TENSILE * KSI	YIELD KSI	% Elong. IN 2"	Hard- ness HB	Size MM x 10 mm	Temp °F	FOOT POUNDS	LATERAL EXPANSION	% SHEAR	
0894CE	93.5 % R.A.	55.6 =54.0	27.0	159						
AZFD	73.7 T	54.0	29.0	197 MAX						
AZHP	73.9 T	54.3	29.0	197 MAX						
AZJH	79.1 T	52.1	33.0	197 MAX						

L - LONGITUDINAL T - TRANSVERSE R - ROUND S - STRIP

HACKNEY is a domestic manufacturer, and these items conform to the following specifications as they apply:

FITTINGS: ASTM A234 WPB, ASME SA234 WPB, ANSI B16.9, B16.28, AND NACE MR01-75.

FLANGES: ASTM A105 AND A516-70, ASME SA105, ANSI B16.5, and NACE MR01-75.

These items were heat treated as required by the applicable specification. They also conform to the requirements of Parts 192 and 195, Title 49, Code of Federal Regulations. All welded fittings are welded by certified welders to ASME Section VIII, and 100% radiographically examined per Article 2, ASME Section V. All are in accordance with the requirements of Paragraph UG-11, Section VII, Division 1, of the ASME code. Hackney weld caps meet ASME Division 1, Section VIII Pressure Vessel Code Requirements, Paragraph UCS-79d. We certify these flanges and fittings capable of passing a hydrostatic test compatible with their rating, and that the above figures are correct as contained in the records of the Company. Hardness testing and stamping are per NACE MR01-75.





# HACKNEY, INC.

A DIVISION OF TRINITY INDUSTRIES  
P.O. Box 568887 • 2525 Stemmons Freeway  
Dallas, Texas 75356-8887 • (214) 634-2850

YOUR ORDER NUMBER	REFERENCE	CUSTOMER NO.	INVOICE NO.	INVOICE DATE	DATE SHIPPED
0099-002979	C139654	454634	821782	12/16/94	12/16/94

OLD TO: M & M SUPPLY CO  
PO BOX 548  
DUNCAN OK 75533

SHIP TO: M & M SUPPLY  
3923 OKLAHOMA AVE  
HOODWARD, OK 73801

## CERTIFIED TEST REPORT

API 414 (R 12/93)

ITEM	QUANTITY	DESCRIPTION/SPECIFICATION	HEAT CODE
42	100	3 STD LR 90 A234-92A/SA234 WPB A106B 09 / L82412 STRESS RELIEVED AT 1200 F	LZA1
51	3	8 STD TEE A234-92A/SA234 WPB A106B 07 / H60403 STRESS RELIEVED AT 1200 F	LZE1
53	6	4 XH LR 90 A234-92A/SA234 WPB A106B 09 / U82173 STRESS RELIEVED AT 1200 F	HCY1

### CHEMICAL ANALYSIS

CODE	C	Mn	P	S	SI	Cr	Mo	Cu	Ni	V	Nb	CE
LZA1	.19	.80	.011	.009	.26	.04	.01	.02	.02	.00	.00	.34
LZE1	.14	.70	.006	.007	.17	.09	.02	.18	.09	.00	.00	.30
HCY1	.17	.78	.012	.010	.23	.03	.01	.01	.01	.00	.00	.31

### PHYSICAL PROPERTIES AND MECHANICAL PROPERTIES

HEAT CODE	TENSILE KSI	YIELD KSI	% Elong. IN 2"	Hard- ness HB	Size MM x 10 mm	Temp °F	FOOT POUNDS	LATERAL EXPANSION	% SHEAR
LZA1	67.5 L	45.1	26.0	127					
LZE1	67.4 L	46.9	36.0	114					
HCY1	70.2 L	51.9	32.0	137					

L = LONGITUDINAL, T = TRANSVERSE, R = ROUND, S = STRIP

HACKNEY is a domestic manufacturer, and these items conform to the following specifications as they apply:

FITTINGS: ASTM A234 WPB, ASME SA234 WPB, ANSI B16.9, B16.28, AND NACE MR01-75.

FLANGES: ASTM A105 AND A516-70, ASME SA105, ANSI B16.5, and NACE MR01-75.

were heat treated as required by the applicable specification. They also conform to the requirements of Parts 192 and 195, Title 49, Code of Federal Regulations. All welded fittings are welded by certified welders to ASME Section X, and 100% radiographically examined per Article 2, ASME Section V. All are in accordance with the requirements of Paragraph UG-11, Section VII, Division 1 of the ASME code. Hackney weld caps meet ASME Division 1, Section VIII Press Vessel Code Requirements, Paragraph UCS-79d. We certify these flanges and fittings capable of passing a hydrostatic test compatible with their rating, and the above figures are correct as contained in the records of the Company. Hardness testing and stamping are per NACE MR01-75.





# HACKNEY, INC.

A DIVISION OF TRINITY INDUSTRIES  
P.O. Box 568887 • 2525 Stemmons Freeway  
Dallas, Texas 75356-8887 • (214) 634-2850

YOUR ORDER NUMBER	REFERENCE	CUSTOMER NO.	INVOICE NO.	INVOICE DATE	DATE SHIPPED
0099-002979	C139654	454634	824237	01/12/95	01/12/95

LD TO: M & M SUPPLY CO  
PO BOX 548  
DUNCAN OK 75533

SHIP TO: M & M SUPPLY  
3923 OKLAHOMA AVE  
WOODHARD, OK 73601

## CERTIFIED TEST REPORT

1414 (R 12/93)

ITEM	QUANTITY	DESCRIPTION/SPECIFICATION	HEAT CODE
35	12	6X4 STD CONC A234-92A/SA234 WPB A106B 07 / H90368 STRESS RELIEVED AT 1200 F	MCA1
41	80	2 STD LR 90 A234-92A/SA234 WPB A106B 09 / L82414 STRESS RELIEVED AT 1200 F	MCH1
45	18	3 STD TEE A234-92A/SA234 WPB A106B 09 / L82412 STRESS RELIEVED AT 1200 F	LZA1
46	18	4 STD TEE A234-92A/SA234 WPB A106B 09 / X85246 STRESS RELIEVED AT 1200 F	MCO1

CHEMICAL ANALYSIS													
CODE	C	Mn	P	S	Si	Cr	Mo	Cu	Ni	V	Nb		CE
MCA1	.14	.64	.007	.006	.21	.08	.02	.14	.09	.00	.00		.25
MCH1	.17	.60	.010	.008	.24	.05	.01	.02	.03	.00	.00		.32
LZA1	.19	.80	.011	.009	.26	.04	.01	.02	.02	.00	.00		.34
MCO1	.16	.78	.014	.007	.22	.03	.01	.01	.01	.00	.00		.32

PHYSICAL PROPERTIES							CHARPY RESULTS			
HEAT CODE	TENSILE * KSI	YIELD KSI	% Elong. IN 2"	Hard- ness HB	Size MM x 10 mm	Temp 1/2"	FOOT POUNDS	LATERAL EXPANSION	% SHEAR	
MCA1	62.6 L	43.7	38.0	107						
MCH1	70.2 L	45.9	35.5	197 MAX						
LZA1	67.5 L	45.1	26.0	127						
MCO1	68.1 L	46.7	47.6	197 MAX						

L = LONGITUDINAL, T = TRANSVERSE, R = ROUND, S = STRIP

HACKNEY is a domestic manufacturer, and these items conform to the following specifications as they apply:

FITTINGS: ASTM A234 WPB, ASME SA234 WPB, ANSI B16.9, B16.28, AND NACE MR01-75.

FLANGES: ASTM A105 AND A516-70, ASME SA105, ANSI B16.5, and NACE MR01-75.

These items were heat treated as required by the applicable specification. They also conform to the requirements of Parts 192 and 195, Title 49, Code of Federal Regulations. All welded fittings are welded by certified welders to ASME Section VIII, and 100% radiographically examined per Article 2, ASME Section V. All are in accordance with the requirements of Paragraph UG-11, Section VII, Division 1 of the ASME code. Hackney weld caps meet ASME Division 1, Section VIII Pressure Vessel Code Requirements, Paragraph UCS-79d. We certify these flanges and fittings capable of passing a hydrostatic test compatible with their rating, and that the above figures are correct as contained in the records of the Company. Hardness testing and stamping are per NACE MR01-75.





# HACKNEY, INC.

A DIVISION OF TRINITY INDUSTRIES  
P.O. Box 568887 • 2525 Stemmons Freeway  
Dallas, Texas 75356-8887 • (214) 634-2850

YOUR ORDER NUMBER	REFERENCE	CUSTOMER NO.	INVOICE NO.	INVOICE DATE	DATE SHIPPED
0099-002979	C139654	454634	826204	01/25/95	01/25/95

OLD TO: M & M SUPPLY CO  
P.O. BOX 548  
DUNCAN, OK 75533

SHIP TO: M & M SUPPLY  
3923 OKLAHOMA AVE  
HOODWARD, OK 73301

## CERTIFIED TEST REPORT

ITEM	QUANTITY	DESCRIPTION/SPECIFICATION	HEAT CODE
10	6	2.150 RF SD A105 26 / 494-3223	1194CR
34	12	6X3 STD CONC A106B 07 / H90368	MCA1
		A105-938/SA105 AS FORGED A234-92A/SA234 WPB STRESS RELIEVED AT 1200 F	

CHEMICAL ANALYSIS													CE
CODE	C	Mn	P	S	SI	Cr	Mo	Cu	Ni	V	Nb		
1194CR	.19	.83	.019	.029	.21	.05	.02	.22	.10	.00	.00		.36
MCA1	.14	.64	.007	.006	.21	.08	.02	.14	.09	.00	.00		.23

PHYSICAL PROPERTIES						CHARPY RESULTS			
HEAT CODE	TENSILE KSI	YIELD KSI	% Elong IN 2"	Hardness HB	Size MM x 10 mm	Temp F	FOOT POUNDS	LATERAL EXPANSION	% SHEAR
1194CR	80.4	46.5	31.0	135					
MCA1	62.6	43.7	38.0	107					

L = LONGITUDINAL T = TRANSVERSE R = ROUND S = STRIP

HACKNEY is a domestic manufacturer, and these items conform to the following specifications as they apply:

FITTINGS: ASTM A234 WPB, ASME SA234 WPB, ANSI B16.9, B16.28, AND NACE MR01-75.

FLANGES: ASTM A105 AND A516-70, ASME SA105, ANSI B16.5, AND NACE MR01-75.

were heat treated as required by the applicable specification. They also conform to the requirements of Parts 192 and 195, Title 49, Code of Federal Regulations. All welded fittings are welded by certified welders to ASME Section V, and 100% radiographically examined per Article 2, ASME Section V. All are in accordance with the requirements of Paragraph UG-11, Section VII, Division 1, of the ASME Code. Hackney weld caps meet ASME Division 1, Section VIII Pressure Vessel Code Requirements, Paragraph UCS-79d. We certify these flanges and fittings capable of passing a hydrostatic test compatible with their rating, and that the above figures are correct as contained in the records of the Company. Hardness testing and stamping are per NACE MR01-75.



JAN-31-95 TUE 12:47

GRINNELL SUPPLY CO.

7079456

P. 02



# HACKNEY, INC.

A DIVISION OF TRINITY INDUSTRIES  
P.O. Box 56687 • 2525 Stemmons Freeway  
Dallas, Texas 75356-6507 • (214) 634-2850

YOUR ORDER NUMBER	REFERENCE	CUSTOMER NO.	INVOICE NO.	INVOICE DATE	DATE SHIPPED
0026945	C116345	297190	974358	11/16/93	11/16/93

TO: GRINNELL CORP.  
4118 SOUTH 70TH AVE.  
TULSA OK 74145

SHIP TO: GRINNELL CORP  
4118 SOUTH 70TH EAST AVE.  
TULSA, OK 74145

## CERTIFIED TEST REPORT

EM	QUANTITY	DESCRIPTION/SPECIFICATION		HEAT CODE
7	20	6 15C RF WN STD A105 26 / 493-1631	A105-92 / SA105 AS FORGED	0593CA
7		6 15C RF WN STD A105 26 / 493-1247	A105-92 / SA105 AS FORGED	0593AX

CHEMICAL ANALYSIS													CE
HEAT CODE	C	Mn	P	S	Si	Cr	Mo	Cu	Ni	V	Nb		
0593CA	.22	.34	.020	.023	.23	.07	.02	.27	.09	.00	.00		.40
0593AX	.25	.33	.034	.029	.24	.12	.02	.34	.09	.00	.00		.45

PHYSICAL PROPERTIES						CHARPY RESULTS			
HEAT CODE	TENSILE * KSI	YIELD KSI	% Elong. IN 2"	Hard- ness HB	Size MM x 10 mm	Temp. °F	FOOT POUNDS	LATERAL EXPANSION	% SHEAR
0593CA	74.4	56.0	30.0	150					
	% R.A. =	58.0							
0593AX	84.3	48.9	28.0	156					
	% R.A. =	52.0							

\* LONGITUDINAL, T = TRANSVERSE

0593CA 0593AX CONFORM TO THE REQUIREMENTS OF NACE MR0175-92

all items were heat treated in accordance with the requirements of the specification to which they were manufactured.

we hereby certify that the products covered by this report comply with the applicable requirements of ASTM and/or ASME specifications, as noted for each item.

we hereby certify that the above figures are correct, as contained in the records of the Company.



# Tank Corrosion Protection




**Glidden**

## PROTECTIVE MAINTENANCE COATINGS DATA

For Industrial Use and Professional Application Only  
Rust Inhibitive Polyamide Epoxy Coating

### GLID-GUARD® Corrosion Resistant HS Epoxy No. 5465 Series

For Interior-Exterior Metal

Read Label and Material Safety Data Sheet Prior to Use.  
See other cautions on last page. DSF1-0690

#### PRODUCT DESCRIPTION

GLID-GUARD Corrosion Resistant HS Epoxy is a low VOC, high solids, two package polyamide epoxy coating intended for direct application to interior and exterior metal. It is rust inhibitive and resistant to moisture and many chemicals. The product's excellent penetrating properties result in superior adhesion.

This product is an excellent choice for application to metal when surface preparation is limited to Hand Tool or Power Tool Cleaning. It is also suitable for use as a high build intermediate coat in heavy-duty industrial systems and may be used as a topcoat when the color and sheen are acceptable.

Like most epoxy coatings, GLID-GUARD Corrosion Resistant HS Epoxy will chalk and lose gloss on exposure to direct sunlight but will maintain excellent film integrity and continue to provide excellent protection to the substrate.

#### PRODUCTS AVAILABLE

GLID-GUARD Corrosion Resistant HS Epoxy Red No. 5465 (Component A)  
GLID-GUARD Corrosion Resistant HS Epoxy Gray No. 5466 (Component A)  
GLID-GUARD Corrosion Resistant HS Epoxy White No. 5467 (Component A)  
GLID-GUARD Corrosion Resistant HS Epoxy Aluminum Mastic No. 5468 (Component A)  
GLID-GUARD Corrosion Resistant HS Epoxy Curing Agent No. 5469 (Component B)

NOTE: Refer to Protective Maintenance Coatings Data sheet Section 8 No. 29 for detailed information on Aluminum Mastic No. 5468.

#### TYPICAL USES

Ideal for use as a primer and intermediate build coat on storage tanks, structural steel, machinery and equipment in the food processing industries, chemical industries, petroleum refineries, paper mills, marine structures, mining industries, waste water treatment facilities, and general industrial buildings.

#### PRODUCT ADVANTAGES

- Low VOC
- Rust inhibitive
- Tolerates surface moisture during application
- Long term flexibility—does not become brittle with age
- Hard, tough film
- Free of toxic amine curing agents
- Excellent alkali and solvent resistance
- High film build
- Protection in fresh or salt water immersion
- Lead and chromate free
- Simple 1 to 1 mixing ratio

#### SERVICE CONDITIONS

Do not use for potable water or direct food contact service. Do not use on unprimed wood or unprimed gypsum wallboard. Do not use on surfaces that may be subjected to severe abrasion.

Will withstand 250°F. continuous and 300°F. intermittent dry heat. The color may change as these limits are approached, but the film will remain intact.

#### REGULATORY RESTRICTIONS

The application VOC of this product may be restricted by law in some locations. Application VOC is increased by thinning with solvent. If the application VOC is restricted to 420 gm/liter (3.5 lbs./gal.), thinning must not exceed 7% by volume (9 fl.oz./gal.) with GLID-GUARD Epoxy Solvent No. 5568. If the application VOC is restricted to 450 gm/liter (3.75 lbs./gal.) or higher or is not restricted, thinning with up to 10% (12 fl.oz./gal.) is permissible.

#### TECHNICAL DATA

All data shown is for a mixed (converted) gallon unless otherwise noted

\*Product No.—5467/5469  
Generic Type—Polyamide epoxy  
Color—White  
Gloss—Approximately 30 @ 60°  
Percent Solids by Weight—71% ± 1%  
Percent Solids by Volume—54% ± 1%  
Theoretical Coverage per 1.0 dry mil (1.9 mils wet)—866 sq.ft./gallon

\*\*Recommended Film Build/Coverage (theoretical, unreduced)

Minimum—3.0 mils dry (5.5 mils wet)  
289 sq.ft./gallon

Typical—5.0 mils dry (9.5 mils wet)  
173 sq.ft./gallon

Maximum—8.0 mils dry (15.0 mils wet)  
108 sq.ft./gallon

(wet mil figures rounded to the nearest 0.5 mil)

When computing working coverage, allow for application losses, surface irregularities, any solvent addition, etc.

Percent Vehicle (Solids) by Weight—28% ± 1%

Percent Pigment by Weight—43% ± 1%

Percent Solvent by Weight—29% ± 1%

Viscosity—95-100 KU

Weight per Gallon—11.1 lbs.

Flash Point (Closed Cup)—Base No.

5467—46°F. Curing Agent No.

5469—43°F.

VOC—3.24 lbs/gallon (388 gm/liter) unreduced

3.48 lbs/gallon (417 gm/liter) reduced

7% by volume with No. 5568

3.56 lbs/gallon (427 gm/liter) reduced

10% by volume with No. 5568

Drying Time (70°F., 50% Relative Humidity)

Touch—1-2 hours

Handle—7 hours

Recoat—7 hours

Full Cure—7 days

Reduction Solvent—GLID-GUARD Epoxy

Solvent No. 5568 (10% maximum)

Clean-Up Solvent—GLID-GUARD Epoxy

Solvent No. 5568 or MEK

Type of Cure—Converted

Mixing Ratio (Base/Curing Agent) by

Volume—1 to 1

Induction Before Use—30 minutes @

material temperatures >70°F.

60 minutes @ material temperatures

60°-70°F.

Pot Life—4 hours @ 70°F.

Tinting—DO NOT TINT

\*Compositional data for other products in this series may differ slightly.

\*\*As measured over the peaks of any surface projections or blast profile.



# GLID-GUARD Corrosion Resistant HS Epoxy (Continued)

## MATERIAL PREPARATION

Do not add unspecified curing agents or solvents or mix with other paints. Do not tint.

Thoroughly mix the selected GLID-GUARD Corrosion Resistant HS Epoxy (Component A) and Corrosion Resistant HS Epoxy Curing Agent No. 5469 (Component B) separately, then combine the two components in equal parts by volume using power agitation. If agitation equipment is not explosion proof, provide good ventilation to prevent build up of vapors. Allow the combined material to stand 30 minutes before use. Extend this induction (standing) time to 60 minutes if the surface or material temperature is 60°–70°F. After the induction period has elapsed, add up to 10% by volume GLID-GUARD Epoxy Solvent No. 5568 (12 fluid ounces per gallon of combined material) if necessary for application and mix thoroughly (see "Regulatory Restrictions" above). Pot life is 4 hours at 70°F., less at higher temperatures.

## SURFACE PREPARATION

All surfaces should be clean, dry and free of all contaminants.

### Metal Surfaces

#### Ferrous Metal

Surface preparation is dependent upon service conditions as follows:

##### TYPE A—AGGRESSIVELY CORROSIVE

This exposure is an area characterized by aggressive chemical fumes, mists or dusts or other chemical contaminants that combine with high humidity and condensed moisture to corrode zinc at rates greater than one mil per year. The need to limit air pollution and protect personnel generally confines chemical concentrations of such an aggressive nature to within a radius of about 50 yards from the source of contamination. For Type A environments and all immersion exposures, White Metal Blast Cleaning (SSPC-SP5-82 and SSPC-SP-COM) is recommended. For splash and spillage, Near-White Blast Cleaning (SSPC-SP10-82 and SSPC-SP-COM) is satisfactory.

##### TYPE C—CORROSIVE

This exposure is less destructive than Type A exposure and is characterized by moderately aggressive chemical fumes, mists, or dusts that combine with moisture and high humidity to corrode zinc at rates less than one mil per year. Type A exposure may, in many instances, become Type C exposure outside of a radius of about 50 yards from the source of contamination for a limited further distance. For Type C environments, Near-White Blast Cleaning (SSPC-SP10-82 and SSPC-SP-COM) is recommended.

##### TYPE M—MODERATE

This exposure is generally outdoors and is characterized by normal atmospheric weathering and/or light or moderate concentrations of chemical fumes that combine with humidity and condensed moisture to corrode carbon steel at rates less than three mils per year. Zinc in this exposure is virtually free of corrosion. Light to moderate chemical fume concentrations in indoor areas without excessive humidity may produce similar conditions. For Type M environments, Commercial Blast Cleaning (SSPC-SP6-82 and SSPC-SP-COM) is recommended. Where exposure is normal weathering only, Brush-Off Blast Cleaning (SSPC-SP7-82 and SSPC-SP-COM), Power Tool Cleaning (SSPC-SP3-82 and SSPC-SP-COM), or Hand Tool Cleaning (SSPC-SP2-82 and SSPC-SP-COM) will provide excellent service.

##### TYPE P—PROTECTED (ARCHITECTURAL)

In this category, surfaces are generally indoors and are not subjected to high humidity or chemical contaminants that will attack paint or steel. For Type P environments, Brush-Off Blast Cleaning (SSPC-SP7-82 and SSPC-SP-COM), Power Tool Cleaning (SSPC-SP3-82 and SSPC-SP-COM), or Hand Tool Cleaning (SSPC-SP2-82 and SSPC-SP-COM) will provide the sound substrate needed for proper adhesion.

### Galvanized and Aluminum

Sandblasting is unnecessary. Remove oil, grease, dirt, dust and chemical contaminants using the prescribed cleaning methods.

### Poured Concrete

Verify that all surface projections have been leveled. Remove all oils, grease, dust, dirt and chemical contaminants with the prescribed cleaning methods. Remove weak or powdery surfaces by acid etching or brush abrasive blasting. Dull very smooth concrete by similar means. Prime with this product thinned 10% by volume with GLID-GUARD Epoxy Solvent No. 5568 (see "Regulatory Restrictions" above).

### Previously Painted Surfaces

The performance of this coating over previously painted surfaces is directly influenced by the type, age and condition of the old finish. For best results in immersion situations, completely remove any old coating and prepare as for new surfaces. For non-immersion service, remove all blistered, loose or peeling old coating. Hard or glossy finishes should be dulled by sanding or other abrasive means. Apply to a test area; if wrinkling or lifting occurs after overnight drying, remove the old coating.

## APPLICATION

Do not apply when air or substrate temperature is below 60°F.

For best appearance, primary application should be by airless or conventional spray. Use brush or roller application for small areas only—flow and leveling will be limited. Spray application is required to obtain 5.0 mils dry in a single coat. Application by brush or roller will limit the film thickness to 3.0-4.0 mils dry per coat.



## SPRAY APPLICATION

### Airless Spray

Glidden equipment is specified.

Gun: ASM 400 Fluid Tip: 315-619

Pump: GLIDDEN 500™, GLIDDEN 750™, GLIDDEN 750GE™, GLIDDEN FORMULA ONE™

Pressure: 2000-2500 psi

NOTE: All pumps must be kept well away from areas where vapors from this product may collect.

### Conventional Spray

Gun: Binks Model 18, Binks 2001, or equivalent

Needle: Binks Model 63A or equivalent

Fluid Nozzle: Binks Model 63PB or equivalent

Air Cap: Binks Model 63B or equivalent

## COVERAGE

Typical coverage (calculated, unreduced) is 173 sq.ft./gallon at 5.0 mils dry (9.5 mils wet). Minimum film thickness is 3.0 mils dry (5.5 mils wet) 289 sq.ft./gallon, maximum is 8.0 mils dry (15.0 mils wet) 108 sq.ft./gallon. All wet mil figures are rounded to the nearest 0.5 mil. When computing working coverage, allow for application losses, surface irregularities, any solvent addition, etc.

## DRYING

Dries to touch in 1-2 hours, to handle in 7 hours, to recoat in 7 hours, to full cure in 7 days at 70°F., 50% relative humidity. Allow longer drying times under cooler or more humid conditions.

## CLEAN-UP

Clean all equipment immediately after use with GLID-GUARD Epoxy Solvent No. 5568 or methyl ethyl ketone.

## TOPCOATS

### SOLVENT EPOXY FINISHES

GLID-GUARD Corrosion Resistant HS Epoxy No. 5465/5469 series

GLID-GUARD Chemical Resistant Epoxy No. 5240/5242 series

GLID-GUARD High Solids Epoxy No. 5430/5434 series

GLID-GUARD® DURAMASTER™ High Solids Epoxy No. 5295/5299 series

GLID-GUARD® METALLITE™ High Build Epoxy No. 5475/5476

GLID-GUARD Cold Cure Epoxy No. 5281/5265

GLID-GUARD Coal Tar Epoxy No. 5270/5271

GLID-GUARD Hi-Build Coal Tar Epoxy No. 5273/5274

GLID-GUARD® GLID-TILE™ Epoxide No. 5550/5552 series

NU-PON® COTE Color Coat No. 7240/7200 series

### WATER-BORNE EPOXY FINISHES

GLID-GUARD Acrylic Epoxy No. 5277/5278

GLID-GUARD Amine-Adduct Epoxy No. 5585/5586 series

### POLYURETHANE FINISHES

GLID-THANE™ ONE Moisture Cured Polyurethane No. 6100 series

GLID-THANE II Acrylic Polyurethane No. 6200/6252 series

GLID-GUARD High Solids Acrylic/Polyester Urethane No. 5410/5414 series

### SOLVENT VINYL FINISHES

GLID-GUARD Double Build Vinyl No. 5514

GLID-GUARD® VINYL-COTE™ High Build No. 5522

### WATER-BORNE ACRYLIC FINISHES

LIFEMASTER™ PRO Hi Performance Acrylic No. 6900 series

LIFEMASTER PRO HB Acrylic No. 5440 series





The Sherwin-Williams Company  
Cleveland, OH 44115

## Hi-Mil Sher-Tar™ Epoxy—B69B40/B60V40

### Description

Hi-Mil Sher-Tar Epoxy is a high build, polyamide cured epoxy coal tar coating. Can be applied at high film thicknesses in one coat.

### Characteristics

Color:	Black
Coverage:	
Recommended:	45-68 sq. ft./gal.
Theoretical, no loss:	24-35 mils wet; 16-24 mils dry
Curing Mechanism:	1090 sq. ft./gal. @ 1.0 mil dry
Drying Schedule: (temperature & humidity dependent)	Crosslink Polymerization
@ 77°F & 50% RH @ 29 mils wet:	
To Touch:	8-10 hours
Tack Free:	48 hours
To Recoat:	
@ 50-60°F	Minimum 24 hours
@ 60-80°F	16 hours
@ 80-100°F	8 hours
@ 100-120°F	1 hour
Finish:	Semi-Gloss
Flash Point:	110°F (Pensky-Martens Closed Cup)
Number of Components (Ratio):	2 (3:1)
Pot Life:	4 hours @ 77°F
Sweat-In time:	30 minutes @ 77°F
Solvent/Reducer:	Reducer #54
Vehicle Type:	Polyamide Epoxy
VOC:	306 grams/liter; 2.55 lbs/gal
Volume Solids:	68 ± 2%
Weight Solids:	77 ± 2%
Weight per Gallon:	10.3 ± .3 lbs

### Application

#### Application Conditions

Temperature (air, surface, material): 50-100°F  
(surface temp. at least 5°F above dew point)  
Relative humidity: 90% max.  
**Brush:** No reduction required. Use a natural bristle brush.  
**Roller:** No reduction required. Use a 3/4" woven nap with phenolic core.  
Small areas may be brushed or rolled, but film build will be lower.

#### Airless spray:

Pump 30:1  
Pressure 2500 - 3000 psi  
Tip .031"  
Hose 3/8" - 1/2" I.D.  
Filter none  
Reduction ... up to 1 quart per gallon of catalyzed material

#### Conventional spray:

Gun Binks 18 gun  
Air Pressure 60 psi  
Fluid Pressure 40 psi  
Fluid/Air Nozzle 6G/63 PB  
Hose 1/2" I.D.

### Specifications

Substrate	Surface Preparation (See pages 2 through 5)
Primer (see primer page for additional details) .....	Page #
Aluminum, atmospheric only .....	SSPC SP7/SW-18
No primer needed	
Concrete .....	SW-6, A
No primer needed	
Galvanized Metal, atmospheric only ...	SSPC SP7/SW-18
No primer needed	
Steel, atmospheric only .....	SSPC SP6/SW-17
Zinc Clad Primer .....	115-120
Tile-Clad II Epoxy Primer .....	109
Steel, immersion .....	SSPC-SP5/SW-16
No primer needed	

### Performance Specifications

#### Physical Properties:

Abrasion Resistance (ASTM D4060, 1000 cycles) ...	101 mg
Direct Impact (ASTM G14) ...	>80 inch lbs.
Dry Heat Resistance (ASTM D2485) ...	250° F
Elcometer Adhesion (ASTM D4341) ...	600 psi
Flexibility (ASTM D522, 180° bend) .....	1" mandrel
Moisture Condensation Resistance (ASTM D4585) 1000 hours	
Pencil Hardness (ASTM D3363) .....	4H
Salt Fog Resistance (ASTM B117) .....	1000 hours
Thermal Shock (ASTM D2246) .....	250 cycles
Wet Heat Resistance (not immersion) ...	120° F

#### Resistance Guide:

(Resistance to fumes, splash and spillage - not immersion-ASTM D3912)

Acid Salt Solutions .....	Severe
Aliphatic Hydrocarbons .....	Severe
Alkalies .....	Severe
Alkali Salt Solutions .....	Severe
Aromatic Hydrocarbon Solvents .....	Moderate
Chlorinated Solvents .....	Moderate
Fresh Water .....	Immersion
Salt Water .....	Immersion
Glycol ethers, alcohols, formaldehyde .....	Severe
Inorganic Acids .....	Severe
Oils (cutting, vegetable, lubricating) .....	Severe
Organic Acids .....	Severe
Oxygenated Solvents .....	Moderate



# WISco, INC.

11811 North Fwy., Suite 670  
Houston, Texas 77060  
(713) 820-8066

Page 1 of 1  
Report Date 11/25/93  
Report No. 002

Customer USPCI Attn: Bruce Patterson  
Order No. 12418-30-46 Dated \_\_\_\_\_ Rev. \_\_\_\_\_ Dated \_\_\_\_\_  
Mat'l Destination Lone Mt. Facility, Waynoka, OK Req. Date \_\_\_\_\_  
Shipment Date is now unknown As of 11/25/93 Changed from \_\_\_\_\_  
Inspector estimated shipment date \_\_\_\_\_ Order is 90 percent completed  
Vendor Delta Tank Co. Order No. \_\_\_\_\_ Dated \_\_\_\_\_  
Manufacturer Lide Tank Co. Phone 817-562-5526  
Shop Location Mexia, TX Shop Order TKEB2 & TKEF4  
Inspector's Contact Mr. Billy Lide Position Customer Contact  
Report is: x Interim \_\_\_\_\_ Final \_\_\_\_\_ Regarding: x Inspection \_\_\_\_\_ Expediting \_\_\_\_\_ Status \_\_\_\_\_  
MATERIAL DESCRIPTION:

Two (2) tanks - one 6' 4" OD x 12' 0" high; one 5' 0" OD X 12' 0" high  
To specifications of USPCI and API 650

STATUS OF ORDER: Engineering, Materials, Fabrication, Inspection, Completion

Writer's visit to vendor on Wednesday, 11/24/93, was to witness sandblast, initial paint coating and first coat of Sher-Tar epoxy.

Sandblast was verified to be as required SSPC-SP6, but due to immediate change in weather conditions, writer informed vendor's Mr. Billy Lide, that painting and/or epoxy coating at this time was not recommended. He also agreed. Items are to be reblasted and inspection of first coatings is to be on Monday, 11/29/93 or Tuesday, 11/30/93, weather permitting.

A spark or holiday test is to be performed on Sher-Tar epoxy along with micro-test of same and external coating of Glidden epoxy #5466-3 to 4 mils. A requirement of 7 mils on Sher-Tar epoxy will also be verified.



INSPECTOR:  
INSPECTION ORDER:

Dub Greer *[Signature]*  
12418-30-46



Post-It™ brand fax transmittal memo 7671 # of pages > 8

To <u>BRUCE PATTERSON</u>	From <u>Luana</u>
Co.	Co.
Dept.	Phone #
Fax #	Fax #

, INC.

70

Page 1 of 1  
Report Date 12/3/93  
Report No. 003

Customer USPCI Attn: Bruce Patterson  
Order No. 12418-30-46 Dated \_\_\_\_\_ Rev. \_\_\_\_\_ Dated \_\_\_\_\_  
Mat'l Destination Lone Mt. Facility, Waynoka, OK Req. Date \_\_\_\_\_  
Shipment Date is now ready now As of 12/3/93 Changed from \_\_\_\_\_  
Inspector estimated shipment date ready now Order is 100 percent completed  
Vendor Delta Tank Co. Order No. \_\_\_\_\_ Dated \_\_\_\_\_  
Manufacturer Lide Tank Co. Phone 817-562-5526  
Shop Location Mexia, TX Shop Order TKE-B2 & TKE-F4  
Inspector's Contact Mr. Billy Lide Position Vice President  
Report is: Interim x Final Regarding: x Inspection \_\_\_\_\_ Expediting \_\_\_\_\_ Status \_\_\_\_\_  
MATERIAL DESCRIPTION:

Two (2) tanks - one 6' 4" OD x 12' 0" high; one 5' 0" OD X 12' 0" high  
To specifications of USPCI and API 650

STATUS OF ORDER: Engineering, Materials, Fabrication, Inspection, Completion

Writer's visits to vendor on Tuesday, 11/30/93, and Friday, 12/3/93, inspection functions were performed as follows:

11/30/93

First coat of Sher-Tar epoxy (internally) was micro-tested. Results were noted to be acceptable with an average of 3.5 mils.

Sandblast was verified to be SSPC-SP-6 with anchor pattern of 3.5 to 4.0. A Keane-Tator surface comparator was used to verify anchor pattern on each vessel.

12/3/93

Writer verified Sher-Tar epoxy to have mil thickness ranging from 7.2 to 14.8 on each vessel.

External gray primer paint range from 3.5 to 6.5 on each vessel.

A holiday test was performed internally on each vessel and found to be satisfactory. Items were released for shipment.

INSPECTOR: Dub Greer  
INSPECTION ORDER: 12418-30-46



# Piping Corrosion Protection





The Sherwin-Williams Company  
Cleveland, OH 44115

## Kem Kromik Universal Metal Primer—B50Z Series

### Description

Kem Kromik Universal Metal Primer is a low VOC, modified alkyd resin primer designed for use over iron and steel substrates. Can be used as a "universal" primer under high performance topcoats and is also suitable as a "barrier" coat over conventional coatings which would normally be attacked by strong solvents in high performance coatings.

### Characteristics

**Color:** Brown, Off White, and Buff

**Coverage:**  
Recommended: 204-273 sq. ft./gal.  
6-8 mils wet; 3-4 mils dry

Theoretical, no loss: 818 sq. ft./ gal. @ 1.0 mil dry

**Curing Mechanism:** Oxidation

**Drying Schedule:** (temperature & humidity dependent)

@ 6 mils wet, 50% R. H. and:

	@ 40°F	@ 77°F	@ 110°F
To Touch:	2 hours	30 minutes	15 minutes
Tack Free:	2½ hours	1 hour	20 minutes

To Recoat with:	2½ hours	1 hour	45 minutes
alkyds	2½ hours	1 hour	45 minutes
epoxy	36 hours	16 hours	16 hours
urethane	36 hours	16 hours	16 hours

**Finish:** 0-10 units @ 85°

**Flash Point:** 80°F (Pensky-Martens Closed Cup)

**Solvent:** Xylene

**Vehicle Type:** Phenolic Alkyd

**VOC:** 415 grams/liter; 3.45 lbs./gal.

**Volume Solids:** 51 ± 2%

**Weight Solids:** 72 ± 2%

**Weight per Gallon:** 12.5 ± .35 lbs

Meets the performance requirements, not necessarily composition, of Federal Specification: TT-P-664D

### Application

#### Application Conditions

**Temperature** (air, surface, material): 40-120°F  
(surface temp. at least 5°F above dew point)

**Relative humidity:** 85% maximum.

**Brush:** No reduction required. Use a natural bristle brush.

**Roller:** No reduction required. Use a 3/8" woven nap with phenolic core.

#### Airless spray:

**Pressure:** 1800-3000 psi

**Tip:** .015" - .019"

**Hose:** 1/4" I.D.

**Filter:** 60 mesh

**Reduction:** normally no reduction required

### Specifications

Substrate	Surface Preparation (See pages 2 through 5)
Steel	SSPC SP2/ SW-14

2 topcoats are recommended over all primers/substrates.

Suggested topcoats	Page
A-100 Exterior Latex Finishes	24-26
Corothane II Satin Polyurethane	32
DTM Acrylic Coatings	34
Heavy Duty Epoxy	49
Hi-Bild Aliphatic Polyurethane	50
Hi-Solids Polyurethane	53
Industrial Enamel	54
Industrial Enamel HS	55
Metalatex Semi-Gloss Coating	64
ProMar Interior & Exterior Alkyd & Latex Topcoats	73-95
Sher-Tile Epoxy	100
Silver-Brite Aluminum	102
Tile-Clad High Solids Epoxy	108
Water Based Catalyzed Epoxy	111

### Performance Specifications

#### Physical Properties:

Abrasion Resistance (ASTM D4060, 1000 cycles)	250 mg
Direct Impact (ASTM G14)	70 inch lbs.
Dry Heat Resistance (ASTM D2485)	200° F
Elcometer Adhesion (ASTM D4541)	260 psi
Exterior Durability (with chalk)	Good
Flexibility (ASTM D522, 180° bend)	1/4" mandrel
Moisture Condensation Resistance (ASTM D4585)	500 hrs.
Pencil Hardness (ASTM D3383)	H
Salt Fog Resistance (ASTM B117)	500 hours
Thermal Shock (ASTM D2246)	5 cycles

#### Resistance Guide:

(Resistance to fumes, splash and spillage - not immersion-ASTM D3912).	
Acid Salt Solutions	Moderate
Aliphatic Hydrocarbons	Moderate
Alkalies	Not recommended
Aromatic Hydrocarbon Solvents	Light
Chlorinated Solvents	Not recommended
Fresh Water	Moderate
Salt Water	Moderate
Glycol ethers, alcohols, formaldehyde	Moderate
Oils (cutting, vegetable, lubricating)	Severe
Organic Acids	Light
Oxygenated Solvents	Not recommended



## Secondary Containment Corrosion Protection



# Dudick Inc.

1818 Miller Parkway  
Streetsboro, Ohio 44241

(216) 562-1970  
(216) 562-7638 FAX

## Primer 67/67C

100 % SOLIDS, MOISTURE-TOLERANT  
EPOXY PRIMER FOR STEEL AND  
CONCRETE 3-4 MILS (0.1 mm)

### RECOMMENDED APPLICATIONS

Concrete Substrates  
Steel Substrates  
Primer for Epoxy and Urethane  
Floor Toppings, Linings, Coatings and Grout

### PHYSICAL PROPERTIES

Tensile Strength	2,000 - 2,500 PSI
ASTM C-307	
Tensile Elongation	12-25 %
ASTM C-307	
Adhesion to Concrete	Cohesive Failure
ASTM D-4541	of concrete
Adhesion to Steel	2,200-2,500 PSI
ASTM D-4541	
Electrical Properties	< 25,000 ohms
NFPA #99,	
ASTM F-150	

### SPECIFICATIONS

Primer shall be 3-4 mils thick, 100% solids bisphenol A epoxy cured with an amine adduct as manufactured by Dudick Inc. Primer 67 shall be brush, roller or spray applied in accordance with the manufacturer's recommended practices. Primer 67C must be spray or roller applied.

### PRIMER 67

Primer 67 is designed to prevent abrasive-blasted steel from developing rust bloom prior to the application of a Dudick coating or lining system. For maximum performance all steel surfaces should be primed, but primer may not be needed for mild, non-immersion service. Concrete, however, must always be primed to aid in the "wetting out" required for good adhesion.

### PRIMER 67C - CONDUCTIVE PRIMER

Primer 67C is a 100% solids, two component epoxy primer designed to be used over concrete whenever the coating or lining system must be spark tested.

### ESTIMATING QUANTITIES AND ORDER BILL OF MATERIAL

SQUARE FEET PER GALLON		
	CONCRETE	STEEL
Primer 67	150-200	250-300
Primer 67C	100-150	———

Quantities shown are for estimating purposes only. Actual field usage may vary. Primer 67/67C are available in 1 and 2 gallon units.

### APPLICATION INSTRUCTIONS

#### SURFACE PREPARATION

**Metal:** Surfaces must be abrasive blasted to an appropriate finish.

Immersion and heavy spillage service: White Metal SSPC SP-5 or NACE #1, 3.0 mil minimum profile.

Heavy, non-immersion service (i.e. fumes and spillage): Near white SSPC SP-10 or NACE #2, 2.0 mil minimum profile.

Atmospheric service: Commercial SSPC SP-6 or NACE #3, 2.0 mil minimum profile.



**Concrete:** Concrete must be abrasive blasted or etched with muriatic acid (Solution of 1 part 20° Be HCl and 1 part water) to remove surface laitance and other contaminants. Concrete must be free of curing compounds and form release agents. Surface texture should be similar to 40-60 grit sandpaper. The prepared surface should have a minimum tensile strength of 250 PSI per ASTM D-4541.

All concrete substrates must be checked for moisture prior to product application using the Plastic Sheet Test, ASTM D-4263.

Additional surface preparation will be required if a 40-60 grit texture is not achieved and the surface laitance not completely removed after a single application of acid or with the first mechanical preparation procedure.

Abrasive blasting removes laitance, exposing honeycombs or voids beneath the surface which must be filled with Scratch Coat 100. (Refer to separate product bulletin)

## APPLICATION SPECIFICATIONS

Substrate temperature for both concrete and metal must be between 50°F and 110°F.

Relative humidity must not exceed 90%.

Substrate temperature must be 5°F above the Dew Point.

## PRIMER 67/67C MIX RATIOS:

### Primer 67

Component A	1 gal.
Component B	1 gal.

### Primer 67C

Component A	1 gal.
Component B	95 fl. oz.

\*Pre-mix primer 67C Component A for 1-2 minutes to disperse the conductive fillers prior to adding the correct amount of Component B.

Primer 67C must be spray or roller applied. Use brush application for small touch-up or repair work only.

The pot life of the mixed Primer 67/67C will depend on the temperature. To prevent material waste and avoid damage to equipment, do not open and mix more material than can be used according to the following table:

## PRIMER 67/ 67C POT LIFE

TEMPERATURE	POT LIFE
50°F	90 min.
75°F	60 min.
90°F	30 min.

At 75° F the pot life and thin film cure of Primer 67 can be decreased by the addition of Accelerator #1 as follows:

Ozs./Accelerator #1 per mixed gal. Primer 67	Pot Life	Thin Film Cure
3-4	36 min.	4 hrs.
6-7	15 min.	2 hrs.

Using 7 ounces of accelerator #1 per mixed gallon of Primer 67, the thin film cure @ 40° F is reduced to 8 hours.



## PRIMING

**Metal:** Mix the pre-measured units of Component A with Component B. Prime all metal surfaces to be coated with Primer 67 at 3-4 mils WFT.

**Concrete:** Mix the pre-measured units of Component A with Component B. Prime all concrete surfaces to be coated with either Primer 67 or 67C at 3-4 mils WFT. The basecoat may be applied over primer that is "tacky". Do not allow the primer to puddle.

Important - With all epoxies after priming and before each additional coat, examine the surface for amine blush (oily film). If present, remove by washing with warm water and detergent.

## Cure Cycle for Primer 67/67C:

Temperature	Minimum Recoat Time	Maximum Recoat Time
50°F	12 hrs.	8 Days
75°F	6-8 hrs.	5 Days
90°F	4-5 hrs.	3 Days

To optimize intercoat adhesion, we recommend application of the basecoat while the primer is tacky. If this is not possible, the above recoat times must be observed. Exposure of the primer to direct sunlight will considerably shorten the recoat times. If recommended recoat times are exceeded, consult a Dudick Representative; sanding or abrasive blasting may be required before the coating, lining or floor topping can be applied.

## CLEANING

Use S-10 Cleaning Solvent to clean tools and equipment. **DO NOT USE ACETONE.**

## SHIPPING

Primer 67/67C Component A's are non-regulated plastic liquids. Primer 67/67C Component B's are flammable corrosives with a flash point of 106°F (Setaflash) and carry both a red warning label and a black and white warning label. S-10 Cleaning Solvent is a flammable liquid with a flash point of 52°F (PMCC) and carries a red warning label.






## STORAGE

**Warning:** All Dudick products classified by DOT labels as either white, yellow or red labels, must not be mixed or stored together as an explosive reaction can occur. All products should be stored in a cool, dry area away from open flames, sparks or other hazards.

When properly stored in their original, unopened containers, Primer 67/67C components have a one year shelf life.

## SAFETY

**M.S.D.S - Sheets must always be read before using products.** Primer 67/67C are intended for application by experienced, professional personnel. Dudick Inc. can supply supervision to help determine that the surface has been properly prepared, the ingredients correctly mixed, and the materials properly and safely applied.



If materials are to be applied by your own personnel or by a third party contractor, please be sure that they are aware of the following safety precautions:

- Exposure to resins and hardeners through direct skin contact and/or inhalation may cause severe dermatitis reactions in some people. Cleanliness of the skin and clothing is critical and must be of paramount concern.
- Fumes are flammable and heavier than air. Proper ventilation should be maintained to minimize breathing of concentrated fumes.
- Suitable respirators should be used during application.
- Safety glasses, gloves, and suitable protective clothing must be worn at all times during application.
- If contact with hardeners occurs, remove any clothing involved and flush the skin with flowing water. Discard the clothing. Do not attempt to wash and reuse it. Primer liquids can be removed with S-10 Cleaning Solvent, MEK, or lacquer thinner. **DO NOT USE ACETONE.**

- Keep open flames and sparks away from the area where materials are being mixed and applied.

- If a rash occurs, remove the individual from the work area and seek a physician's care for dermatitis.

- In case of eye contact, flush with water for at least 15 minutes and consult a physician.

- If swallowed, do not induce vomiting; call a physician immediately.

### Note:

Dudick Inc. ("Dudick") warrants all goods of its manufacture to be as represented in its catalogs and that the application of its products by its employees or sub-contractors shall be performed in a workmanlike manner. Dudick's obligation under this warranty shall be the repair to and replacement of any applications which its examination shall disclose to be defective. Dudick makes no warranty concerning the suitability of its product for application to any surface, it being understood that the goods have been selected and the application ordered by the purchaser. DUDICK INC. MAKES NO WARRANTY, EXPRESS OR IMPLIED, THAT THE GOODS SHALL BE MERCHANTABLE OR THAT THE GOODS ARE FIT FOR ANY PARTICULAR PURPOSE. THE WARRANTY OF REPAIR OR REPLACEMENT SET FORTH HEREIN IS EXCLUSIVE AND IN LIEU OF ALL OTHER WARRANTIES ARISING BY LAW OR OTHERWISE; AND DUDICK INC. SHALL NOT BE LIABLE FOR INCIDENTAL OR CONSEQUENTIAL DAMAGES, INCLUDING BUT NOT LIMITED TO LOST PROFITS, DOWNTIME, DAMAGES TO PROPERTY OF THE PURCHASER OR OTHER PERSONS, OR DAMAGES FOR WHICH THE PURCHASER MAY BE LIABLE TO OTHER PERSONS, WHETHER OR NOT OCCASIONED BY DUDICK'S NEGLIGENCE. This warranty shall not be extended, altered or varied except by written instrument signed by Dudick and Purchaser.



# Dudick Inc.

Dudick Incorporated  
Corrosion-Proof Products  
1818 South Wason Drive  
Streetsboro, Ohio 44241

216-562-1970  
FAX No. 216-562-7638

## Protecto-Coat 200

ELASTOMERIC, SPRAY APPLIED, ENVIRONMENTALLY SAFE, URETHANE COATING. 40-60 MILS (1-1 1/2 mm)

Protecto-Coat 200 is a high solids aromatic polyurethane coating with superior elongation. It is especially suited to bridge cracks in concrete.

## RECOMMENDED APPLICATIONS

Secondary Containment Areas	Spent Liquor Storage Tanks
Process Floors	Food Processing
Railroad Tank Cars	Pharmaceutical
Underground Pipes & Tanks - Exterior	Breweries
Thickener Tanks & Mechanisms	Structural Steel

## CHEMICAL RESISTANCE

Protecto-Coat 200 provides a tough, durable surface and will withstand splash and spills of many inorganic and organic acids as well as alkalis. Also resistant to aliphatic solvents.

## PHYSICAL PROPERTIES

Protecto-Coat 200	40 Mil Basecoat	20 Mil Topcoat
Tensile Strength (PSI) ASTM C307	2,400-2,600	2,200-2,500
Elongation*	225% to 250%	50 to 60%
Shore D Hardness	40-45	65-70
Abrasion Resistance CS 17 wheels/1000 cycles x 1000 gm load	10 mg weight loss	32 mg weight loss
Solids by Volume	80%	100%

\*At 60% elongation the chemical resistant topcoat begins to surface crack while the basecoat will continue to elongate to 250% extension.

## SPECIFICATIONS

Coating shall be 40-60 mils thick, 80-100% solids aromatic urethane resin, consisting of 2 basecoats and a topcoat of 20 mils each, manufactured by Dudick, Inc. Materials shall be brush-, roller- or spray- applied in accordance with manufacturer's recommended practices.

## THE PROTECTO-COAT 200 SYSTEM

The Protecto-Coat 200 system uses a moisture tolerant primer and two or three coats of elastomeric thermosetting urethane resins to protect concrete and steel.

**Primer 67** is designed to prevent abrasive-blasted steel from developing rust bloom prior to the application of a Protecto-Coat System. For maximum performance, all steel surfaces should be primed, but primer may not be needed for mild, non-immersion service. Concrete, however, must always be primed to aid in the "wetting out" required for good bonding.

Protecto-Coat 200 is applied in three coats by brush, roller or spray. The elastomeric basecoat is applied in two 25 mil applications to achieve a nominal 40 mils DFT. The chemical resistant topcoat is applied in a single 20 mil application. Total thickness shall be a nominal 60 mils.

Post-It™ brand fax transmittal memo 7671		# of pages >
To <i>Common Owners</i>	From <i>R.O.H.</i>	
Co.	Co.	
Dept.	Phone # <i>Mid-America</i>	
Fax # <i>697-3592</i>	Fax #	



## ESTIMATING QUANTITIES AND ORDER BILL OF MATERIAL

SQUARE FEET PER GALLON		
	CONCRETE	STEEL
Primer 67	150-200	250-300
Protecto-Coat 200		
2 Base Coats Actual		
35-40 mil DFT	25	25
Top Coat Actual		
15-20 mil DFT	60	60
S-10 Solvent	500	500

Quantities shown are for estimating purposes only. Actual field usage may vary.

## APPLICATION INSTRUCTIONS

### SURFACE PREPARATION

**Metal:** For immersion service, abrasive blast to a white metal finish and a 2-4 mils minimum profile according to SSPC 5 or NACE No. 1. For fume or splash service, abrasive blast to a near-white metal finish according to SSPC 10 or NACE No. 2.

Atmospheric service: Commercial SSPC 6 or NACE No. 3.

**Concrete:** Concrete must be abrasive-blasted or etched with muriatic acid (solution of 1 part 20° Be HCl and 1 part water) to remove surface laitance and other contaminants. Concrete must be free of curing compounds and form release agents. Surface texture should be similar to 40-60 grit sandpaper. The prepared surface should have a tensile strength of between 250 and 300 PSI per ASTM D4541.

Additional surface preparation will be required if a 40-60 grit texture is not achieved and the surface laitance not completely removed after a single application of acid or with the first mechanical preparation procedure.

If, after abrasive blasting, honeycombs/voids appear on the concrete, these have to be filled with a suitable material. Contact a Dudick representative for this information.

Recommended application temperatures should be between 40°F and 90°F substrate temperature. Do not apply Protecto-Coat 200 over concrete exposed to direct sunlight during the warming trend of the concrete as measured by surface temperature. To do so may lead to blistering, pinholes, or wrinkling in the coating due to outgassing of air in the concrete and high substrate temperatures. Wait for a definite downturn or cooling trend within the concrete as again measured by surface temperature. If this is not possible consult a Dudick representative for alternatives such as double priming.

### PRIMING

**Metal:** For maximum performance, prime all steel surfaces with Primer 67, mixed with appropriate amount of hardener to 3-4 mils. For mild non-immersion service, priming of steel may be omitted.

**Concrete:** Concrete must be primed to aid in the "wetting out" required for good bonding. Mix Component A with Component B in the premeasured units for 2-3 minutes and apply by brush, roller, or spray. We recommend the basecoat be applied over slightly tacky or tack-free primer. Do not allow the primer to puddle.

### Protecto-Coat 200 Mix Ratio:

Protecto-Coat 200 Basecoat	
Component A*	1 Gallon
Component B*	54 fl. ozs.

\*Premeasured units by weight

### Protecto-Coat 200 Topcoat

Protecto-Coat 200 Top Coat Comp. A*	1 Gal.
Component B*	54 fl. oz.

\*Premeasured quantities by weight

### BASECOAT

Add appropriate amount of hardener for each gallon of Protecto-Coat Liquid and mix thoroughly until uniform color is achieved. Apply a 25 mil wet (20 mil DFT) basecoat using spray, brush or roller. Allow basecoat application to cure to at least a "firm" or slightly "tacky" feel before applying the second 25 mil wet (20 mil DFT) basecoat. Brush or roller may require several coats to achieve desired thickness.



Horizontal surfaces may be basecoated in one application by applying 50 mils wet (40 mil DFT) in a single coat.

### TOPCOAT

Add appropriate amount of hardener for each gallon of Protecto-Coat Liquid and mix thoroughly until a uniform color is achieved. Apply a 20-mil-thick topcoat using spray, brush or roller.

### Cure Cycle for Protecto-Coat 200

TEMPERATURE	RECOAT TIME	CURE TIME
50°	48 Hrs.	96 Hrs.
70°	24 Hrs.	48 Hrs.
90°	16 Hrs.	36 Hrs.

If these recoat times are exceeded, consult a Dudick representative: sanding or abrasive blasting may be required before the next coat. Recoat times are dramatically reduced when the coating is exposed to direct sunlight.

Single Component Airless Spray Equipment — Graco King 45-to-1 spray pump or equivalent. Use Graco Golden Mastic Gun or Graco No. 207945 Gun with airless adapter equipped with a Reverse-A-Clean tip and a tip size between .035-.041. Spray hose should be 1/2" or 3/8" ID. Available inlet pressure must be a minimum of 100 psi.

Brush or roller application may require additional coats to meet specified dry film thickness.

Pot life of the opened and mixed Protecto-Coat 200 will depend on the temperature at the work site. To prevent material waste and avoid damage to equipment, do not open and mix more material than can be used according to the following table:

TEMPERATURE	POT LIFE
50°F	120 Min.
75°F	60 Min.
90°F	45 Min.

Do not attempt to store mixed material. Residual material should be properly disposed of at the end of each work period.

Where immersion service is required, spark test the coating with a 5,000 to 7,000 volt AC spark tester. Mark and repair all pinholes. Use Protecto-Coat liquid mixed with the appropriate amount of hardener. Retest only the repairs.

### CLEANING

Use S-10 Solvent to clean tools and equipment.

### SHIPPING

Protecto-Coat 200 Topcoat A and B and Protecto-Coat 200 Basecoat A are classified as plastic liquids and are non-regulated.

Protecto-Coat 200 Basecoat B is combustible. Primer 67 Component B is corrosive and carries a black and white warning label. Primer 67 Component A is classified as a plastic liquid and is nonregulated, while S-10 Cleaning Solvent is red label liquid with a flash point of 52°F (PMCC).

### STORAGE

**Warning:** All Dudick products classified by DOT labels as either white, yellow or red labels must not be mixed or stored together as an explosive reaction may occur.

When stored in a cool and dry location, Protecto-Coat 200 ingredients have a one-year shelf life. Exposure to excessive heat may cause premature gelling and reduce working time.

### SAFETY

M.S.D.S. - Sheets must always be read before using products. Protecto-Coat Systems are intended for application by experienced, professional personnel. Dudick Inc. can supply Protecto-Coat systems supervision to help determine that the surface has been properly prepared, the ingredients correctly mixed, and the materials properly and safely applied.

## Protecto-Coat 200

Elastomeric, Spray Applied, Environmentally Safe, Urethane Coat.

Dudick Incorporated  
Corrosion-Proof Products



If Protecto-Coat materials are to be applied by your own personnel or by a third-party contractor, please be sure that they are aware of the following safety precautions:

- Exposure to resins and hardeners may cause severe dermatitis reactions in some people. Cleanliness of the skin and clothing is critical and must be of paramount concern.
- Safety glasses, gloves and suitable protective clothing must be worn at all times during application.
- Suitable respirators should be used.
- If contact with hardeners occurs, remove any clothing involved and wash the skin with large amounts of water. Discard the clothing. Do not attempt to wash and reuse it. Protecto-Coat liquid may be washed off with S-10 Cleaning Solvent, MEK liquid, or laquer thinner.
- Fumes are flammable and heavier than air. Proper ventilation should be maintained to minimize breathing of concentrated fumes.
- If a rash or dermatitis occurs, remove the individual from the work area and seek a physician's care for dermatitis.
- Keep open flames and sparks away from the area where toppings are being mixed and applied.
- In case of eye contact, wash with water for at least 15 minutes and consult a physician. If swallowed, do not induce vomiting; call a physician immediately.

#### Note:

Dudick Inc. ("Dudick") warrants all goods of its manufacture to be as represented in its catalogs and that the application of its products by its employees or sub-contractors shall be performed in a workmanlike manner. Dudick's obligation under this warranty shall be the repair to and replacement of any applications which its examination shall disclose to be defective. Dudick makes no warranty concerning the suitability of its product for application to any surface, it being understood that the goods have been selected and the application ordered by the purchaser. DUDICK INC. MAKES NO WARRANTY, EXPRESS OR IMPLIED, THAT THE GOODS SHALL BE MERCHANTABLE OR THAT THE GOODS ARE FIT FOR ANY PARTICULAR PURPOSE. THE WARRANTY OF REPAIR OR REPLACEMENT SET FORTH HEREIN IS EXCLUSIVE AND IN LIEU OF ALL OTHER WARRANTIES ARISING BY LAW OR OTHERWISE; AND DUDICK INC. SHALL NOT BE LIABLE FOR INCIDENTAL OR CONSEQUENTIAL DAMAGES, INCLUDING BUT NOT LIMITED TO LOST PROFITS, DOWN TIME, DAMAGES TO PROPERTY OF THE PURCHASER OR OTHER PERSONS, OR DAMAGES FOR WHICH THE PURCHASER MAY BE LIABLE TO OTHER PERSONS, WHETHER OR NOT OCCASIONED BY DUDICK'S NEGLIGENCE. This warranty shall not be extended, altered or varied except by written instrument signed by Dudick and Purchaser.



# Waste Analysis



Treated  
Blowdown

## ANACHEM INC.

8 Prestige Circle, Suite 104 • Allen, Texas 75002  
214/727-9003 • FAX # 214/727-9686 • 1-800-966-1186

Customer Name: USPCI  
Date Received: August 17, 1994 at 11:10:45  
Date Reported: August 26, 1994  
Submission #: 9408000203  
Project: HEAT EXCHANGERS

**SAMPLES** The submission consisted of 1 sample with sample I.D. shown in the attached data table.

**TESTS** The sample listed in the attached result pages was analyzed for:

- \* ALKALINITY, TOTAL (EPA 310.1)
- \* ANION/CATION RATIO (CALCULATION)
- \* CALCIUM/Ca (EPA 215.1)
- \* CHLORIDE (EPA 300.6)
- \* CYANIDE, TOTAL (EPA 335.2)
- \* HARDNESS, TOTAL (BASED ON AAS/ICP)
- \* ICP SCAN (EPA 200.7)
- \* IRON/Fe (EPA 236.1)
- \* MAGNESIUM/Mg (EPA 242.1)
- \* MICROWAVE DIGESTION (EPA 3015)
- \* pH (EPA 150.1)
- \* POTASSIUM/K (EPA 200.7)
- \* SILICA (EPA 370.1)
- \* SODIUM/Na (EPA 273.1)
- \* SPECIFIC CONDUCTANCE (EPA 120.1)
- \* SULFATE (EPA 375.4)
- \* TDS-TOTAL DISSOLVED SOLIDS (EPA 160.1)
- \* TSS-TOTAL SUSPENDED SOLIDS (EPA 160.2)

Distribution Of Reports

2-Bruce Patterson of USPCI  
Ph. (405) 697-3500 Fax (405) 697-3592

Respectfully Submitted,  
Anachem, Inc.

C.E. Newton, Ph.D.  
Chemist

Submission #: 9408000203 lms

NOTE: Submitted material will be retained for 60 days unless notified or consumed in analysis. Material determined to be hazardous will be returned or a \$20 disposal fee will be assessed. Our letters and reports are for the exclusive use of the client to whom they are addressed. The use of our name must receive our prior written approval. Our letters and reports apply to the sample tested and/or inspected, and are not necessarily indicative of the qualities of apparently identical or similar materials.



08/26/94 16:25 214 727 9886

ANACHEM

002/004

Client Name: USPCI  
 Submission #: 9408000203  
 Project Name: HEAT EXCHANGERS  
 Report Date: 08/26/94

Client Sample #: TREATED EXHAUST BLOWOFF

Laboratory ID #: 35372 Matrix: Liquid  
 Sample Container: 3xGallon Plastic  
 Sampling Location: Not listed on the chain of custody.  
 Sampling Date: Not listed on the chain of custody.  
 Temperature (Celsius): 21

ALKALINITY, TOTAL (EPA 310.1)

Analyte	Results(mg/l)	Det. Limit
Total Alkalinity	7800	1

ANION/CATION RATIO (CALCULATION)

Analyte	Results(%)	Det. Limit
Anion/Cation Ratio	1.00	0

CALCIUM/Ca (EPA 215.1)

Analyte	Results(mg/l)	Det. Limit
Calcium	30.2	0.01

CHLORIDE (EPA 300.6)

Analyte	Results(mg/l)	Det. Limit
Chloride	145000	0.1

CYANIDE, TOTAL (EPA 335.2)

Analyte	Results(mg/l)	Det. Limit
Total Cyanide	23.9	0.20

NESS, TOTAL (BASED ON AAS/ICP)

Analyte	Results(mg/l)	Det. Limit
Hardness, Calculated	1500	

ICP SCAN (EPA 200.7)

Analyte	Results(mg/l)	Det. Limit
Silver	<0.0120	0.0120
Cadmium	0.072	0.0014
Chromium	0.112	0.0146
Copper	0.286	0.0046
Cobalt	1.38	0.0028
Lead	0.362	0.042
Manganese	0.034	0.0004
Nickel	0.925	0.0049
Antimony	<0.0246	0.0246
Thallium	0.286	0.056
Zinc	0.031	0.0031
Arsenic	32.6	0.044
Selenium	2.61	0.026
Aluminum	2.96	0.107
Barium	0.152	0.045
Beryllium	<0.0011	0.0011
Molybdenum	31.2	0.0069
Tin	<0.023	0.023
Titanium	<0.017	0.017
Vandium	0.139	0.0037
Silicon	4.09	0.015
Strontium	1.33	0.0013
Lithium	12	0.001

Iron (EPA 236.1)

Analyte	Results(mg/l)	Det. Limit
Iron	5.09	0.03

MAGNESIUM/Mg (EPA 242.1)

Analyte	Results(mg/l)	Det. Limit
Magnesium	31.7	0.01



08/26/94 16:25 214 727 0686

ANACHEM

003/004

Client Name: USPCI  
Submission #: 9408000203  
Project Name: HEAT EXCHANGERS  
Report Date: 08/26/94

PH (EPA 150.1)

Analyte  
pH For Liquid

Results(----)  
7.5

Det. Limit  
0

POTASSIUM/K (EPA 200.7)

Analyte  
Potassium

Results(mg/l)  
12300

Det. Limit  
0.010

SILICA (EPA 370.1)

Analyte  
Silicon Dioxide/Silica

Results(mg/l)  
100

Det. Limit  
2

SODIUM/Na (EPA 273.1)

Analyte  
Sodium

Results(mg/l)  
105000

Det. Limit  
0.01

SPECIFIC CONDUCTANCE (EPA 120.1)

Analyte  
Specific Conductance

Results(umhos/cm)  
78900

Det. Limit  
1

SULFATE (EPA 375.4)

Analyte  
Sulfate

Results(mg/l)  
30200

Det. Limit  
1

TDS-TOTAL DISSOLVED SOLIDS (EPA 160.1)

Analyte  
Total Dissolved Solids

Results(mg/l)  
299000

Det. Limit  
1

TOTAL SUSPENDED SOLIDS (EPA 160.2)

Analyte  
Total Suspended Solids

Results(mg/l)  
1440

Det. Limit  
1



Report to: USPCI  
Lab Number: 9408000203  
Page 4 of 4

Project: Heat Exchangers

## QUALITY CONTROL DATA

<u>ANALYTE</u>	<u>DATE</u> <u>ANALYZED</u>	<u>SPIKE</u> <u>VOL</u>	<u>STAND.</u> <u>DEV.</u>	<u>COEFF. OF</u> <u>VAR %</u>	<u>REC1/%</u>	<u>REC2/%</u>
Hardness, Calc.	8/19/94	----	0	0	96	----
Total Alkalinity	8/19/94	----	5.7	0.7	100	----
Silica	8/25/94	----	0	0	100	----
Sulfate	8/19/94	----	0.31	1.2	100	----
Chloride	8/25/94	----	178	8	100	----
T.S.S.	8/18/94	----	181	10	99	98
Total Cyanide	8/25/94	----	0	0	109	----

Standard Deviation =  $(x1-x2)/1.414$ Coefficient of Variability % =  $(S.D./Avg.) \times 100$ Recovery % =  $[(\text{spiked}-\text{unspiked})/\text{expected}] \times 100$ 

## ICP SCAN INFORMATION

**Note:** ICP scans are very general in nature and do not include precise calibration or quality control. The process is intended as a screening procedure to identify very high metal concentrations.



Evaporator  
Blowdown

USPCI  
9407000227  
HEAT EXCHANGERS  
08/04/94

Sample #: EV #1  
Laboratory ID #: 33964 Matrix: Liquid  
Sample Container: 2 Liter Plastic Bottle  
Sampling Location: Not listed on the chain of custody.  
Sampling Date: Not listed on the chain of custody.

**CAN (EPA 6010)**

	Results(mg/l)	Det. Limit
As	333	
Bar	2.4 -	
Bism	0.166	
Brom	0.514	
Calc	1.76	
Chlor	97.6	
Copper	12600	
Fluor	0.242	
Iron	41.7	
Magnesium	0.264	
Manganese	136000	
Mercury	36.4	
Nickel	0.336	
Selenium	0.198	
Silver	0.264	
Sulfur	52.2	
Titanium	4.5	
Zinc	67.2	
Aluminum	3.1	
Antimony	1	
Vanadium	22.4	

**MERCURY DIGESTION (EPA 7470)**  
Date of Mercury Digestion: 07/20/94

	Results(mg/l)	Det. Limit
MERCURY / Hg BY COLD VAPOR (EPA 245.1)	0.002	

Sample #: EV #2  
Laboratory ID #: 33965 Matrix: Liquid  
Sample Container: 2x2 Liter Plastic Bottle  
Sampling Location: Not listed on the chain of custody.  
Sampling Date: Not listed on the chain of custody.

	Results(mg/l)	Det. Limit
ALKALINITY, TOTAL (EPA 310.1)	18900	1

	Results	Det. Limit
ANION / CATION RATIO (CALCULATION)	1.08	0

	Results(mg/l)	Det. Limit
ANIONATE ALKALINITY (EPA 310.1)	23100	1

	Results(mg/l)	Det. Limit
ALCIUM / Ca (EPA 200.7)	735 -	0.001



Name: USPCI  
Site: 9407000227  
Sample: HEAT EXCHANGERS  
Date: 08/04/94

NATE ALKALINITY (EPA 310.1)

Alkalinity

Results(mg/l)  
1

Det. Limit  
1

IDE (EPA 300.6)

3

Results(mg/l)  
176000

Det. Limit  
0.1

DE, TOTAL (EPA 335.2)

yanide

Results(mg/l)  
0.02

Det. Limit  
0.02

Fe (EPA 200.7)

Results(mg/l)  
112

Det. Limit  
0.013

ESIUM/Mg (EPA 200.7)

ium

Results(mg/l)  
222

Det. Limit  
0.030

A 150.1)

Liquid

Results(----)  
13

Det. Limit  
0

SIUM/K (EPA 200.7)

ium

Results(mg/l)  
17400

Det. Limit  
0.010

LA 370.1)

Dioxide/Silica

Results(mg/l)  
400

Det. Limit  
2

M/Na (EPA 200.7)

ium

Results(mg/l)  
150000

Det. Limit  
0.001

FIC CONDUCTANCE (EPA 120.1)

Conductance

IS A CALCULATED VALUE; THE MATRIX OF THE  
SAMPLE PRECLUDED THE USE OF A CONDUCTIVITY  
CELL DUE TO OILY COATING; THE CALCULATED VALUE  
BASED ON MES INFINITE DILUTION OF THE SAMPLE.)

Results(umhos/cm)  
840000

Det. Limit  
1

FIC GRAVITY (USP 841)

Gravity

Results()  
1.31

Det. Limit  
1

ATE (EPA 375.4)

ate

Results(mg/l)  
55300

Det. Limit  
1

TOTAL DISSOLVED SOLIDS (EPA 160.1)

Dissolved Solids

Results(mg/l)  
417000

Det. Limit  
1

TOTAL SUSPENDED SOLIDS (EPA 160.2)

Suspended Solids

Results(mg/l)  
6780

Det. Limit  
1



Report to: USPCI  
Report Number: 9407000227  
Page 4 of 4

Project: Heat Exchangers

#### QUALITY CONTROL DATA

<u>ANALYTE</u>	<u>DATE ANALYZED</u>	<u>SPIKE VOL</u>	<u>STAND. DEV.</u>	<u>COEFF. OF VAR %</u>	<u>REC1/%</u>	<u>REC2/%</u>
Mercury	7/20/94	---	0.141	2.0	102	99
Total Alkalinity	7/26/94	---	0	0	100	---
C.D.S.	7/28/94	995	304	0.1	96	96
Silicon Dioxide/ Silica	8/1/94	---	0	0	100	---
Sulfate	8/1/94	---	5	2.4	99	---
Chloride	7/26/94	500	2.1	1.1	100	99
Hardness, Calcium	8/1/94	---	±4.2	1.1	110	100
C.S.S.	7/21/94	298	0.7	0	98	95

Standard Deviation =  $(x1-x2)/1.414$

Percent of Variability % =  $(S.D./Avg.) \times 100$

Recovery % =  $[(\text{spiked}-\text{unspiked})/\text{expected}] \times 100$

#### ICP SCAN INFORMATION

**Note:** ICP scans are very general in nature and do not include precise calibration or quality control. The process is intended as a screening procedure to identify very high metal concentrations.







## Ancillary Equipment Drawings







# Tank Drawings








## Ancillary Equipment Drawings





**PRETREATMENT**  
 PRETREATMENT STORAGE  
 RAW LEACHATE  
 FLOW RATE: VARIABLE  
 SPECIFIC GRAVITY: 1.03  
 TOTAL SOLIDS: 2-4%

**IF4**  
 EVAPORATION FEED TANK  
 ATM'S DESIGN TANK  
 SIZE: 8'-4" DIA. X 10' HIGH  
 MATERIAL: CARBON STEEL  
 VOLUME: 1825 GALS  
 MAKE UP: LEVEL CONTROLLED  
 INSULATION: NONE

**P78 & P79**  
 RAW LEACHATE FEED PUMP  
 DESIGN: END SUCTION  
 GPM: 80  
 HEAD: 50 FT (PRELIMINARY)  
 HP: 2  
 SPECIFIC GRAVITY: 1.03  
 LB/HR: 20412± (PER FT)  
 TEMP: 40 TO 80 F

**P75**  
 EVAPORATION FEED PUMP  
 DESIGN: END SUCTION  
 GPM: 800  
 HEAD: 231 FEET  
 HP: 60  
 SPECIFIC GRAVITY: 1.2  
 LB/HR: 451,800  
 TEMP: 200 TO 210 F

**EU2**  
 EVA  
 DES  
 MAT  
 HEA

REVISIONS						REVISIONS						REFERENCE DRAWING	
NO	DESCRIPTION	DATE	BY	CHK	APP	NO	DESCRIPTION	DATE	BY	CHK	APP	DRAWING NO.	TITLE

40158-001-CP-ANCY-EC001  
 873904/ESH ACIO 12  
 PLOT SCALE 1=1  
 10/23/86 08:59:29



# SECTION EO1



**SECTION 305**  
**ASSESSMENT OF EVAPORATOR OVERFLOW TANK (EO1)**  
**LONE MOUNTAIN HAZARDOUS WASTE FACILITY**  
**U.S.P.C.I.**  
**WAYNOKA, OKLAHOMA**

**A. TANK SYSTEM DESCRIPTION**

Evaporator Overflow Tank (EO1) is an aboveground evaporator overflow storage tank. The wastewater stored in this tank is treated or neutralized wastewater according to USPCI. The tank is horizontal in position and cylindric in shape. This tank and a portion of the ancillary piping is located together inside a concrete containment area.

**B. PRIMARY TANK VESSEL**

**1. General Description**

Evaporator Overflow Tank (EO1) consists of a circular steel tank placed in the horizontal position supported by a steel plate support system. The actual steel specifications to which the tank is constructed of is not known. The tank was inspected prior to the placement of interior coatings. Influent piping is located from the wastewater treatment building. This tank receives water from roof drains. Water from rains or an overflow of the flash tank will be collected in the gutter system and deposited into this tank.

**2. Design Standards.**

Structure calculations were performed to compare the existing tank and supports to those sections that are applicable in the American Petroleum Institute Standard 650 - 1988 edition (API-650) and the American Institute of Steel Construction (AISC) Manual of Steel Construction (8th Edition). These calculations can be found in Appendix B and C of this report. The actual steel specifications to which the tank is constructed are not known. Appendix A of API-650 was utilized in the analysis of this vessel due to the small diameter of the vessel.

**3. Hazardous Characteristics of Wastes Stored**

The wastes which are treated in this tank have the following characteristics:

Neutralized wastewater with a pH level between 4-10

N < 6

Temperature = Ambient

The hazardous characteristics of the waste treated in this tank were examined. It was determined that the pH and normality levels of the waste are the primary areas of concern. This is to determine the applicability of a corrosion allowance for the tank material type and thickness



#### 4. Existing Corrosion Protection

The interior of the tank is coated with a coal tar epoxy coating. This coating was applied in May of 1992 and is in excellent condition. The exterior of the tank is painted with an epoxy paint as corrosion protection.

#### 5. Documented Age of Tank

This tank was purchased as a used tank and the actual documented age is unknown. This tank was installed in July of 1987. The estimated age of the tank is 5 years old. This age was determined by using a 20 year design life less the estimated useful life of 15 years. A 20 year design life is assumed from the time of installation at USPCI.

#### 6. Result of Leak Tests

No leak tests have been performed, however, the vessel is in service and a visual leak inspection was performed. In the visual leak test items such as welds, seams, flange connections, valves and threaded connections were examined to verify that no leaks were present. From this visual analysis it was determined that the primary tank is not leaking.

#### 7. Existing Data Obtained

Diameter of Tank	6.87'
Height	20'-6"
Material	Carbon Steel.
* Thickness	0.70"
Specific Gravity	1.5
Operating Temperature	< 230°
Maximum Volume	5514 Gal.
Seismic Zone	1

\* A complete and exhaustive ultrasonic thickness corrosion survey has been completed, the results of which can be found in Appendix F of this assessment.

#### 8. Calculation of Foundation Loading

Total Weight of Tank and Contents = 37.07 tons

Detailed calculations reflecting the volume and weight of the tank along with the minimum required foundation thickness and steel reinforcement are included in Appendix A and E of this assessment.

#### 9. Required Structural Calculation

The calculated required wall thickness for this tank is 0.066 inches. 0.0625 inches is added for corrosion allowance. This corrosion allowance is based on a best engineering estimate taking into account the materials being treated and a 20 year design life. (See Appendix B of this assessment for detailed calculations or required wall thickness and structural analysis of the tank support system).



## 10. Comparison of Actual Structure to Theoretical Values

### Wall Thickness Comparison

Calculated Required Thickness	0.066"
Minimum Required Wall Thickness By API 650-88	0.1875"
Measured Wall Thickness	0.70"

## C. SECONDARY CONTAINMENT SYSTEM

### 1. General Description of Secondary Containment

The secondary containment system is designed and operated to prevent any migration of wastes or liquids out of the system. (See Appendix G of this assessment for layout of secondary containment area.) The Evaporator Overflow Tank (EO1) #1 is located in a 12' x 24.5' x 3' high concrete containment area.

The containment area and tanks are routinely visually monitored on a daily basis for leaks. A sump pump and drain are located in the containment area. The floor is sloped to the sump to collect any drainage or spills. Any released tank contents or surface runoff will drain on top of the sloped concrete to the sump area. The accumulated liquids are then removed and pumped to the wastewater pretreatment area within a maximum of 24 hours, as a permit condition.

### 2. Design Standards

The structural capacity of the foundation and walls were compared to those sections that are applicable in the API 650-88 and the American Concrete Institute (ACI 318-89/318r-89) and these calculations were used as a guide in verifying the ability of the system to contain hazardous waste.

### 3. Hazardous Characteristics of Wastes Treated

The wastes which are treated in the primary tank have the following characteristics:

Treated Wastes  
pH Level (4-10)  
N < 6  
Temperature = Ambient

The hazardous characteristics of the waste treated in the primary tank were examined. It was determined that the pH and normality levels of the waste are the primary areas of concern. This is to determine the applicability of a corrosion allowance for the containment system material type and thickness.



#### 4. Existing Corrosion Protection

The entire secondary containment area floor and walls are coated with an impermeable coating by (Overcrete Plus by Concrete Protection Systems, Inc.) installed by Mid-America Painters of Woodward, Oklahoma. See Appendix H of this report for detailed information on this coating.

#### 5. Documented Age of the Containment Area

The secondary containment system was constructed and installed in 1992 thus making the containment system less than 1 year old.

#### 6. Result of Leak Tests

A visual inspection of the containment area was performed and from this inspection there were no cracks or breaks in the impermeable coating, therefore it appears to be adequate to contain any leaks or spills.

#### 7. Existing Data Obtained

Area	295.23 s.f.
Wall Height	3.05 ft.
Material	Concrete
Gross Volume	906.44 c.f.

#### 8. Calculation of Existing Capacity

##### Containment Capacity Available (CCA)

$CCA = \text{Gross Volume} - \text{Volume of items in the containment} - \text{Volume of rainfall.}$

See the appendix of this report for detailed calculations of the available containment volume. The containment capacity available = 749.13 c.f.

#### 9. Required Volume

##### Containment Capacity Required (CCR)

$CCR = \text{Volume of Largest Tank in the secondary containment}$

Volume of Largest Tank = 737.29 c.f.

#### 10. Comparison of Available Volume to Required Volume

##### Containment Capacity Comparison

Containment Capacity Required =	737.29 c.f.
Secondary Containment Volume Available =	749.13 c.f.
Excess Containment Volume =	11.84 c.f.

$CCA > CCR$  Adequate Capacity (under normal operating conditions) is available.



## **D. CONCLUSIONS**

### **1. Primary Tank Vessel**

The tank vessel at the time of inspection was fit for use with the present waste stream at given densities, chemical and physical characteristics as verified by USPCI.

### **2. Secondary Containment System**

The secondary containment area at the time of inspection was fit for use, if the present waste stream at given densities and chemical and physical characteristics as verified by USPCI were released from the primary tank. The useful life of the concrete containment area is estimated at 15 years. This useful life was determined by using a design life of 20 years less the period that the tank has been in use at the USPCI Lone Mountain Facility. There did not seem to be any extensive corrosion or deterioration of the secondary containment area.

## **E. RECOMMENDATIONS**

The following repairs or modifications should be made:

### **1) Primary Tank**

The tank should be checked periodically with ultrasonic testing procedures to establish a verified limit of corrosion. USPCI should continually insure compatibility with the waste and densities stored. Daily inspections should be continued to detect any visual corrosion or defects.

### **2) Secondary Containment System**

The secondary containment should be checked periodically for any deterioration and structural integrity.


### **3) Routine Inspections**

When routine and preventative measures are to be completed, the tank should be cleaned and internally inspected to determine any interior defects or corrosion. Continued routine painting and coating of tanks on the interior and exterior, and routine inspection is recommended.



## F. CERTIFICATION

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted, is to be the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment from knowing violations.





**APPENDIX A**  
**Primary Tank Volume Calculations**



## SECTION 305 - APPENDIX A

### EO1, Evaporator Overflow Tank

#### PRIMARY TANK VOLUME CALCULATIONS

##### DIMENSIONS:

Geometry:	CYLINDRICAL
Diameter:	6.87 FEET
Height =	17.60 FEET
Top = Std. Umbrella =	
Bottom = Std. Umbrella =	

##### TANK VOLUME:

Top = approx. Std. Umbrella volume = $0.05539 \cdot D^3$	42.44 C.F.
Bottom = Std. approx. Umbrella volume = $0.05539 \cdot D^3$	42.44 C.F.
Tank Cylinder =	652.40 C.F.

TOTAL PRIMARY TANK VOLUME =	737.29 C.F.
	OR 5,514.93 GAL

##### WEIGHT ON FOUNDATION

CONTENTS S.G.:	1.50
DENSITY:	93.60 LB/C.F.

##### SURFACE AREA CALCULATION

Tank Top = $0.8418 \cdot D^2$ =	39.73 S.F.
Tank Bottom = $0.8418 \cdot D^2$ =	39.73 S.F.
Tank Wall = $Cir \cdot h$	379.86 S.F.

TOTAL SURFACE AREA =	459.32 S.F.
----------------------	-------------

Steel Thickness=	
Sidewalls	0.26 INCHES
Top and bottom Dish	0.34 INCHES
Volume of Steel =	
Sidewalls	8.23 C.F.
Top and bottom dish	2.22 C.F.
Density of Steel =	490.00 LB/C.F.
Weight of Steel =	2.56 TONS

WEIGHT OF TANK CONTENTS =	34.51 TONS
---------------------------	------------

TOTAL WEIGHT OF TANK AND CONTENTS =	37.07 TONS
-------------------------------------	------------



## APPENDIX B

### Primary Tank Wall Thickness Calculations



## SECTION 305 - APPENDIX B

EO1, Evaporator Overflow Tank

### PRIMARY TANK WALL THICKNESS

---

#### DIMENSIONS:

GEOMETRY:	CYLINDRICAL	
DIAMETER:		6.87
LENGTH:		17.60
TANK VOLUME:		737.29 C.F.
CONTENTS S.G.:		1.30
DENSITY:		81.12 LB/C.F.
TOTAL WEIGHT OF TANK AND CONTENTS =		37.14 TONS
STEEL THICKNESS =		0.740 INCHES

---

THIS TANK IS LYING ON ITS SIDE THEREFORE TREAT TANK AS A  
CONTINUOUS BEAM

Allowable Stress API-650-88

I =

S (provided) =

w =

Length Between Supports =

M =  $wl^2/8$

S required =

Thickness Required =

Corrosion Allowance =

Thickness Required =

23200.00	psi
162819.18	in <sup>4</sup>
3950.00	in <sup>3</sup>
4.22	K/LF
8.80	feet
40.85	K-FT
490.25	K-IN

21.13	in <sup>3</sup>
0.004	in

0.0625	in
--------	----

0.066	in
-------	----

---



## APPENDIX C

### Structural Support Calculations



## SECTION 305 - APPENDIX C

### EO1, Evaporator Overflow Tank

### STRUCTURAL SUPPORT CALCULATIONS

---

<b>GIVEN:</b>	
Tank Diameter =	6.87 feet
Total Height =	17.60 feet
Weight of Tank (Steel) =	5120.00 lbs
Weight of Max. Contents =	69020.00 lbs
Tank Nominal Thickness =	0.25 in

---

#### —SEISMIC DESIGN CHECK—

ZONE COEFFICIENT (Z):	0.1875
ESSENTIAL FACILITIES FACTOR (I):	1.000
LATERAL EARTHQUAKE FORCE COEFF. (C1):	0.240
D/H:	0.390
k factor:	0.550
SITE AMPLIFICATION FACTOR (S):	1.500
NATURAL PERIOD OF FIRST SLOSHING (T):	1.442
LATERAL EARTHQUAKE FORCE COEFF. (C2):	0.312
WEIGHT OF TANK SHELL (Ws):	5120.000 LBS
TOTAL WEIGHT OF TANK CONTENTS (Wt):	69020.000 LBS
W1/Wt:	0.900
W2/Wt:	0.100
WEIGHT OF EFFECTIVE MASS OF CONTENTS THAT MOVES IN UNISON WITH THE TANK SHELL (W1):	62118.000 LBS
WEIGHT OF EFFECTIVE MASS IN FIRST SLOSHING (W2):	6902.000 LBS
HT FROM BTM OF SHELL TO CENT. OF SHELL (Xs):	8.800 FEET
X1/H:	0.480
HT FROM BTM TO CENT. OF LAT. SEISMIC FORCE (X1):	8.448 FEET
X2/H:	0.800
HT FROM BTM TO CENT. OF LAT. SEISMIC FORCE (X2):	14.080 FEET
OVERTURNING MOMENT (M) = $Z \cdot I \cdot (C1 \cdot Ws \cdot Xs + C1 \cdot W1 \cdot X1 + C2 \cdot W2 \cdot X2)$	
OVERTURNING MOMENT (M):	31330.178 FT-LBS



Note: All of the above calculations are based on API-650-88 Seismic Design Procedure (Appendix E).

---

CHECK STRESS IN TANK SHELL FROM SEISMIC FORCES:

Wl = MAXIMUM WEIGHT OF TANK CONTENTS THAT MAY BE USED TO RESIST THE SHELL OVERTURNING MOMENT

$$Wl = 7.9 \cdot t_b \cdot (F_{by} \cdot G \cdot H)^{.5}$$

Wl must be less than  $1.25 \cdot G \cdot H \cdot D$ :

226.71

$t_b$  = THK. OF BTM. PLATE UNDER SHELL:

0.250 IN

$F_{by}$  = MINIMUM YIELD STRENGTH OF BOTTOM PLATE:

36000.000 PSI

G = DESIGN SPECIFIC GRAV. OF LIQUID:

1.50

Wl =

1925.40 LBS/FT OF SHELL CIRCUMFERENCE

DENSITY OF TANK SHELL MATERIAL:

490.00 LBS/CF

WT = WEIGHT OF TANK SHELL AND THE PORTION OF FIXED ROOF SUPPORTED BY TANK SHELL:

179.67 LBS/FT OF SHELL CIRCUMFERENCE

$$M/[D^2(WT+Wl)]:$$

0.3153

b = MAXIMUM LONGITUDINAL COMPRESSIVE FORCE AT THE BTM. OF TANK SHELL

$$b = WT + 1.273 \cdot M/D^2$$

b:

1024.71 LBS/FT OF SHELL

$$G \cdot H \cdot D^2/t^2:$$

19935.97

$$F_a = \text{MINIMUM OF } 10^6/t^2 \cdot 2.5 \cdot D + 600 \cdot (G \cdot H)^{.5} \text{ or } .5 \cdot F_{ty}$$

18000.00 PSI

$F_{ty}$  = MINIMUM YIELD STRENGTH OF BTM. SHELL COURSE:

36000.00 PSI

MAX. LONGITUDINAL COMPRESSIVE STRESS IN THE TANK SHELL =  $b/12t$  =

341.57 PSI

---

CHECK OVERTURNING MOMENT FROM WIND PRESSURE

Mmax must be Less Than or Equal To  $.66 \cdot (WD)/2$

Where:

W = Shell Weight Available To Resist Uplift (lbs)

D = Tank Diameter (feet)

M = Overturning Moment




$$M = P_w \cdot \text{Projected Area} \cdot H_1$$

$H_1$  = Height from ground to centroid of tank shell

$P_w$  = Wind Pressure (18 psi for 100 MPH Wind on cylinders)

Mmax: 11607.55 FT-LBS

M: 19152.46 FT-LBS



## APPENDIX D

### Containment Area Volume Calculations



## SECTION 305 APPENDIX D

EO1, Evaporation Overflow Tank

### SECONDARY CONTAINMENT CALCULATIONS

Area No.1	
Length =	24.50 feet
Width =	12.05 feet
Height =	3.05 feet
Surface Area =	295.23 S.F.
Volume =	900.44 C.F.

Gross Area =	Area 1	295.23 S.F.
Gross Volume =	Vol. 1	900.44 C.F.

Volumes of Items of Displacement \*\*

There are no items in secondary containment except tank EO1

Total volume to deduct for items in containment area =	0.00 C.F.
--	-----------

Subtraction for volume of rainfall

Volume of rain = Area x depth of rainfall	
Depth of rainfall =	6.15 In.
Area =	295.23 S.F.
Volume =	151.30 C.F.

TOTAL AVAILABLE VOLUME = Gross Volume - Subtractions =	900.44 C.F.
Items of displacement	0.00 C.F.
Volume of rainfall	-151.30 C.F.

TOTAL AVAILABLE VOLUME =	749.13 C.F.
	OR 5603.52 Gal.



## APPENDIX E

### Foundation Design Analysis



## SECTION 305 - APPENDIX E

### EO1, Evaporator Overflow Tank

### FOUNDATION DESIGN ANALYSIS

---

#### ASSUMPTIONS:

$f'_c$ =	3.50 KSI
$f_y$ =	60.00 KSI
Allowable Soil Press. =	2.00 KSI
Structural Steel =	A36

---

#### GIVEN:

Tank Diameter =	6.87 feet
Sidewall Height =	17.60 feet
Weight of Tank (Shell)	5120.00 lbs
Weight of Max. Contents =	69020.00 lbs

Tank is Resting on a concrete foundation.

---

#### CHECK CONCRETE FOUNDATION DESIGN:

Assume Footing Depth =	6.00 inches
Assume Footing Width =	12.00 inches
Assumed Effective Soil Press. =	1925.00 psf

Look at what is resisting overturning moment from seismic load:

$b =$  1024.71 lb/ft of circ.

Where  $b$  is the maximum shell compression at the bottom of the shell.

If the footing is 12.00 inches wide  
then the actual applied pressure to the subgrade is 1024.71 lb/sf

This is less than the effective soil pressure.



## **APPENDIX F**

### **Ultrasonic Thickness Testing Results**



# REPORT OF UT THICKNESS INSPECTION

TESTED FOR:

USPCI  
LONE MOUNTAIN

PROJECT:

CORROSION  
SURVEY

DATE:

8-3-92

OUR REPORT NO.:

53

Client Order Number:		Lab Number: UT #1		Location: EO-1																																																																					
Test Method Standard: QC UT 5		Acceptance Standard: QC UT 5		Scanning Method: RANDOM / 2'																																																																					
UT UNIT <input type="checkbox"/> A-Scan <input checked="" type="checkbox"/> Direct Readout <input type="checkbox"/> A-Scan and Direct Readout		Manufacturer: KBA Model: PME Serial No.: 103162																																																																							
CALIBRATION BLOCK		ID Number: 01		Size: .100" - .500" STEP																																																																					
		Material Type: STEEL																																																																							
SEARCH UNIT		<input type="checkbox"/> Single Element <input checked="" type="checkbox"/> Dual Element		Size: .625" Frequency: 5 MHZ Serial No.: E08931																																																																					
Measurements <table border="1"> <tbody> <tr><td>1</td><td>18</td><td>35</td><td>52</td></tr> <tr><td>2</td><td>19</td><td>36</td><td>53</td></tr> <tr><td>3</td><td>20</td><td>37</td><td>54</td></tr> <tr><td>4</td><td>21</td><td>38</td><td>55</td></tr> <tr><td>5</td><td>22</td><td>39</td><td>56</td></tr> <tr><td>6</td><td>23</td><td>40</td><td>57</td></tr> <tr><td>7</td><td>24</td><td>41</td><td>58</td></tr> <tr><td>8</td><td>25</td><td>42</td><td>59</td></tr> <tr><td>9</td><td>26</td><td>43</td><td>60</td></tr> <tr><td>10</td><td>27</td><td>44</td><td>61</td></tr> <tr><td>11</td><td>28</td><td>45</td><td>62</td></tr> <tr><td>12</td><td>29</td><td>46</td><td>63</td></tr> <tr><td>13</td><td>30</td><td>47</td><td>64</td></tr> <tr><td>14</td><td>31</td><td>48</td><td>65</td></tr> <tr><td>15</td><td>32</td><td>49</td><td>66</td></tr> <tr><td>16</td><td>33</td><td>50</td><td>67</td></tr> <tr><td>17</td><td>34</td><td>51</td><td>68</td></tr> </tbody> </table>				1	18	35	52	2	19	36	53	3	20	37	54	4	21	38	55	5	22	39	56	6	23	40	57	7	24	41	58	8	25	42	59	9	26	43	60	10	27	44	61	11	28	45	62	12	29	46	63	13	30	47	64	14	31	48	65	15	32	49	66	16	33	50	67	17	34	51	68	<p>* NOTE: Diagram SEE DRWG. #EO-1 AND ATTACHMENTS FOR READINGS AND LOCATIONS.</p> <p>* NOTE: BLANK AREAS ON DRAWING DENOTE AREAS UNINSPECTABLE DUE TO INACCESSABILITY.</p>	
1	18	35	52																																																																						
2	19	36	53																																																																						
3	20	37	54																																																																						
4	21	38	55																																																																						
5	22	39	56																																																																						
6	23	40	57																																																																						
7	24	41	58																																																																						
8	25	42	59																																																																						
9	26	43	60																																																																						
10	27	44	61																																																																						
11	28	45	62																																																																						
12	29	46	63																																																																						
13	30	47	64																																																																						
14	31	48	65																																																																						
15	32	49	66																																																																						
16	33	50	67																																																																						
17	34	51	68																																																																						
Technician: J. BROOKS		Level: II		Technician: J. Brooks Level: II																																																																					

REMARKS:

READINGS TAKEN AT 2 FOOT GRIDS




P.S.I.

Tank Number E0-1Date 8-3-92


0.724	29	0.951	57	0.708	85	0.696	113	0.755	141	0.	168	0.
0.953	30	0.985	58	0.719	86	0.734	114	0.701	142	0.	169	0.
0.707	31	0.985	59	0.714	87	0.765	115	0.708	143	0.	170	0.
0.695	32	0.693	60	0.720	88	0.757	116	0.754	144	0.	171	0.
0.728	33	0.705	61	0.711	89	0.756	117	0.695	145	0.	172	0.
0.702	34	0.719	62	0.711	90	0.778	118	0.702	146	0.	173	0.
0.720	35	0.705	63	0.728	91	0.760	119	0.738	147	0.	174	0.
0.920	36	0.706	64	0.701	92	0.757	120	0.706	148	0.	175	0.
0.893	37	0.709	65	0.728	93	0.741	121	0.720	149	0.	176	0.
0.918	38	0.717	66	0.971	94	0.743	122	0.745	150	0.	177	0.
0.970	39	0.696	67	0.937	95	0.765	123	0.725	151	0.	178	0.
0.931	40	0.708	68	0.953	96	0.752	124	0.702	152	0.	179	0.
0.96	41	0.726	69	0.910	97	0.719	125	0.706	153	0.	180	0.
0.700	42	0.766	70	0.905	98	0.699	126	0.694	154	0.	181	0.
0.699	43	0.730	71	0.499	99	0.715	127	0.705	155	0.	182	0.
0.686	44	0.741	72	0.895	100	0.710	128	0.	156	0.	183	0.
0.952	45	0.755	73	0.943	101	0.740	129	0.	157	0.	184	0.
0.955	46	0.747	74	0.910	102	0.700	130	0.	157	0.	185	0.
0.923	47	0.740	75	0.934	103	0.688	131	0.	158	0.	186	0.
0.911	48	0.730	76	0.912	104	0.687	132	0.	159	0.	187	0.
0.949	49	0.765	77	0.970	105	0.693	133	0.	160	0.	188	0.
0.993	50	0.720	78	0.931	106	0.685	134	0.	161	0.	189	0.
0.923	51	0.743	79	0.715	107	0.680	135	0.	162	0.	190	0.
0.928	52	0.746	80	0.739	108	0.705	136	0.	163	0.	192	0.
0.915	53	0.714	81	0.742	109	0.709	137	0.	164	0.	193	0.
0.929	54	0.730	82	0.743	110	0.750	138	0.	165	0.	194	0.
0.908	55	0.711	83	0.725	111	0.718	139	0.	166	0.	195	0.
0.950	56	0.711	84	0.683	112	0.722	140	0.	167	0.	196	0.



North End



South End



H.S.L.

Block Number EU-1

Date 8-3-72.

North End

16	14	15	34	33	1	32	18	82	101
103	105		38	37	35	36	83	84	104
106			41	40	3	39	85	86	107

West Side

East Side

109	108	44	43	4	42	87	88	110
112	111	48	47	45	46	89	90	113
115	114	51	50	5	49	91	92	116

Bottom

118	117	54	53	6	52	93	94	119
121	120	58	57	55	56	95	96	122
124	123	62	61	59	60	97	98	125
126	13	65	64	7	63	99	100	127

West Side

East Side

South End



## APPENDIX G

### Drawings








[illegible]

USPCI  
LONE MOUNTAIN FACILITY  
WAYNOKA, OKLAHOMA


**Myers**  
ENGINEERING CORPORATION  
1102 N. Stratford Dr., Suite B400  
Oklahoma City, Oklahoma 73120  
(405) 755-5325

## ELEVATIONS OF WASTEWATER FINAL TREATMENT AREA

JOB NO. 511  
SCALE 1"=1'  
DRAWN DIC  
DATE 9-16-92







SECTION "A" - "A" SECONDARY CONTAINMENT

COMPACTED SUBGRADE TO 95% SPD

RECORD DRAWING

REVISIONS

NO. DATE

DESCRIPTION

**USPCI**  
A Subsidiary of  
Union Pacific Corporation

**USPCI**  
LONE MOUNTAIN FACILITY  
WAYNOKA, OKLAHOMA

**Myers**  
ENGINEERING CORPORATION  
1102 N. Stamford Dr. Suite B400  
Oklahoma City, Oklahoma 73120  
(405) 756-6325

(E01) EVAPORATION OVERFLOW  
TANK DETAIL

JOB NO. 5111  
SCALE 1" = 1'-0"  
DRAWN 8-10-92  
DATE 8-10-92  
SHEET 1 OF 1



# SECTION FT1



**ASSESSMENT  
Of  
EVAPORATOR FLASH TANK NO. 1  
(FT 1)  
Located At The  
LONE MOUNTAIN HAZARDOUS WASTE  
FACILITY  
WAYNOKA, OKLAHOMA**

PREPARED FOR



July 2002



---

**ASSESSMENT  
Of  
EVAPORATOR FLASH TANK NO. 1 (FT 1)  
Located At The  
LONE MOUNTAIN HAZARDOUS WASTE FACILITY  
WAYNOKA, OKLAHOMA  
Prepared For  
SAFETY-KLEEN, INC.**

---

**TABLE OF CONTENTS**

<b>1.</b>	<b>TANK SYSTEM DESCRIPTION .....</b>	<b>1.</b>
<b>2.</b>	<b>PRIMARY TANK VESSEL .....</b>	<b>1.</b>
2.1	General Description .....	1.
2.2	Design Standards .....	1.
2.3	Hazardous Characteristics of Waste Stored .....	1.
2.4	Welding Specifications and Inspection .....	2.
2.5	Corrosion Protection .....	2.
2.6	Documented Age of Tank .....	2.
2.7	Results of Leak Tests .....	2.
2.8	Existing Data Obtained .....	2.
2.9	Calculation of Existing Foundation Loading .....	2.
2.10	Required Structural Calculation .....	3.
2.11	Comparison of Actual to Theoretical Structural Values .....	3.
2.12	Ancillary Equipment .....	3.
<b>3.</b>	<b>SECONDARY CONTAINMENT SYSTEM .....</b>	<b>4.</b>
3.1	General Description of Secondary Containment .....	4.
3.2	Corrosion Protection .....	4.
3.3	Documented Age of the Containment Area .....	4.
3.4	Results of Leak Tests .....	4.
3.5	Calculation of Capacity Available (CCA) .....	4.
3.6	Required Volume .....	4.
3.7	Comparison of Available Volume to Required Volume .....	4.
<b>4.</b>	<b>CONCLUSIONS .....</b>	<b>5.</b>
<b>5.</b>	<b>RECOMMENDATIONS .....</b>	<b>5.</b>
<b>6.</b>	<b>CERTIFICATION .....</b>	<b>5.</b>

**LIST OF APPENDICES:**

<b>APPENDIX A.</b>	<b>MANUFACTURER'S CERTIFICATION</b>
<b>APPENDIX B.</b>	<b>WELDING PROCEDURES AND INSPECTIONS</b>
<b>APPENDIX C.</b>	<b>HYDROSTATIC LEAK TESTS</b>
<b>APPENDIX D.</b>	<b>CALCULATIONS</b>
<b>APPENDIX E.</b>	<b>METALLURGICAL INFORMATION</b>
<b>APPENDIX F.</b>	<b>SUPPORT STRUCTURE CALCULATIONS</b>
<b>APPENDIX G.</b>	<b>FOUNDATION ANALYSIS</b>
<b>APPENDIX H.</b>	<b>CONCRETE COATING INFORMATION FOR SECONDARY CONTAINMENT</b>
<b>APPENDIX I.</b>	<b>SECONDARY CONTAINMENT</b>



---

**ASSESSMENT  
Of  
EVAPORATOR FLASH TANK NO. 1 (FT 1)  
Located At The  
LONE MOUNTAIN HAZARDOUS WASTE FACILITY  
WAYNOKA, OKLAHOMA  
Prepared For  
SAFETY-KLEEN, INC.**

---

**1. TANK SYSTEM DESCRIPTION**

Evaporator Flash Tank No. 1 (FT 1) is a welded, above-ground wastewater treatment and storage tank to be installed as a part of the final wastewater treatment plant at the Lone Mountain Facility in Waynoka, Oklahoma. This tank is a replacement for an existing tank which is constructed of carbon steel. The new tank, which is constructed of stainless steel, is exactly the same size as the original tank. The top of the tank is completely open to the atmosphere for evaporation purposes. Evaporator Flash Tank No. 1 (FT 1) is located within the Wastewater Final Treatment building on the first mezzanine level of the support structure. The complete tank system consists of Evaporator Flash Tank No. 1 (FT 1), Circulating Pump (P 78), Heat Exchanger (EU 1), Pump (P 80), Filter Press (FP 1), and associated piping and instruments.

**2. PRIMARY TANK VESSEL**

- 2.1 General Description.** Evaporator Flash Tank No. 1 (FT 1) is a circular steel tank with an outside diameter of 6-ft. 4-in. and a height of 31-ft. The tank proper's skirt is anchored to the support structure, and the bottom of the tank is dished and welded to the shell. A self-supporting flue is attached to the top of the tank. Evaporator Flash Tank No. 1 (FT 1) is being assessed to determine if the unit is adequately designed with sufficient structural strength and compatibility with the waste to be stored.
- 2.2 Design Standards.** The tank is designed and constructed to those sections that are applicable in the American Petroleum Institute Standard 650, 10<sup>TH</sup> Edition (API-650). The manufacturer's certification is included in *Appendix A*.
- 2.3 Hazardous Characteristics of Waste Stored.** The waste stored in this tank is treated and untreated brine solutions. The following parameters are characteristics of the waste treated:

*Ignitability:* Flash Point > 240° F

*Corrosiveness:* 6 < pH < 13  
0 < N < 7

*Reactivity:* None

*Temperature:* < 240° F

Based on the results of the examination of the hazardous characteristics of the waste to be stored in this tank, it was determined that the pH, normality levels, and salinity (corrosiveness) of the waste are the primary areas of concern. These levels are used to determine the applicability of a corrosion allowance for the tank material type and thickness.



**2.4 Welding Specifications and Inspection.** The welding procedures utilized in the tank construction and the Radiographic Examination Report are included in *Appendix B*.

**2.5 Corrosion Protection.** The tank shell is constructed of 316L stainless steel for corrosion protection.

**2.6 Documented Age of Tank.** This tank was manufactured by Lide Industries of Mexia, Texas, in January 2002, and installed in July 2002.

**2.7 Results of Leak Tests.** The manufacturer conducted a hydrostatic leak test of the tank prior to shipping. A description of this test is included in *Appendix C* of this assessment. In addition, a visual inspection was performed of the tank's interior and exterior subsequent to installation. This inspection was conducted specifically to detect the presence, if any, of the following defects:

- (a) Weld break
- (b) Punctures
- (c) Cracks
- (d) Corrosion
- (e) Other structural damage or inadequacies of construction and/or installation

The tank was again hydrostatically tested subsequent to installation. A description of this procedure is summarized in *Appendix C* of this assessment. Based on the results of these tests, it was determined that the primary tank was not leaking.

**2.8 Existing Data Obtained.**

Tank Diameter	6-ft. 4-in.
Nominal Height of Tank	31-ft.
Maximum Capacity	3,785-gal.*
Overflow Liquid Level	9-ft. 1-in.
Overflow Volume	1,137-gal.
Design Specific Gravity	1.5
Maximum Bottom Pressure	10.8-psi
Maximum Operating Temperature	300° F
Construction Material:	
Flue	ASTM A36
Shell	ASTM 316L
Bottom	ASTM 316L
Skirt	ASTM A36
Flanges, Blinds, Coupler and Plugs	ASTM 316L
Bolts	SA 193-B7/SA 194-2H
Wall Thickness (Shell and Bottom)	0.250-in.
Operating Pressure	Atmospheric
Seismic Zone	1

- \* The maximum capacity of the assessed tank is the same as the original tank, however the original tank assessment indicates otherwise. There appears to have been an error in the original assessment's volume calculations.

**2.9 Calculation of Existing Foundation Loading.**

Total Weight of Tank and Contents (maximum volume) 59,406-lb.

Detailed calculations reflecting the volume and weight of the tank are included in *Appendix D* of this assessment.



- 2.10 Required Structural Calculation.** Calculations for the required wall thickness for this tank are presented in *Appendix D* of this assessment. Metallurgical information on the materials used is included in *Appendix E* of this assessment. The minimum required thickness in accordance with API 650 is 0.1875-in. A corrosion allowance of 0.125 is provided for. The measured wall thickness is 0.25-in.

Design calculations for the support structure are included in *Appendix F* of this assessment. These calculations were completed in accordance with the BOCA National Building Code 1990 Edition and were part of a previous tank assessment prepared by Black and Veach. The structural support was inspected and no changes have been made since the date of the Black and Veach assessment.

Structural analysis of the foundation is included in *Appendix G* of this assessment.

**2.11 Comparison of Actual to Theoretical Structural Values.**

(a) *Wall Thickness Comparison:*

Calculated Required Wall Thickness (includes corrosion allowance)	0.156-in.
Minimum Required Wall Thickness by API 650	0.1875-in.
Measured Wall Thickness	0.250-in.

(b) *Bottom Thickness Comparison:*

Calculated Required Bottom Thickness	0.151-in.
Minimum Required Bottom Thickness by API 650	0.250-in.
Measured Bottom Thickness	0.250-in.

(c) *Foundation Integrity Comparison:*

Maximum Calculated Load (6-in. Slab)	17.6 Kips
Calculated Foundation Support (6-in. Slab)	26.7 Kips
Maximum Calculated Load (17-in. Slab)	62.9 Kips
Calculated Foundation Support (17-in. Slab)	127.7 Kips

- 2.12 Ancillary Equipment.** The ancillary equipment for the Evaporator Flash Tank No. 1 (FT 1) system includes the following:

- (a) *Circulating Pump (P 78).* A centrifugal pump designed to pump 800-GPM at 150-ft. of discharge head with a suction head of 11-ft.
- (b) *Heat Exchanger (EU 1).* A plate and frame unit of stainless steel construction designed to operate at a pressure of 150-PSIG and a temperature of 300° F.
- (c) *Pump (P 80).* A pneumatically-operated, double-diaphragm pump designed to pump from 100- to 0-GPM at head pressures varying from 0- to 100-PSIG, pumping fluid at a temperature up to 212° F.
- (d) *Filter Press (FP 1).* A gasketed unit employing glass-filled polypropylene plates designed to operate at a temperature/pressure limit of 100-psi at 212° F.
- (e) *Associated Piping, Valves, and Instruments.* All piping is Schedule 40 carbon steel fitted with 150-psi flanges. All piping with an inside diameter of 2-in. or smaller is socket-welded using, at minimum, 3,000-lb. connections. All piping with an inside diameter greater than 2-in. is butt-welded. All valves, fittings, and instruments are rated for 150-psi or higher.



**Note:** Items (a) - (c) are part of the tank system. However, no changes were made to them during the installation of the new FT 1 tank.

### 3. SECONDARY CONTAINMENT SYSTEM

- 3.1 General Description of Secondary Containment.** The secondary containment system is designed and operated to prevent migration of wastes or liquids out of the system. Evaporator Flash Tank Nos. 1, 2 and 3, Evaporator Blowdown Tank No. 2, and Evaporator Feed Tank No. 4 are located on a reinforced concrete base floor area with vertical concrete sidewalls. This area is inspected daily on a routine basis.

At the time of inspection, the concrete area was withstanding daily operations and routine climatic conditions. No cracks from compression or uplift were visually apparent.

Any released tank contents are removed and pumped to an appropriate storage area within the maximum time allowed as a permit condition.

- 3.2 Corrosion Protection.** There is an impermeable coating applied to the entire concrete floor and curbs. Detailed information on the coatings employed is included in *Appendix H* of this assessment.
- 3.3 Documented Age of the Containment Area.** The concrete secondary containment system was constructed and installed in 1987.
- 3.4 Results of Leak Tests.** A visual inspection of the containment area was conducted and no cracks or breaks in the impermeable coating were observed. Therefore, it appears to be adequate to contain any leaks or spills.
- 3.5 Calculation of Capacity Available (CCA).**

Area .....	2,739-sf
Curb Height .....	0.25-ft.
Material .....	Concrete
Gross Volume .....	685-cf

**Note:** See *Appendix I* for secondary containment.

- 3.6 Required Volume.**

- (a) *Containment Capacity Required (CCR):*

CCR = Volume of Largest Tank (Overflow Volume) in the Secondary Containment

Volume of Largest Tank = (FT1) ..... 506.cf

- 3.7 Comparison of Available Volume to Required Volume.**

- (a) *Containment Capacity Available (CCA):*

Containment Capacity Required (CCR) .....	506-cf
Secondary Containment Volume Available .....	685-cf
Excess Containment Volume .....	179-cf

CCA > CCR Adequate Capacity (under normal operating conditions is available.)

**Note:** See *Appendix I* for secondary containment calculations.



#### 4. CONCLUSIONS

The foundation and structural support for the Evaporator Flash Tank No. 1 (FT1) system have been previously analyzed, reviewed, and deemed to be adequately designed.

The Evaporator Flash Tank No. 1 (FT 1) system has sufficient structural strength, is compatible with the waste to be stored and treated, and has adequate corrosion protection to ensure that it will not collapse, rupture, or fail.

The Evaporator Flash Tank No. 1 (FT 1) system was inspected on July 18, 2002, for weld breaks, punctures, scrapes of protective coating, cracks, leaks, corrosion, and other structural damage or inadequacies of construction/installation.

The Evaporator Flash Tank No. 1 (FT 1) equipment was hydrostatically tested on July 18, 2002, and it was determined that the tank does not leak.

The Secondary Containment for the Evaporator Flash Tank No. 1 (FT 1) system is of sufficient structural strength and volume to meet the requirements set forth in 40 CFR 264.193.

#### 5. RECOMMENDATIONS

Due to a previous history with interior deterioration of the Evaporator Flash Tank No. 1 (FT 1), the following recommendations are suggested:

- ☐ Visual inspections of the tank interior subsequent to the initial 6-mo. of operation.
- ☐ Annual visual inspections of the tank interior subsequent to the initial 6-mo. inspection.
- ☐ Perform an ultrasonic survey of the tank shell subsequent to 5-yr. of operation to determine the average shell thickness.

#### 6. CERTIFICATION

*"I certify under penalty of law that this document and all attachments were prepared under my direction or supervision, in accordance with a system designed to ensure that qualified personnel properly collect and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for collecting the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.*



8/5/02



Rob L. Stallings, P.E.  
Envirotech Engineering & Consulting, Inc.

C.A. 1960 - Expiration Date 06/30/03












SKIRT & BASE PLATE DETAIL



1/2" SA-36 FLANGE  
(COVER TO BE SUPPLIED  
BY CUSTOMER)



DO NOT FABRICATE FLANGE RING UNTIL RECEIPT OF  
CUSTOMER FURNISHED BLINDS OR TEMPLATE.

SPLASH DEFLECTOR

(3 TYP.)

MANWAY DETAIL

(3 TYP.)



2500 North 30th Street - Fort Collins, CO 80501  
Phone (970) 224-8700 Fax (970) 227-4302  
CA #8551 Expiration Date 6-30-2002  
www.envirotechconsulting.com

3	5/21/02	CERTIFIED - AS BUILT
2	2/26/02	REVISED PER CUSTOMER COMMENTS
1	1/23/02	REVISED PER CUSTOMER COMMENTS
0	1/04/02	ISSUED FOR APPROVAL

DRAWN BY: JED	JOB NO.: 203
CHECKED BY: BDL	DATE: 1/04/02

PURCHASE ORDER NO. 102034	PROG. NO. CAPITAL	DRAWING NAME: SK-001
---------------------------	-------------------	----------------------

SAFETY - KLEEN




CAPITAL PROJECT / LONE MOUNTAIN FACILITY  
TWO 6'-4" O.D. X 20'-6" TALL STAINLESS STEEL FLASH TANK

LIDE INDUSTRIES

8 MILLES E. HWY 84  
MEXIA, TEXAS 76667

SHEET 2 OF 3






TOP FLUE FLANGE CONNECTION

INFLUENT CONNECTION (NOZZLE "7") DETAIL

5/8" Ø HOLE FOR 1/2" BOLT  
(2 TYP. PER ANGLE)



CLIP "A1" DETAIL

3/8" X 2" X 2" CLIP  
(316L)

3/8" X 2" F.B. RING  
(316L)

OPENING IN TOP RING  
45°



2" X 2" X 3/8" ANGLE  
(316L)

SEE CLIP "A1"  
3/8" X 2" F.B. RING  
(316L)

FLEXIMESH MIST ELIMINATOR  
(SUPPLIED BY CUST.)

BOTTOM GRID


TOP OF MESH PAD SUPPORT

15°

2" X 2" X 3/8" ANGLE  
(316L)

3/8" X 2" F.B. RING  
(316L)

2" X 2" X 3/8" ANGLE  
(316L)



MIST PAD DETAIL

NO.	DATE	REVISIONS
2	5/21/02	CERTIFIED - AS BUILT
1	1/23/02	REVISED PER CUSTOMER COMMENTS
0	1/04/02	ISSUED FOR APPROVAL

DRAWN BY: JED	JOB NO.: 203
CHECKED BY: BDL	DATE: 1/04/02
PURCHASE ORDER NO. 103034	
PROG. NO. CAPITAL DRAWING NAME: SK-001	

CAPITAL PROJECT / LONE MOUNTAIN FACILITY  
TWO 6'-4" O.D. X 20'-6" TALL STAINLESS STEEL FLASH TANK

**LIDE INDUSTRIES**

8 MILES E. HWY 84  
MEXIA, TEXAS 76667

**ENVIROTECH**  
ENGINEERING & CONSULTING, INC.

7320 North 8th Street - Fort Belknap 73010  
Phone (800) 241-8700 Fax (800) 221-4262  
C/A MS&D Operations Dept. 5-80 2003  
www.envirotech.com/usa/eng.htm



# ***APPENDIX A.***

## **PRIMARY TANK VOLUME CALCULATIONS**



---

## APPENDIX A.

### PRIMARY TANK VOLUME CALCULATIONS For EVAPORATOR FEED TANK NO. 2 (EF2)

---

☐ **DIMENSIONS:**

Geometry: Cylindrical  
Diameter: 60.00-ft.  
Height: 16.90-ft.  
Operating Height: 15.50-ft.  
Bottom: Flat

☐ **TANK VOLUME:**

Maximum Volume = 47,785.26-cf = 357,458.57-gal.  
Operating Volume = 43,826.72-cf = 327,846.63-gal.  
  
Total Primary Tank Volume = 47,785.26-cf = 357,458.57-gal.

☐ **WEIGHT ON FOUNDATION:**

Contents S.G. 1.3  
Density 81.12-lb/cf

☐ **SURFACE AREA CALCULATION:**

Tank Top = n/a  
Tank Bottom = 2,827.53-sf  
Tank Wall = 3,185.68-sf

Total Surface Area = 6,013.21-sf

Steel Thickness: Sidewalls = 0.250-in.  
Bottom = 0.240-in.

Volume of Steel: Sidewalls = 66.37-cf  
Bottom = 56.55-cf

Density of Steel = 490-lb/cf

Weight of Steel (Tank): = 30.12-ton = 60,230.32-lb.

Weight of Tank Contents = 1,938-ton = 3,876,340-lb.

Total Weight of Tank and Contents = 1,968-ton = 3,936,570-lb.



# ***APPENDIX B.***

## **PRIMARY TANK WALL THICKNESS**



---

## APPENDIX B.

### PRIMARY TANK WALL THICKNESS For EVAPORATOR FEED TANK NO. 2 (EF2)

---

☐ **DIMENSIONS:**

Geometry:	Cylindrical
Diameter:	60.00-ft
Height:	16.90-ft
Specific Gravity:	1.30
Normal Operating Temperature:	Ambient

☐ **STEEL THICKNESS CALCULATIONS:**

$$\text{Thickness (t)} = (2.6 * H * D * S.G.) / (s * E) + CA$$

s	=	Allowable Design Stress	=	23,200.00-psi
E	=	Joint Efficiency	=	85.00%
Thickness (t)			=	0.1738-in.
Corrosion Allowance			=	0.0625-in.
Calculated Minimum Wall Thickness			=	0.2363-in.



# ***APPENDIX C.***

## **SEISMIC CALCULATIONS**



## APPENDIX C.

### SEISMIC CALCULATIONS For EVAPORATOR FEED TANK NO. 2 (EF2)

#### ☐ DIMENSIONS:

Diameter: 60.00-ft.  
Height: 16.90-ft.  
Weight of Tank (Steel): 60,230.32-lb.  
Weight of Maximum Contents: 3,876,340.00-lb.  
Tank Shell Thickness: 0.25-in.  
Tank Bottom Thickness: 0.240-in.

#### ☐ STRESS IN TANK SHELL FROM SEISMIC FORCES:

Maximum weight of tank contents that may be used to resist shell overturning moment: WI

$$WI = 7.9 * tb * (Fby * G * H)^{.5}$$

$$Fby = \text{Minimum Yield Strength in Bottom Plate} \quad 36,000.00$$

$$tb = \text{Thickness of Tank Bottom} \quad 0.240$$

$$G = \text{Design Specific Gravity of Liquid} \quad 1.3$$

$$WI = 1686.18$$

$$\text{Note: } WI \text{ Shall Not Exceed } 1.25 * G * H * D \quad 1,647.75\text{-lb/ft. of Shell Circumference}$$

$$\text{Density of Tank Shell Material} \quad 490.00\text{-lb/cf}$$

$$WT = \text{Weight of Tank Shell} \quad 172.52\text{-lb/ft. of Shell Circumference}$$

$$M[D^2(WT+WI)] \quad 0.1071$$

$$b = \text{Maximum Longitudinal Compressive Force at the Bottom of Tank Shell}$$

$$b = WT + 1.273 * M/D^2$$

$$b = 420.63\text{-lb/ft. of Shell}$$

$$G * H * D^2 / t^2 = 1,265,472$$

$$Fa = 10^6 * t / D = 4,167\text{-psi}$$

OR

$$Fa = .5 * Fty = 18,000\text{-psi}$$

$$\text{Use Minimum Value for } Fa \quad Fa = 4,167\text{-psi}$$

$$b/12 * t = 140.21\text{-psi}$$

Note:  $b/12t$  Cannot Exceed  $Fa$  for a Stable Tank





### OVERTURNING MOMENT:

Overturing Moment (M)	=	$Z \cdot I \cdot (C1 \cdot Ws \cdot Xs + C1 \cdot W1 \cdot X1 + C2 \cdot W2 \cdot X2)$
Zone Coefficient (Z)	=	0.1875
Essential Facilities Factor (I)	=	1.000
Lateral Earthquake Force Coefficient (C1)	=	0.240
D/H	=	3.55
k Factor (@ D/H = 3.55)	=	0.680
Site Amplification Factor (S)	=	1.5
Natural Period of First Sloshing Mode (T)	=	5.11
Lateral Earthquake Force Coefficient (C2)	=	0.07755
Weight of Tank (Ws)	=	60,230.32
Weight of Tank Contents (Wt)	=	3,876,340.00
W1 / Wt (@ D/H = 3.55)	=	0.32
W2 / Wt (@ D/H = 3.55)	=	0.60
Weight of Effective Mass (W1)	=	1,240,428.80
Weight of Effective Mass (W2)	=	2,325,804.00
Ht from Btm of Shell to Cent. of Shell (Xs)	=	8.45
X1/H	=	0.38
Ht from Btm of Cent. of Lat Seismic Force (X1)	=	6.422
X2/H	=	0.55
Ht from Btm of Cent. of Lat. Seismic Force (X2)	=	9.295
Overturing Moment	M	= 695,718-ft/lb.
Opposing Moment	M*	= 118,097,110-ft/lb.



# ***APPENDIX D.***

## **WIND LOAD CALCULATIONS**



---

## APPENDIX D.

### WIND LOAD CALCULATIONS For EVAPORATOR FEED TANK NO. 2 (EF2)

---

☐ **DIMENSIONS:**

Diameter:	60.00-ft.
Height:	16.90-ft.
Weight of Tank (Steel):	60,230.32-lb.
Weight of Max. Contents:	3,876,340.00-lb.
Tank Shell Thickness:	0.25-in.
Tank Bottom Thickness:	0.240-in.

☐ **OVERTURNING MOMENT FROM WIND LOADS:**

M	=	Overturning Moment Due to Wind Loading	
M	=	$P_w * A_p * H_c$	
P <sub>w</sub>	=	Wind Pressure (Assume 18-psi for 100-MPH Wind on Cylinders)	= 18.00-psi
A <sub>p</sub>	=	Projected Frontal Area of Tank (H*D)	= 1,014-Ft <sup>2</sup>
H <sub>1</sub>	=	Height from Ground to Centroid of Tank	= 8.45-ft
M	=	Overturning Moment	154,229.40-ft-lb.
M Max	=	Returning Moment	.66*(WD)/2
W	=	Wt of Tank	= 60,230.32-lb.
M Max	=		1,192,560-ft-lb.

*M Must Be Less Than M Max*



# ***APPENDIX E.***

## **FOUNDATION INTEGRITY MONITORING DOCUMENTS**



## Annual Tank In-Service Inspection Checklist

Tank Name: EF-2 Tank Number: # 2  
Tank Location: WWPT Date: 06-11-01  
Inspected By: TERRY L. Phillips Signature: Terry L. Phillips  
Date of Last Inspection: 03-07-01

## Foundation

- A. Measure foundation levelness and bottom elevations (8 points for EF-1 and 9 points for EF-2).  
Note: No other tanks require foundation levelness and elevation survey.

## EF-1:

37 \_\_\_\_\_ 47 \_\_\_\_\_ 55 \_\_\_\_\_ 263 \_\_\_\_\_  
271 \_\_\_\_\_ 279 \_\_\_\_\_ 293 \_\_\_\_\_ 303 \_\_\_\_\_

## EF-2:

65 1425.84 73 1425.74 81 1425.78 89 1425.86 191 1425.71  
205 1425.63 211 1425.70 219 1425.77 227 1425.78

- B. Has the yearly maximum settlement exceeded 1 inch? (EF-1 and EF-2 only)

## EF-1:

## EF-2:

Yes \_\_\_\_\_ No \_\_\_\_\_ Yes \_\_\_\_\_ No \_\_\_\_\_

- C. Check 8 inch annular channel for deflection of more than 2 degrees from its correct position. (EF-1 only)

Deflection \_\_\_\_\_

Comments: \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_



## Annual Tank In-Service Inspection Checklist

Tank Name: EF-2 Tank Number: # 2  
Tank Location: WWPT Date: 4-17-02  
Inspected By: \_\_\_\_\_ Signature: \_\_\_\_\_  
Date of Last Inspection: \_\_\_\_\_

## I. Foundation

- A. Measure foundation levelness and bottom elevations (8 points for EF-1 and 9 points for EF-2).  
Note: No other tanks require foundation levelness and elevation survey

EF-1:

37 \_\_\_\_\_ 47 \_\_\_\_\_ 55 \_\_\_\_\_ 263 \_\_\_\_\_  
271 \_\_\_\_\_ 279 \_\_\_\_\_ 293 \_\_\_\_\_ 303 \_\_\_\_\_

EF-2:

65 1425.80 73 1425.92 81 1425.98 89 1425.84 191 1425.66  
205 1425.58 211 1425.65 219 1425.74 227 1425.75

- B. Has the yearly maximum settlement exceeded 1 inch? (EF-1 and EF-2 only)

EF-1:

Yes \_\_\_\_\_

No \_\_\_\_\_

EF-2:

Yes \_\_\_\_\_

No X

- C. Check 8 inch annular channel for deflection of more than 2 degrees from its correct position. (EF-1 only)

Deflection \_\_\_\_\_

Comments: \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_



## Annual Tank In-Service Inspection Checklist

Tank Name: EF-2 Tank Number: # 2  
Tank Location: WWPT Date: 4-14-04  
Inspected By: \_\_\_\_\_ Signature: \_\_\_\_\_  
Date of Last Inspection: \_\_\_\_\_

## I. Foundation

- A. Measure foundation levelness and bottom elevations (8 points for EF-1 and 9 points for EF-2).  
Note: No other tanks require foundation levelness and elevation survey.

EF-1:

37 \_\_\_\_\_ 47 \_\_\_\_\_ 55 \_\_\_\_\_ 263 \_\_\_\_\_  
271 \_\_\_\_\_ 279 \_\_\_\_\_ 293 \_\_\_\_\_ 303 \_\_\_\_\_

EF-2:

65 1425.82 73 1425.94 81 1425.99 89 1425.86 191 1425.69  
205 1425.61 211 1425.67 219 1425.76 227 1425.76

- B. Has the yearly maximum settlement exceeded 1 inch? (EF-1 and EF-2 only)

EF-1:

Yes \_\_\_\_\_ No \_\_\_\_\_

EF-2:

Yes \_\_\_\_\_ No X

- C. Check 8 inch annular channel for deflection of more than 2 degrees from its correct position. (EF-1 only)

Deflection \_\_\_\_\_

Comments: \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_



## Annual Tank In-Service Inspection Checklist

Tank Name: EF-2 Tank Number: # 2  
Tank Location: WWPT Date: 4/24/06  
Inspected By: \_\_\_\_\_ Signature: \_\_\_\_\_  
Date of Last Inspection: ~~4-24-06~~ 4/14/04

## I. Foundation

- A. Measure foundation levelness and bottom elevations (8 points for EF-1 and 9 points for EF-2)  
Note: No other tanks require foundation levelness and elevation survey.

EF-1:

37 \_\_\_\_\_ 47 \_\_\_\_\_ 55 \_\_\_\_\_ 263 \_\_\_\_\_  
271 \_\_\_\_\_ 279 \_\_\_\_\_ 293 \_\_\_\_\_ 303 \_\_\_\_\_

EF-2:

65 1425.78 73 1425.90 81 1425.93 89 1425.80 191 1425.67  
205 1425.58 211 1425.67 219 1425.73 227 1425.72

- B Has the yearly maximum settlement exceeded 1 inch? (EF-1 and EF-2 only)

EF-1:EF-2:

Yes \_\_\_\_\_ No \_\_\_\_\_ Yes \_\_\_\_\_ No \_\_\_\_\_

- C. Check 8 inch annular channel for deflection of more than 2 degrees from its correct position. (EF-1 only)

Deflection \_\_\_\_\_

Comments: \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_



# ***APPENDIX F.***

## **LAW ENGINEERING GEOTECHNICAL REPORT**



November 22, 1993



**LAW**

ENGINEERING AND ENVIRONMENTAL SERVICES

Mr. Walter Sonne, P.E.  
USPCI, Inc.  
515 West Greens Road, Suite 500  
Houston, Texas 77067

**SUBJECT: REVISED REPORT OF GEOTECHNICAL EXPLORATION**  
Expansion of Wastewater Treatment Facilities--  
Lone Mountain Facility, Major County, Oklahoma  
Law Engineering Projects No. 392-01406-01

Law Engineering, Inc. has completed the geotechnical exploration at the subject site. Our services were provided in accordance with our Revised Proposal for Geotechnical Exploration Services No. HP-8173-93G, dated September 22, 1993; and a Request for Change Order letter dated October 12, 1993. This report briefly discusses our understanding of the project information, describes our exploratory procedures and findings, and presents our recommendations and conclusions. The data obtained during the field exploration and from the laboratory testing program is presented in the appendices.

We will be happy to discuss our recommendations with you and would welcome the opportunity to provide the additional studies or construction testing services necessary to complete this project. We look forward to serving as your geotechnical engineer on the remainder of this project and on future projects.

If you have any questions, or if you require additional information, please do not hesitate to contact us.

Sincerely,

**LAW ENGINEERING, INC.**

*Fernando Pons*  
Fernando Pons, E.I.  
Project Geotechnical Engineer

*Michael W. Palmer*  
Michael W. Palmer, P.E.  
Principal Geotechnical Engineer  
USPCI - Client Manager

*Michael H. Homan*  
Michael H. Homan, P.E.  
Principal Geotechnical Engineer  
Oklahoma Registration No. 15777


Distribution Copies:

Walter Sonne (2) - USPCI  
Larry Marr (1) - USPCI

LAW COMPANIES GROUP, INC.

5500 GULF ROAD • HOUSTON, TX 77040  
(713) 939-8444 • FAX (713) 462-1653





LAW ENGINEERING

REVISED REPORT OF GEOTECHNICAL EXPLORATION

EXPANSION  
OF WASTEWATER TREATMENT FACILITIES

LONE MOUNTAIN FACILITY  
MAJOR COUNTY, OKLAHOMA

prepared for  
USPCI, Inc.  
HOUSTON, TEXAS

LAW ENGINEERING PROJECT NO. 392-1406-01

NOVEMBER 1993



## Expansion of Wastewater Facilities

USPCI, Inc.

Law Eng. Proj. No. 392-01406-01

### 1.0 PURPOSE OF EXPLORATION

The purpose of this exploration was to obtain specific subsurface data at the site and to provide recommendations and opinions for:

- ~~o General geotechnical design and construction criteria for the Expansion of Wastewater Final Treatment Facilities (WWFT): Phase I (Expansion of the WWFT Building) and Phase II (Leachate Storage Tanks).~~
- ~~o Site preparation and construction of compacted fills for the WWFT Phase I, and the WWFT Phase II.~~
- o Soil stratigraphy at the Wastewater Pretreatment Facilities (WWPT): Phase III tanks.

It should be noted that it was not the purpose of this study to directly assess or to address any environmental conditions at the site, i.e., the presence of contaminants or substances in the soil, rock, or ground water. An additional study should be undertaken if USPCI decides to specifically address environmental conditions.



Expansion of Wastewater Facilities

PCI, Inc.

Law Eng. Proj. No. 392-01406-01

## ~~2.2 LEACHATE STORAGE TANKS~~

~~We understand that USPCI plans to construct three tanks within a containment area. The proposed site of construction is south of Cell 4. The proposed tanks will include a 60-foot diameter, 16-foot tall, 300,000 gallon tank; and two 33-foot diameter, 16-foot tall, 100,000 gallon tanks.~~

~~The proposed tanks, containing leachate with a specific gravity of 1.3, will be located within a concrete containment structure with walls on the order of 7 feet in height.~~

~~We understand that the preferred foundation system at the present time is a drilled pier underground system, 18-inch diameter, straight-sided drilled piers founded at 8-feet on centers. In turn, these drilled piers will support the containment wall and a 10-inch thick concrete slab on 6 inches of sand and 24 inches of structural fill.~~

## 2.3 WASTEWATER PRETREATMENT (WWPT) BUILDING

We understand that two existing on-line 300,000 storage tanks structures within the Wastewater Pretreatment (WWPT) Building are experiencing foundation distress. We further understand that these two tanks and the containment area are supported on shallow footings.



#### 4.1.3 Wastewater Pretreatment (WWPT) Building

Exploration borings L-5, L-6, L-6A, and L-7 were drilled in this area. The measured surface elevation of these borings were 1418.35, 1428.62, 1428.48, and 1430.23 feet MSL, respectively, as provided by USPCI. The subsurface conditions for this area are generalized as follows:

#### AREA C

#### WASTEWATER PRETREATMENT BUILDING

(Borings L-5, L-6, L-6A, and L-7)

STRATUM	DEPTH (ft)	DESCRIPTION	USCS CLASSIFICATION <sup>2</sup>
I C	0 to 2	FILL: GRAVEL	Unclassified
II C	1 to 22.5	FILL: Soft to hard, reddish brown with gray, silty CLAY, with gypsum fragments and gravel.	CL
III C	15.5 to 20.5	Very stiff to hard, reddish brown with gray, silty CLAY, with gypsum fragments and gray silt streaks.	CL
IV C	18.5 to TOB <sup>1</sup>	Gray silty CLAYSTONE to reddish brown silty CLAYSTONE	Unclassified

<sup>1</sup> Termination of Boring

<sup>2</sup> Unified Soil Classification System



Expansion of Wastewater Facilities

CI, Inc.

Law Eng. Proj. No: 392-01406-01

With reference to the Soil Stratum Summary, the TEST BORING RECORDS, Soil Profiles and the Laboratory Test Results, our discussion of the soil conditions for Area C is as follows:

Stratum IC consists of GRAVEL to gravelly fill soils encountered in all borings from a existing surface to approximately 2 feet below existing grade.

Stratum IIC consists of fill soils of soft to hard, reddish brown with gray, silty CLAY with gypsum fragments and gravel. Law personnel performed continuous sampling with Shelby tubes, and utilized on-site extruding techniques to better identify the extent of this fill stratum. These fill soils were encountered from a depth of 1 foot from existing surface to 22.5 feet below grade. Organic odor and wet seams were identified in the lower two feet of this formation in Borings L-6 and L-7. Plasticity for this stratum was medium with plasticity index values ranging from 17 to 21. Liquid limit values range from 43 to 45 percent and plastic limit values range from 24 percent to 26 percent. Stratum IIC soils were generally moist with occasional wet seams. Natural moisture contents ranged from 24 to 30 percent, and were from 0 to 2 percent above corresponding PL values.

Pocket penetrometer tests and laboratory unconfined compression tests, on relatively undisturbed samples, indicated shear strength values that varied erratically throughout the fill depth in Boring L-5 (easternmost boring). Shear strength values in Borings L-6 and L-7 were similar throughout the same depths of the fill stratum. There was a similar uniform decrease of shear strength values with depth in Borings L-6 and L-7 to a depth of approximately 12.5 feet. (See TEST BORING RECORDS L-6 and L-7).

Stratum IIIC consists of very stiff to hard, reddish brown with gray, silty CLAY with gypsum fragments and gray silt streaks. These soils were encountered in all borings, except Boring L-5, from 15.5 feet from existing surface to a depth of 20.5 feet below grade. One Standard Penetration Test N-value was 40 blows per foot (bpf) at a depth of 17 feet in Boring L-6A. Plasticity for this stratum was medium with a plasticity index value of 13, a LL value of 32 percent, and a PL value of 19 percent. One natural moisture content was 24 percent. Based on this natural moisture content and corresponding Atterberg Limit tests, the soil was very moist with a moisture content 5 percent above the corresponding PL value. Pocket penetrometer tests resulted in cohesion values ranging from 3,750 psf to an excess of 4,500 psf.



Expansion of Wastewater Facilities

PCI, Inc.

Law Eng. Proj. No. 392-01406-01

Stratum IV consists of gray silty CLAYSTONE to reddish brown silty CLAYSTONE. This formation was encountered from a depth of 18.5 feet below existing surface to termination depth. Standard Penetration Test N-values resulted in refusal values ranging from 6 inches per 50 blows to 4.5 inches per 50 blows. One natural moisture content was 21 percent. All pocket penetrometer tests resulted in cohesion values in excess of 4,500 psf.

#### 4.2 WATER LEVEL CONDITIONS

~~Water level observations were made in the boreholes during drilling operations and 24 hours after completion of drilling to investigate the short term ground water levels.~~

~~Ground water was identified during our subsurface exploration at depths of 7 feet and 5.5 feet in Borings L-1 and L-2A, respectively (24 hour readings). Ground water was encountered 1.5-feet to 1-foot above the top of the claystone formation in these borings.~~

~~Borings L-3 and L-4 were dry at the time of drilling and 24 hours thereafter.~~

Water was identified during drilling at a depth of 24 feet below existing ground surface in Boring L-5. Boring L-6 was dry to termination depth during drilling operations and 24 hours thereafter. Ground water was not identified in Borings L-6A and L-7 during and immediately following drilling operations. Law personnel could not obtain 24 hour water level readings at L-5, L-6A, or L-7, due to caving soils in L-5 at 15.8 feet, and surficial cuttings that obstructing the boreholes at L-6A and L-7.

Fluctuations in rainfall, evaporation, construction activity, surface runoff, and other site specific factors could cause ground water conditions at the time of construction to vary from that observed during our field exploration.



Expansion of Wastewater Facilities

PCI, Inc.

Law Eng. Proj. No. 392-01406-01

#### ~~5.4.3 Settlement~~

~~Predicted settlements for the drilled piers will be relatively small and are expected to be limited to the elastic compression of the founding claystone formation. The maximum total settlement of any drilled shaft under the anticipated sustained loading conditions is predicted to be less than 0.25 inch.~~

#### 5.5 CONSTRUCTION CONSIDERATIONS

Once a foundation excavation is completed, the setting of reinforcing steel and placement of concrete should proceed expeditiously to reduce exposure of the bearing stratum and possible disturbance of the material. Should the bottom of an excavation become disturbed due to ponding of water or desiccation, the disturbed soils should be removed before concrete is placed.

~~I recommend that the geotechnical engineer, or their representative, observe the foundation excavations immediately prior to placing concrete. The engineer should compare the soils exposed with those encountered in the soil test borings and document the results. Any significant differences should be brought to the attention of the Owner's representatives along with appropriate recommendations. The foundation bearing area should be level or suitably benched. It should also be free of loose soil, ponded water and debris prior to the inspection.~~

#### 5.6 WASTEWATER PRETREATMENT BUILDING STRATIGRAPHY

We understand that two existing on-line 300,000 storage tanks structures within the Wastewater Pretreatment (WWPT) Building are experiencing foundation distress. We further understand that these two tanks and the containment area are supported on shallow footings, which are currently bearing in fill soils consisting of soft to hard, reddish brown with gray, silty CLAY with gypsum fragments and gravel (Stratum IIC).



Expansion of Wastewater Facilities

PCI, Inc.


Law Eng. Proj. No. 392-01406-01

As discussed previously in this report, the soil stratigraphy encountered in the WWPT area generally consists of silty fill soils to a maximum depth of 22.5 feet underlain by silty clay soils which grade into claystone. Law personnel performed continuous sampling in Borings L-5, L-6, and L-7 and utilized shelly tubes and on-site extruding techniques to better identify the extent of this fill stratum.

The properties of the soils, deemed significant in the evaluation of distress of the structures, are the following:

- (a) the moist condition of the silty clay fill soils (Stratum IIC) at the site;
- (b) the medium shrink-swell potential of the silty clay matrix within the zone of major seasonal moisture change;
- (c) the erratic variation in consistency of the fill soils encountered in Boring L-5;
- (d) the similar uniform decrease in shear strength in Borings L-6 and L-7 to a minimum at approximately 13 feet from existing ground level;
- (e) the presence of wet seams, organics, and organic odor in the fill soils of Boring L-6 and Boring L-5;
- (f) the presence of ground water in Boring L-5 at a depth of 24.5 feet;







DESCRIPTION OF MATERIAL	DEPTH (ft)	ELEVATION	SAMPLES / TESTS				Plastic Limit(%)    NM (%)    Liquid Limit(%) +-----+-----+ △ ⊗ ⊕ COHESION (100 psf) ● PENETRATION (bpf)													
			DEPTH (ft)	Sample		Test														
				Type	No.	Dry density (pcf)	% Fines	10	20	30	40	50	60	70	80	90				
SURF. EL: 1430.23 ft. MSL																				
GRAVEL																				
Soft to hard, reddish-brown with some gray CLAY with gypsum fragments and			3.0		1									⊗						
	5	1425.2	5.0		2									⊗						
			7.0		3								⊗							
			9.0		4	102.9					⊗	⊕		+						
	10	1420.2	11.0		5						⊗									
			13.0		6						⊗									
			15.0		7							⊕								
Stiff to hard, reddish-brown with gray, silty		1415.2	17.0		8									⊗						
Stiff, gray silty CLAY with gypsum fragments, very moist			19.0		9							+	⊕	+						
	20	1410.2	21.0		10															
Gray CLAYSTONE																				
Brown silty CLAYSTONE																				
Boring terminated at 25 feet	25	1405.2			11															

NOTES: N10920.34 E9182.90. Borehole advanced by 75 truck-mounted drill rig using 3 1/4" I.D. hollow

Arnold Caesar  
Fernando Pons

SEE KEY SHEET FOR EXPLANATION OF SYMBOLS AND ABBREVIATIONS USED ABOVE

TEST BORING RECORD	
BORING NUMBER	L-7
DATES DRILLED	Start: October 1, 1993 Complete: October 1, 1993
PROJECT NUMBER	392-01406-01
PROJECT	Expansion of WWT Facilities
PAGE 1 OF 1	
LAW ENGINEERING	



DESCRIPTION OF MATERIAL	DEPTH (ft)	ELEVATION	SAMPLES / TESTS				Plastic Limit(%) NM(%) Liquid Limit(%)									
			DEPTH (ft)	Sample		Test	+---+---+ △⊗⊕ COHESION (100 psf) ● PENETRATION (bp)									
				Type	No.		10 20 30 40 50 60 70 80 90									
SURF. EL: 1428.48 ft. MSL																
LEVEL																
ery Stiff to soft, reddish brown, silty with gypsum fragments and gravel																
	5	1423.5-														
	10	1418.5-														
	15	1413.5-														
rown with some gray, silty CLAY with y silt streaks			17.0		1											
CLAYSTONE			19.0		2											
rown silty CLAYSTONE	20	1408.5-														
	25	1403.5-			3											
Boring terminated at 25 feet																

NOTES: N10829.08 E9253.23. Borehole advanced 5' truck-mounted drill rig using 3 1/4" I.D. hollow Soil classification from 0 to 16 feet is based on

Arnold Caesar  
Bernardo Pons

SEE KEY SHEET FOR EXPLANATION OF SYMBOLS AND ABBREVIATIONS USED ABOVE

TEST BORING RECORD	
BORING NUMBER	L-6A
DATES DRILLED	Start: October 1, 1993 Complete: October 1, 1993
PROJECT NUMBER	392-01406-01
PROJECT	Expansion of WWT Facilities
PAGE 1 OF 1	
LAW ENGINEERING Tulsa, Oklahoma	



DESCRIPTION OF MATERIAL	DZM (mm)	DEPTH (ft)	ELEVATION	SAMPLES / TESTS				Plastic Limit(%) NM (%) Liquid Limit(%)																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																													
				Sample		Test		+---+---+ △ ⊗ ⊕ COHESION (100 psf) ● PENETRATION (bpf)																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																													
				Type	No.	Dry density (pcf)	% Fines	10	20	30	40	50	60	70	80	90																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																					
SURF. EL: 1423.62 ft. MSL																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																					

KS:  
 NOTES: N10826.86 E9250.81. Borehole advanced  
 -75 truck-mounted drill rig using 3 1/4" I.D. hollow  
 ers. Borehole dry 24 hours after drilling.

Arnold Caesar  
 odo Pons

TEST BORING RECORD	
BORING NUMBER	L-6
DATES DRILLED	Start: October 1, 1993 Complete: October 1, 1993
PROJECT NUMBER	392-01406-01
PROJECT	Expansion of WWT Facilities
PAGE 1 OF 1	
LAW ENGINEERING	

SEE KEY SHEET FOR EXPLANATION OF  
 SYMBOLS AND ABBREVIATIONS USED ABOVE



DESCRIPTION OF MATERIAL	DIAMETER (R)	DEPTH (R)	ELEVATION	SAMPLES / TESTS				Plastic Limit(%)    NM (%)    Liquid Limit(%)												
				DEPTH (R)	Sample		Test	+ - - - - + △ ⊗ ⊕ COHESION (100 psf) ● PENETRATION (bpf)												
					Type	No.		Dry density (pcf)	% Fines	10	20	30	40	50	60	70	80	90		
SURF. EL: 1418.35 ft. MSL																				
GRAVEL																				
Soft to hard, reddish brown with gray, silty with some gravel						1														
				3.0		2														
	5	1413.4		5.0		3														
				7.0		4	96.7													
				9.0		5														
	10	1408.4		11.0		6														
				13.0		7														
				15.0		8														
	15	1403.4		17.0		9														
				19.0		10														
	20	1398.4		21.0		11														
					12															
with organics and organic odor at 22.																				
1" wet seam with some gravel																				
brown silty CLAYSTONE																				
tube refusal at 23 feet																				
Boring terminated at 23 feet		25	1393.4			13														50.6"

NOTES: N10939.63 E9409.49. Borehole advanced by 75 truck-mounted drill rig using 3 1/4" I.D. HSAs. Drilled immediately following drilling operations. Borehole at 15.8' identified on 10/2/93.

Arnold Caesar  
Fernando Pons

SEE KEY SHEET FOR EXPLANATION OF SYMBOLS AND ABBREVIATIONS USED ABOVE

TEST BORING RECORD	
BORING NUMBER	L-5
DATES DRILLED	Start: October 1, 1993 Complete: October 1, 1993
PROJECT NUMBER	392-01406-01
PROJECT	Expansion of WWT Facilities
PAGE 1 OF 1	
LAW ENGINEERING Tulsa, Oklahoma	



# ***APPENDIX G.***

## **FOUNDATION DESIGN ANALYSIS**



---

## APPENDIX G.

### FOUNDATION DESIGN ANALYSIS For EVAPORATOR FEED TANK NO. 2 (EF2)

---

☐ **DIMENSIONS:**

Diameter:	60.00-ft.
Height:	16.90-ft.
Weight of Tank (Steel):	60,230.32-lb.
Weight of Max. Contents:	3,876,340.00-lb.
Tank Shell Thickness:	0.25-in.
Tank Bottom Thickness:	0.240-in.

☐ **CONCRETE FOUNDATION DESIGN:**

Assumed Footing Depth	=	48-in.
Assumed Footing Width	=	12-in.
Assumed Effective Soil Pressure (Based on Law Engineering Investigation)	=	1,500-psf
Maximum Shell Compression at Bottom of Shell (Based on Seismic Analysis) b	=	420.63-lb/ft. of circ.
Footing Width	=	1.00-ft.
Actual Applied Loading	=	420.63-psf

*The actual applied loading is significantly less than the assumed effective soil pressure and therefore, the foundation should be stable.*



# ***APPENDIX H.***

## **DUDICK, INC. PROTECTO-COAT 200 DATA**



# Dudick Inc.

Dudick Incorporated  
Corrosion-Proof Products  
1818 South Wason Drive  
Streetsboro, Ohio 44241

216-562-1970  
FAX No. 216-562-7638

## Protecto-Coat 200

ELASTOMERIC, SPRAY APPLIED, ENVIRONMENTALLY SAFE, URETHANE COATING. 40-60 MILS (1-1 1/2 mm)

Protecto-Coat 200 is a high solids aromatic polyurethane coating with superior elongation. It is especially suited to bridge cracks in concrete.

### RECOMMENDED APPLICATIONS

Secondary Containment Areas  
Process Floors  
Railroad Tank Cars  
Underground Pipes & Tanks - Exterior  
Thickener Tanks & Mechanisms

Spent Liquor Storage Tanks  
Food Processing  
Pharmaceutical  
Breweries  
Structural Steel

### CHEMICAL RESISTANCE

Protecto-Coat 200 provides a tough, durable surface and will withstand splash and spills of many inorganic and organic acids as well as alkalis. Also resistant to aliphatic solvents.

### PHYSICAL PROPERTIES

Protecto-Coat 200	40 Mil Basecoat	20 Mil Topcoat
Tensile Strength (PSI) ASTM C307	2,400-2,600	2,200-2,500
Elongation*	225% to 250%	50 to 60%
Shore D Hardness	40-45	65-70
Abrasion Resistance CS 17 wheels/1000 cycles x 1000 gm load	10 mg weight loss	32 mg weight loss
Solids by Volume	80%	100%

\*At 60% elongation the chemical resistant topcoat begins to surface crack while the basecoat will continue to elongate to 250% extension.

### SPECIFICATIONS

Coating shall be 40-60 mils thick, 80-100% solids aromatic urethane resin, consisting of 2 basecoats and a topcoat of 20 mils each, manufactured by Dudick, Inc. Materials shall be brush-, roller- or spray-applied in accordance with manufacturer's recommended practices.

### THE PROTECTO-COAT 200 SYSTEM

The Protecto-Coat 200 system uses a moisture tolerant primer and two or three coats of elastomeric thermosetting urethane resins to protect concrete and steel.

**Primer 67** is designed to prevent abrasive-blasted steel from developing rust bloom prior to the application of a Protecto-Coat System. For maximum performance, all steel surfaces should be primed, but primer may not be needed for mild, non-immersion service. Concrete, however, must always be primed to aid in the "wetting out" required for good bonding.

Protecto-Coat 200 is applied in three coats by brush, roller or spray. The elastomeric basecoat is applied in two 25 mil applications to achieve a nominal 40 mils DFT. The chemical resistant topcoat is applied in a single 20 mil application. Total thickness shall be a nominal 60 mils.



## ESTIMATING QUANTITIES AND ORDER BILL OF MATERIAL

SQUARE FEET PER GALLON		
	CONCRETE	STEEL
Primer 67	150-200	250-300
Protecto-Coat 200		
2 Base Coats		
Actual		
35-40 mil DFT	25	25
Top Coat		
Actual		
15-20 mil DFT	60	60
S-10 Solvent	500	500

Quantities shown are for estimating purposes only. Actual field usage may vary.

## APPLICATION INSTRUCTIONS

### SURFACE PREPARATION

**Metal:** For immersion service, abrasive blast to a white metal finish and a 2-4 mils minimum profile according to SSPC 5 or NACE No. 1. For fume or splash service, abrasive blast to a near-white metal finish according to SSPC 10 or NACE No. 2. Atmospheric service: Commercial SSPC 6 or NACE No. 3.

**Concrete:** Concrete must be abrasive-blasted or etched with muriatic acid (solution of 1 part 20° Be HCl and 1 part water) to remove surface laitance and other contaminants. Concrete must be free of curing compounds and form release agents. Surface texture should be similar to 40-60 grit sandpaper. The prepared surface should have a tensile strength of between 250 and 300 PSI per ASTM D4541.

Additional surface preparation will be required if a 40-60 grit texture is not achieved and the surface laitance not completely removed after a single application of acid or with the first mechanical preparation procedure.

If, after abrasive blasting, honeycombs/voids appear on the concrete, these have to be filled with a suitable material. Contact a Dudick representative for this information.

Recommended application temperatures should be between 40°F and 90°F substrate temperature. Do not apply Protecto-Coat 200 over concrete exposed to direct sunlight during the warming trend of the concrete as measured by surface temperature. To do so may lead to blistering, pinholes, or wrinkling in the coating due to outgassing of air in the concrete and high substrate temperatures. Wait for a definite downturn or cooling trend within the concrete as again measured by surface temperature. If this is not possible consult a Dudick representative for alternatives such as double priming.

### PRIMING

**Metal:** For maximum performance, prime all steel surfaces with Primer 67, mixed with appropriate amount of hardener to 3-4 mils. For mild non-immersion service, priming of steel may be omitted.

**Concrete:** Concrete must be primed to aid in the "wetting out" required for good bonding. Mix Component A with Component B in the premeasured units for 2-3 minutes and apply by brush, roller, or spray. We recommend the basecoat be applied over slightly tacky or tack-free primer. Do not allow the primer to puddle.

### Protecto-Coat 200 Mix Ratio:

#### Protecto-Coat 200 Basecoat

Protecto-Coat 200 Basecoat Comp. A*	1 Gal.
Component B*	4 Gal.

\*Premeasured quantities by weight

#### Protecto-Coat 200 Topcoat

Protecto-Coat 200 Top Coat Comp. A*	1 Gal.
Component B*	54 fl. oz.

\*Premeasured quantities by weight

### BASECOAT

Add appropriate amount of hardener for each gallon of Protecto-Coat Liquid and mix thoroughly until uniform color is achieved. Apply a 25 mil wet (20 mil DFT) basecoat using spray, brush or roller. Allow basecoat application to cure to at least a "firm" or slightly "tacky" feel before applying the second 25 mil wet (20 mil DFT) basecoat. Brush or roller may require several coats to achieve desired thickness.

**P. Protecto-Coat 200**

Elastomeric, Spray Applied, Environmentally Safe, Urethane Coat  
in 10-60 Mils (1-1 1/2 mm)

Dudick Incorporated  
Corrosion-Proof Products



Horizontal surfaces may be basecoated in one application by applying 50 mils wet (40 mil DFT) in a single coat.

### TOPCOAT

Add appropriate amount of hardener for each gallon of Protecto-Coat Liquid and mix thoroughly until a uniform color is achieved. Apply a 20-mil-thick topcoat using spray, brush or roller.

### Cure Cycle for Protecto-Coat 200

TEMPERATURE	RECOAT TIME	CURE TIME
50°	48 Hrs.	96 Hrs.
70°	24 Hrs.	48 Hrs.
90°	16 Hrs.	36 Hrs.

If these recoat times are exceeded, consult a Dudick representative; sanding or abrasive blasting may be required before the next coat. Recoat times are dramatically reduced when the coating is exposed to direct sunlight.

**Single Component Airless Spray Equipment**  
-- Graco King 45-to-1 spray pump or equivalent. Use Graco Golden Mastic Gun or Graco No. 207945 Gun with airless adapter equipped with a Reverse-A-Clean tip and a tip size between .035-.041. Spray hose should be 1/2" or 3/8" ID. Available inlet pressure must be a minimum of 100 psi.

Brush or roller application may require additional coats to meet specified dry film thickness.

Pot life of the opened and mixed Protecto-Coat 200 will depend on the temperature at the work site. To prevent material waste and avoid damage to equipment, do not open and mix more material than can be used according to the following table:

TEMPERATURE	POT LIFE
50°F	120 Min.
75°F	60 Min.
90°F	45 Min.

Do not attempt to store mixed material. Residual material should be properly disposed of at the end of each work period.

Where immersion service is required, spark test the coating with a 5,000 to 7,000 volt AC spark tester. Mark and repair all pinholes. Use Protecto-Coat liquid mixed with the appropriate amount of hardener. Retest only the repairs.

### CLEANING

Use S-10 Solvent to clean tools and equipment.

### SHIPPING

Protecto-Coat 200 Topcoat A and B and Protecto-Coat 200 Basecoat A are classified as plastic liquids and are non-regulated.

Protecto-Coat 200 Basecoat B is combustible. Primer 67 Component B is corrosive and carries a black and white warning label. Primer 67 Component A is classified as a plastic liquid and is nonregulated, while S-10 Cleaning Solvent is red label liquid with a flash point of 52°F (PMCC).

### STORAGE

**Warning:** All Dudick products classified by DOT labels as either white, yellow or red labels must not be mixed or stored together as an explosive reaction may occur.

When stored in a cool and dry location, Protecto-Coat 200 ingredients have a one-year shelf life. Exposure to excessive heat may cause premature gelling and reduce working time.

### SAFETY

**M.S.D.S. - Sheets must always be read before using products.** Protecto-Coat Systems are intended for application by experienced, professional personnel. Dudick Inc. can supply Protecto-Coat systems supervision to help determine that the surface has been properly prepared, the ingredients correctly mixed, and the materials properly and safely applied.

## Protecto-Coat 200

Elastomeric, Spray Applied, Environmentally Safe, Urethane Coat  
10-60 Mils (1-1 1/2 mm)

Dudick Incorporated  
Corrosion-Proof Products



If Protecto-Coat materials are to be applied by your own personnel or by a third-party contractor, please be sure that they are aware of the following safety precautions:

- Exposure to resins and hardeners may cause severe dermatitis reactions in some people. Cleanliness of the skin and clothing is critical and must be of paramount concern.
- Safety glasses, gloves and suitable protective clothing must be worn at all times during application.
- Suitable respirators should be used.
- If contact with hardeners occurs, remove any clothing involved and wash the skin with large amounts of water. Discard the clothing. Do not attempt to wash and reuse it. Protecto-Coat liquid may be washed off with S-10 Cleaning Solvent, MEK liquid, or laquer thinner.
- Fumes are flammable and heavier than air. Proper ventilation should be maintained to minimize breathing of concentrated fumes.
- If a rash or dermatitis occurs, remove the individual from the work area and seek a physician's care for dermatitis.
- Keep open flames and sparks away from the area where toppings are being mixed and applied.
- In case of eye contact, wash with water for at least 15 minutes and consult a physician. If swallowed, do not induce vomiting; call a physician immediately.

**Note:**

Dudick Inc. ("Dudick") warrants all goods of its manufacture to be as represented in its catalogs and that the application of its products by its employees or sub-contractors shall be performed in a workmanlike manner. Dudick's obligation under this warranty shall be the repair to and replacement of any applications which its examination shall disclose to be defective. Dudick makes no warranty concerning the suitability of its product for application to any surface, it being understood that the goods have been selected and the application ordered by the purchaser. DUDICK INC. MAKES NO WARRANTY, EXPRESS OR IMPLIED, THAT THE GOODS SHALL BE MERCHANTABLE OR THAT THE GOODS ARE FIT FOR ANY PARTICULAR PURPOSE. THE WARRANTY OF REPAIR OR REPLACEMENT SET FORTH HEREIN IS EXCLUSIVE AND IN LIEU OF ALL OTHER WARRANTIES ARISING BY LAW OR OTHERWISE; AND DUDICK INC. SHALL NOT BE LIABLE FOR INCIDENTAL OR CONSEQUENTIAL DAMAGES, INCLUDING BUT NOT LIMITED TO LOST PROFITS, DOWN TIME, DAMAGES TO PROPERTY OF THE PURCHASER OR OTHER PERSONS, OR DAMAGES FOR WHICH THE PURCHASER MAY BE LIABLE TO OTHER PERSONS, WHETHER OR NOT OCCASIONED BY DUDICK'S NEGLIGENCE. This warranty shall not be extended, altered or varied except by written instrument signed by Dudick and Purchaser.

PROTECTO-COAT 200

Elastomeric, Spray Applied, Environmentally Safe, Urethane Coat-  
ing (100% Solids) (1/2" mm)

Dudick Incorporated  
Corrosion-Proof Products

1818 South Wason Drive  
Streetsboro, Ohio 44241  
(12-91)



# ***APPENDIX I.***

## **SECONDARY CONTAINMENT CALCULATIONS**



---

---

## APPENDIX I.

### SECONDARY CONTAINMENT CALCULATIONS For EVAPORATOR FEED TANK NO. 2 (EF2)

---

---

☐ **DIMENSIONS:**

EF Tank Diameter:	60.00-ft.
PCL Tank Diameter:	12.00-ft.
Secondary Containment Height - Hsc	5.50
Secondary Containment Surface Area - Asc	14,589.00-sf
Gross Volume of Secondary Containment	80,239.50-cf

☐ **DISPLACEMENT VOLUMES:**

EF Tank Base	$\text{PI} \cdot \text{D}^2 / 4 \cdot \text{Hsc}$	15,551.42-cf
PCL Tank Base	$\text{PI} \cdot \text{D}^2 / 4 \cdot \text{Hsc}$	622.06-cf

*Note: Displacement volumes include only one of the EF tanks. It is assumed that a failed tank would not displace available secondary containment.*

Displacement Volume	16,173.47-cf
---------------------	--------------

☐ **RAINFALL VOLUMES:**

Depth of Rainfall	6.150-in.
Impacted Area	8,934.00-sf
Rainfall Volume	4,578.68-cf

☐ **CONTAINMENT CAPACITY AVAILABLE:**

CCA = Gross Volume - Displacement Volume - Rainfall Volume

CCA	=	59,487-cf
Volume of Largest Tank (EF1)	=	47,785.26-cf
Excess Containment Volume	=	11,702-cf
Safety Factor	=	1.24