



**Clean Harbors Environmental Services, LLC
Lone Mountain Facility
Waynoka, Oklahoma**

**RCRA/HSWA
Permit Renewal
Application**

Volume 8

October 1, 2020

VOLUME 8

CONTENTS IN THIS VOLUME:

SECTION FT2
SECTION FT3 (OUT OF SERVICE)
SECTION T-6
SECTION UT1 (OUT OF SERVICE)

SECTION FT2

**ASSESSMENT
Of
EVAPORATOR FLASH TANK NO. 2
(FT 2)
Located At The
LONE MOUNTAIN HAZARDOUS WASTE
FACILITY
WAYNOKA, OKLAHOMA**

PREPARED FOR



July 2002



C. A. 1960—Expiration Date 06/30/03

**ASSESSMENT
Of
EVAPORATOR FLASH TANK NO. 2 (FT 2)
Located At The
LONE MOUNTAIN HAZARDOUS WASTE FACILITY
WAYNOKA, OKLAHOMA
Prepared For
SAFETY-KLEEN, INC.**

TABLE OF CONTENTS

1.	TANK SYSTEM DESCRIPTION	1.
2.	PRIMARY TANK VESSEL	1.
2.1	General Description	1.
2.2	Design Standards	1.
2.3	Hazardous Characteristics of Waste Stored	1.
2.4	Welding Specifications and Inspection	2.
2.5	Corrosion Protection	2.
2.6	Documented Age of Tank	2.
2.7	Results of Leak Tests	2.
2.8	Existing Data Obtained	2.
2.9	Calculation of Existing Foundation Loading	2.
2.10	Required Structural Calculation	3.
2.11	Comparison of Actual to Theoretical Structural Values	3.
2.12	Ancillary Equipment	3.
3.	SECONDARY CONTAINMENT SYSTEM	4.
3.1	General Description of Secondary Containment	4.
3.2	Corrosion Protection	4.
3.3	Documented Age of the Containment Area	4.
3.4	Results of Leak Tests	4.
3.5	Calculation of Capacity Available (CCA)	4.
3.6	Required Volume	4.
3.7	Comparison of Available Volume to Required Volume	4.
4.	CONCLUSIONS	5.
5.	RECOMMENDATIONS	5.
6.	CERTIFICATION	5.

LIST OF APPENDICES:

APPENDIX A.	MANUFACTURER'S CERTIFICATION
APPENDIX B.	WELDING PROCEDURES AND INSPECTIONS
APPENDIX C.	HYDROSTATIC LEAK TESTS
APPENDIX D.	CALCULATIONS
APPENDIX E.	METALLURGICAL INFORMATION
APPENDIX F.	SUPPORT STRUCTURE CALCULATIONS
APPENDIX G.	FOUNDATION ANALYSIS
APPENDIX H.	CONCRETE COATING INFORMATION FOR SECONDARY CONTAINMENT
APPENDIX I.	SECONDARY CONTAINMENT

**ASSESSMENT
Of
EVAPORATOR FLASH TANK NO. 2 (FT 2)
Located At The
LONE MOUNTAIN HAZARDOUS WASTE FACILITY
WAYNOKA, OKLAHOMA
Prepared For
SAFETY-KLEEN, INC.**

1. TANK SYSTEM DESCRIPTION

Evaporator Flash Tank No. 2 (FT 2) is a welded, above-ground wastewater treatment and storage tank to be installed as a part of the final wastewater treatment plant at the Lone Mountain Facility in Waynoka, Oklahoma. This tank is a replacement for an existing tank which is constructed of carbon steel. The new tank, which is constructed of stainless steel, is exactly the same size as the original tank. The top of the tank is completely open to the atmosphere for evaporation purposes. Evaporator Flash Tank No. 2 (FT 2) is located within the Wastewater Final Treatment building on the first mezzanine level of the support structure. The complete tank system consists of Evaporator Flash Tank No. 2 (FT 2), Circulating Pump (P 78), Heat Exchanger (EU 1), Pump (P 80), Filter Press (FP 1), and associated piping and instruments.

2. PRIMARY TANK VESSEL

- 2.1 General Description.** Evaporator Flash Tank No. 2 (FT 2) is a circular steel tank with an outside diameter of 6-ft. 4-in. and a height of 31-ft. The tank proper's skirt is anchored to the support structure, and the bottom of the tank is dished and welded to the shell. A self-supporting flue is attached to the top of the tank. Evaporator Flash Tank No. 2 (FT 2) is being assessed to determine if the unit is adequately designed with sufficient structural strength and compatibility with the waste to be stored.
- 2.2 Design Standards.** The tank is designed and constructed to those sections that are applicable in the American Petroleum Institute Standard 650, 10TH Edition (API-650). The manufacturer's certification is included in *Appendix A*.
- 2.3 Hazardous Characteristics of Waste Stored.** The waste stored in this tank is treated and untreated brine solutions. The following parameters are characteristics of the waste treated:

Ignitability: Flash Point > 240° F

Corrosiveness: 6 < pH < 13
0 < N < 7

Reactivity: None

Temperature: < 240° F

Based on the results of the examination of the hazardous characteristics of the waste to be stored in this tank, it was determined that the pH, normality levels, and salinity (corrosiveness) of the waste are the primary areas of concern. These levels are used to determine the applicability of a corrosion allowance for the tank material type and thickness.

2.4 Welding Specifications and Inspection. The welding procedures utilized in the tank construction and the Radiographic Examination Report are included in *Appendix B*.

2.5 Corrosion Protection. The tank shell is constructed of 316L stainless steel for corrosion protection.

2.6 Documented Age of Tank. This tank was manufactured by Lide Industries of Mexia, Texas, in January 2002, and installed in July 2002.

2.7 Results of Leak Tests. The manufacturer conducted a hydrostatic leak test of the tank prior to shipping. A description of this test is included in *Appendix C* of this assessment. In addition, a visual inspection was performed of the tank's interior and exterior subsequent to installation. This inspection was conducted specifically to detect the presence, if any, of the following defects:

- (a) Weld break
- (b) Punctures
- (c) Cracks
- (d) Corrosion
- (e) Other structural damage or inadequacies of construction and/or installation

The tank was again hydrostatically tested subsequent to installation. A description of this procedure is summarized in *Appendix C* of this assessment. Based on the results of these tests, it was determined that the primary tank was not leaking.

2.8 Existing Data Obtained.

Tank Diameter	6-ft. 4-in.
Nominal Height of Tank	31-ft.
Maximum Capacity	3,785-gal.*
Overflow Liquid Level	9-ft 1-in.
Overflow Volume	1,137-gal.
Design Specific Gravity	1.5
Maximum Bottom Pressure	10.8-psi
Maximum Operating Temperature	300° F
Construction Material:	
Flue	ASTM A36
Shell	ASTM 316L
Bottom	ASTM 316L
Skirt	ASTM A36
Flanges, Blinds, Coupler and Plugs	ASTM 316L
Bolts	SA 193-B7/SA 194-2H
Wall Thickness (Shell and Bottom)	0.250-in.
Operating Pressure	Atmospheric
Seismic Zone	1

- * The maximum capacity of the assessed tank is the same as the original tank, however the original tank assessment indicates otherwise. There appears to have been an error in the original assessment's volume calculations.

2.9 Calculation of Existing Foundation Loading.

Total Weight of Tank and Contents (maximum volume) 59,406-lb.

Detailed calculations reflecting the volume and weight of the tank are included in *Appendix D* of this assessment.

- 2.10 Required Structural Calculation.** Calculations for the required wall thickness for this tank are presented in *Appendix D* of this assessment. Metallurgical information on the materials used is included in *Appendix E* of this assessment. The minimum required thickness in accordance with API 650 is 0.1875-in. A corrosion allowance of 0.125 is provided for. The measured wall thickness is 0.25-in.

Design calculations for the support structure are included in *Appendix F* of this assessment. These calculations were completed in accordance with the BOCA National Building Code 1990 Edition and were part of a previous tank assessment prepared by Black and Veach. The structural support was inspected and no changes have been made since the date of the Black and Veach assessment.

Structural analysis of the foundation is included in *Appendix G* of this assessment.

2.11 Comparison of Actual to Theoretical Structural Values.

(a) Wall Thickness Comparison:

Calculated Required Wall Thickness (includes corrosion allowance)	0.156-in.
Minimum Required Wall Thickness by API 650	0.1875-in.
Measured Wall Thickness	0.250-in.

(b) Bottom Thickness Comparison:

Calculated Required Bottom Thickness	0.151-in.
Minimum Required Bottom Thickness by API 650	0.250-in.
Measured Bottom Thickness	0.250-in.

(c) Foundation Integrity Comparison:

Maximum Calculated Load (6-in. Slab)	17.6 Kips
Calculated Foundation Support (6-in. Slab)	26.7 Kips
Maximum Calculated Load (17-in. Slab)	62.9 Kips
Calculated Foundation Support (17-in. Slab)	127.7 Kips

- 2.12 Ancillary Equipment.** The ancillary equipment for the Evaporator Flash Tank No. 2 (FT 2) system includes the following:

- (a) Circulating Pump (P 7B).** A centrifugal pump designed to pump 800-GPM at 150-ft. of discharge head with a suction head of 11-ft.
- (b) Heat Exchanger (EU 1).** A plate and frame unit of stainless steel construction designed to operate at a pressure of 150-PSIG and a temperature of 300° F.
- (c) Pump (P 80).** A pneumatically-operated, double-diaphragm pump designed to pump from 100- to 0-GPM at head pressures varying from 0- to 100-PSIG, pumping fluid at a temperature up to 212° F.
- (d) Filter Press (FP 1).** A gasketed unit employing glass-filled polypropylene plates designed to operate at a temperature/pressure limit of 100-psi at 212° F.
- (e) Associated Piping, Valves, and Instruments.** All piping is Schedule 40 carbon steel fitted with 150-psi flanges. All piping with an inside diameter of 2-in. or smaller is socket-welded using, at minimum, 3,000-lb. connections. All piping with an inside diameter greater than 2-in. is butt-welded. All valves, fittings, and instruments are rated for 150-psi or higher.

Note: Items (a) - (c) are part of the tank system. However, no changes were made to them during the installation of the new FT 2 tank.

3. SECONDARY CONTAINMENT SYSTEM

- 3.1 General Description of Secondary Containment.** The secondary containment system is designed and operated to prevent migration of wastes or liquids out of the system. Evaporator Flash Tank Nos. 1, 2 and 3, Evaporator Blowdown Tank No. 2, and Evaporator Feed Tank No. 4 are located on a reinforced concrete base floor area with vertical concrete sidewalls. This area is inspected daily on a routine basis.

At the time of inspection, the concrete area was withstanding daily operations and routine climatic conditions. No cracks from compression or uplift were visually apparent.

Any released tank contents are removed and pumped to an appropriate storage area within the maximum time allowed as a permit condition.

- 3.2 Corrosion Protection.** There is an impermeable coating applied to the entire concrete floor and curbs. Detailed information on the coatings employed is included in *Appendix H* of this assessment.
- 3.3 Documented Age of the Containment Area.** The concrete secondary containment system was constructed and installed in 1987.
- 3.4 Results of Leak Tests.** A visual inspection of the containment area was conducted and no cracks or breaks in the impermeable coating were observed. Therefore, it appears to be adequate to contain any leaks or spills.
- 3.5 Calculation of Capacity Available (CCA).**

Area	2,739-sf
Curb Height	0.25-ft.
Material	Concrete
Gross Volume	685-cf

Note: See *Appendix I* for secondary containment.

- 3.6 Required Volume.**

- (a) *Containment Capacity Required (CCR):*

CCR = Volume of Largest Tank (Overflow Volume) in the Secondary Containment

Volume of Largest Tank = (FT1) 506.cf

- 3.7 Comparison of Available Volume to Required Volume.**

- (a) *Containment Capacity Available (CCA):*

Containment Capacity Required (CCR)	506-cf
Secondary Containment Volume Available	685-cf
Excess Containment Volume	179-cf

CCA > CCR Adequate Capacity (under normal operating conditions is available.)

Note: See *Appendix I* for secondary containment calculations.

4. CONCLUSIONS

The foundation and structural support for the Evaporator Flash Tank No. 2 (FT1) system have been previously analyzed, reviewed, and deemed to be adequately designed.

The Evaporator Flash Tank No. 2 (FT 2) system has sufficient structural strength, is compatible with the waste to be stored and treated, and has adequate corrosion protection to ensure that it will not collapse, rupture, or fail.

The Evaporator Flash Tank No. 2 (FT 2) system was inspected on July 18, 2002, for weld breaks, punctures, scrapes of protective coating, cracks, leaks, corrosion, and other structural damage or inadequacies of construction/installation.

The Evaporator Flash Tank No. 2 (FT 2) equipment was hydrostatically tested on July 18, 2002, and it was determined that the tank does not leak.

The Secondary Containment for the Evaporator Flash Tank No. 2 (FT 2) system is of sufficient structural strength and volume to meet the requirements set forth in 40 CFR 264.193.

5. RECOMMENDATIONS

Due to a previous history with interior deterioration of the Evaporator Flash Tank No. 2 (FT 2), the following recommendations are suggested:

- ☐ Visual inspections of the tank interior subsequent to the initial 6-mo. of operation.
- ☐ Annual visual inspections of the tank interior subsequent to the initial 6-mo. inspection.
- ☐ Perform an ultrasonic survey of the tank shell subsequent to 5-yr. of operation to determine the average shell thickness.

6. CERTIFICATION

"I certify under penalty of law that this document and all attachments were prepared under my direction or supervision, in accordance with a system designed to ensure that qualified personnel properly collect and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for collecting the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations."



Rob L. Stallings, P.E.
Envirotech Engineering & Consulting, Inc.

CA 1960 - Expiration Date 06/30/03

APPENDIX A.

MANUFACTURER'S CERTIFICATION

SECTION 400
ASSESSMENT OF ROTARY DRUM FILTER SYSTEM
LONE MOUNTAIN HAZARDOUS WASTE FACILITY
USPCI
Waynoka, Oklahoma

A. TANK SYSTEM DESCRIPTION

The Rotary Drum Filter System is a dewatering unit located in the pre-treatment building of the Lone Mountain Hazardous Waste Facility. The system consists of a skid mounted pre-engineered unit supplied by Alar Engineering, Inc. of Mokena, IL and other additional tanks, pumps, and piping. The Rotary Drum Filter and its ancillary equipment are located together on two levels and within a concrete curbed containment area. The purpose of this system is to dewater sludge and compress it into filter cakes.

The tank system actually consists of three tanks or vessels which hold hazardous waste:

- Filter Pan
- Receiver Tank
- Recycled Water Tank

The function, design and construction of each of the three tanks will be described individually.

In addition to the three tanks mentioned, two other tanks (Seal Flush Tank and Recycled Water Tank) are part of the system; however, these tanks do not hold hazardous waste.

Filter Pan - RF-1

This is a horizontal, cylindrical tank with an open top and flat ends. The filter pan is part of the Alar system and is located on the upper level. The dimensions are 7-ft in length and 4.2-ft in width and 2-ft in depth at the deepest point. It houses the rotary drum filter. There are several pipe inlets located in this tank.

During start-up operations, a diatomaceous earth and water mixture is piped into the filter pan and the rotary drum filtration process is started. A vacuum is used to draw the diatomaceous earth mixture onto the polypropylene cloth-coated rotary drum. After a sufficient pre-coating is generated on the drum, a valve controlling the flow of the mixture is closed. Another valve is opened and hazardous waste is pumped into the filter pan. The waste is filtered through the drum in the same manner described for the diatomaceous earth and water mix. As the hazardous waste solids are built up on the drum, a knife blade is advanced and the semi-dry solids are removed and collected in a container for disposal.

CS \BRUCE\USPC\VF1-SCH 01/03/98 10:09


USPCI
LAIDLAW
 ENVIRONMENTAL
 SERVICES INC.

LONE MOUNTAIN FACILITY

ROTARY DRUM FILTER SYSTEM ASSESSMENT

SCALE: N.T.S.

DWG. NO.



**MANUFACTURER'S CERTIFICATION FOR
A TANK BUILT TO API STANDARD 650**

To Safety-Kleen Corp. (Lone Mountain Facility)
(name and address of purchaser)

Route 2 Box 170

Waynoka, TX 73860

We hereby certify that the tank constructed for you at Lide Industries, Inc.
(location)

Route 2, Box 159F

Mexia, TX 76667

and described as follows: Two 6'-4" O.D. x 20'-6" Tall Stainless Steel
(serial or contract number, diameter, height, capacity, floating or fixed roof)

Flash Tanks Serial #'s 1733 and 1734

meets all applicable requirements of API Standard 650, 10th Edition, _____ Revision, Appendix

JM&S, dated _____, including the requirements for design, materials, fabrication, and erection.

The tank is further described on the attached as-built data sheet dated 05/21/02.

Lide Industries, Inc.
Manufacturer

Billy Lide *BL*
Authorized Representative

05/23/02
Date


Figure 8-2—Manufacturer's Certification Letter

API STANDARD 350			
APPENDIX	J.M.S		5-02
EDITION	10		
NO. OF SHEETS	76		20-6
NO. OF SHEETS	3,865		
DESIGN SPECIFIC GRAVITY	1.5		300 F
DESIGN PRESSURE	ATM		N.A.
MANUFACTURER'S SERIAL NO.	1733		
DATE		J-203	
			103034
1		315	55
2		316	55
3		317	55

API STANDARD 350			
APPENDIX	J.M.S		5-02
EDITION	10		
NO. OF SHEETS	76		20-6
NO. OF SHEETS	3,865		
DESIGN SPECIFIC GRAVITY	1.5		300 F
DESIGN PRESSURE	ATM		N.A.
MANUFACTURER'S SERIAL NO.	1733		
DATE		J-203	
			103034
1		315	55
2		316	55
3		317	55

APPENDIX B.

WELDING PROCEDURES AND INSPECTIONS



Longview Inspection, Inc.
405 N. Eastman Road
Longview, TX 75601
903/753-2375

RADIOGRAPHIC EXAMINATION REPORT

Page 7 of 7

SC# 12-8226

CUSTOMER/CONTACT *Lide Industries*

DATE: 5-9-02

LOCATION/ADDRESS Mexico Tex.

UNIT/SYSTEM J-203 Talk-1 Talk-2

P.O.

MATERIAL	S/S ^A	B	C	D	E	
THICKNESS	250 ^A	B	C	D	E	
DIAMETER	6 ^A	B	C	D	E	
REINF. THICK.	1/16 ^A	B	C	D	E	
SFD	18 ^A	B	C	D	E	
EXP. TIME	3min ^A	B	C	D	E	
IQI SIZE/MAT'L	SP-77P ^A	B	C	D	E	
IQI LOC. S/F	S ^A	B	C	D	E	
SHIM THK & MAT'L	1/16 ^A	B	C	D	E	
# OF EXPOSURES	6 ^A	B	C	D	E	
MARKERS: NO. OR SPACING	6 ^A	B	C	D	E	

SOURCE (Ir) Co X-Ray	(C1) KV 50	Ma 1.48	FOCAL SPOT FRONT: 010 REAR: 010	SCREENS / FS FRONT: 010 REAR: 010	FILM LOADING (SINGLE) / DOUBLE	FILM PROCESS: TIME 1/4. TEMP 74°	AUTO <input type="checkbox"/> MANUAL <input checked="" type="checkbox"/>
NDE PROCEDURE RT-1 R604	ACCEPTANCE STANDARD API 650	SURFACE CONDITION As Welded	STAGE OF MANUFACTURE: <input type="checkbox"/> INTERMEDIATE <input checked="" type="checkbox"/> FINAL <input type="checkbox"/> REPAIR	<input type="checkbox"/> BEFORE PWHT <input type="checkbox"/> AFTER PWHT			
C - CRACK SL - SLAG T - TUNGSTEN	CP - CLUSTER POROSITY P - POROSITY/GAS POCKET HB - HOLLOW BEAD	IP - INSUFFICIENT PENETRATION IF - INSUFFICIENT FUSION EP - EXCESSIVE PENETRATION	EU - EXTERNAL UNDERCUT IU - INTERNAL UNDERCUT IC - INTERNAL CONCAVITY	SU - SURFACE HL - IF DUE TO HIGH/LOW BT - BURN THROUGH			

[illegible]☐ ADDITIONAL PAGES COMMENTS:

# OF FILM & SIZE		FILM BRAND/TYPE		TOTAL # OF WELDS:	
6 - 4 1/2 x 10		AGFA D4			
Date	Customer/Contact	Par Diam	Report No.	Unit No.	No. on Job
5-4-02	Billy Lids	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	1	198	2
Travel if Applicable		Airline <input type="checkbox"/>	Hours: Worked	AM and	Total Hours
12 HRSR Miles Total		Vehicle <input type="checkbox"/>	10:30 to	to 1:30 PM	9

Signature of Customer's Representative certifies time and material correct.

Kare Rick ^{II} / *B. Molloy*
Name, Signature, and Level of Longview Inspection Examiner / Assistant

QW-482 SUGGESTED FORMAT FOR WELDING PROCEDURE SPECIFICATION (WPS)
(See QW-200.1, Section IX, ASME Boiler and Pressure Vessel Code)

Company Name LIDE TANK COMPANY By: EVAN LEMON
Welding Procedure Specification No. BB15L Date 4/24/89 Supporting PQR No.(s) BB15L
Revision No. 0 Date ---
Welding Process(es) SMAW/FCAW Type(s) MANUAL/SEMI AUTOMATIC
(Automatic, Manual, Machine, or Semi-Auto.)

JOINTS (QW-402)

Details

Joint Design SEE PRODUCTION DRAWINGS
Backing (Yes) F6 (No) F5
Backing Material (Type) WELD METAL OR BASE METAL
(Refer to both backing and retainers.)

☐ Metal ☐ Nonfusing Metal **RETAINERS NOT USED**
☐ Nonmetallic ☐ Other

Sketches, Production Drawings, Weld Symbols or Written Description should show the general arrangement of the parts to be welded. Where applicable, the root spacing and the details of weld groove may be specified.

(At the option of the Mfr., sketches may be attached to illustrate joint design, weld layers and bead sequence, e.g. for notch toughness procedures, for multiple process procedures, etc.)

***BASE METALS (QW-403)**

P-No. 8 Group No. 1 to P-No. 8 Group No. 1

OR

Specification type and grade SA-240-316L
to Specification type and grade SA-240-316L

OR

Chem. Analysis and Mech. Prop. ---
to Chem. Analysis and Mech. Prop. ---

Thickness Range:

Base Metal: Groove .1875 - .4818 * Fillet ALL
Pipe Dia. Range: Groove ALL Fillet ALL

Other FCAW SHORT CIRCUIT MODE LIMITED TO 1.1 * BASE METAL THICKNESS

***FILLER METALS (QW-404)**

Spec. No. (SFA) <u>5.4</u>	<u>5.22</u>
AWS No. (Class) <u>E308L-16</u>	<u>E308LT-1</u>
F-No. <u>5</u>	<u>6</u>
A-No. <u>8</u>	<u>8</u>
Size of Filler Metals <u>3/32" - 1/8"</u>	<u>.035 - .045</u>
Deposited Weld Metal <u>.250</u>	<u>.188</u>

Thickness Range:

Groove <u>.4818 *</u>	<u>.2068 **</u>
Fillet <u>ALL</u>	<u>ALL</u>

Electrode-Flux (Class) ---

Flux Trade Name ---

Consumable Insert ---

Other --- **** 1.1 * WELD METAL SHORT CIRCUIT MODE**

* Each base metal-filler metal combination should be recorded individually. FCAW - NO POWDERED OR SUPPLEMENTAL FILLER METALS WILL BE USED. FILLER METAL IS FLUX CORED

QW-482 (Back)

WPS No. BB15L Rev. 0

POSITIONS (QW-405) Position(s) of Groove <u>ALL</u> Welding Progression: Up <u>XX</u> Down _____ Position(s) of Fillet <u>ALL</u>	POSTWELD HEAT TREATMENT (QW-407) Temperature Range <u>NA</u> Time Range <u>---</u>																
PREHEAT (QW-406) Preheat Temp. Min. <u>50 degrees F</u> Interpass Temp. Max. <u>400 degrees F</u> Preheat Maintenance <u>NA</u> (Continuous or special heating where applicable should be recorded)	GAS (QW-408) <table border="1"> <thead> <tr> <th></th> <th>Gas(es)</th> <th>Percent Composition (Mixture)</th> <th>Flow Rate</th> </tr> </thead> <tbody> <tr> <td>Shielding</td> <td><u>ARG/CO2</u></td> <td><u>75/25</u></td> <td><u>20-35 CFM</u></td> </tr> <tr> <td>Trailing</td> <td><u>---</u></td> <td><u>---</u></td> <td><u>---</u></td> </tr> <tr> <td>Backing</td> <td><u>---</u></td> <td><u>---</u></td> <td><u>---</u></td> </tr> </tbody> </table>		Gas(es)	Percent Composition (Mixture)	Flow Rate	Shielding	<u>ARG/CO2</u>	<u>75/25</u>	<u>20-35 CFM</u>	Trailing	<u>---</u>	<u>---</u>	<u>---</u>	Backing	<u>---</u>	<u>---</u>	<u>---</u>
	Gas(es)	Percent Composition (Mixture)	Flow Rate														
Shielding	<u>ARG/CO2</u>	<u>75/25</u>	<u>20-35 CFM</u>														
Trailing	<u>---</u>	<u>---</u>	<u>---</u>														
Backing	<u>---</u>	<u>---</u>	<u>---</u>														

ELECTRICAL CHARACTERISTICS (QW-409)

Current AC or DC DC Polarity REV
 Amps (Range) SEE BELOW Volts (Range) SEE BELOW

(Amps and volts range should be recorded for each electrode size, position, and thickness, etc. This information may be listed in a tabular form similar to that shown below.)

Tungsten Electrode Size and Type _____ (Pure Tungsten, 2% Thoriated, etc.)

Mode of Metal Transfer for GMAW SHORT CIRCUIT ARC
 (Spray arc, short circuiting arc, etc.)

Electrode Wire feed speed range ---

TECHNIQUE (QW-410)

String or Weave Bead SMAW = STRING, FCAW = WEAVE

Orifice or Gas Cup Size 3/8" - 1/2"

Initial and Interpass Cleaning (Brushing, Grinding, etc.) BRUSH, GRIND, OR CHIP AS NEEDED

Method of Back Gauging AIR ARC OR GRIND AS NEEDED

Oscillation NONE

Contact Tube to Work Distance .750"

Multiple or Single Pass (per side) MULTIPLE

Multiple or Single Electrodes SINGLE

Travel Speed (Range) ---

Peening NONE


Other NO SINGLE PASS TO EXCEED 1/2" IN THICKNESS

Weld Layer(s)	Process	Filler Metal		Current		Volt Range	Travel Speed Range	Other (e.g., Remarks, Comments, Hot Wire Addition, Technique, Torch Angle, Etc.)
		Class	Dia.	Type Polar.	Amp. Range			
1 & 2	SMAW	EXXX X	3/32"	REV	65-130	19-26	NA	
"	"	"	1/8"	"	85-165	20-26	"	
REM	FCAW	EXXXXT1	.035	"	60-175	17-24	"	
"	"	"	.045	"	100-225	18-27	"	

QW-483 SUGGESTED FORMAT FOR PROCEDURE QUALIFICATION RECORDS (PQR)
(See QW-200.2, Section IX, ASME Boiler and Pressure Vessel Code)
Record Actual Conditions Used to Weld Test Coupon.

Company Name Lide Tank Company Date 4/24/89
 Procedure Qualification Record No. BB15L
 WPS No. BB15L
 Welding Process(es) SMAW/FCAW
 Types (Manual, Automatic, Semi-Auto.) Manual/Semi-Automatic

JOINTS (QW-402)



Groove Design of Test Coupon

(For combination qualifications, the deposited weld metal thickness shall be recorded for each filler metal or process used.)

BASE METALS (QW-403)
 Material Spec. SA-240
 Type or Grade 316L
 P-No. 8 to P-No. 8
 Thickness of Test Coupon .438
 Diameter of Test Coupon 3-1/2" OD
 Other ---

POSTWELD HEAT TREATMENT (QW-407)
 Temperature NA
 Time ---
 Other ---

	Percent Composition		
	Gas(es)	(Mixture)	Flow Rate
Shielding	<u>ARG/CO2</u>	<u>75/25</u>	<u>25 CFH</u>
Trailing	<u>---</u>	<u>---</u>	<u>---</u>
Backing	<u>---</u>	<u>---</u>	<u>---</u>

FILLER METALS (QW-404)	
SFA Specification <u>5.4</u>	<u>5.22</u>
AWS Classification <u>E308L-16</u>	<u>E308LT-1</u>
Filler Metal F-No. <u>5</u>	<u>6</u>
Weld Metal Analysis A-No. <u>8</u>	<u>8</u>
Size of Filler Metal <u>3/32"</u>	<u>.045"</u>
Other <u>---</u>	<u>---</u>
Weld Metal Thickness <u>.250</u>	<u>.188</u>

ELECTRICAL CHARACTERISTICS (QW-409)
 Current DC
 Polarity REV
 Amps. F5-110, F6-150 Volts F5-21, F5-24
 Tungsten Electrode Size NA
 Other FCAW-SHORT CIRCUIT ARC

POSITION (QW-405)
 Position of Groove 6G
 Weld Progression (Uphill, Downhill) UPHILL
 Other ---

TECHNIQUE (QW-410)
 Travel Speed 8IPM
 String or Weave Bead SMAW-STRING FCAW-WEAVE
 Oscillation NONE
 Multipass or Single Pass (per side) MULTIPLE
 Single or Multiple Electrodes SINGLE
 Other FCAW-NO. POWDERED OR SUPPLEMENTAL FILLER METALS WERE USED. FILLER METAL IS FLUX CORED.

PREHEAT (QW-406)
 Preheat Temp. 70 DEGREES F
 Interpass Temp. 300 DEGREES F
 Other ---

QW-483 (BACK)

PQR No. BB15T

Tensile Test (QW-150)

Specimen No.	Width	Thickness	Area	Ultimate Total Load lb	Ultimate Unit Stress psi	Type of Failure & Location
T-1	.752	.468	.352	28750	81676	EM DUCT
T-2	.749	.465	.348	28250	81178	EM DUCT

Guided-Bend Tests (QW-160)

Type and Figure No.	Result
ROOT BEND QW-462.3 (a)	ACCEPTABLE
ROOT BEND QW-462.3 (a)	ACCEPTABLE
FACE BEND QW-462.3 (a)	ACCEPTABLE
FACE BEND QW-462.3 (a)	ACCEPTABLE

Toughness Tests (QW-170)

Specimen No.	Notch Location	Specimen Size	Test Temp.	Impact Values			Drop Weight Break (Y/N)
				Ft. lbs.	% Shear	Min	

Comments: _____

Fit-Weld Test (QW-180)

Result — Satisfactory: Yes _____ No _____ Penetration Into Parent Metal: Yes _____ No _____

Macro — Results _____

Other Tests

Type of Test _____
 Deposit Analysis _____
 Other _____

Welder's Name ROBERTO CONTRERAZ Clock No. 460-47-7944 Stamp No. _____
 Tests conducted by: LONGVIEW INSPECTION, INC. Laboratory Test No. 127-89

We certify that the statements in this record are correct and that the test welds were prepared, welded, and tested in accordance with the requirements of Section IX of the ASME Code.

Manufacturer LIDE TANK COMPANY

Date 4/24/89

By B. J. Lile

(Detail of record of tests are illustrative only and may be modified to conform to the type and number of tests required by the Code.)

APPENDIX C.

HYDROSTATIC LEAK TESTS

L I D E INDUSTRIES

Route 2, Box 159F Mexia, Texas 76667 254-562-0233 Fax 254-562-0247

TEST INSPECTION REPORT

DATE: 05/22/02

CUSTOMER: Safety-Kleen

PURCHASE ORDER: 103034

ITEM NO.: 1

EQUIPMENT: Flash Tank

CODE: API 650

X-RAY: Spot

METHOD OF TEST: Filled with water and held for 24 hours

INSPECTED BY: Lide Industries, Inc.

RESULTS: Satisfactory (no leaks)

HYDROSTATIC TEST RECORD

Customer: Safety-Kleen - Lone Mountain Facility

Project: Evaporator Flash Tank No. 2

Location: Waynoka, Oklahoma

Test Start Date: 07/18/02 **Test Start Time:** 4:00 p.m.

Test Finish Date: 07/19/02 **Test Finish Time:** 5:00 p.m.

Test Procedure: Fill evaporator flash tank to the overflow nozzle with water.

Results: All nozzles were flanged-off below the test water level. There was no change in the water level inside the flash tank. Visual inspection of the tank and tank nozzles indicated no water leaks.

(Witness)

July 19, 2002
(Date)



ENVIROTECH
ENGINEERING & CONSULTING, INC.


APPENDIX D.

CALCULATIONS



ENVIROTECH
ENGINEERING & CONSULTING, INC.

Project Name Rocky Klean
Project No. EF 1+2 Sheet 1 of
Prepared By R. Stallings Date 7/20/02
Reviewed By Date
Scale



Shell BOTTOM

$$V = \frac{\pi D^2 L}{4} + \frac{1}{4} \pi h (3a^2 + h^2)$$

$$L = 15.5' \quad h = 1.1' \\ D = 6.33' \quad a = \frac{6.33'}{2} = 3.167'$$

MAX Vol

$$V = \frac{(\pi \times 6.33^2)}{4} (15.5) + \frac{1}{4} (\pi) (1.1) [3(3.167^2) + 1.1^2]$$

$$V = 488 + 18$$

$$V = 504 \text{ ft}^3 = 3785 \text{ gals (MAX Vol)}^*$$

* includes flange



ENVIROTECH
ENGINEERING & CONSULTING, INC.

Project Name Safety Keen
Project No ET 112 Sheet 2 of
Prepared By R. Stallings Date 7/20/02
Reviewed By Date
Scale

OVERFLOW VOL

$$V = \frac{\pi D^2 L}{4} + \frac{1}{6} \pi h (3a^2 + h^2)$$

$$D = 6.333' \quad h = 1.1'$$

$$L = 4.25' \quad a^2 = 3.167$$

$$V = \frac{\pi (6.333^2)(4.25)}{4} + \frac{1}{6} \pi (1.1) [3(3.167^2) + 1.1^2]$$

$$V = 134 + 18 = 152 \text{ ft}^3 = 1137 \text{ gals}$$

WATER WEIGHTS (tank content only)

Max Vol

$$W = (3785 \text{ gals})(8.341 \text{ #/gal})(1.5) = 47,356 \text{ #}$$

OVERFLOW VOL

$$W = (1137 \text{ gals})(8.341 \text{ #/gal})(1.5) = 14,226 \text{ #}$$

WEIGHT OF TANK

7300 # Weight of New tank shell + skirt (as per Mfg DWG)

1500 # Weight of Flue

250 # insulation (estimated)

3000 # accessories (estimated)

12,050 # Total Wt Tank



ENVIROTECH
ENGINEERING & CONSULTING, INC.

Project Name Safety Krew

Project No ET18R Sheet 20 of

Prepared By E. Stallinga Date 8/1/02

Reviewed By Date

Scale

Weight of Tank & Contents

MAX Volume

Wt Tank 12,050 #

Wt Content 47,356 #

TOTAL 59,406 #

OVERFLOW Vol

Wt Tank 12,050 #

Wt Content 14,226 #

TOTAL 26,276 #



ENVIROTECH
ENGINEERING & CONSULTING, INC.

Project Name Safety Klean

Project No. FT 142 Sheet 3 of

Prepared By Stallings Date 7/20/82

Reviewed By Date

Scale

MAX Bottom Operating Pressures

Assume tank pressure at atmospheric

c MAX Vol

$$H = 15.5' + 1.1' = 16.6'$$

$$P = \frac{(16.6')(1.5)}{2.31} = 10.8 \text{ PSI}$$

c Overflow Vol


$$H = 4.25 + 1.1 = 5.35'$$

$$P = \frac{(5.35)(1.5)}{2.31} = 3.47 \text{ PSI}$$



ENVIROTECH
ENGINEERING & CONSULTING, INC.

Project Name Safety Kiosk
Project No FT 112 Sheet 4 of 4
Prepared By R. Stallings Date 7/20/02
Reviewed By _____ Date _____
Scale _____



Overturning Moment (WIND)

$$OTM = [(130)(10.25) + (14)(22.5) + (27.25)(22.5)] (8)$$

$$OTM = 40,691$$

Cg Calc:

$$D = 6.33 \quad L = 20.5' \\ r_1 = 3.165' \quad r_2 = 1.5' \quad h = 3' \\ D' = 3' \quad L' = 7.5'$$

$$\text{Bottom: } W_B = \left(\frac{\pi D^2}{4} \right) \left(\frac{0.25}{12} \right) (499) = 327 \#$$

$$\text{Shell } W_S = \pi D L \left(\frac{0.25}{12} \right) (499) = 4238 \#$$

$$W_f = \left(\pi D' L' + \pi (r_1 + r_2) \sqrt{(r_1 - r_2)^2 + h^2} \right) \left(\frac{0.25}{12} \right) (499) \\ = (70.7 + 50.3) \left(\frac{0.25}{12} \right) (499) = 1258 \#$$



ENVIROTECH
ENGINEERING & CONSULTING, INC.

Project Name Safety Klean

Project No. FF 148 Sheet 5 of

Prepared By R. Stallings Date 7/20/02

Reviewed By Date

Scale

1 2 3 4 5 6 7 8 9 10 1 2 3 4 5 6 7 8 9 10 1 2 3 4 5 6 7 8 9 10 1 2 3 4 5 6 7 8 9 10 1 2 3 4

$$C_g = \frac{[(327)(5) + (4230)(0.25) + (1258)(23.5)]}{5823}$$
$$C_g = 12.81'$$

2500 N. Eleventh Street ■ Enid, OK 73702 ■ (580) 234-8780 ■ Fax (580) 237-4302 ■ www.envirotech-consulting.com



ENVIROTECH
ENGINEERING & CONSULTING, INC.

Project Name Pakty Klen

Project No FT 112 Sheet 6 of 6

Prepared By R. Stalling Date 7/20/02

Reviewed By _____ Date _____

Scale _____

Wind Loads on Vessel API 6D, 3.11

Wind Load = 18 PSF on projected frontal area

(See Sheet A for OTM Calc)

OTM = 40,691 ft-#

Tank Weight (empty) = 12,050 #

$$\left(\frac{2}{3}\right)\left(\frac{WD}{2}\right)$$

W = Empty Tank Weight

D = tank Dia

$$\frac{2}{3} \frac{(12050)(6.22)}{2} = 25,425$$

40,691 > 25,425 ∴ Anchors are required

ANCHORS

$$T_B = \frac{4M}{dN} - \frac{W}{N}$$

N = 8

T_B = tension load / anchor (#)

$$T_B = \frac{4(40,691)}{(6.5)(8)} - \frac{12050}{8} = 1623 \text{ #}$$



ENVIROTECH
ENGINEERING & CONSULTING, INC.

Project Name Patty Kren

Project No FT 182 Sheet 7 of

Prepared By R. Stallings Date 7/20/02

Reviewed By Date

Scale

Assume $3/4"$ A-36 Anchor Bolt

$$\text{Root Area} = 0.309 \text{ in}^2$$

$$\text{Allowable Tension} = 15,000 \text{ PSI (Sec API 650 F17)}$$

Allow $0.25"$ CA on the diameter "

$$\text{Eq Dia} = \sqrt{\frac{(0.309)(4)}{\pi}} - 0.25 = .3772 \text{ in}$$

$$\text{Adj Root Area} = (.3772)^2 \frac{\pi}{4} = .112 \text{ in}^2$$

$$\text{Allowable Tensile Strength / Root} = (.112 \text{ in}^2) \left(\frac{15,000 \text{ PSI}}{\text{in}^2} \right) = 1680 \#$$

$$\text{Allowable Tensile Strength / Anchor} \geq \text{tension load / anchor}$$

$$1680 > 1623$$

$\therefore 8 - 3/4"$ A-36 Bolt OK!



ENVIROTECH
ENGINEERING & CONSULTING, INC.

Project Name Safety Kleen

Project No FT182 Sheet 8 of

Prepared By R. Stallings Date 7/20/02

Reviewed By Date

Scale

SEISMIC LOADS Per API 650 Appendix E

Zone 1 $R = 0.1875$ Table E-1

$I = 1.0$

$C_1 = 0.24$

Calc C_2

$W_T = \text{total wt of contents (MAX VOL)} = 47356 \#$

$D = 6.33'$

$H = 9.0'$

$$\frac{D}{H} = \frac{6.33}{9.0} = 0.70$$

$$\frac{W_1}{W_T} = 0.87 \quad \frac{W_2}{W_T} = 0.15 \quad (\text{See Fig E-2})$$

$$\frac{X_1}{H} = 0.42 \quad \frac{X_2}{H} = 0.78 \quad (\text{See Fig E-3})$$

$K = 0.57$ (See Fig E-4)

$$T = K \sqrt{D} \\ = (0.57) \sqrt{6.33} = 1.434$$

$S = 1.5$ (Site Amp Factor Unknown - See Table E-2)

$$C_2 = \frac{0.25}{T} = \frac{(0.3)(1.5)}{1.434} = 0.314$$



ENVIROTECH
ENGINEERING & CONSULTING, INC.

Project Name Safety Klean

Project No. FT 1+2 Sheet 9 of

Prepared By R. Stallings Date 7/20/02

Reviewed By Date

Scale

$$W_1 = W_T (0.87) = (47356) (0.87) = 41,200 \text{ \#}$$

$$W_2 = W_T (0.15) = (47356) (0.15) = 7,103 \text{ \#}$$

$$X_1 = (0.42)(9.0) = 3.78'$$

$$X_2 = (0.78)(9.0) = 7.02'$$

$$M = \sum I (C_1 X_1 W_1 + C_1 W_r H_t + C_1 W_1 X_1 + C_2 W_2 X_2)$$

$$X_s = (\text{Base to shell C.G.}) = 12' \text{ approx}$$

$$W_s = W_t \text{ shell (H)} = 12050$$

$$W_r = \text{N/A (included in shell)}$$

$$H_t = \text{N/A}$$

$$M = (0.1875)(1) ((0.24)(12)(12050) + (0.24)(41200)(3.78) + (0.314)(7103)(7.02))$$

$$M = 13544 \text{ FT-}\#$$

Seismic

$$M_{\text{WIND}} = 40691 \text{ FT-}\#$$

\therefore Wind Dictates

Anchor Bolt Cals are OK!



ENVIROTECH
ENGINEERING & CONSULTING, INC.

Project Name Safety Klean
Project No ET132 Sheet 10 of
Prepared By R. Stallings Date 7/20/02
Reviewed By Date
Scale

1 2 3 4 5 6 7 8 9 10 1 2 3 4 5 6 7 8 9 10 1 2 3 4 5 6 7 8 9 10 1 2 3 4 5 6 7 8 9 10 1 2 3 4

Max Long Comp (Anchored Tanks)

$$b = \frac{Wt}{\pi D} + \frac{11273 M}{D^2}$$

Wt = Wt shell

$$b = \frac{12050}{\pi(4.33)} + \frac{(1.273)(40691)}{(4.33)^2}$$

$$b = 1898 \text{ \#/ft} \text{ LIRC}$$

$$\frac{b}{12t} = \frac{1898}{(12)(.25)} = 402 \text{ PSI}$$

$$\frac{M}{D^2(Wt+Wc)} = \frac{40691}{(4.5)^2 \left(\frac{12050 + 23032}{\pi(4.5)} \right)} = 0.56$$

$$\frac{GHD^2}{R^2} = \frac{(1.5)(9.0)(4.5)^2}{(125)^2} = 9/24$$

$$\therefore F_a = \frac{10^6 t}{2.5D} + 400 \sqrt{GH}$$

$$= \frac{(10^6)(.25)}{(2.5)(4.5)(12)} + 400 \sqrt{(1.5)(9)(12)}$$

$$F_a = 8918 \text{ PSI}$$

$$SF_y = (0.5)(42000) = 21,000$$

$$\frac{b}{12t} < F_a \quad \text{OK!}$$

$$F_a \leq .5 F_y \therefore \text{OK}$$



ENVIROTECH
ENGINEERING & CONSULTING, INC.

Project Name Safety Kurn

Project No FT 102 Sheet 11 of

Prepared By R. Stallings Date 7/20/02

Reviewed By Date

Scale

SHELL THICKNESS CALC

Thermal Red. Factor

$$RF @ 200^{\circ}F = 0.81$$

Min Thickness as per 3.6.3.2

$$t_d = \frac{2.4 P (H-1) G}{E S_d R_F} + CA$$

Design Shell Thickness Method

$$\left. \begin{array}{l} S_y = 42 \text{ KSI} \\ S_t = 81 \text{ KSI} \end{array} \right\}$$

316L Stainless Steel

$$\frac{3}{4} S_y = 28 \text{ KSI}$$

$$\frac{3}{4} S_t = 54 \text{ KSI}$$

$$\Rightarrow S_d = 28 \text{ KSI}$$

$$E = 0.7$$

Assume $H = 20.5$ (conservative)

$$t_d = \frac{(2.4)(4.3)(20.5-1)(1.5)}{(0.7)(28000)(.81)} + 0.125$$

$$t_d = 0.156''$$

$$t_t = \frac{2.4 P (H-1)}{S_t}$$

Hydrostatic Test Shell Thickness Method

$$\frac{3}{4} S_y = 31,500$$

$$\frac{3}{4} S_t = 23,142$$

$$\Rightarrow S_t = 23,142$$



ENVIROTECH
ENGINEERING & CONSULTING, INC.

Project Name Safety Kren
Project No ET 142 Sheet 12 of
Prepared By R. Stalling Date 7/20/02
Reviewed By Date
Scale

$$L_t = \frac{(2.6)(6.33)(20.5-1)}{23,192}$$

$$L_t = 0.0139$$

$$L_d > L_t \therefore t = L_d = 0.156''$$

min

Min Shell Thickness (calc)

$$t = 0.156$$

Note: 1/4" plate OK!



ENVIROTECH
ENGINEERING & CONSULTING, INC.

Project Name Safety Klean
Project No ET 148 Sheet 13 of
Prepared By R. Stollings Date 7/20/02
Reviewed By Date
Scale

Tank Bottom Calculations

$$G_c = \frac{PR}{t} \Rightarrow t = \frac{PR}{G_c} + CA$$

G_c = Circumferential Stress SF = safety factor

P = tank pressure (11.42 PSI - see Calc sheet)

R = tank radius (3.165') t = req thickness

$$G_c = \frac{S_y}{SF} = \frac{42,000 \text{ PSI (316 stainless)}}{2.5}$$

$$= 16,800 \text{ PSI}$$

$$t = \frac{(11.42 \text{ PSI})(3.165 \text{ ft})(\frac{12 \text{ in}}{\text{ft}})}{16,800 \text{ PSI}} + 0.125 \text{ in}$$

$$t = 0.151 \text{ in} \quad \text{Min Bottom Thickness (calc)}$$

Note: $\frac{1}{4}$ " plate OK!

APPENDIX E.

METALLURGICAL INFORMATION



Heads

AvestaPolarit, Inc.
Plate Products

14290(2) 80 3/4" OD X 1/4" 316L
Certificate of Analysis and Tests

ORDER 221463 - 15

HEAT & PIECE 814488-3A 8/24/01

SOLD TO: METAL SERVICES, INC
PO BOX 550639

DALLAS

TX 75355

SHIP TO: METAL SERVICES, INC.
10770 SANDHILL ROAD
1-214-348-7140
DALLAS
649001-0004

TX 75238

YOUR ORDER & DATE

M 0115429

0/00/00

TAG# 10716

ITEM DESCRIPTION

HEAT & PIECE 814488 - 3A

WEIGHT 2143

FINISH

GRADE 316L

DIMENSIONS 250 X 96.000 X 288.000 EXACT

SPECIFICATIONS

*** MFG IN NEW CASTLE, IN, USA
ASTM A240-00 ASME SA240 98ED
ASTM A167-93, ASME SA167-92
ASTM A262-98 PRAC E
NACE MRO175-2000
NO WELD REPAIRS

FROM SLABS IMPORTED FROM BRITAIN
ASTM A480-99 ASME SA480-98ED
ASTM A262-98 PRAC A
ASTM A262-98 PRACTICE B
NO GRIPPER MARKS

Lide Industries
PO# 1476
(2) 75 1/4" OD X 1/4" 316L
Std

PLATES & TEST PCS SOLUTION ANNEALED @ 1950 DEGREES FARENHEIT MINIMUM.
THEN WATER COOLED OR RAPIDLY COOLED BY AIR
FREE OF MERCURY CONTAMINATION
NOT ROLLED, ANNEALED & PICKLED (HRAP)

MECHANICAL & OTHER TESTS

HARDNESS RB 87
GRAIN SIZE 6
YIELD STRENGTH (PSI) 54278
TENSILE STRENGTH (PSI) 89291
BEND OK
INTERGRANULAR CORROSION OK
ELONGATION % IN 2" 50.0
REDUCTION OF AREA % 71.1

MILL TEST REPORTS FURNISHED
BY TAD METALS INC. SOUTH WEST

CUSTOMER BAKER TANKHEAD
YOUR PO 14890
DATE 3-21-08
ITEM NO. 01-003# 53099
OUR INV. NO. 0119238

CHEMICAL COMPOSITION

CARBON (C) .014
MANGANESE (MN) 1.68
PHOSPHORUS (P) .027
SULFUR (S) .001
SILICON (SI) .36
CHROMIUM (CR) 16.35
NICKEL (NI) 10.07
COBALT (CO) .16
COPPER (CU) .34
MOLY (MO) 2.16
NITROGEN (N) .04
COLUMBIUM (CB) .008
TITANIUM (TI) .001
ALUMINUM (AL) .007
TIN (SN) .011

P.O. 0115429
ITEM 1/4 x 96 x 288
316L

814488

KNOWINGLY & WILLFULLY FALSIFYING OR CONCEALING A MATERIAL FACT ON THIS FORM,
OR MAKING FALSE, FICTITIOUS OR FRAUDULENT STATEMENTS OR REPRESENTATIONS
HEREIN COULD CONSTITUTE A FELONY PUNISHABLE UNDER FEDERAL STATUTES.

JAMES DOUBMAN, QUALITY ASSURANCE MANAGER

James Doubman
AvestaPolarit, Inc.
Plate Products
P.O. Box 370
New Castle, Indiana 47356

VUB
2250



NOTICE OF SHIPMENT/ PACKING LIST



Allegany Ludlum
An Allegany Technologies Company

Sheil

248499
CERTIFICATE OF

AL 9188A-7 400

CUST. ORDER NO. & DATE

816779

FORM DISTRIBUTION

SOLD TO 1 SHIP TO 1

CUST. CODE

01/11/02 836385

ACCEPTING MILL

MASSILLON, OH

SHIPPER NO.

418872

PRODUCT CODE

31020101060000

MILL ORDER NUMBER

52-012-052

DATE SHIPPED

01/15/02

SHIP TO

1

SHIP TO

1

SHIP TO

1

SHIP TO

1

SHIP TO

1

SHIP TO

1

SHIP TO

1

SHIP TO

1

SHIP TO

1

SHIP TO

1

SHIP TO

1

SHIP TO

1

SHIP TO

1

SHIP TO

1

SHIP TO

1

SHIP TO

1

SHIP TO

1

SHIP TO

1

SHIP TO

1

SHIP TO

1

SHIP TO

1

SHIP TO

1

SHIP TO

1

SHIP TO

1

SHIP TO

1

SHIP TO

1

SHIP TO

1

SHIP TO

1

SHIP TO

1

SHIP TO

1

SHIP TO

1

SHIP TO

1

SHIP TO

1

SHIP TO

1

SHIP TO

1

SHIP TO

1

SHIP TO

1

SHIP TO

1

SHIP TO

1

SHIP TO

1

SHIP TO

1

SHIP TO

1

SHIP TO

1

SHIP TO

1

SHIP TO

1

SHIP TO

1

SHIP TO

1

SHIP TO

1

SHIP TO

1

SHIP TO

1

SHIP TO

1

SHIP TO

1

SHIP TO

1

SHIP TO

1

SHIP TO

1

SHIP TO

1

SHIP TO

1

SHIP TO

1

SHIP TO

1

SHIP TO

1

SHIP TO

1

SHIP TO

1

SHIP TO

1

SHIP TO

1

SHIP TO

1

SHIP TO

1

SHIP TO

1

SHIP TO

1

SHIP TO

1

SHIP TO

1

SHIP TO

1

SHIP TO

1

SHIP TO

1

SHIP TO

1

SHIP TO

1

SHIP TO

1

SHIP TO

1

SHIP TO

1

SHIP TO

1

SHIP TO

1

SHIP TO

1

SHIP TO

1

SHIP TO

1

SHIP TO

1

SHIP TO

1

SHIP TO

1

SHIP TO

1

SHIP TO

1

SHIP TO

1

SHIP TO

1

SHIP TO

1

SHIP TO

1

SHIP TO

1

SHIP TO

1

SHIP TO

1

SHIP TO

1

SHIP TO

1

SHIP TO

1

SHIP TO

1

SHIP TO

1

SHIP TO

1

SHIP TO

1

SHIP TO

1

SHIP TO

1

SHIP TO

1

SHIP TO

1

SHIP TO

1

SHIP TO

1

SHIP TO

1

SHIP TO

1

SHIP TO

1

SHIP TO

1

SHIP TO

1

SHIP TO

1

SHIP TO

1

SHIP TO

1

SHIP TO

1

SHIP TO

1

SHIP TO

1

SHIP TO

1

SHIP TO

1

SHIP TO

1

SHIP TO

1

SHIP TO

1

SHIP TO

1

SHIP TO

1

SHIP TO

1

SHIP TO

1

SHIP TO

1

SHIP TO

1

SHIP TO

1

SHIP TO

1

SHIP TO

1

SHIP TO

1

SHIP TO

1

SHIP TO

1

SHIP TO

1

SHIP TO

1

SHIP TO

1

SHIP TO

1

SHIP TO

1

SHIP TO

1

SHIP TO

1

SHIP TO

1

SHIP TO

1

SHIP TO

1

SHIP TO

1

SHIP TO

1

SHIP TO

1

५८३

CERTIFICATE OF RESEARCH

DATE SUBMITTED

[illegible]

CONTACT - JONES MOTOR CO., INC. (204) 11-1304M
ANNEALED PICKLED 3 COSE EASTN. 4-480/4-430M-00

006	007	008	009	010	011	012	013	014	015	016	017	018	019	020	021	022	023	024	025	026	027	028	029	030	031	032	033	034	035	036	037	038	039	040	041	042	043	044	045	046	047	048	049	050	051	052	053	054	055	056	057	058	059	060	061	062	063	064	065	066	067	068	069	070	071	072	073	074	075	076	077	078	079	080	081	082	083	084	085	086	087	088	089	090	091	092	093	094	095	096	097	098	099	100	101	102	103	104	105	106	107	108	109	110	111	112	113	114	115	116	117	118	119	120	121	122	123	124	125	126	127	128	129	130	131	132	133	134	135	136	137	138	139	140	141	142	143	144	145	146	147	148	149	150	151	152	153	154	155	156	157	158	159	160	161	162	163	164	165	166	167	168	169	170	171	172	173	174	175	176	177	178	179	180	181	182	183	184	185	186	187	188	189	190	191	192	193	194	195	196	197	198	199	200	201	202	203	204	205	206	207	208	209	210	211	212	213	214	215	216	217	218	219	220	221	222	223	224	225	226	227	228	229	230	231	232	233	234	235	236	237	238	239	240	241	242	243	244	245	246	247	248	249	250	251	252	253	254	255	256	257	258	259	260	261	262	263	264	265	266	267	268	269	270	271	272	273	274	275	276	277	278	279	280	281	282	283	284	285	286	287	288	289	290	291	292	293	294	295	296	297	298	299	300	301	302	303	304	305	306	307	308	309	310	311	312	313	314	315	316	317	318	319	320	321	322	323	324	325	326	327	328	329	330	331	332	333	334	335	336	337	338	339	340	341	342	343	344	345	346	347	348	349	350	351	352	353	354	355	356	357	358	359	360	361	362	363	364	365	366	367	368	369	370	371	372	373	374	375	376	377	378	379	380	381	382	383	384	385	386	387	388	389	390	391	392	393	394	395	396	397	398	399	400	401	402	403	404	405	406	407	408	409	410	411	412	413	414	415	416	417	418	419	420	421	422	423	424	425	426	427	428	429	430	431	432	433	434	435	436	437	438	439	440	441	442	443	444	445	446	447	448	449	450	451	452	453	454	455	456	457	458	459
-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----

1007. 9509097

REF ID: A66342

THE
FALL
OF

[illegible]

Household Safety Data Shows In the United States, more than 100 million people live in homes with faulty wiring. On an average, every person in the U.S. has 100 feet of wiring in his or her home. The National Fire Protection Association estimates that 25 percent of all fires are caused by faulty wiring. For more information on household safety, call 1-800-368-7233. The National Fire Protection Association is the leader in fire safety information.

Les films d'animation - attrait de près de 400 millions de spectateurs chaque semaine. Pour cela, les animateurs expérimentés de la MGM ont mis au point un système unique : les films d'animation sont réalisés par des artistes professionnels, qui travaillent en étroite collaboration avec les réalisateurs et les producteurs.

90-10050 10/51/50

The above is my copy of the will. It is enclosed subject to the conditions in the under contract and specifications as set forth in Anthony L. Latham's Order of Appointment.



**NOTICE OF SHIPMENT/
PACKING LIST**

CUST. ORDER NO. & DATE
816779

FORMS DISTRIBUTION	SHIP TO	SPEED
1	1	1

SOLD TO
SOUTHWEST STAINLESS
2805 MARKET STREET
SUITE #150
GARLAND

TX 75041

HOLSTON

SOUTHWEST STAINLESS
C/O TSA PROCESSING
1625 W SAM HOUSTON F
HOUSTON

TX 77043

GRADE AND SPECIFICATIONS

ALLEGHENY STAINLESS STEEL TYPE 316-L PLATE-HOT ROLLED COILS ANNEALED PICKLED 3 EDGE (ASTM-A-480/A-480M-01)
(ASME-SA-240 2001 ED) (ASTM-A-240-01) (316/316L)

ITEM PCS DIMENSIONS W/G/L

THEO TAG #/ CD SKID #

012 1 72./250/362.
C

23100

9603901

69421FC 05641N

-/250/362.

COIL

25100

23100

7103

TYPE HEAT/TEST
HEAT 69421FC

20. N

MO
2.04

--CR--
16-74

---P---S---S1
 .029 .0005 .60

TEST
FC

ITEM TEST NO
012 9603901

HARDENABILITY
HR

GRAIN
SIZE
NR

CORROS
A 262 P
NR

NESS
B

LE % ELONG	IN 2"	% R/A
0.	61.	73.

01

* Y-S. BY 0.2% OFFSET METHOD

NR = DATA NOT REQUIRED

PAGE 01 - FINAL PAGE.

SHIPPING CONTROL COPY

01/19/02 08:41:27

CONSIGNEE—Please Note—This consignment was turned over to carrier in first class condition, being correctly loaded, at which time our responsibility for loss or damage is shipment ceased. For your protection please examine shipment as it arrives. If any shortage or damage is discovered, fills a full description made by transportation agent on arrival before signing.

Wildmaier Safety Data Sheets for this product have been supplied to your Purchasing Department. For an additional copy please 781-642-0878. CAUTION: Processing that makes solder, flux, or solutions may cause lung disease. See Material Safety Data Sheet for further information.

[illegible]

The above is a true copy of data on file. The materials and test results conform to the sales contract and specification(s) as set forth in Alabachery Lockhart's Order Acknowledgement.

Chad Hagdale
C.H. Hagdale - Manager, Technical Support

BIETALFAR
PRODOTTI INDUSTRIALI S.p.A.
Sede e stabilimento: viale dell'Industria 100001 (Napoli) Italia
Tel. (031) 855441
Telex 658149
MATERIAL TEST DEPARTMENT



SHILB INC. THREE LANE STAR
170 PUDWAY DRIVE
USA CAROL SPANAN, ILL.

3043, 14, 13

INSPECTION CERTIFICATE DNI 80049/3.1B - RN 19204/3.1B - CERTIFICATO DI COLLAUDO

NAME	761	10/01/2002
ADDRESS / NUMBER	551	07/01/2002
DATE	27928	
TEL. NUMBER / CELL	981	07/01/2002

[illegible]

TALFAR

MODOTTI INDUSTRIALI S.p.A.

3881 CESANA BRANZA (Lecce) ITALY

Tel. (031) 866441

Telex 655149

MATERIAL TEST DEPARTMENT

SALA PROVE ED ANALISI MATERIALI

BURNING QUALITY SYSTEM



INSPECTION CERTIFICATE 30049/3.1B - EN 10204/3.1B - CERTIFICATO DI COLLAUDO

SILCO IEN921138

50 CHIEF OF FIBRE 2019

87415 MONTANA S.p.

N. 1741/

23/05/2001

INVOICE / FATURA 1691/

24/05/2001

S. 1691

DEL. NOTE / BOLLE 1551/

24/05/2001

HEAT CODE COD. CALDA		HEAT CALDA	ITEM POS.	YOUR P.O. VS. ORDINE	OUR REFERENCE VS. ORDINE	QUANTITY QUANTITÀ	D E S C R I P T I O N D E S C R I Z I O N E										DIM. IN ACCORDANCE TO DIM. IN ACCORDO A										VISUAL & DIMENSIONAL VISIVO E DIMENSIONALE									

NOTE

MATERIAL IN ACCORDANCE WITH NACE MR-0175/2000

MUTTI LORENZO

(MFF)

QUALITY CONTROL DEPARTMENT
UFFICIO CONTROLLO QUALITÀINSPECTION AUTHORITY
ENTE LITALE COLLAUDOMANUFACTURER'S SYMBOL
MARCHIO PROCEDURA



TAIPEI : TEL (02)26940222 FAX (02)26945878
 NAN-KANG : TEL (049)253726 FAX (049)253729
 PHILS. : TEL (046)4371023 FAX (046)4371021
 U.S.A. : TEL (949)3880714 FAX (949)3881440

R47161

MILL TEST REPORT

DATE: Jan/4/2002
 PURCHASER: SOUTHWEST STAINLESS, INC. PURCHASE ORDER NO.: 816148
 ENLIN S/C NO.: B234SW

PRODUCT : STAINLESS STEEL FORGED FLANGE

HEAT NO.	QTY	TYPE	DESIGNATION	SIZE	SPECIFICATION
GCJ9	50	316L/316	150# SLIP ON RF	6"	ANSI B16.5

CHEMICAL ANALYSIS OF MATERIAL

HEAT NO.	C	Mn	Si	P	S	Cr	Ni	Mo	N	SPECIFICATION
Maxi	0.035	2.00	1.00	0.040	0.030	16 - 18	10 - 14	2 - 3	0.100	ASME SA182-92
GCJ9	0.016	1.39	0.33	0.023	0.001	16.43	10.70	2.04	0.034	ASTMA182-95

MECHANICAL CHARACTERISTICS

HEAT NO.	TS.-PSI	YS.-PSI	%-EL	%-RA	HEAT-TREAT	DIMENSION	P.M.I
Mini	75,000	30,000	30	50	1050- 1150 °C		
GCJ9	81,000	38,600	57	60	1060 °C	OK	OK

MATERIAL RESISTANT TO INTERCRYSTALLINE CORROSION ACCORDING TO
 ASTM A262 PRACTICE E.
 FREE FROM MERCURY CONTAMINATION.
 MATERIAL IN ACCORDANCE WITH NACE MR0175-94.

FACTORY INSPECTOR :

Yi Tsai Lin
 YI TSAI LIN

QUALITY ASSURANCE DEPARTMENT



柏緯鐵工股份有限公司

高雄縣仁武鄉烏林村仁心路 303 號

BOTH-WELL STEEL FITTINGS CO., LTD.

NO.303, JEN-HSIN ROAD JEN-WU HSIANG

KAOSHIUNG HSIEN, TAIWAN R.O.C. (81405)

TEL: (07) 371-0497, 371-1536, 372-0260

HOME PAGE: <http://www.bothwell.com.tw> E-MAIL: bothwell@www.bothwell.com.tw or box@mail.bothwell.com.tw

An ISO-9002 Registered Manufacturer



Dutch Council
For Accreditation



R47161

FAX: (886-7) 371-3864, 371-3882

MILL TEST & INSPECTION CERTIFICATE

CUSTOMER: SELBO INDUSTRIES, INC. ACCORDING TO EN10204 / DIN50049 / 3.1.B
CERT NO: 12082 ORDER NO: 87058 INVOICE NO: BW01100080
L/C NO: 511262119

DATE: 01/12/04
PAGE: 10

ITEM	RAW MATERIAL HEAT NO.	BOTH WELL HT CD.	DESCRIPTION	QUANTITY	Specification: ASME SA182 F316/316L-036 DIMENSION: ASME B16.11 - 1996 SURFACE: BY VISUAL...GOOD
030	9N236	T426	FULL CPLG 1/2" 3000# S/W	25 PCS	
031	9P045	T445	FULL CPLG 1" 3000# S/W	25 PCS	
037	P0784	T431	FULL CPLG 1/4" 3000# NPT	15 PCS	
038	P0136	T404	FULL CPLG 3/8" 3000# NPT	5 PCS	
039	9N241	T424	FULL CPLG 3/4" 3000# NPT	10 PCS	
040	A28750	W137	FULL CPLG 1-1/2" 3000# NPT	5 PCS	
041	449344	T357	FULL CPLG 2" 3000# NPT	15 PCS	
046	P0136	T404	HALF CPLG 3/8" 3000# NPT	15 PCS	
047	A33282	W162	HALF CPLG 1" 3000# NPT	25 PCS	
059	706659	T359	TRE 2" 3000# S/W	10 PCS	

CHEMICAL COMPOSITION (%)

ITEM	C	Si	Mn	P	S	Cu	Cr	Ni	Mo	V	Nb	N
Min	-	-	-	-	-	-	16.00	10.00	2.000	-	-	-
Max	0.035	1.000	2.000	0.045	0.030	-	18.00	15.00	3.000	-	-	0.100
030	0.018	0.360	1.650	0.027	0.024	-	17.24	11.02	2.100	-	-	0.035
031	0.018	0.450	1.640	0.019	0.025	-	17.22	11.48	2.090	-	-	0.080
037	0.018	0.450	1.580	0.034	0.025	-	16.40	10.75	2.130	-	-	0.067
038	0.050	0.420	1.810	0.036	0.026	-	16.52	10.82	2.200	-	-	0.050
039	0.015	0.310	1.620	0.026	0.025	-	17.19	11.31	2.080	-	-	0.038
040	0.023	0.340	1.680	0.032	0.012	-	16.64	11.53	2.244	-	-	0.026
041	0.009	0.450	1.810	0.025	0.021	-	17.46	12.54	2.540	-	-	0.058
046	0.030	0.420	1.810	0.036	0.026	-	16.52	10.82	2.200	-	-	0.050
047	0.020	0.410	1.230	0.030	0.003	-	16.27	11.23	2.265	-	-	0.050
059	0.018	0.290	1.300	0.035	0.024	-	16.32	12.01	2.060	-	-	0.044

MECHANICAL TEST

ITEM	Tensile Strength (Kg/mm2)	Yield Strength (Kg/mm2)	Elong- ation (%)	R of A (%)	Hard- ness (HB)
Min	52.70	21.10	30.00	50.00	-
Max	-	-	-	-	235
030	58.70	28.00	58.00	76.00	163
031	60.60	29.50	58.00	74.00	170
037	58.70	33.20	58.00	71.70	163
038	57.40	30.60	57.20	72.10	161
039	56.90	25.30	61.50	71.20	158
040	54.10	24.30	56.50	70.50	152
041	58.80	27.70	64.70	71.70	163
046	57.40	30.60	57.20	72.10	161
047	60.30	30.10	57.10	72.60	170
059	59.80	29.90	53.80	70.80	167

Remark :

SOLUTION TREATED : 1040°C, W.Q.
CONFORMS TO NACE MR01-75
STEEL MARKING PROCESS: ELECTRIC FURNACE

WE CERTIFY THE ABOVE MENTIONED FITTINGS HAVE BEEN
MANUFACTURED AND TESTED IN ACCORDANCE WITH THE
SPECIFICATIONS SHOWN.

S. C. Lee Q. C. Manager
C. C. Huang INSPECTOR

550001

BRISTOL METALS L.P.
BRISTOL, TN. U.S.A.
MILL TEST REPORT

SOUTHWEST STAINLESS-
TO: 2805 MARKET STREET
SUITE #150
GARLAND, TX

75041

CUST NO: 63800080
JOB NO: 9098C
PO NO: 813439
DATE: 04/05/00

HEAT NO. ITEM DESCRIPTION

927264 2" WELDED PIPE SCH 40S TP316L/TP316 ASTM A312-75A/ASME SA312-98,99ADD,WELDED

HEAT NO.	C	MN	P	S	SI	NI	CR
927264	.020	1.740	.028	.0170	.37	10.110	16.400

HEAT NO.	NO	CU	CO	N2	TENSILE	YIELD
927264	2.03	.34	.00	.009	91,900	46,800

HEAT NO.	CO		
927264	.160		

HEAT NO. HARDNESS ELONGATION TG BEND FLATTENING TENSION

927264 RBBS 42.00 % NA OK OK

REVERSE BEND FLANGE FLARE REVERSE FLATTENING EDDY CURRENT HYDRO

NA NA NA NA NA 1900 PSI

ANNEALED AT 1900 DEG F.
AND WATER QUENCHED TO
BELOW 600 DEG. F. IN
LESS THAN 3 MIN.

HEAT NO.

927264

YES

RADIOGRAPHIC
EXAMINATION

NA

HARDNESS IN ACCORDANCE WITH NACE MR0175.
BRISTOL METALS DOES NOT ADD MERCURY DURING ANY MANUFACTURING PROCESSES.
WE CERTIFY THIS REPORT TO BE
TRUE AND ACCURATE, ACCORDING
TO OUR RECORDS ON FILE.

BRISTOL METALS L.P.

David Singleton
REPRESENTATIVE

FREED

247161

TEST CERTIFICATE



AICHI STEEL CORPORATION

Messrs :

KARIYA PLANT: KARIYA-CITY,
AICHI-PREF., JAPAN
Date: AUG. 05. 2000 No. K-8230

Material	Size (INCH)	Section Code	Charge No.	Condition Code	Bundle No.	No. of Piece	Netweight (LBS)
AISI316/316L	2 X 2 X 3/8	61	23208	DS	SB5105-SB5106	21	2,061

Ladle Analysis (%)									
C. x100	Si. x100	Mn. x100	P. x100	S. x100	Cu. x100	Ni. x100	Cr. x100	Mo. x100	B. x10000
MAX 3	MAX 100	MAX 200	MAX 45	MAX 30	MAX 50	1000-1400	1600-1800	200-300	
2.0	50	139	32	1	20	1136	1687	213	
									16
									2

The Quality Management System of ISO9002
in Kariya Plant and Relative Head Office
have been approved by
Lloyd's Register Quality Assurance Limited



Mechanical Properties									
Heat Treatment (°C)					Tensile Test				
SOLUTION TREATMENT	2nd Quenching	Tempering	Yield Strength	Tensile Strength	Elongation	Reduction of Area	Impact Test	Hardness Test	Bed Test
-	-	-	MIN 30	MIN 75	MIN 40	MIN 50		HRB	
AS DELIVERED			34	75	65	73		78-90	
								79	

ASTM A276-98A, A484, A479/479M-97C+S2.1; ASME SA479/479M-98ED+S2.1 SAE AMS Q95 763; INTER GRANULAR CORROSION TESTED ASTM A262 A.C.E:OK.1/LOT:1976°F X 2MINUTES WATER QUENCH			
Section	Code	Condition	Code
10: Round Bar 20: Square Bar 30: Hexagonal Bar 50: Flat Bar (Round edge) 51: Flat Bar (Square edge) 54: Flat Bar (Parabolic type)	60: Flat Bar (Stainless steel) 61: Equal Leg Angle Bar (Stainless steel) 62: Unequal Leg Angle Bar (Stainless steel) 63: Channel Bar 66: Sheet Bar (Stainless steel) 91: Wire Rod	A: Annealed B: Low Temperature Annealed D: Solution Heat Treated G: Centerless Ground H: Quenched and Tempered N: Normalized	P: Cold Drawn Q: Spheroidized R: Hot Rolled S: Pickled T: Bar Turned

M. Kariya
Chief, Inspection Department
AICHI STEEL CORPORATION

APPENDIX F.

SUPPORT STRUCTURE CALCULATIONS

Structural Support Calculations

COLUMN LOADS


A-1 - 3.6 k
 B-1 - 14.3 k
 C-1 - 14.1 k
 D-1 - 19.0 k
 E-1 - 14.2 k
 A-2 - 4.5 k
 B-2 - 36.3 k
 D-2 - 62.9 k
 E-2 - 34.1 k
 A-3 - 8.4 k
 B-3 - 27.9 k
 C-3 - 28.8 k
 D-3 - 19.9 k
 E-3 - 14.4 k
 A-5 - 9.8 k
 B-5 - 17.6 k
 A-7 - 4.8 k
 B-7 - 8.5 k
 C-7 - 11.5 k
 F-7 - 12.1 k
 C-6 - 24.8 k
 F-6 - 24.2 k
 C-4 - 28.1 k
 F-4 - 24.2 k
 F-3.1 - 12.0 k

EXCEPT @ GRID F. ALL COLUMNS
WILL BE 14.8-24.


WITH KL 13.0 ALLOWABLE

COL LOAD IS 93.0 k.

THIS SATISFIES ALL CONDITIONS



HORIZ. FORCES @ GRID. F'




$$\frac{3.26}{4} = .8150 \text{ KIPS PER COL.}$$

$$.8150 \times 11.5 = 9.37 \text{ K' MOMENT}$$

$$\frac{9.37 \times 12 \times 1000}{21600} = 5.2 \text{ KIPS}$$

$$12 \times 31 \times 27.5 = 5.2 \text{ COLUMNS OK}$$




HORZ. FORCES & DIAG. BRACING.

7.26 KIPS @ C-7 TO E-7

12.23 @ E-2 TO E-3

6.10 @ A-1 TO A-2

14.64 @ D-1-1 TO E-1



DIAG. BRACES. $A = 4 \times \frac{3}{8} = 1.5 \text{ in}^2$ $\frac{26.13}{1.5} = 17.42 \text{ ksi} < 24$
BRACES O.K.


COLUMN UPLIFT 21.65 W/ $4 \times \frac{3}{4}$ EPOXY ANCHORS:

PULLOUT TEST ON $\frac{3}{4}$ EPOXY ANK. W/ $\frac{1}{2}$ IN EMBEDMENT IS

24.2 KIPS. WITH A SAFETY FACTOR OF 4 TO 1

24 KIPS PER ANCHOR

$6 \text{ k} \times 4 = 24 > 21.65$ O.K.



DESKAN LOADS (1990 BOCA NATIONAL BUILD. CODE)

LIVE LOAD ... 100 PSF. (LIGHT MANUFACTURING - PAGE 246)
DEAD LOAD ... 20 PSF.
TOTAL ... 120 PSF.

TANKS FT1, FT2, & FT3 47,300 LBS. EACH (FILLED).
TANK EF4 25,300 LBS (FILLED).

LATERAL FORCES FOR EARTHQUAKE LOADS

$V = 2.5 A_v I K C S W$ (PAGE 272)
 $A_v = .1$ (ZONE 1) (PAGE 273)
 $I = 1.0$ (TABLE 1113.1, PAGE 275)
 $K = 1.0$ (TABLE 1113.4.3, PAGE 278)
 $C = .12$ (PAGE 279)
 $S = 1.5$ (TABLE 1113.4.6, PAGE 281)
 $W = \text{WEIGHT}$


$$V = 2.5 \times .1 \times 1.0 \times 1.0 \times .12 \times 1.5 \times W$$
$$V = .045 W$$



BEAM GRID A-1 TO B-1

(12/2/14)

UNBRACED LENGTH 3'-1"




$$M @ 1 = 0 = 2.4 \times 3.08 = 7.4$$

FROM ASD 2.174 ALLOWABLE $M = 27.3 > 7.4$

BEAM GRID A-2 TO B-2

(12/2/14)

UNBRACED LENGTH 3'-1"



$$M @ 1 = 3.3 \times 3.08 = 10.2$$

$$M @ 2 = 3.3 \times 4.50 = 2.4 \times 1.42 = 11.4$$

$$M @ 3 = 4.3 \times 3.08 = 1.9 \times 1.71 = 11.9$$

$$M @ 4 = 4.3 \times 2.37 = 10.2$$

FROM ASD 2.174 ALLOWABLE $M = 27.3 > 11.9$

Otis A Clark PE.


TEL NO. 405 878-0338

Mar 29, 95 9:09 P.11
PAGE 9

BEAM & GRID B-2 TO D-2

(W12.35)

UNBRACED LETH 21.1



$$M @ ① \quad 26.0 \times 2.21 = 46.4$$

$$M @ ② \quad 26.0 \times 5.13 - 20.4 \times 2.92 = 48.2$$


$$M @ ③ \quad 26.0 \times 2.21 = 46.4$$

FROM ASD 2.172 ALLOWABLE $M = 91.2 > 48.2$

BEAM & GRID D-2 TO E-2

(W12.26)

UNBRACED LETH 21.1



$$M @ ① \quad 26.4 \times 2.21 = 58.3$$


$$M @ ② \quad 26.4 \times 5.13 - 25.8 \times 2.92 = 60.1$$

$$M @ ③ \quad 26.4 \times 2.21 = 58.3$$

FROM ASD 2.173 ALLOWABLE $M = 66.8 > 60.1$

BEAM & GRID D.1-1 TO E-1 & D.1-3 TO E-3 (W12x16)

(UNBOLTED LATCH 241)



$$M = ① 15.4 \times 67 = 10.3$$


$$M = ② 15.4 \times 3.59 - 12.9 \times 2.92 = 17.6$$

$$M = ③ 11.0 \times 2.21 = 24.3$$

FROM ASD 2-173 ALLOWABLE $M = 66.6 > 24.3$

BEAM & GRID B-1 TO C-1 (W12x19)

(UNBOLTED LATCH 241)




$$M = ① 6.4 \times 2.21 = 14.1$$

$$M = ② 6.4 \times 5.13 - 7.5 \times 2.92 = 10.9$$

$$M = ③ 9.2 \times 67 = 6.2$$

FROM ASD 2-174 ALLOWABLE $M = 42.5 > 14.1$



(12/12/14)

UNBRACED LETH 30

$$M_1 = 4.4 \times 1.5 = 6.6$$

$$M_2 = 4.4 \times 3.75 - 1.5 \times 3.00 = 16.5$$

$$M_3 = 3.7 \times 5.14 - 1.9 \times 2.37 = 19.1$$


$$M_4 = 3.7 \times 2.37 = 8.77$$

FROM ASD 2.174 ALLOWABLE $M = 27.3 >$

BEAM - GRID A-5 TO A-7

(WING)

UNBRACED LETH 310



$$M_1 = 6.1 \times 3.35 = 20.4$$

$$M_2 = 6.1 \times 7.17 - 3.1 \times 3.82 = 31.9$$

$$M_3 = 6.2 \times 6.24 - 2.7 \times 3.35 = 29.6$$


$$M_4 = 6.2 \times 2.89 = 17.9$$

FROM ASD 2.172 ALLOWABLE $M = 76.2 > 31.9$

BEAM @ GRID A-3 TO A-5

(W12x26)

UNBRACED LENGTH 41.0



$$M @ 1 = 4.2 \times 3.31 = 13.9$$

$$M @ 2 = 4.2 \times 6.62 - 1.8 \times 3.31 = 22.0$$

$$M @ 3 = 4.0 \times 7.96 - 2.2 \times 3.98 = 23.4$$


$$M @ 4 = 4.0 \times 3.98 = 15.9$$

FROM ASD 2-17C ALLOWABLE $M = 76.2 > 23.4$

BEAM @ GRID B-3 TO B-5

(W12x26)

UNBRACED LENGTH 41.0



$$M @ 1 = 7.6 \times 3.31 = 25.1$$


$$M @ 2 = 7.6 \times 6.62 - 3.3 \times 3.31 = 39.3$$

$$M @ 3 = 7.1 \times 7.96 - 3.9 \times 3.98 = 41.2$$


$$M @ 4 = 7.1 \times 3.98 = 28.4$$

FROM ASD 2-17C ALLOWABLE $M = 76.2 > 41.2$

BEAM & GRID B-5 TO B-7.

(12x26)
UNBRACED LETH 3192

$$\begin{aligned}
 M @ 1 &= 6.9 \times 3.35 = 23.1 \\
 M @ 2 &= 6.9 \times 7.17 - 3.5 \times 3.82 = 36.1 \\
 M @ 3 &= 7.0 \times 6.24 - 32.1 \times 3.35 = 33.3 \\
 M @ 4 &= 7.0 \times 2.89 = 20.2
 \end{aligned}$$


FROM ASD 2.172 ALLOWABLE $M = 76.2 > 33.3$ CROSS BEAM UNDER FT 1, 2, 3 (C-PLATE) 5'10" SPAN (12x18)
UNBRACED LETH 116

$$\begin{aligned}
 M @ 1 &= 7.0 \times 1.42 = 9.9 \\
 M @ 2 &= 7.0 \times 2.92 - 6.7 \times 1.50 = 10.4 \\
 M @ 3 &= 7.0 \times 1.42 = 9.9
 \end{aligned}$$

FROM ASD 2.174 ALLOWABLE $M = 30.3 > 10.4$

BEAM - GRID C-3 TO C-4

(W12x35)



$$M @ 1 = 13.7 \times 1.87 = 25.6$$

$$M @ 2 = 13.7 \times 3.35 - 1.6 \times 1.48 = 43.5$$

$$M @ 3 = 13.7 \times 5.87 - 1.6 \times 4.0 - 8.4 \times 2.52 = 52.9$$

$$M @ 4 = 11.1 \times 6.19 - 3.3 \times 3.19 - 1.7 \times 2.21 = 54.4$$


$$M @ 5 = 11.1 \times 3.78 - 3.3 \times .98 = 40.9$$

$$M @ 6 = 11.1 \times 3.00 = 33.3$$

FROM ASD 2-172 ALLOWABLE $M = 91.2 > 54.4$

BEAM - GRID F-3 TO F-4, F-4 TO F6
F6 TO F-7

(W12x26)



$$M @ 1 = 9.2 \times 3.35 = 30.8$$


$$M @ 2 = 9.2 \times 3.35 = 30.8$$

FROM ASD 2-172 ALLOWABLE $M = 66.2 > 30.8$

BEAM • GRID C-6 TO C-7

(W12x26)

UNBRACED LEN 31.44



$$M_1 = ① \quad 9.0 \times 3.35 = 30.2$$

$$M_2 = ② \quad 9.0 \times 7.17 - 8.4 \times 3.82 = 37.4$$


$$M_3 = ③ \quad 9.4 \times 3.35 = 31.5$$

FROM ASD 2.173 ALLOWABLE $M = 66.8 > 37.4$

BEAM • GRID C-4 TO C-6

(W12x26)

UNBRACED LEN 36.44



$$M_1 = ① \quad 10.2 \times 3.35 = 34.2$$

$$M_2 = ② \quad 10.2 \times 6.25 - 9.8 \times 2.90 = 35.3$$

$$M_3 = ③ \quad 10.8 \times 3.35 - 1.5 \times 1.43 = 34.0$$

$$M_4 = ④ \quad 10.8 \times 1.5 = 16.2$$

FROM ASD 2.173 ALLOWABLE $M = 66.8 > 35.3$


Otis A Clark, PE.

TEL NO. 405 878-0338

Mar 29, 95 9:14 P.18

BEAM UNDER EP 4 (2 PLACES) (V12.2C)

UNBROKEN LGTH 54'0 3/4




$$M @ ① \& ④ = 8.1 \times 3.55 = 28.8$$

$$M @ ② \& ③ = 8.1 \times 4.63 - 4.9 \times 1.08 = 32.2$$

FROM ADS 2-173 ALLOWABLE $M = 66.8 > 32.2$

BEAM @ GRID B-3 TO C-3

(V12.35)



$$M @ ① = 12.8 \times 2.21 = 28.3$$

$$M @ ② = 12.8 \times 5.13 - 12.9 \times 2.92 = 28.0$$


$$M @ ③ = 25.5 \times 1.46 - 13.7 \times 1.7 = 26.4$$

$$M @ ④ = 25.5 \times 6.7 = 17.1$$

FROM ADS 2-172 ALLOWABLE $M = 91.2 > 28.3$

CROSS BENT UNDER RF 4 (2 PLACES) 5' 10" SPAN (W8x18)

UNBRACED LGTH 11'6"



$$M = ① \quad 4.3 \times 1.42 = 6.1$$

$$M = ② \quad 4.3 \times 2.92 - 4.0 \times 1.50 = 6.6$$


$$M = ③ \quad 4.3 \times 1.42 = 6.1$$

FROM ASD 2-174 ALLOWABLE $M = 30.3 > 6.6$

BENT UNDER FLASH TANK (6 PLACES)

(W12x26)

UNBRACED LGTH 5' 10 3/4"



$$M = ① \text{ \& } ⑥ = 12.9 \times 3.55 = 45.8$$

$$M = ② \text{ \& } ⑤ = 12.9 \times 4.63 - 7.0 \times 1.08 = 52.2$$

FROM ASD 2-173 ALLOWABLE $M = 66.8 > 52.2$

BEAM @ GRID E-2 TO E-3

(W8.24)

UNBRACED LETH 12.4

$$M = \frac{1.8 \times 12.33}{8} = 2.8 \text{ k'}$$

FROM ASD 2-174 ALLOWABLE $M = 38.3 > 2.8$

BEAM @ GRID B-2 TO B-3

(W8.24)

UNBRACED LETH 12.4

$$M = \frac{3.6 \times 12.33}{8} = 5.5 \text{ k'}$$

FROM ASD 2-174 ALLOWABLE $M = 38.3 > 5.5$

BEAM @ GRID B-1 TO B-2

(W8.24)

UNBRACED LETH 12.4

$$M = \frac{4.2 \times 12.33}{8} = 6.5 \text{ k'}$$

FROM ASD 2-174 ALLOWABLE $M = 38.3 > 6.5$

BEAM @ GRID A-1 TO A-2

(W8.24)

UNBRACED LETH 12.4

$$M = \frac{2.4 \times 12.33}{8} = 3.7 \text{ k'}$$

FROM ASD 2-174 ALLOWABLE $M = 38.2 > 3.7$

BEAM @ GRID A-5 TO B-5

(W8.24)

UNBRACED LETH 9.3

$$M = \frac{3.4 \times 9.25}{8} = 3.9$$

FROM ASD 2-174 ALLOWABLE $M = 38.3 > 3.9$

BEAM $7\frac{1}{2}$ SOUTH OF GRID B-7 TO C-7

(WB-10)

UNBRACED LGTH $7\frac{1}{2}$

$$M = \frac{3.2 \times 7.25}{8} = 2.9 \text{ K'}$$

FROM ASD PAGE 2-175 ALLOWABLE $M = 11.5 > 2.9$

BEAM $6\frac{1}{2}$ NORTH OF GRID B-5 TO C-5

(WB-10)

UNBRACED LGTH $7\frac{1}{2}$

$$M = \frac{3.2 \times 7.25}{8} = 2.9 \text{ K'}$$

FROM ASD 2-175 ALLOWABLE $M = 11.5 > 2.9$

BEAM $2\frac{1}{2}$ NORTH OF GRID B-5 TO C-5

(WB-10)

UNBRACED LGTH $7\frac{1}{2}$

$$M = \frac{2.8 \times 7.25}{8} = 2.5 \text{ K'}$$

FROM ASD 2-175 ALLOWABLE $M = 11.5 > 2.5$

BEAM $3\frac{1}{2}$ SOUTH OF GRID B-5 TO C-5

(WB-10)

UNBRACED LGTH $7\frac{1}{2}$

$$M = \frac{3.0 \times 7.25}{8} = 2.7 \text{ K'}$$

FROM ASD 2-175 ALLOWABLE $M = 11.5 > 2.7$

BEAM $6\frac{1}{2}$ SOUTH OF GRID B-5 TO C-5

(WB-10)

UNBRACED LGTH $7\frac{1}{2}$

$$M = \frac{3.2 \times 7.25}{8} = 2.9 \text{ K'}$$

FROM ASD 2-175 ALLOWABLE $M = 11.5 > 2.9$

BEAM 2'10" NORTH OF GRID A-5 TO B-5 (W8x10)

UNBRACED LTH 9'3"

$$M = \frac{3.4 \times 9.25}{8} = 3.9 \text{ K'}$$

FROM ADS 2-175 ALLOWABLE $M = 9.0 > 3.9$

BEAM 6'3" NORTH OF GRID A-5 TO B-5 (W8x10)

UNBRACED LTH 9'3"

$$M = \frac{4.0 \times 9.25}{8} = 4.6 \text{ K'}$$

FROM ADS 2-175 ALLOWABLE $M = 9.0 > 4.6$

BEAM 7'2" SOUTH OF GRID A-7 TO B-7 (W8x10)

UNBRACED LTH 9'3"

$$M = \frac{4.2 \times 9.25}{8} = 4.9 \text{ K'}$$

FROM ADS 2-175 ALLOWABLE $M = 9.0 > 4.9$

BEAM 3'4" SOUTH OF GRID A-7 TO B-7 (W8x10)

$$M = \frac{4.0 \times 9.25}{8} = 4.6 \text{ K'}$$

FROM ADS 2-175 ALLOWABLE $M = 9.0 > 4.6$

BEAM 3'4" SOUTH OF GRID B-5 TO C-5 (W8x10)

UNBRACED LTH 7'3"

$$M = \frac{3.2 \times 7.25}{8} = 2.9 \text{ K'}$$

FROM ADS 2-175 ALLOWABLE $M = 11.5 > 2.9$

Mar 29, 95 9:18 P.23
PAGE 41

A Clark PE.

TEL NO. 405 878-0338

BEAM @ GRID D-2 TO D-3

(W12.14)

UNBRACED LTH 11'10"

$$M = \frac{3.8 \times 11.83}{8} = 4.7 \text{ K}'$$

FROM ASD 2.175 ALLOWABLE $M = 20.75 > 4.7$

BEAM @ GRID D-1 TO D-2

(W12.19)

UNBRACED LTH 12'0"

$$M = \frac{3.2 \times 12.5}{8} = 5.0 \text{ K}'$$

FROM ASD 2.175 ALLOWABLE $M = 17.0 > 5.0$

BEAM 3'11 3/4 + 7'11 1/2 NORTH OF GRID A-3 TO B-3 (W8.10)

UNBRACED LTH 9'3"

$$M = \frac{4.4 \times 9.25}{8} = 5.1 \text{ K}'$$

FROM ASD 2.175 ALLOWABLE $M = 9.0 > 5.1$

BEAM 6'7 1/2 SOUTH OF GRID A-5 TO B-5 (W8.10)

UNBRACED LTH 9'3"

$$M = \frac{4.0 \times 9.25}{8} = 4.6$$

FROM ASD 2.175 ALLOWABLE $M = 9.0 > 4.6$

BEAM 3'3 3/4 SOUTH OF GRID A-5 TO B-5 (W8.10)

UNBRACED LTH 9'3"

$$M = \frac{3.6 \times 9.25}{8} = 4.2$$

FROM ASD 2.175 ALLOWABLE $M = 9.0 > 4.2$

tlis A Clark PE.

TEL NO. 405 878-0338

Mar 29, 95

9:19 P.24

PAGE 22

BEAM 3-1 & 6-2 WEST OF GRID B-1 TO B-2 (2 PLACES)

(W8.15) UNBROKEN LATH 13#

$$M = \frac{4.8 \times 13}{8} = 7.8 \text{ K'}$$

FROM ASD 2.175 ALLOWABLE $M = 12.1 > 7.8$

BEAM 2-4 & 5-6 OF GRID B-2 TO B-3 (W8.15)

UNBROKEN LATH 13#

$$M = \frac{3.8 \times 13}{8} = 6.2 \text{ K'}$$

FROM ASD 2.175 ALLOWABLE $M = 12.1 > 6.2$

BEAM UNDER TANKS (8 PLACES) (W8.10)

UNBROKEN LATH 8#

$$M = \frac{16 \times 5.9}{8} = 12 \text{ K'}$$

FROM ASD 2.175 ALLOWABLE $M = 15.6 > 12$

BEAM @ TANKS 3-4 & 5-6 SPAN (8 PLACES) (W8.10)

UNBROKEN LATH 3-6#

$$M = \frac{4.2 \times 3.55}{8} = .5 \text{ K'}$$

FROM ASD 2.175 ALLOWABLE $M = 15.6 > .5$

BEAM - GRID A-7 TO B-7

(W8.24)

UNBRACED LETH 9'3"

$$M = \frac{1.8 \times 9.25}{8} = 2.1 \text{ k'}$$

FROM ASD 2.174 ALLOWABLE $M = 38.3 > 2.1$

BEAM - GRID B-7 TO C-7

(W8.24)

UNBRACED LETH 7'3"

$$M = \frac{1.4 \times 7.25}{8} = 1.3$$

FROM ASD 2.174 ALLOWABLE $M = 38.3 > 1.3$

BEAM - GRID B-5 TO C-5

(W8.24)

UNBRACED LETH 7'3"

$$M = \frac{2.6 \times 7.25}{8} = 2.4 \text{ k'}$$

FROM ASD 2.174 ALLOWABLE $M = 38.3 > 2.4$

BEAM - GRID C-7 TO F-7

(W12.26)

UNBRACED LETH 18'0"

$$M = \frac{3.6 \times 18.0}{8} = 8.1 \text{ k'}$$

$$M = \text{CANT. END.} = \frac{120 \times 5.45^2}{2} = 3.0 \text{ k'}$$

FROM ASD 2.174 ALLOWABLE $M = 31.4 > 8.1$

BEAM @ GRID C-6 TO F-6 & C-4 TO F-4 (W 12.26)

UNBRACED LENGTH 18'0"

$$M = \frac{7.2 \times 18.64}{8} = 16.2 \text{ k'}$$

$$M_{\text{CONT}} = \frac{.40 \times 5.45^2}{2} = 5.9 \text{ k'}$$

FROM ASD 2.174 ALLOWABLE $M = 31.4 > 16.2$

BEAM @ GRID C-3.1 TO F-3.1 (W 12.26)

UNBRACED LENGTH 18'0"

$$M = \frac{6.6 \times 18.64}{8} = 14.9 \text{ k'}$$

$$M_{\text{CONT}} = \frac{.20 \times 5.45^2}{2} = 3.0 \text{ k'}$$

FROM ASD 2.174 ALLOWABLE $M = 31.4 > 14.9$

BEAM - FILTER PRESSURE GRID C TO F (6 PLACES) (W 12.26)

UNBRACED LENGTH 18'0"

$$M = \frac{3.6 \times 18.64}{8} = 8.1 \text{ k'}$$

$$M_{\text{CONT}} = \frac{.46 \times 5.45^2}{2} = 6.8 \text{ k'}$$

FROM ASD 2.174 ALLOWABLE $M = 31.4 > 8.1$

BEAM #116 #341³ NORTH OF GRID B-3 TO C-3 (W8.10)

UNBRACED LETH 7.3

$$M = \frac{34 \times 7.25}{8} = 3.1 \text{ k'}$$

FROM ASD 2.175 ALLOWABLE $M = 11.5 > 3.1$

BEAM @ GRID E-1 TO E-2 (W8.10)

UNBRACED LETH 12.4

$$M = \frac{1.8 \times 11.23}{8} = 2.5$$

FROM ASD PAGE 2.175 ALLOWABLE $M = 5.2 > 2.5$

BEAM #16 EAST OF GRID A-3 TO A-2 (W8.10)

UNBRACED LETH 13.0


$$M = \frac{1.8 \times 13}{8} = 2.9 \text{ k'}$$

FROM ASD 2.175 ALLOWABLE $M = 4.8 > 2.9$

MEZZ BEAM - GRID B-1 TO C9-1

(W8x15)

UNBRACED LTH. 410



$$M @ 1 = 2.8 \times 3.12 = 6.6$$


$$M @ 2 = 2.8 \times 1.58 = 4.4$$

FROM ASD 2.175 ALLOWABLE $M = 23.6 > 6.6$

MEZZ BEAM - GRID B-2 TO D-2

(W12x14)

UNBRACED LTH 210



$$M @ 1 = 5.2 \times 1.54 = 8.0$$

$$M @ 2 = 5.2 \times 3.12 = 16.2$$


$$M @ 3 = 5.2 \times 5.12 = 26.6$$

$$M @ 4 = 6.7 \times 3.12 = 20.9$$

$$M @ 5 = 6.7 \times 1.54 = 10.3$$

FROM ASD 2.174 ALLOWABLE $M = 29.8 > 14.4$

(3 PAGES)

MEZZ BEAM B-3 TO C-3 & D-1 TO E-3 (WELLS)
E-1 TO D-1-1 UNBROKEN LGTH 34.7


$$M @ \textcircled{1} = 1.9 \times 1.54 = 2.9 \text{ k'}$$

$$M @ \textcircled{2} = 0.7 \times 3.58 = 2.5 \text{ k'}$$

FROM ASD 2-175 ALLOWABLE $M = 23.6 > 2.9$

MEZZ BEAM @ GRID D-2 TO E-2 (WELLS)

UNBROKEN LGTH 34.7



$$M @ \textcircled{1} = 5.6 \times 1.54 = 8.6$$

$$M @ \textcircled{2} = 5.6 \times 5.12 - 5.2 \times 3.58 = 10.1$$

$$M @ \textcircled{3} = 4.7 \times 1.54 = 7.2$$

FROM ASD 2-114 ALLOWABLE $M = 27.6 > 10.1$

MEZZ BEAM C9-1 TO C9-2

(WB15)

(UNBRACED LGTH = 10'10")

$$M = \frac{3.6 \times 1267}{8} = 5.7 \text{ k'}$$

FROM ADS 2-175 ALLOWABLE $M = 14.0 > 5.7$ MEZZ BEAM D1-1 TO D1-2

(WB15)

(UNBRACED LGTH = 7'2")

$$M = \frac{5.2 \times 1267}{8} = 8.2 \text{ k'}$$

FROM ADS 2-175 ALLOWABLE $M = 21.0 > 8.2$ MEZZ BEAM 11'10" EAST OF C9-1 TO C9-2

(WB15)

(UNBRACED LGTH 4'6")

$$M = \frac{4.2 \times 13}{8} = 6.8 \text{ k'}$$

FROM ADS 2-175 ALLOWABLE $M = 21.25 > 6.8$ MEZZ BEAM 3'10" EAST OF B1 TO B-2

(WB15)

(4'6" UNBRACED LGTH)

$$M = \frac{5.6 \times 13}{8} = 9.1$$

FROM ADS 2-175 ALLOWABLE $M = 21.25 > 9.1$ MEZZ BEAM 1'6" EAST OF B2 TO B3

(WB15)

(UNBRACED LGTH 7'2")

$$M = \frac{4.0 \times 13}{8} = 6.5$$

FROM ADS 2-175 ALLOWABLE $M = 21.0 > 6.5$

MEZ2 BEAM & GRID E-1 TO E-2 (W8.10)

R2 TO R3 & E2 TO E3

$$M = \frac{1.2 + 1.3}{8} \cdot 1.95 \text{ k}' \quad (\text{UNBRACED LTH } 18'0")$$

FROM ADS 2.15 ALLOWABLE $M = 4.0 > 1.95$

MEZ2 BEAM & GRID R1 TO R2 (W8.10)

(UNBRACED LTH 6'8")

$$M = \frac{2.6 + 1.3}{8} \cdot 4.2 \text{ k}'$$

FROM ADS PAGE 2.15 ALLOWABLE $M = 12.2 >$

MEZ2 BEAM & GRID C9-3 TO C9-2 & D1-3 TO D1-2

(W8.15) (UNBRACED LTH 7'2")

$$M = \frac{5.2 + 1.3}{8} \cdot 8.5 \text{ k}'$$

FROM ADS 2.15 ALLOW. $M = 21.2 > 8.5$

MEZ2 BEAM 1/2 W. OF E1 TO E2 & E2 TO E3 (W8.15)

(UNBRACED LTH 7'2")

$$M = \frac{4.0 + 1.3}{8} \cdot 6.5 \text{ k}'$$

FROM ADS 2.15 ALLOWABLE $M = 21.2 > 6.5$

MEZZ BEAM 2-11 SPAN, 6 PLACES, 12.8x10...(2-11 UNBRACED LETH)

$$M = \frac{1.2 \times 2.92}{2} = 1.4 \text{ K}$$

FROM ADS 2-175 ALLOWABLE M = 16.0 > 1.4MEZZ BEAM & TANK OPENINGS (6 PLACES) (12.8x10)(UNBRACED LETH 2-11)

$$M = \frac{.6 \times 7.16}{4} = 1.1 \text{ K}$$

FROM ADS 2-175 ALLOWABLE M = 16.0 > 1.1

Otis A. Clark PE.

TEL NO. 405 878-0338

Apr 03.95 13:36 P.02

(REVISED)


COLUMNS ON 6" SLAB

Max Cal Load Is At B.S. - 17.6 KIPS

6" SLAB 4000 PSI CONC W/ #4 @ 12 IN. CTR.

ALLOWABLE M PER FT OF SLAB

$$= A_s f_s j d = .20 \times 24000 \times .85 \times 3 = 12,240 \text{ " LBS.}$$



CHECK OF 2 WAY (PUNCHING) SHEAR

$$4 \times 16" \times 6" \times 1.1 \times 4000 = 26.7 \text{ K} > 17.6 \text{ K. O.K.}$$

REQUIRED MOMENT PER FT OF SLAB

$$\frac{2500 \times 11.5}{12} \times 11.5 = 9184 \text{ " LBS} < 12,240 \text{ " LBS. O.K.}$$

FROM ASD PAGE 2.302 BEAM DIAG. #20


Otis A Clark PE. TEL NO. 405 878-0338

Apr 03, 95 13:36 P.03

(REVISED)

HORZ. FORCES & GRID

F_H



$$\frac{3.26}{4} = .8150 \text{ KIPS PER COL.}$$

4

$$.8150 \times 11.5 = 9.37 \text{ K' MOMENT}$$


$$\frac{9.37 \times 12 \times 1000}{21600} = 5.2 \text{ GOOD S3}$$

$$W8x31 \times 27.5 > 5.2 \text{ COLUMNS OK}$$

COMBINED LOADS

$$\frac{5.2}{27.5} + \frac{24.2}{149} = .3515 < 1 \text{ COLS OK}$$

FROM 605-331



Otis A Clark PE.

TEL NO. 405 878-0338

Apr 03, 95 13:37 P.04

Page 32

Horz Forces @ Node Max Col Load @ B2 = 7.1 k

D2 = 12.3 k

E2 = 5.9 k

Horz Force @ Girder 2 = $(7.1 + 12.3 + 5.9) \times .045 = 1.14$ k

$\frac{1.14}{3} = .38$ k Horz Force per Col.

M_k Max Ave. of Col = $.38 \times 12.25 = 4.66$ k'


Rein S₂ = $\frac{4.66 \times 12}{21.6} = 2.59 < 5.63$ OK

COMBINED LOADING

$\frac{2.59}{5.63} + \frac{12.3}{95} = .46 + .13 = .59 < 1$

Cols. OK

MOMENT CONN @ COL CAP PLATE - Cols F3, F4, F5, F7



CAP PL. @ Cols F3, F4, F5, F7

FROM PAGE 5 MOMENT IS 9.37 k'

$$FORCES = F_{UC} = \frac{9.37 \times 12}{(8 - 1.435)} = 14.86 \text{ k}$$

WELD @ PLANKS TO 4 x 8 - 22.4 > 14.86 OK

$$\text{MOMENT @ BOLTS} = \frac{9.37 \times 12}{6.75} = 16.66 \text{ k}$$

$$\frac{16.66}{2} = 8.33 \text{ PER BOLT} < 9.3 \text{ OK}$$

APPENDIX G.

FOUNDATION ANALYSIS

Foundation Design Analysis

USPCI

A Subsidiary of
Union Pacific Corporation



March 27, 1995

Mr. Jim Richenbaugh
Black & Veatch Waste Science
4717 Grand Avenue, Suite 500
Kansas City, MO 64112

Re: USPCI Lone Mountain Facility
Subject: Waste Water Treatment Floor Structural Design

The concrete floors in the area where the mezzanine has been erected were poured as part of two different building expansions. The first expansion was poured in the spring of 1987 and was designed to be eighteen inches thick with two layers of 3/4 inch reinforcement bars tied on one foot centers and separated by twelve inches between the top and bottom mats. All reinforcement bars were kept within three inches of the slab's surfaces and were supported by concrete brick on a two inch layer of sand. This slab underlies the area that supports the Flash Tanks and EF4 and extends to the south edge of the filter press mezzanine.

The second expansion attaches to the north side of the first slab and was poured in November of 1987. It was poured around four existing boiler foundations that were 2 feet wide, 3 feet deep, and 24 feet long. The floor slab was poured six inches thick and used a layer of 1/2 inch reinforcement bars tied on one foot centers, supported on a concrete brick and a 2 inch layer of sand. This slab underlies the area supporting the filter presses.

Both slabs were poured using a 4000 psi concrete strength mix as verified by the core sample tested by Meyers Engineering of which a report has been sent to you earlier this week.

I hope this will provide the information you needed for the certification work now in progress.

Sincerely,

Lawson Fenton

Lawson Fenton
Project Manager

Box 170
Aynoka, Oklahoma 73860-9622


tl: 405/697-3500
lx: 405/697-3596

Our Mission:

Provide the highest quality waste and by-product management services that consistently meet or exceed customer needs and regulatory requirements at competitive cost while enhancing shareholder value.

(14) — CONTAINMENT AREA NUMBER

LOCATION OF CORE




FWT: Final Water Treatment

LAYOUT OF WASTE WATER TREATMENT BUILDING USED LONG MOUNTAIN HAZARDOUS WASTE FACILITY WATKINS, OREGON

<u>Specimen</u>	<u>Diameter, in.</u>	<u>Drilled Length, in.</u>	<u>Capped Length, in.</u>	<u>Crushing Load, lbs.</u>	<u>L/D Correction Factor</u>	<u>Compressive Strength, psi</u>
PHT-1	3.75	5.5	5.7	32,440	0.96	2,810
PHT-2	3.75	5.5	4.9	47,200	0.93	3,980
PHT-3	3.75	6.5	4.5	41,400	0.93	3,490
PHT-4	3.75	7.5	4.6	60,700	0.93	5,110
PHT-5	3.75	7.0	7.1	43,000	0.99	3,860
PHT-6	3.75	6.5	4.1	57,100	0.88	4,550
PHT-7	3.75	7.0	5.8	43,800	0.96	3,810
PHT-8	3.75	6.0	5.8	74,800	0.96	6,480
PHT-9	3.75	5.0	5.5	33,900	0.96	2,950
PHT-10	3.75	6.0	4.7	72,500	0.93	6,100
PHT-11	3.75	6.0	5.6	55,720	0.96	4,840
PHT-12	3.75	6.0	6.6	65,600	0.98	5,800
PHT-13	3.75	5.0	5.3	68,700	0.94	5,850
PHT-14	3.75	5.0	5.1	80,200	0.95	6,900
PHT-15	3.75	6.0	5.1	60,200	0.97	5,290
FHT-1A	3.75	6.0	4.7	53,800	0.93	4,530
FHT-1B	3.75	13.0	6.0	50,800	0.97	4,460
FHT-2	3.75	22.0	7.0	30,740	0.99	2,760
*FHT-3	3.75	15.0	-	-	-	-
FHT-4	3.75	6.0	7.0	81,600	0.99	7,320
FHT-5	3.75	6.0	5.8	81,700	0.96	7,100
*FHT-6	3.75	19.0	-	-	-	-
*FHT-7	3.75	14.5	-	-	-	-
FHT-8	3.75	7.0	7.0	53,200	0.99	4,770

PHT - Pre-Water Treatment
FHT - Final Water Treatment

* Samples which we were not able to pull out of the hole.



CORE PLUG DETAIL

CORE PLUG DETAIL FOR
USPCI, LONE MOUNTAIN FACILITY
WAYNOKA, OKLAHOMA

Myers

ENGINEERING COOPERATION
Oklahoma City Oklahoma

JOB NO. 511
SCALE NTS
DRAWN DMC
DATE 6/23/97

1 SHEET
OF 1

OTIS A Clark PE.

TEL NO.405 878-0338

Mar 29,95 9:02 P.02

OTIS A. CLARK PE.

Phone
(405) 878-0338

130 Bdwy. Bldg.
Suite 202
Shawnee, OK. 74801

To: USPCI
Lone Mountain Facility
Route 2, Box 180A
Waynoka, Okla. 73806

Attn: Lawson Fenton

March 28, 1995

The following is an investigation for the foundation support for the mezzanine platforms for the Wastewater Final Treatment Facility, and the calculations for the design of the beams, columns, and bracing for the structure. The design loads are per the 1990 BOCA National Building Code and are shown on page #7 of the following submittal.

COLUMN	LOAD, KIPS	FOUNDATION CONDITION	REMARKS
A-1	3.6	17" floor slab	OK (see page #2)
A-2	4.5		
A-3	8.4		
A-5	9.8	6" floor slab	OK (see page #1)
A-7	4.8		
B-1	14.3	17" floor slab	OK (see page #2)
B-2	36.3		
B-3	27.9		
B-5	17.6	6" floor slab	OK (see page #1)
B-7	8.5		
C-4	28.1	24" x 36" cont.ftg.	Ok (see page #3)

C-6	24.8	24" x 36" cont.ftg.	Ok (see page #3)
C-7	11.5	6" floor slab	OK (see page #1)
C.9-1	14.1	17" floor slab	OK (see page #2)
C.9-3	28.8		
D-2	62.9		
D.1-1	19.0		
D.1-3	19.9		
E-1	14.2		
E-2	34.1		
E-3	14.4		
F-3.1	12.0	6" floor slab	OK (see page #1)
F-4	24.2	24" x 36" cont. ftg.	OK (see page #3)
F-6	24.2		
F-7	12.1	6" floor slab	OK (see page #1)




COLUMNS ON 6" SLABS

Max. Cal. Load is at B.S - 17.6 KIP.

6" SLAB, 4,000 PSI CONC. w/ #4 @ 12" EW. & CTR.

ALLOWABLE M PER FT. OF SLAB

$$= A_s f_s d = .20 \times 24,000 \times .85 \times 3 = 12,240 \text{ " LBS.}$$



CHECK OF 2 WAY (PUNCHING) SHEAR

$$4 \times 6 \text{ " } \times 6 \text{ " } \times 1.1 \sqrt{4000} = 26.7 \text{ K.} > 17.6 \text{ K O.K.}$$

REQUIRED MOMENT PER FT. OF SLAB

$$\frac{2500 \times 11.5}{12} \times 11.5 = 6,888 \text{ " LBS.} < 12,240 \text{ " LBS. O.K.}$$

COLUMNS ON 17" SLABS W/ #6 REIN. T & B

MAX. COL. LOAD IS AT GRID D-2 = 62.9 KIPS.

ALLOWABLE MOMENT IN SLAB

$$.44 \times 24000 \times 12 = 126,720 \text{ LB.} = 10.56 \text{ K'}$$

ALLOWABLE SOIL BEAR. = 2500 * SUB WT 180 = 2320

$$\frac{62.9}{2.32} = 27.11 \text{ SQ FT REQD. AREA} = 5.3 \text{ SQUARES}$$

$$2 \text{ WAY (PUNCHING) SHEAR } 4 \times 27.1 \times 17 \times 1.1 \sqrt{4000}$$

$$= 127.7 \text{ K} > 62.9 \text{ K} \quad \text{OK}$$

REQD MOMENT IN GRID BEAN

$$\frac{295 \times 2.32}{4} = 1.31 \text{ K' } < 10.56 \text{ K'}$$

OK

COLUMNS ON 24" x 36" GRADE BEAM

Max COL LOAD is AT COL C-4 - 28.1 KIPS.

GRADE BEAM HAS 2 #6 @ TOP, CTR & BOTT
(ACCORDING TO LAWSON FENTON)

ALLOWABLE MOMENT IN GRADE BEAM (FIGURING T & B REIN.)


As f'd = .85 x 24000 x 30 x 632,600" LB. OR 52.8 K'

ALLOWABLE SOIL BRG 2500 - GB WEIGHT 360 = 2140

$\frac{28.1 \text{ K}}{2140} \times 6'-8" \text{ LENGTH OF GRADE BEAM TO SUPPORT SOIL}$
2140.2


REQD MOMENT IN GRADE BEAM

$\frac{21.8 \text{ K} \times 6.67}{2} = 18.2 \text{ K} < 52.8 \text{ K} \quad \text{O.K.}$



⑭ --- CONTAINMENT AREA NUMBER

--- LOCATION OF CORE



LAYOUT OF WASTE WATER TREATMENT BUILDING USPO LONE MOUNTAIN HAZARDOUS WASTE FACILITY MAYNOKA, OKLAHOMA		METS		JOB NO. 100-100-100-100		SCALE 1/8" = 1'-0"		DATE 10-10-10		BY 100-100-100-100	

APPENDIX H.

CONCRETE COATING INFORMATION FOR SECONDARY CONTAINMENT

Dudick Inc.

1818 Miller Parkway
Streetsboro, Ohio 44241

(216) 562-1970
(216) 562-7638 FAX

Primer 67/67C

100 % SOLIDS, MOISTURE-TOLERANT
EPOXY PRIMER FOR STEEL AND
CONCRETE 3-4 MILS (0.1 mm)

RECOMMENDED APPLICATIONS

Concrete Substrates
Steel Substrates
Primer for Epoxy and Urethane
Floor Toppings, Linings, Coatings and Grout

PHYSICAL PROPERTIES

Tensile Strength	2,000 - 2,500 PSI
ASTM C-307	
Tensile Elongation	12-25 %
ASTM C-307	
Adhesion to Concrete	Cohesive Failure
ASTM D-4541	of concrete
Adhesion to Steel	2,200-2,500 PSI
ASTM D-4541	
Electrical Properties	< 25,000 ohms
NFPA #99,	
ASTM F-150	

SPECIFICATIONS

Primer shall be 3-4 mils thick, 100% solids bisphenol A epoxy cured with an amine adduct as manufactured by Dudick Inc. Primer 67 shall be brush, roller or spray applied in accordance with the manufacturer's recommended practices. Primer 67C must be spray or roller applied.

PRIMER 67

Primer 67 is designed to prevent abrasive-blasted steel from developing rust bloom prior to the application of a Dudick coating or lining system. For maximum performance all steel surfaces should be primed, but primer may not be needed for mild, non-immersion service. Concrete, however, must always be primed to aid in the "wetting out" required for good adhesion.

PRIMER 67C - CONDUCTIVE PRIMER

Primer 67C is a 100% solids, two component epoxy primer designed to be used over concrete whenever the coating or lining system must be spark tested.

ESTIMATING QUANTITIES AND ORDER BILL OF MATERIAL

SQUARE FEET PER GALLON		
	CONCRETE	STEEL
Primer 67	150-200	250-300
Primer 67C	100-150	—

Quantities shown are for estimating purposes only. Actual field usage may vary. Primer 67/67C are available in 1 and 2 gallon units.

APPLICATION INSTRUCTIONS

SURFACE PREPARATION

Metal: Surfaces must be abrasive blasted to an appropriate finish.

Immersion and heavy spillage service: White Metal SSPC SP-5 or NACE #1, 3.0 mil minimum profile.

Heavy, non-immersion service (i.e. fumes and spillage): Near white SSPC SP-10 or NACE #2, 2.0 mil minimum profile.

Atmospheric service: Commercial SSPC SP-6 or NACE #3, 2.0 mil minimum profile.

Concrete: Concrete must be abrasive blasted or etched with muriatic acid (Solution of 1 part 20° Be HCl and 1 part water) to remove surface laitance and other contaminants. Concrete must be free of curing compounds and form release agents. Surface texture should be similar to 40-60 grit sandpaper. The prepared surface should have a minimum tensile strength of 250 PSI per ASTM D-4541.

All concrete substrates must be checked for moisture prior to product application using the Plastic Sheet Test, ASTM D-4263.

Additional surface preparation will be required if a 40-60 grit texture is not achieved and the surface laitance not completely removed after a single application of acid or with the first mechanical preparation procedure.

Abrasive blasting removes laitance, exposing honeycombs or voids beneath the surface which must be filled with Scratch Coat 100. (Refer to separate product bulletin)

APPLICATION SPECIFICATIONS

Substrate temperature for both concrete and metal must be between 50°F and 110°F.

Relative humidity must not exceed 90%.

Substrate temperature must be 5°F above the Dew Point.

PRIMER 67/67C MIX RATIOS:

Primer 67

Component A	1 gal.
Component B	1 gal.

Primer 67C

Component A	1 gal.
Component B	95 fl. oz.

*Pre-mix primer 67C Component A for 1-2 minutes to disperse the conductive fillers prior to adding the correct amount of Component B.

Primer 67C must be spray or roller applied. Use brush application for small touch-up or repair work only.

The pot life of the mixed Primer 67/67C will depend on the temperature. To prevent material waste and avoid damage to equipment, do not open and mix more material than can be used according to the following table:

PRIMER 67/ 67C POT LIFE

TEMPERATURE	POT LIFE
50°F	90 min.
75°F	60 min.
90°F	30 min.

At 75° F the pot life and thin film cure of Primer 67 can be decreased by the addition of Accelerator #1 as follows:

Ozs./Accelerator #1 per mixed gal. Primer 67	Pot Life	Thin Film Cure
3-4	36 min.	4 hrs.
6-7	15 min.	2 hrs.

Using 7 ounces of accelerator #1 per mixed gallon of Primer 67, the thin film cure @ 40° F is reduced to 8 hours.

PRIMING

Metal: Mix the pre-measured units of Component A with Component B. Prime all metal surfaces to be coated with Primer 67 at 3-4 mils WFT.

Concrete: Mix the pre-measured units of Component A with Component B. Prime all concrete surfaces to be coated with either Primer 67 or 67C at 3-4 mils WFT. The basecoat may be applied over primer that is "tacky". Do not allow the primer to puddle.

Important - With all epoxies after priming and before each additional coat, examine the surface for amine blush (oily film). If present, remove by washing with warm water and detergent.

Cure Cycle for Primer 67/67C:

Temperature	Minimum Recoat Time	Maximum Recoat Time
50°F	12 hrs.	8 Days
75°F	6-8 hrs.	5 Days
90°F	4-5 hrs.	3 Days

To optimize intercoat adhesion, we recommend application of the basecoat while the primer is tacky. If this is not possible, the above recoat times must be observed. Exposure of the primer to direct sunlight will considerably shorten the recoat times. If recommended recoat times are exceeded, consult a Dudick Representative; sanding or abrasive blasting may be required before the coating, lining or floor topping can be applied.

CLEANING

Use S-10 Cleaning Solvent to clean tools and equipment. **DO NOT USE ACETONE.**

SHIPPING

Primer 67/67C Component A's are non-regulated plastic liquids. Primer 67/67C Component B's are flammable corrosives with a flash point of 106°F (Setaflash) and carry both a red warning label and a black and white warning label. S-10 Cleaning Solvent is a flammable liquid with a flash point of 52°F (PMCC) and carries a red warning label.

STORAGE

Warning: All Dudick products classified by DOT labels as either white, yellow or red labels, must not be mixed or stored together as an explosive reaction can occur. All products should be stored in a cool, dry area away from open flames, sparks or other hazards.

When properly stored in their original, unopened containers, Primer 67/67C components have a one year shelf life.

SAFETY

M.S.D.S - Sheets must always be read before using products. Primer 67/67C are intended for application by experienced, professional personnel. Dudick Inc. can supply supervision to help determine that the surface has been properly prepared, the ingredients correctly mixed, and the materials properly and safely applied.

If materials are to be applied by your own personnel or by a third party contractor, please be sure that they are aware of the following safety precautions:

- Exposure to resins and hardeners through direct skin contact and/or inhalation may cause severe dermatitis reactions in some people. Cleanliness of the skin and clothing is critical and must be of paramount concern.
- Fumes are flammable and heavier than air. Proper ventilation should be maintained to minimize breathing of concentrated fumes.
- Suitable respirators should be used during application.
- Safety glasses, gloves, and suitable protective clothing must be worn at all times during application.
- If contact with hardeners occurs, remove any clothing involved and flush the skin with flowing water. Discard the clothing. Do not attempt to wash and reuse it. Primer liquids can be removed with S-10 Cleaning Solvent, MEK, or lacquer thinner. **DO NOT USE ACETONE.**

- Keep open flames and sparks away from the area where materials are being mixed and applied.

- If a rash occurs, remove the individual from the work area and seek a physician's care for dermatitis.

- In case of eye contact, flush with water for at least 15 minutes and consult a physician.

- If swallowed, do not induce vomiting; call a physician immediately.

Note:

Dudick Inc. ("Dudick") warrants all goods of its manufacture to be as represented in its catalogs and that the application of its products by its employees or sub-contractors shall be performed in a workmanlike manner. Dudick's obligation under this warranty shall be the repair to and replacement of any applications which its examination shall disclose to be defective. Dudick makes no warranty concerning the suitability of its product for application to any surface, it being understood that the goods have been selected and the application ordered by the purchaser. **DUDICK INC. MAKES NO WARRANTY, EXPRESS OR IMPLIED, THAT THE GOODS SHALL BE MERCHANTABLE OR THAT THE GOODS ARE FIT FOR ANY PARTICULAR PURPOSE. THE WARRANTY OF REPAIR OR REPLACEMENT SET FORTH HEREIN IS EXCLUSIVE AND IN LIEU OF ALL OTHER WARRANTIES ARISING BY LAW OR OTHERWISE; AND DUDICK INC. SHALL NOT BE LIABLE FOR INCIDENTAL OR CONSEQUENTIAL DAMAGES, INCLUDING BUT NOT LIMITED TO LOST PROFITS, DOWN TIME, DAMAGES TO PROPERTY OF THE PURCHASER OR OTHER PERSONS, OR DAMAGES FOR WHICH THE PURCHASER MAY BE LIABLE TO OTHER PERSONS, WHETHER OR NOT OCCASIONED BY DUDICK'S NEGLIGENCE.** This warranty shall not be extended, altered or varied except by written instrument signed by Dudick and Purchaser.

Primer 67/67C

100% SOLIDS, MOISTURE-TOLERANT EPOXY PRIMER for
STEEL AND CONCRETE 3-4 MILS (0.1 mm)

Dudick Incorporated

1818 Miller Parkway
Streetsboro, Ohio 44241
(1-94)

Dudick Inc.

Dudick Incorporated
Corrosion-Proof Products
1818 South Wason Drive
Streetsboro, Ohio 44241

216-562-1970
FAX No. 216-562-7638

Protecto-Coat 200

ELASTOMERIC, SPRAY APPLIED, ENVIRONMENTALLY SAFE, URETHANE COATING. 40-60 MILS (1-1 1/2 mm)

Protecto-Coat 200 is a high solids aromatic polyurethane coating with superior elongation. It is especially suited to bridge cracks in concrete.

RECOMMENDED APPLICATIONS

Secondary Containment Areas	Spent Liquor Storage Tanks
Process Floors	Food Processing
Railroad Tank Cars	Pharmaceutical
Underground Pipes & Tanks - Exterior	Breweries
Thickener Tanks & Mechanisms	Structural Steel

CHEMICAL RESISTANCE

Protecto-Coat 200 provides a tough, durable surface and will withstand splash and spills of many inorganic and organic acids as well as alkalis. Also resistant to aliphatic solvents.

PHYSICAL PROPERTIES

Protecto-Coat 200	40 Mil Basecoat	20 Mil Topcoat
Tensile Strength (PSI) ASTM C307	2,400-2,600	2,200-2,500
Elongation*	225% to 250%	50 to 60%
Shore D Hardness	40-45	65-70
Abrasion Resistance CS 17 wheels/1000 cycles x 1000 gm load	10 mg weight loss	32 mg weight loss
Solids by Volume	80%	100%

*At 60% elongation the chemical resistant topcoat begins to surface crack while the basecoat will continue to elongate to 250% extension.

SPECIFICATIONS

Coating shall be 40-60 mils thick, 80-100% solids aromatic urethane resin, consisting of 2 basecoats and a topcoat of 20 mils each, manufactured by Dudick, Inc. Materials shall be brush-, roller- or spray- applied in accordance with manufacturer's recommended practices.

THE PROTECTO-COAT 200 SYSTEM

The Protecto-Coat 200 system uses a moisture tolerant primer and two or three coats of elastomeric thermosetting urethane resins to protect concrete and steel.

Primer 67 is designed to prevent abrasive-blasted steel from developing rust bloom prior to the application of a Protecto-Coat System. For maximum performance, all steel surfaces should be primed, but primer may not be needed for mild, non-immersion service. Concrete, however, must always be primed to aid in the "wetting out" required for good bonding.

Protecto-Coat 200 is applied in three coats by brush, roller or spray. The elastomeric basecoat is applied in two 25 mil applications to achieve a nominal 40 mils DFT. The chemical resistant topcoat is applied in a single 20 mil application. Total thickness shall be a nominal 60 mils.

Post-It™ brand fax transmittal memo 7671

of pages >

To	Dominic Quinn	From	R. O. H.
Co.		Co.	
Dept.		Phone #	Mid-America
Fax #	697-3592	Fax #	

ESTIMATING QUANTITIES AND ORDER BILL OF MATERIAL

SQUARE FEET PER GALLON		
	CONCRETE	STEEL
Primer 67	150-200	250-300
Protecto-Coat 200		
2 Base Coats Actual		
35-40 mil DFT	25	25
Top Coat Actual		
15-20 mil DFT	60	60
S-10 Solvent	500	500

Quantities shown are for estimating purposes only. Actual field usage may vary.

APPLICATION INSTRUCTIONS

SURFACE PREPARATION

Metal: For immersion service, abrasive blast to a white metal finish and a 2-4 mils minimum profile according to SSPC 5 or NACE No. 1. For fume or splash service, abrasive blast to a near-white metal finish according to SSPC 10 or NACE No. 2. Atmospheric service: Commercial SSPC 6 or NACE No. 3.

Concrete: Concrete must be abrasive-blasted or etched with muriatic acid (solution of 1 part 20° Be HCl and 1 part water) to remove surface laitance and other contaminants. Concrete must be free of curing compounds and form release agents. Surface texture should be similar to 40-60 grit sandpaper. The prepared surface should have a tensile strength of between 250 and 300 PSI per ASTM D4541.

Additional surface preparation will be required if a 40-60 grit texture is not achieved and the surface laitance not completely removed after a single application of acid or with the first mechanical preparation procedure.

If, after abrasive blasting, honeycombs/voids appear on the concrete, these have to be filled with a suitable material. Contact a Dudick representative for this information.

Recommended application temperatures should be between 40°F and 90°F substrate temperature. Do not apply Protecto-Coat 200 over concrete exposed to direct sunlight during the warming trend of the concrete as measured by surface temperature. To do so may lead to blistering, pinholes, or wrinkling in the coating due to outgassing of air in the concrete and high substrate temperatures. Wait for a definite downturn or cooling trend within the concrete as again measured by surface temperature. If this is not possible consult a Dudick representative for alternatives such as double priming.

PRIMING

Metal: For maximum performance, prime all steel surfaces with Primer 67, mixed with appropriate amount of hardener to 3-4 mils. For mild non-immersion service, priming of steel may be omitted.

Concrete: Concrete must be primed to aid in the "wetting out" required for good bonding. Mix Component A with Component B in the premeasured units for 2-3 minutes and apply by brush, roller, or spray. We recommend the basecoat be applied over slightly tacky or tack-free primer. Do not allow the primer to puddle.

Protecto-Coat 200 Mix Ratio:

Protecto-Coat 200 Basecoat	
Component A*	1 Gallon
Component B*	54 fl. ozs.

*Premeasured units by weight

Protecto-Coat 200 Topcoat

Protecto-Coat 200 Top Coat Comp. A*	1 Gal.
Component B*	54 fl. oz.

*Premeasured quantities by weight

BASECOAT

Add appropriate amount of hardener for each gallon of Protecto-Coat Liquid and mix thoroughly until uniform color is achieved. Apply a 25 mil wet (20 mil DFT) basecoat using spray, brush or roller. Allow basecoat application to cure to at least a "firm" or slightly "tacky" feel before applying the second 25 mil wet (20 mil DFT) basecoat. Brush or roller may require several coats to achieve desired thickness.

Protecto-Coat 200

Elastomeric, Spray Applied, Environmentally Safe, Urethane Coating
 405 256 2232 (11/1/88)

Dudick Incorporated
 Corrosion-Proof Products

Horizontal surfaces may be basecoated in one application by applying 50 mils wet (40 mil DFT) in a single coat.

TOPCOAT

Add appropriate amount of hardener for each gallon of Protecto-Coat Liquid and mix thoroughly until a uniform color is achieved. Apply a 20-mil-thick topcoat using spray, brush or roller.

Cure Cycle for Protecto-Coat 200

TEMPERATURE	RECOAT TIME	CURE TIME
50°	48 Hrs.	96 Hrs.
70°	24 Hrs.	48 Hrs.
90°	16 Hrs.	36 Hrs.

If these recoat times are exceeded, consult a Dudick representative: sanding or abrasive blasting may be required before the next coat. Recoat times are dramatically reduced when the coating is exposed to direct sunlight.

Single Component Airless Spray Equipment — Graco King 45-to-1 spray pump or equivalent. Use Graco Golden Mastic Gun or Graco No. 207945 Gun with airless adapter equipped with a Reverse-A-Clean tip and a tip size between .035-.041. Spray hose should be 1/2" or 3/8" ID. Available inlet pressure must be a minimum of 100 psi.

Brush or roller application may require additional coats to meet specified dry film thickness.

Pot life of the opened and mixed Protecto-Coat 200 will depend on the temperature at the work site. To prevent material waste and avoid damage to equipment, do not open and mix more material than can be used according to the following table:

TEMPERATURE	POT LIFE
50°F	120 Min.
75°F	60 Min.
90°F	45 Min.

Do not attempt to store mixed material. Residual material should be properly disposed of at the end of each work period.

Where immersion service is required, spark test the coating with a 5,000 to 7,000 volt AC spark tester. Mark and repair all pinholes. Use Protecto-Coat liquid mixed with the appropriate amount of hardener. Retest only the repairs.

CLEANING

Use S-10 Solvent to clean tools and equipment.

SHIPPING

Protecto-Coat 200 Topcoat A and B and Protecto-Coat 200 Basecoat A are classified as plastic liquids and are non-regulated.

Protecto-Coat 200 Basecoat B is combustible. Primer 67 Component B is corrosive and carries a black and white warning label. Primer 67 Component A is classified as a plastic liquid and is nonregulated, while S-10 Cleaning Solvent is red label liquid with a flash point of 52°F (PMCC).

STORAGE

Warning: All Dudick products classified by DOT labels as either white, yellow or red labels must not be mixed or stored together as an explosive reaction may occur.

When stored in a cool and dry location, Protecto-Coat 200 ingredients have a one-year shelf life. Exposure to excessive heat may cause premature gelling and reduce working time.

SAFETY

M.S.D.S. - Sheets must always be read before using products. Protecto-Coat Systems are intended for application by experienced, professional personnel. Dudick Inc. can supply Protecto-Coat systems supervision to help determine that the surface has been properly prepared, the ingredients correctly mixed, and the materials properly and safely applied.

Protecto-Coat 200

Elastomeric, Spray Applied, Environmentally Safe, Urethane Coat.

Dudick Incorporated
Corrosion-Proof Products

If Protecto-Coat materials are to be applied by your own personnel or by a third-party contractor, please be sure that they are aware of the following safety precautions:

- Exposure to resins and hardeners may cause severe dermatitis reactions in some people. Cleanliness of the skin and clothing is critical and must be of paramount concern.
- Safety glasses, gloves and suitable protective clothing must be worn at all times during application.
- Suitable respirators should be used.
- If contact with hardeners occurs, remove any clothing involved and wash the skin with large amounts of water. Discard the clothing. Do not attempt to wash and reuse it. Protecto-Coat liquid may be washed off with S-10 Cleaning Solvent, MEK liquid, or laquer thinner.
- Fumes are flammable and heavier than air. Proper ventilation should be maintained to minimize breathing of concentrated fumes.
- If a rash or dermatitis occurs, remove the individual from the work area and seek a physician's care for dermatitis.
- Keep open flames and sparks away from the area where toppings are being mixed and applied.
- In case of eye contact, wash with water for at least 15 minutes and consult a physician. If swallowed, do not induce vomiting; call a physician immediately.

Note:

Dudick Inc. ("Dudick") warrants all goods of its manufacture to be as represented in its catalogs and that the application of its products by its employees or sub-contractors shall be performed in a workmanlike manner. Dudick's obligation under this warranty shall be the repair to and replacement of any applications which its examination shall disclose to be defective. Dudick makes no warranty concerning the suitability of its product for application to any surface, it being understood that the goods have been selected and the application ordered by the purchaser. DUDICK INC. MAKES NO WARRANTY, EXPRESS OR IMPLIED, THAT THE GOODS SHALL BE MERCHANTABLE OR THAT THE GOODS ARE FIT FOR ANY PARTICULAR PURPOSE. THE WARRANTY OF REPAIR OR REPLACEMENT SET FORTH HEREIN IS EXCLUSIVE AND IN LIEU OF ALL OTHER WARRANTIES ARISING BY LAW OR OTHERWISE; AND DUDICK INC. SHALL NOT BE LIABLE FOR INCIDENTAL OR CONSEQUENTIAL DAMAGES, INCLUDING BUT NOT LIMITED TO LOST PROFITS, DOWN TIME, DAMAGES TO PROPERTY OF THE PURCHASER OR OTHER PERSONS, OR DAMAGES FOR WHICH THE PURCHASER MAY BE LIABLE TO OTHER PERSONS, WHETHER OR NOT OCCASIONED BY DUDICK'S NEGLIGENCE. This warranty shall not be extended, altered or varied except by written instrument signed by Dudick and Purchaser.

APPENDIX I.

SECONDARY CONTAINMENT

**SAFETY KLEEN
LONE MOUNTAIN FACILITY
FT 1 & 2 TANK ASSESSMENT
SECONDARY CONTAINMENT
VOLUME CALCULATIONS**

A. DIMENSIONS

- | | | |
|----|--------|--------|
| 1. | Length | 64' 9" |
| 2. | Width | 44' 0" |
| 3. | Height | 3" min |

B. VOLUME (Before encroachments) $64.75' \times 44' \times .25' = 712.25 \text{ ft}^3$

C. ENROACHMENTS

- | | | |
|-----|-----------------|---------------------|
| 1. | Posts | 16 @ 10" x 10" x 3" |
| 2. | Posts | 9 @ 12" x 10" x 3" |
| 3. | Posts | 1 @ 14" x 15" x 3" |
| 4. | Posts | 1 @ 24" x 8" x 3" |
| 5. | Posts | 2 @ 12" x 12" x 3" |
| 6. | Posts | 2 @ 32" x 12" x 3" |
| 7. | Posts | 1 @ 24" x 24" x 3" |
| 8. | Ramps | 4 @ 14' x 30" x 3" |
| 9. | Ramps | 1 @ 16' x 32" x 3" |
| 10. | Heat Exchangers | 2 @ 2' x 51" x 3" |
| 11. | Pumps | 4 @ 5' x 20" x 3" |
| 12. | Pumps | 4 @ 3' x 1' x 3" |

D. ENCROACHMENT VOLUME CALCULATIONS


- | | | |
|-----|---|---------------------|
| 1. | $16 \times 0.83 \text{ ft} \times 0.83 \text{ ft} \times 0.25 \text{ ft} =$ | 2.75 ft^3 |
| 2. | $9 \times 1 \text{ ft} \times 0.83 \text{ ft} \times 0.25 \text{ ft} =$ | 1.87 ft^3 |
| 3. | $1 \times 1.17 \text{ ft} \times 1.25 \text{ ft} \times 0.25 \text{ ft} =$ | 0.37 ft^3 |
| 4. | $1 \times 2 \text{ ft} \times 0.67 \text{ ft} \times 0.25 \text{ ft} =$ | 0.34 ft^3 |
| 5. | $2 \times 1 \text{ ft} \times 1 \text{ ft} \times 0.25 \text{ ft} =$ | 0.5 ft^3 |
| 6. | $2 \times 2.67 \text{ ft} \times 1 \text{ ft} \times 0.25 \text{ ft} =$ | 1.34 ft^3 |
| 7. | $1 \times 2 \text{ ft} \times 2 \text{ ft} \times 0.25 \text{ ft} =$ | 1.0 ft^3 |
| 8. | $4 \times 1.17 \text{ ft} \times 2.5 \text{ ft} \times 0.25 \text{ ft} =$ | 2.93 ft^3 |
| 9. | $1 \times 1.33 \text{ ft} \times 2.67 \text{ ft} \times 0.25 \text{ ft} =$ | 0.89 ft^3 |
| 10. | $2 \times 2 \text{ ft} \times 4.25 \text{ ft} \times 0.25 \text{ ft} =$ | 4.25 ft^3 |
| 11. | $4 \times 5 \text{ ft} \times 1.67 \text{ ft} \times 0.25 \text{ ft} =$ | 8.35 ft^3 |
| 12. | $4 \times 3 \text{ ft} \times 1 \text{ ft} \times 0.25 \text{ ft} =$ | 3 ft^3 |

TOTAL ENCROACHMENT VOLUME 27.59 FT^3



AVAILABLE CONTAINMENT VOLUME 685 FT^3

LARGEST TANK VOLUME (FT 1) 506 FT^3


EXCESS CONTAINMENT 179 FT^3



SPLASH DEFLECTOR
(3 TYP.)




SKIRT & BASE PLATE DETAIL



DO NOT FABRICATE FLANGE RING UNTIL RECEIPT OF CUSTOMER FURNISHED BLINDS OR TEMPLATE.



MANWAY DETAIL
(3 TYP.)




3	5/21/02	CERTIFIED - AS BUILT
2	2/26/02	REVISED PER CUSTOMER COMMENTS
1	1/23/02	REVISED PER CUSTOMER COMMENTS
0	1/04/02	ISSUED FOR APPROVAL
REVISIONS		
DRAWN BY: JED		JOB NO.: 203
CHECKED BY: BDL		DATE: 1/04/02
PURCHASE ORDER NO. 103034 PROG.No. CAPITAL DRAWING NAME: SK-001		

ENVIROTECH
ENGINEERING & CONSULTING, INC.
2500 North 24th Street - End A, Oklahoma City, OK 73107
Phone (405) 234-8763 Fax (405) 237-4302
E-MAIL: envirotech@earthlink.net
www.envirotech-consulting.com


SAFETY - KLEEN
CAPITAL PROJECT / LONE MOUNTAIN FACILITY
TWO 6'-4" O.D. X 20'-6" TALL STAINLESS STEEL FLASH TANK
LIDE INDUSTRIES
8 MILES E. HWY 84
MEXIA, TEXAS 76667




TOP FLUE FLANGE CONNECTION




INFLUENT CONNECTION (NOZZLE "7") DETAIL




CLIP "A1" DETAIL



MIST PAD DETAIL



REVISIONS		
2	5/21/02	CERTIFIED - AS BUILT
1	1/23/02	REVISED PER CUSTOMER COMMENTS
0	1/04/02	ISSUED FOR APPROVAL
DRAWN BY: JED		
CHECKED BY: BDL		
PURCHASE ORDER NO. 103034		
PROG.No. CAPITAL		
DRAWING NAME: SK-001		
SAFETY - KLEEN CAPITAL PROJECT / LONE MOUNTAIN FACILITY TWO 6'-4" O.D. X 20'-6" TALL STAINLESS STEEL FLASH TANK		
LIDE INDUSTRIES 6 MILES E. HWY 84 MEXIA, TEXAS 76867		
ENVIROTECH ENGINEERING & CONSULTING, INC. 2500 North 18th Street - 4th Floor - Suite 777 Phoenix, AZ 85016-1803 Phone: (602) 234-8800 Fax: (602) 234-8802 E-Mail: envirotech@earthlink.net		



FLOOR PLAN

SCALE: 1"=6'

COPYRIGHT

This document and the information contained may NOT be reproduced or excerpted from without the express written permission of Envirotech Services, Inc. Unauthorized copying, disclosure or construction use are prohibited by the copyright law.

NO.	DATE	REVISION	DRAWN BY	CHECKED BY



**FT-1 & FT-2
FLASH TANK
ASSESSMENT**

Secondary Containment

Lone Mountain Facility, Oklahoma

ENVIROTECH

Date: August 5, 2002

Scale: 1"=6'

Designed by: R. Stollings

Drawn by: C. Grieve

Checked By: R. Stollings

Project No. 02 084

Sheet No. 1 of 1

SECTION FT3

(OUT OF SERVICE)

**ASSESSMENT OF EVAPORATOR FLASH TANK NO.3 (FT3)
LONE MOUNTAIN HAZARDOUS WASTE FACILITY
U.S.P.C.I./LAIDLAW
WAYNOKA, OKLAHOMA**

A TANK SYSTEM DESCRIPTION

Evaporator Flash Tank No.3 (FT3) is a new welded above-ground waste-water treatment and storage tank to be installed as a part of the final waste-water treatment plant at the Lone Mountain Facility. The top of the tank is completely open to the atmosphere for evaporation purposes. Evaporator Flash Tank #3 (FT3) is located within the Waste-water Final Treatment building on the first mezzanine level of the support structure. The tank system consists of Evaporator Flash Tank #3 (FT3), Circulating Pump (P5), Heat Exchanger (EU3), Pump (P83), Filter press (FP3), and associated piping and instruments.

B PRIMARY TANK VESSEL

1. General Description

Evaporator Flash Tank No.3 (FT3) is a circular steel tank with an outside diameter of 6'4" and a height of 31'0". The tank proper has a skirt that is anchored to the support structure. The bottom of the tank is dished and welded to the shell. A self-supporting Flue is attached to the top of the tank. Flash Tank No. 3 is being assessed to determine if the unit is adequately designed with sufficient structural strength and compatibility with the waste to be stored.

2. Design Standards

The tank is designed and constructed to those sections that are applicable in the American Petroleum Institute Standard 650-1993 edition (API-650).

3. Hazardous Characteristics of Wastes Stored

The wastes which are stored in this tank are treated and untreated brine solutions. Representative samples of both the treated and the untreated wastes were sent for analysis. The results of those analyses are included in Appendix G of this assessment. In addition, the following characteristics of the wastes were verified:

Ignitability - Flash Point > 240° F

Corrosiveness

7 < pH < 12

2 < N < 7

Reactivity - None

Temp < 300° F

From the examination of the hazardous characteristics of the waste to be stored in this tank, it was determined that the pH and normality levels (Corrosiveness) of the waste are the primary areas of concern. This is to determine the applicability of a corrosion allowance for the tank material type and thickness.

4. Corrosion Protection

The interior of the tank is coated with two layers of Plasite 7156 Hi-Resistant Heavy Build Protective coating. Each layer is applied at a dry film thickness of not less than 5.0 mils. The corrosion protection system was installed according to the application instructions in Appendix F of this assessment. The exterior coating consists of one layer of Glid-Guard corrosion resistant HS Epoxy No. 5466 series at a dry film thickness of not less than 3.0 mils.

5. Documented Age of Tank

This tank was manufactured by Scott Manufacturing, Inc. of Lubbock, Texas in August 1995 and installed in October 1995.

6. Result of Leak Tests

The manufacturer conducted a hydrostatic leak test of the tank before shipping. A description of that test is included in Appendix D of this assessment. In addition, a visual inspection was performed of the interior and exterior of the tank after installation. This inspection was conducted specifically to detect the presence of any of the following defects:

- a) Weld break
- b) Punctures
- c) Scrapes of protective coatings
- d) Cracks
- e) Corrosion
- f) Other structural damage or inadequacies of construction and/or installation

The tank hydrostatic test after installation is included in Appendix D of this Assessment. A description of that procedure is also included in Appendix D of this assessment. From these tests it was determined that the primary tank was not leaking.

7. Existing Data Obtained

a. Diameter of Tank	6'4"
b. Nominal Height of Tank	31'0"
c. Maximum Capacity	2981 gal.
d. Overflow Liquid level	9'1"
e. Overflow Volume	2234 gal.
f. Design Specific Gravity	1.5
g. Maximum Bottom Pressure	4.7 psi
h. Maximum Operating Temperature	300° F
i. Material of Construction	
i) Shell	ASTM A36
ii) Bottom	ASTM A516 F&D Head
iii) Roof	ASTM A36
iv) Steel Pipe	ASTM A53, Grade B
v) Bolts	ASTM A307, Grade B
j. Wall Thickness	0.375"
k. Operating Pressure	Atmospheric
l. Seismic Zone	1

8. Calculation of Existing Foundation Loading

Total Weight of Tank and Contents 48,162 lbs.

Detailed calculations reflecting the volume and weight of the tank are included in Appendix A of this assessment.

9. Required Structural Calculation

Calculations for the required wall thickness for this tank are shown in Appendix B. Metallurgical information on the materials used is included in Appendix E of this assessment. The minimum required thickness in accordance with API 650, is 0.148 inches. A corrosion allowance of 0.125 is provided for. The measured wall thickness is 0.375 inches.

Design calculations for the support structure are included in Appendix C of this assessment. These calculations were done in accordance with BOCA National Building Code 1990 Edition.

Structural analysis of the foundation is included in Appendix C of this assessment.

10. Comparison of Actual to Theoretical Structural Values

Wall Thickness Comparison

Calculated Required Wall Thickness	0.1875"
Minimum Required Wall Thickness By API 650	0.148"

Measured Wall Thickness 0.375"

Bottom Thickness Comparison

Calculated Required Bottom Thickness	0.150"
Minimum required Bottom Thickness by API 650	0.250"
Measured Bottom Thickness	0.375"

Support Structure Comparison

See Appendix C of this assessment for complete comparison of the loads and support information for vertical columns, horizontal beams and diagonal bracing.

Foundation Integrity Comparison

Maximum Calculated Load (6" Slab)	17.6 Kips
Calculated Foundation Support (6" Slab)	26.7 Kips
Maximum Calculated Load (17" Slab)	62.9 Kips
Calculated Foundation Support (17" Slab)	127.7 Kips

C ANCILLARY EQUIPMENT

1. General Description

The ancillary equipment for the Evaporator Flash Tank No. 3 (FT3) system includes the following:

- a) Circulating Pump (P5) - a centrifugal pump designed to pump 800 GPM at 150 feet of discharge head with a suction head of 11 feet.
- b) Heat exchanger (EU3) -- a plate and frame unit of stainless steel construction designed to operate at a pressure of 150 PSIG and a temperature of 300°F. Manufacturer's design information is included in Appendix B of this assessment.
- c) Pump (P83) - a pneumatically operated double diaphragm pump designed to pump from 100 to 0 GPM at head pressures varying from 0 to 100 PSIG, pumping fluid at a temperature up to 212°F.
- d) Filter press (FP3) - a gasketed unit employing glass filled polypropylene plates designed to operate at a temperature/pressure limit of 100 psi at 212°F. Manufacturer information and special operating instructions are included in Appendix B of this assessment.
- e) Associated piping, valves and instruments - all piping is Schedule 40 carbon steel fitted with 150 psi flanges except the Low pressure blow

down line from Pump P5 to EB-2 shall be heater hose rated at -40°F to 350°F and 175 to 250 psi respectively. All piping with an inside diameter of 2" or smaller is socket-welded using, at a minimum, 3000# connections. All piping with an inside diameter greater than 2" is butt-welded. All valves, fittings & instruments are rated for 150 psi or higher.

2. Design Standards

All piping was installed according to ASME/ANSI Code section B31.3. Metallurgical information on the materials used is included in Appendix E of this assessment.

3. Corrosion Protection

The exterior of all waste piping is coated with two layers of Kem-Kromik Universal Metal Primer - B50Z Series. Each layer is applied at a dry film thickness of not less than 3 mils. Detailed information on the coating is included in Appendix F of this assessment.

4. Documented Age of Piping System

The piping and other ancillary equipment was purchased during a period of time between December 1994 and January 1995. It was installed in June 1995.

5. Result of Leak Tests

A Hydrostatic leak test was performed in accordance with ASME/ANSI B31.3 Chapter VI paragraph 345.5 using paragraph 345.4.2 to determine the pressure requirements of the test. A description of this testing procedure along with the results of that test are included in Appendix D of this assessment.

6. Data Obtained

Included in Appendix H of this assessment is a Piping and Flow Diagram of the treatment process. This Piping and Flow Diagram reflects data such as valves, blowoffs, vents, level controls and the overall flow pattern of the treatment process.

7. Pipe Support System

A visual inspection of the pipe support system was conducted. This inspection included a look at such things as materials of construction, welds, and construction methods. From this inspection a determination was made that the pipe support system is adequate.

D SECONDARY CONTAINMENT SYSTEM**1. General Description of Secondary Containment**

The secondary containment system is designed and operated to prevent any migration of wastes or liquids out of the system. Evaporator Flash Tank No. 1, Evaporator Flash Tank No. 2, Evaporator Flash Tank No. 3, Evaporator Blowdown Tank No. 2, and Evaporator Feed Tank No. 4 are located on a reinforced concrete base floor area with vertical concrete sidewalls. All associated piping is above ground and located within the secondary containment system. The area is inspected daily on a routine basis.

At the time of inspection the concrete area was withstanding daily operations, and routine climatic conditions. No cracks from compression or uplift were visually apparent.

Any released tank contents are removed and pumped to an appropriate storage area within the maximum time allowed as a permit condition.

2. Design Standards

Corings of the concrete in the existing containment area were taken and tested for compressive strength. A copy of the report generated from those tests is included in Appendix C of this assessment. The structural capacity of the foundation was compared to those sections that are applicable in the API-650 and the ACI-318, and these calculations were used as a guide in verifying the ability of the system to contain hazardous waste.

3. Corrosion Protection

There is an impermeable coating applied to the entire concrete floor and curbs. Appendix F of this assessment contains detailed information on the coating(s) employed.

4. Documented Age of the Containment Area

The secondary containment system was constructed and installed in 1987.

5. Result of Leak Tests

A visual inspection of the containment area was performed and from this inspection there were no cracks or breaks in the impermeable coating, therefore it appears to be adequate to contain any leaks or spills.

6. Calculation of Capacity Available (CCA)

Area	2739 s.f.
Curb Height	0.25 ft.

Material	Concrete
Gross Volume	685 c.f.

See Appendix H for detailed drawings of this containment area. Appendix A of this assessment contains detailed calculations of the available containment volume. The containment capacity available = 685 c.f.

7. Required Volume

Containment Capacity Required (CCR)

CCR=Volume of Largest Tank in the secondary containment

Volume of Largest Tank = (FT1) = 401 c.f.

8. Comparison of Available Volume to Required Volume

Containment Capacity

Containment Capacity Required =	401 c.f.
Secondary Containment Volume Available=	685 c.f.
Excess Containment Volume =	284 c.f.


E CONCLUSIONS

1. The foundation, structural support, seams, connections, and controls for the Evaporator Flash Tank No. 3 (FT3) System have been adequately designed.
2. The Evaporator Flash Tank No. 3 (FT3) system has sufficient structural strength, is compatible with the wastes to be stored and treated, and has adequate corrosion protection to ensure that it will not collapse, rupture or fail.
3. The Evaporator Flash Tank No. 3 (FT3) system was inspected after installation for weld breaks, punctures scrapes of protective coating, cracks, leaks, corrosion, and other structural damage or inadequacies of construction/installation.
4. The Evaporator Flash Tank No. 3 (FT3) was tightness tested after installation and it was found that the tank tested positive for tightness.
5. The Secondary Containment for the Evaporator Flash Tank No. 3 (FT3) system is of sufficient structural strength and of sufficient volume to meet the requirements set forth in 40 CFR 264.193.
6. All ancillary equipment associated with the Evaporator Flash Tank No.3 (FT3) system is properly supported and protected against physical damage and excessive stress due to settlement, vibration, expansion, or contraction.

7. The Evaporator Flash Tank No. 3 (FT3) system associated ancillary equipment was tightness tested after equipment installation in accordance with ASME/ANSI B31 and it was found that the ancillary equipment tested positive for tightness.
8. All instruments and heat exchanger plates shall be installed, calibrated, and tested before operating personnel starts FT-3 process cycle.

F CERTIFICATION

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.



James C. Reichenbach, P. E.
JAMES CLARK
REICHENBACH
14328
OKLAHOMA

Primary Tank Volume Calculations

ROBERTS AND THOMA, INC.

2574 74th St. Suite 202
LUBBOCK, TEXAS 79423
(806) 745-4881
FAX (806) 745-9688

JOB USPCI, WAYNOKA, OK
SHEET NO. 2 OF
CALCULATED BY RJT DATE 8-1-95
CHECKED BY DATE
SCALE



OVERFLOW VOLUME = 2234 GAL.
MAX. VOLUME = 2981 GAL.

$$\text{MAX. WATER HT.} = \frac{(2981 - 110)}{7.48052 \frac{\text{GAL}}{\text{FT.}^3}} \left(\frac{1}{\pi \frac{(6.33')^2}{4}} \right) = 12.2'$$

$$\text{OVERFLOW WATER HT.} = 9.1'$$

$$\text{MAX. WATER WT.} = 2981 \text{ GAL.} (8.3454) (1.5) = 37,317 \#$$

$$\text{OVERFLOW WATER WT.} = 2234 (8.3454) (1.5) = 27,966 \#$$

ROBERTS AND THOMA, INC.
2574 74th St. Suite 202
LUBBOCK, TEXAS 79423
(806) 745-4881
FAX (806) 745-9688

JOB USPCI, WAYNOKA, OK
SHEET NO. 4 OF
CALCULATED BY RJT DATE 8-1-95
CHECKED BY DATE
SCALE

- WIND LOAD ON TANK - PER API 650, 3.11

WIND LOAD = 18 PSF

$$O.T.M. = 18 \text{ PSF} \left(3' (10.5') \left(\frac{10.5'}{2} + 20.5' \right) + 6.33' \left(\frac{20.5'}{2} \right)^2 \right)$$

$$O.T.M._{\text{WIND}} = 38542 \text{ FT-}\#$$

- DETERMINE SHELL WT.

ELEMENT

FLUE	$10.21 \text{ PSF} (\pi) (3') (10.5')$	$= 1010 \#$
INSULATION	$2 \text{ PSF} (\pi) (3') (10.5')$	$= 192 \#$
ROOF R	$12.76 \text{ PSF} (\pi) (6.33')^2 \left(\frac{1}{2} \right)$	$= 402 \#$
$\frac{3}{8}$ " SHELL R	$15.31 \text{ PSF} (\pi) (6.33') (20.5')$	$= 6241 \#$
ACCESSORIES		$= 3000 \#$
		<u>10,845 #</u>

TOTAL TANK WT.

CONTENTS 2981 GAL

$$= 37317 \#$$

TOTAL TANK + CONTENTS

$$48,162 \#$$

$$C = \frac{2 M}{D (P)} = \frac{2 (38542)}{6.33' (.9 (10845))}$$

$$C = 1.25 > 0.66$$

\therefore ANCHOR BOLTS ARE REQ'D.

Secondary Containment Volume Calculations

SECONDARY CONTAINMENT VOLUME CALCULATIONS

A. DIMENSIONS

1. Length	64' 9"
2. Width	44' 0"
3. Height	3" min

B. VOLUME (Before encroachments) $64.75' \times 44' \times .25' = 712.25 \text{ft}^3$

C. ENCROACHMENTS

1. Posts	16 @ 10" x 10" x 3"
2. Posts	9 @ 12" x 10" x 3"
3. Posts	1 @ 14" x 15" x 3"
4. Posts	1 @ 24" x 8" x 3"
5. Posts	2 @ 12" x 12" x 3"
6. Posts	2 @ 32" x 12" x 3"
7. Posts	1 @ 24" x 24" x 3"
8. Ramps	4 @ 14' x 30" x 3"
9. Ramps	1 @ 16' x 32" x 3"
10. Heat Exchangers	2 @ 2' x 51" x 3"
11. Pumps	4 @ 5' x 20" x 3"
12. Pumps	4 @ 3' x 1' x 3"

D. ENCROACHMENT VOLUME CALCULATIONS

1. $16 \times 0.83 \text{ ft} \times 0.83 \text{ ft} \times 0.25 \text{ ft} =$	2.75 ft^3
2. $9 \times 1 \text{ ft} \times 0.83 \text{ ft} \times 0.25 \text{ ft} =$	1.87 ft^3
3. $1 \times 1.17 \text{ ft} \times 1.25 \text{ ft} \times 0.25 \text{ ft} =$	0.37 ft^3
4. $1 \times 2 \text{ ft} \times 0.67 \text{ ft} \times 0.25 \text{ ft} =$	0.34 ft^3
5. $2 \times 1 \text{ ft} \times 1 \text{ ft} \times 0.25 \text{ ft} =$	0.5 ft^3
6. $2 \times 2.67 \text{ ft} \times 1 \text{ ft} \times 0.25 \text{ ft} =$	1.34 ft^3
7. $1 \times 2 \text{ ft} \times 2 \text{ ft} \times 0.25 \text{ ft} =$	1.0 ft^3
8. $4 \times 1.17 \text{ ft} \times 2.5 \text{ ft} \times 0.25 \text{ ft} =$	2.93 ft^3
9. $1 \times 1.33 \text{ ft} \times 2.67 \text{ ft} \times 0.25 \text{ ft} =$	0.89 ft^3
10. $2 \times 2 \text{ ft} \times 4.25 \text{ ft} \times 0.25 \text{ ft} =$	4.25 ft^3
11. $4 \times 5 \text{ ft} \times 1.67 \text{ ft} \times 0.25 \text{ ft} =$	8.35 ft^3
12. $4 \times 3 \text{ ft} \times 1 \text{ ft} \times 0.25 \text{ ft} =$	3 ft^3

TOTAL ENCROACHMENT VOLUME 27.59 FT^3

AVAILABLE CONTAINMENT VOLUME 684.66 FT^3

LARGEST TANK VOLUME (FT 1) 401 FT^3

EXCESS CONTAINMENT 283.66 FT^3

Q Manufacturers Design Information

Primary Tank

MANUFACTURER'S CERTIFICATION FOR
TANK BUILT TO API STANDARD 650

TO USPCI/LAIDLAW
(Name and address of purchaser)

ROUTE 2, BOX 170

WAYNOKA, OKLAHOMA 73860-9622

We hereby certify that the tank constructed for you at

USPCI - LONE MOUNTAIN FACILITY
(Location)

WAYNOKA, OKLAHOMA

and described as follows: (1) SMI 499-3, 6'-4" O.D., 31'H
(Serial or contract number, diameter,
height, capacity, floating or fixed roof)

2981 GAL, WITH FIXED FLUE OPEN TOP ROOF

meets all applicable requirements of API Standard 650, NINTH

Edition, JULY 1993 Revision, Appendix A, J, & M

dated NOVEMBER 30, 1994, including design, materials,
fabrication, and testing.

The tank is further described on the attached as-built data sheet dated

8-1-95 (LAST REVISION DATE)

SCOTT MANUFACTURING, INC.
Manufacturer

William A. Bacon MGR/HC
Authorized representative

8-24-95
Date

ROBERTS AND THOMA, INC.
2574 74th St. Suite 202
LUBBOCK, TEXAS 79423
(806) 745-4881
FAX (806) 745-9688


JOB USPCI, WAYNOKA, OK
SHEET NO. 1 OF
CALCULATED BY RJT DATE 8-1-95
CHECKED BY DATE
SCALE

• DESIGN DATA

OPERATING PRESSURE	ATMOSPHERE
DESIGN TEMPERATURE	300° F.
SEISMIC ZONE	1
WIND VELOCITY	100 MPH
CORROSION ALLOWANCE	1/8"
MIN. PLATE THICKNESS	3/8"
SPECIFIC GRAVITY	1.5

DESIGN STANDARD* API 650 WITH
APPENDIX A, J, & M

* THE DESIGN OF THIS TANK IS "BASED" ON
API 650, ALTHOUGH API 650 IS MEANT TO
COVER ONLY TANKS WHOSE ENTIRE BOTTOM IS
UNIFORMLY SUPPORTED ON THE GROUND. THE
BOTTOM FOR THIS TANK IS NOT UNIFORMLY SUPPORTED.
HOWEVER, THE DESIGN WILL COMPLY WHEREVER
POSSIBLE TO API 650.



8-1-95
WATER STORAGE TANK DESIGN
CALCULATIONS, P. 1 TO 12.

ROBERTS AND THOMA, INC.
2574 74th St. Suite 202
LUBBOCK, TEXAS 79423
(806) 745-4881
FAX (806) 745-9688

JOB USPCI, WAYNOKA, OK
SHEET NO. 5 OF
CALCULATED BY RJT DATE 8-1-95
CHECKED BY DATE
SCALE

TRY USING (8) - $\frac{3}{4}$ " ϕ A36 ANCHOR BOLTS

$$\text{ROOT AREA} = 0.309 \text{ in}^2$$

$$\text{ALLOW. TENSILE STRESS} = 15,000 \text{ PSI}$$

DESIGN ANCHOR BOLTS PER API 650, F.7

PROVIDE $\frac{1}{4}$ " CORROSION ALLOWANCE ON THE DIAMETER

$$\text{EQUIV. DIAMETER} = \sqrt{\frac{.309(4)}{\pi}} - .25" = .3772 \text{ in}^2$$

$$\text{ADJUSTED ROOT AREA} = \frac{\pi(.3772)^2}{4} = .112 \text{ in}^2$$

$$\text{ALLOW. BOLT TENSION} = .112 \text{ in}^2 (15000 \text{ PSI}) \left(\frac{4}{3}\right)$$

$$\text{ALLOW. BOLT TENSION} = 2235.4 \#$$

$$\text{BOLT CIRCLE} = 6'-4" + 2(1\frac{1}{2}") = 6'-7"$$

$$\text{BOLT CIRCLE ; } d = 6.583 \text{ FT.}$$

$$\text{NUMBER OF ANCHOR BOLTS} = \frac{4(38542)}{6.583(2235.4)} - \frac{.9(10,845\#)}{2235.4\#}$$

$$\text{REQ'D. NUMBER OF A.B.} = 6.11 \text{ BOLTS} < 8 \checkmark \text{OK}$$

USE (8) - $\frac{3}{4}$ " ϕ A36 ANCHOR BOLTS

ROBERTS AND THOMA, INC.
2574 74th St. Suite 202
LUBBOCK, TEXAS 79423
(806) 745-4881
FAX (806) 745-9688

JOB USPCI, WAYNOXA, OK
SHEET NO. 6 OF
CALCULATED BY RJT DATE 8-1-95
CHECKED BY DATE
SCALE

- CHECK SEISMIC LOADS PER API 650, APPEN. E.

ZONE 1 - $Z = 0.1875$ (TABLE E-1)

$$I = 1.0$$

$$C_1 = 0.24$$

$$W_{FLUE} = 1202^\#$$

$$W_{SHELL} = 9241^\#$$

$$W_R = 402^\#$$

$$W_T = 37317^\#$$

$$\frac{D}{H} \approx \frac{6.33'}{12.66'} = .5$$

$$\frac{W_1}{W_T} = .91$$

$$W_1 = .91(37317^\#) = 33959^\#$$

$$\frac{W_2}{W_T} = .13$$

$$W_2 = .13(37317^\#) = 4852^\#$$

$$\frac{X_1}{H} = .45$$

$$X_1 = .45(12.66') + 5' = 10.7'$$

$$\frac{X_2}{H} = .833$$

$$X_2 = .833(12.66') + 5' = 15.6'$$

$$k = .57 \quad T = .57(6.33')^{1/2} = 1.434 \quad S = 1.5$$

$$C_2 = \frac{0.30(1.5)}{1.434} = .314$$

ROBERTS AND THOMA, INC.
2574 74th St. Suite 202
LUBBOCK, TEXAS 79423
(806) 745-4881
FAX (806) 745-9688

JOB USPCI, WAYNOKA, OK
SHEET NO. 7 OF
CALCULATED BY RJT DATE 8-1-95
CHECKED BY DATE
SCALE

SEISMIC CONT. -

$$\begin{aligned} C_1 W_{FLUE} X_{FLUE} &= .24(1202\#)(25.75') = 7428.4 \\ C_1 W_s X_s &= .24(924\#)(10.25') = 22732.9 \\ C_1 W_R H_R &= .24(402\#)(20.5') = 1977.8 \\ C_1 W_1 X_1 &= .24(33959\#)(10.7') = 87206.7 \\ C_2 W_2 X_2 &= .314(4852\#)(15.6') = 23767.0 \\ & \underline{143,112.8} \end{aligned}$$

$$\text{SEISMIC O.T.M.} = .1875(1.0)(143,112.8)$$

$$\text{SEISMIC O.T.M.} = 26834 \text{ FT-}\# < \text{WIND O.T.M.} = 38542 \text{ FT-}\#$$

\therefore WIND O.T.M. GOVERNS DESIGN OF ANCHOR BOLTS

PER API 650 - E.5.2

$$b = Wt + \frac{1.273 M}{D^2}$$

$$b = \frac{10845\#}{\pi(6.33')^2} + \frac{1.273(38542)}{(6.33')^2} = 1770 \text{ \#/FT.}$$

$$\frac{b}{12t} = \frac{1770\#/\text{ft}}{12(.375'')} = 393.3 \text{ PSI}$$

$$\frac{GH D^2}{t^2} = \frac{1.5(13')(6.33')^2}{.375''} = 2083.6 \text{ PSI} < 10^6$$

$$F_a = \frac{10^6(.375)}{2.5(6.33')(12)} + 600 \sqrt{1.5(13')(12)} = 11,153 \text{ PSI}$$


$$F_a = 11,153 \text{ PSI} > \frac{b}{12t} = 393 \text{ PSI} \quad \checkmark \text{ OK}$$

ROBERTS AND THOMA, INC.
2574 74th St. Suite 202
LUBBOCK, TEXAS 79423
(806) 745-4881
FAX (806) 745-9688

JOB USPCI, WAYNOKA, OK
SHEET NO. 10 OF
CALCULATED BY RJT DATE 8-1-95
CHECKED BY DATE
SCALE

• DESIGN SELF-SUPPORTED FLUE

REFER TO "DESIGN OF
PLATE STRUCTURES,
VOLUME 2", p. 25



$$F_L = \frac{C_L D_o g_{cr}}{2\beta}$$

$$C_L = 0.2 \quad D_o = 3' \quad \beta = 1\% = .01$$

$$f_t = \frac{352 \cdot D}{4\pi H_1^2} \left[\frac{E g}{2 W_s} \right]^{\frac{1}{2}}$$

$$f_t = \frac{3.52(36'')}{4\pi(10.5'(12))^2} \left[\frac{28,300,000(386)}{2(.2836 \text{ #/IN}^3)} \right]^{\frac{1}{2}}$$

$$f_t = 88.2 \text{ cps}$$

$$V_{cr1} = 3.41 D_o f_t$$

$$= 3.41(3 \text{ FT.})(88.2 \text{ cps})$$

$$V_{cr1} = 901.8 \text{ MPH} = 1322.6 \text{ fps}$$

$$V_{cr2} = \frac{f_t D_o}{S} \quad S = .2$$

$$= \frac{88.2(3')}{0.2}$$

$$V_{cr2} = 1322.6 \text{ fps}$$

$$g_{cr} = .00119 V_{cr}^2$$

$$= .00119 (1322.6)^2$$

$$g_{cr} = 2082 \text{ PSF} > 18 \text{ PSF}$$

∴ DYNAMIC WIND IS NOT CRITICAL

ROBERTS AND THOMA, INC.

2574 74th St. Suite 202
LUBBOCK, TEXAS 79423
(806) 745-4881
FAX (806) 745-9688

JOB USPCI, WAYNOKA, OK

SHEET NO. 11 OF

CALCULATED BY RJT DATE 8-1-95

CHECKED BY DATE

SCALE

$$f_o = \frac{678.5 t}{D_o^2}$$

$$= \frac{678.5 (.25)}{(3')^2}$$

$$f_o = 18.85$$

$$V_o = \frac{f_o D_o}{25}$$

$$= \frac{18.85 (3')}{2 (.2)}$$

$$V_o = 141.4 \text{ FT/SEC.} = 96.4 \text{ MPH}$$

$$\frac{P}{250} = \frac{36''}{250} = .144''$$

∴ **OVALING VIBRATIONS ARE NOT CRITICAL**

$$\frac{t}{R_o} = \frac{.25}{18''} = .01389$$

$$F_{cr} = F_y \left[.8 + \frac{5t}{R_o} \right]$$

$$= 36,000 \text{ PSI} \left[.8 + \frac{5(.25)}{18} \right]$$

$$F_{cr} = 31,300 \text{ PSI}$$

$$C'_c = \sqrt{\frac{2\pi^2 E}{F_{cr}}}$$

$$= \sqrt{\frac{2\pi^2 (28,300,000)}{31,300}}$$

$$C'_c = 133.6$$

ROBERTS AND THOMA, INC.
2574 74th St. Suite 202
LUBBOCK, TEXAS 79423
(806) 745-4881
FAX (806) 745-9688

JOB USPCI, WAYNOKA, OK
SHEET NO. 12 OF
CALCULATED BY RJT DATE 8-1-95
CHECKED BY DATE
SCALE

$$\frac{KL}{r}, \quad K=2.0 \quad L=10.5'$$
$$r = \frac{\sqrt{(36'')^2 + (35.5'')^2}}{4}$$

$$r = 12.64 \text{ in}^2$$

$$\frac{KL}{r} = \frac{2.0(10.5')(12)}{12.64}$$

$$\frac{KL}{r} = 19.94 < C_c = 133.6$$

$$K\phi = 1 - .5 \left[\frac{KL/r}{C_c} \right]^2$$

$$= 1 - .5 \left(\frac{19.94}{133.6} \right)^2$$

$$K\phi = .989$$

$$F_c = \frac{K\phi F_{cr}}{FS}$$

$$FS = 2.0$$

$$= \frac{.989(31,300)}{2.0}$$

$$F_c = 15,476 \text{ PSI}$$

$$S = \frac{\pi((36'')^4 - (35.5'')^4)}{32(36'')} = 249.22 \text{ in}^3$$

$$WIND QTM. = 18 \text{ PSF} \left(\frac{10.5'}{2} \right)^2 = 2977 \text{ FT-}\#$$

$$f_c = \frac{3 \text{ FT-K}(12)}{249.22} = .144 \text{ KSI} < F_c = 15.4 \text{ KSI} \quad \checkmark \text{ OK}$$

Tank Wall Thickness

ROBERTS AND THOMA, INC.
2574 74th St. Suite 202
LUBBOCK, TEXAS 79423
(806) 745-4881
FAX (806) 745-9688

JOB USPCI, WAYNOKA, OK
SHEET NO. 3 OF
CALCULATED BY RJT DATE 8-1-95
CHECKED BY DATE
SCALE

- CALCULATE SHELL THICKNESS PER API 650, M.3
FROM TABLE M-1;
FOR 300°F, REDUCTION FACTOR (RF.) = 0.88

$$t_{REQ'D.} = \frac{2.6 D (H-1) G}{E (21000) (RF.)} + C.A.$$

$D = 6.33'$ $H = 12.2'$ (SAY 13') $G = 1.5$
USE $E = 0.70$ $C.A. = \frac{1}{8}"$ (.125") $RF. = .88$

$$t_{REQ'D.} = \frac{2.6 (6.33') (13' - 1) (1.5)}{.70 (21000) (.88)} + .125$$

$t_{REQ'D.} = .148 \text{ in.}$ $X Z = .296 \text{ in.}$

USE MIN. $\frac{3}{8}"$ STEEL PLATE FOR SHELL

REINFORCEMENT PLATES AROUND SHELL OPENINGS
ARE NOT REQUIRED BECAUSE $t = \frac{3}{8}" > .296"$
(.375")

ROBERTS AND THOMA, INC.
2574 74th St. Suite 202
LUBBOCK, TEXAS 79423
(806) 745-4881
FAX (806) 745-9688

JOB USPCI, WANOKA, OK

SHEET NO. 8 OF 8

CALCULATED BY RJT DATE 8-1-95

CHECKED BY _____ DATE _____

SCALE _____

- DESIGN SHELL MANWAY & BOTTOM MANWAY - 30" ϕ

$$P = 13' (62.4 \text{ #/FT.}^3) (1.5) = 1216.8 \text{ PSF} = 8.45 \text{ PSI}$$

$$S = \frac{Pr^2}{t^2} \quad S = 21,000 \text{ PSI}$$

$$t_{\text{REQ'D.}} = \sqrt{\frac{Pr^2}{S}}$$

$$= \sqrt{\frac{8.45 (15'')^2}{21,000}}$$

$$t_{\text{REQ'D.}} = .30'' + .125'' \xleftarrow{\text{C.A.}} = .425''$$

USE $\frac{1}{2}''$ PL

ROBERTS AND THOMA, INC.
2574 74th St. Suite 202
LUBBOCK, TEXAS 79423
(806) 745-4881
FAX (806) 745-9688

JOB USPCI, WANOKA, OK
SHEET NO. 9 OF
CALCULATED BY RJT DATE 8-1-95
CHECKED BY DATE
SCALE

• DESIGN FLANGED & DISHED BOTTOM

$$t_{REQ'D} = .0000757272 PR + C.A.
= .0000757272 (8.45 \text{ PSI}) \left(\frac{6.33'(12)}{2} \right) + .125"$$

$$t_{REQ'D} = .15 \text{ IN.}$$


USE 3/8" THICK PL

Heat Exchanger


Designed, Constructed and National Board Stamped in Accordance with latest
1992 A.S.M.E. Code and Addendum.




Side




Front



Footing



Section AA



B= 42 5/16" (1075) A= See Plate Spec Documentation Dimensions in () are millimeters (mm)

LOC	Function	Fluid	Connections	Material	Size	Rating	Type
S1	Hotside Inlet	30.7 psig Steam		SS	6"	150#	STUD
S2	Hotside Outlet	30.7 psig Steam		SS	6"	150#	STUD
S3	Coldside Inlet	Solution		SS	6"	150#	STUD
S4	Coldside Outlet	Solution		SS	6"	150#	STUD

Notes: Carboline 134 1.5 mils DFT (Alfa Laval Blue)

CERTIFIED
APPROVED FOR FABRICATION
BY [Signature] DATE 6/23/94

Customer Name : USPCI
P.O. Number : 20572
Item : # 2 Heat Exchangers
Order Number : 942005
A/L Serial#(s) : 30101-96638 thru 96639

Design Press/Temp.: 150 PSI / 300 °F
Plate/Gasket Mat'l: AISI 316 / EPDM
Plates Actual/Max.: 39 / 64 (0.5mm)
Weight Dry/Flooded: 2350 lb / 2607 lb
Length CBar/TBolt.: 900 mm / 750 mm

M15-FFG

Alfa Laval Thermal Inc.

Manufactured in Richmond, Virginia

rev.	description	by	chk.	date
A	Revised Stud Bolt, Foot Dimension & Fast Print	UC	AV	11/91
		date	check	date
		11/91	AV	11/91
		approval	TC	11/91

Alfa Laval Thermal Inc.
400 International Trade Drive
Falls Church, VA 22044

Plate Heat Exchanger
Bill of Materials



Implementation Date: 2/28/94
Revision: 1

Page 1 of 1

QA03138

Subject: M15-FFD


BACKGROUND

Given are standard ASME/ASTM materials of construction.

No.	Item	Quantity	Material	Notes	Dimensions
1.	Frame Plate	1	SA516-70	1	
2.	Pressure Plate	1	SA516-70	1	900 mm
3a.	Carrying Bar	1	Aluminum		
3b.	T-Profile Cladding	2	SA240,304SS		900 mm
4.	Guide Bar	1	SA479,304SS		750 mm
5.	Tightening Bolt	8	SA193,B7		2" - 4 1/2 UNC
6.	Tightening Nut	8	SA194,2H2		2" - 4 1/2 UNC
7.	Support Column	1	Aluminum	1	
8.	Support Foot	1	SA36	1	
9.	Frame Foot	2	SA36	2	
10.	Stud Bolt	48	SA193,B7		
11.	Connection Liner	4	SA240,316SS		
12.	N/A				
13.	Channel Plate Gasket	40	EPDM		Electropolished
14.	Channel Plate	39	SA240,316SS		
Not Shown	OSHA Shroud	1	Aluminum	3	

Notes: (1)Painted. (2)Zinc Plated. (3)Not Shown

Drawing is not an accurate depiction, see certified print.



USPCI
P.O. #: 20572
TAG: #2 HEAT EXCHANGERS
A/L ORDER #: 942005
A/L SERIAL #: 30101-96638
30101-96639

CERTIFIED
APPROVED FOR FABRICATION
BY [Signature] DATE 6/23/94

ALFA - LAVAL THERMAL

PLATE HEAT EXCHANGER Specification Sheet

CUSTOMER: USPCI
Supplier: Alfa Laval Thermal Inc.
Agent: Charles Martin, Thermal Engineering Co

P.O.#: 20572
Order#: 942005
Tag#: # 2 Heat Exchangers

Quantity: 2
Serial#: 30101-96638 thru 96639

PHE Model Type: M15-FFG

HOT SIDE
-1-

COLD SIDE
=2=

Fluids	:	30.7 psig Steam	Solution
Flow rates	lb/hr	10349	312000
Inlet temperature	F	275.0	180.0
Outlet temperature	F	272.2	230.0
Pressure drops	psi	2.0	8.9
Total Surface Area	:	260 sq ft	
Flow regimen fluids	:	counterflow	
Connection locations in	:	S1	S3
out	:	S2	S4
Material in connections	:	SS	SS
Total number of plates	:	39	
Plates material	:	AISI 316	
thickness	:	0.5mm	
Gasket material	:	EPDM Clip-on	
Design pressure	:	150 PSI	
Design temperature	:	300 F	
Liquid volumes	US gallon	13	13
Total unit dry weight	:	2300 lb	

CERTIFIED
APPROVED FOR FABRICATION
BY DATE 6/24/96

06/22/94

2*M15-F CH__ AISI_316 0.5mm EPDM_Clip-on

```

1*19 L  S1->S2  30.7 psig Steam
1*19 L  S4<=S3  Solution

```

					←-----	0.6mm
39	End Plt1 16B	H			O O	
38	Chan Plt.03A	L	U==<===U		U U	
37	Chan Plt.03B	L	O O		O O	
36	Chan Plt.03A	L	U U		U U	
35	Chan Plt.03B	L	O O		O O	
))))	
			((((
6	Chan Plt.03A	L	U U		O O	
5	Chan Plt.03B	L	O O		U U	
4	Chan Plt.03A	L	U U		O O	
3	Chan Plt.03B	L	O O		U--<---U	
2	Chan Plt.03A	L	U==<===U		O O	
1	End Plt2 83B	H	O O		O O	
			-S4-----S3-----S2-----S1-			

Date 06/22/94

ment

P.O.#: 20572

CUSTOMER: USPCI

=====

ALFA-LAVAL THERMAL PLATE HEAT EXCHANGER

=====

Model Type M15-FFG
 Quantity 2
 Serial#: 30101-96638 thru 96639
 Supplier: Alfa Laval Thermal Inc.
 Agent: Charles Martin, Thermal Engineering Co

Order#: 942005
 Tag#: # 2 Heat Exchangers

Gasket sides of the plates are facing the frame plate.
 Plates with parallel flow.

Plates material AISI 316
 thickness 0.5mm
 Gasket material EPDM Clip-on
 A - Dimension (See Drawing) 174 mm
 Total number of plates 39
 Total unit dry weight 2300 lb
 Extra/Inspection port location Side 1: Side 2:

-----SAMPLE FLOW DIAGRAMS-----

Sample SINGLEPASS Flow Diagram

121	End Plt1 76A	H	===<=====				
120	Chan Plt 03B	L	O	U--<---O-----U			
119	Chan Plt 03A	L	O	U	O	U	
))))	S
			((((
3	Chan Plt 03A	H	U==<===O=====U				A D
2	Chan Plt 03B	H	O	U--<---O-----U			
1	End Plt2 83A	H	O	O	O	O	M I
			-S4-----S3-----S2-----S1-				P A

Sample MULTIPASS Flow Diagram

				-----T3-----	T2-----		
121	Tran Plt 43A	H	O	O	O	O	
120	Turn Plt 04B	H		O	U--<---		E R
119	Chan Plt 03A	L	U==<===U	O	O		A
))))	
			((((
71	Chan Plt 03B	H	O	O	U--<---U		F M
70	Chan Plt 03A	L	U==<===U	O	O		
69	Turn Plt 11B	H	O		----->--U		L S
68	Chan Plt 03A	L	U===>==U	O	O		O
))))	
			((((W
4	Chan Plt 03A	L	O	O	O	O	
3	Chan Plt 03B	H	O	O	U--->--U		
2	Chan Plt 03A	L	U===>==U	O	O		
1	End Plt2 84B	H		O	O		
			-----S3-----S2-----				

See following page for Flow Diagram Discriptions.
 *** SEE PAGE 1 FOR YOUR FLOW DIAGRAM. ***

Date 06/22/94

ment



=====FLOW DIAGRAM DESCRIPTIONS=====

ylepass....Plate heat exchanger with connections on frame plate
 (stationary cover) only.
 :ipass....Plate heat exchanger with both frame plate and pressure
 plate (movable cover) connections.
 S2,S3,S4...Frame plate connection designations.
 P2,T3,T4...Pressure plate connection designations.
 (See drawing for locations of T and S ports.)

-----PLATE DESCRIPTIONS-----


o 121...Plate position starting from frame plate.
 n Plt...Channel Plate. Standard 4-port channel plate. Gasketed so
 that flow from two ports opens to the channel plate center.
 . Plt2...End Plate 2. Channel plate adjacent to frame plate. With
 port holes fully gasketed so that flow does not go between
 this plate and the frame plate.
 | Plt1...End Plate 1. Channel plate adjacent to pressure plate
 on single pass unit.
 n Plt...Turning Plate. Redirects flow with port locations which are
 not punched (no U or O) on multipass units.
 . Plt...Transition Plate. Channel plate adjacent to both pressure
 plate and partition plates on multipass unit.
 ct Plt...Partition Plate. Thicker steel plate required on some
 multipass units.
 in Plt...Twin plate. Channel plate type used on welded units only.
 ,03,83...Plate hole punching description. A-L internal use only.

-----PORT PUNCHING-----

.....Port surrounded by ring gasket. Fluid in this port
Flow opening port. Fluid flows into this channel.
 O or U...If no U or O is shown then this port location is not punched
 and fluid does not flow through this port.

-----PLATE ORIENTATION-----

B.....Plate orientation, as seen from gasketed side of plates:

A Plate =>  <= B Plate
 (Channel plate arrangements alternate between A and B plates)

.....High Theata channel plate. Chevrons at angle greater than
 90 degrees.
Low Theata channel plate. Chevrons at angle less than 90
 degrees.
 (Channel plate arrangements can have all Highs, all Lows or
 a mixture of Highs and Lows.)

Plates: M15-F CH AISI 316 0.5mm EPDM Clip-on
74 37 Chan Plt.03 L Channel plate
2 1 End Plt1 16B H End plate 1 0.6mm
2 1 End Plt2 83B H End plate 2

Gaskets: EPDM Clip-on
74 37 32330-1804-3 Channel plate gasket
2 1 32330-1804-3 Channel plate gasket
2 1 End plate gasket II consists of:
4 2 32330-1804-3 2 Channel plate gaskets

Structural Support Calculations

Otis A Clark PE.

TEL NO. 405 878-0338

Mar 29, 95

9:45 P.M.
PAGE 4.

COLUMN LOADS

A-1 - 3.6 k
B-1 - 14.3 k
C-1 - 14.1 k
D-1 - 19.0 k
E-1 - 14.2 k
A-2 - 4.5 k
B-2 - 36.3 k
D-2 - 62.9 k
E-2 - 34.1 k
A-3 - 8.4 k
B-3 - 27.9 k
C-3 - 28.8 k
D-3 - 19.9 k
E-3 - 14.4 k
A-5 - 9.8 k
B-5 - 17.6 k
A-7 - 4.8 k
B-7 - 8.5 k
C-7 - 11.5 k
F-7 - 12.1 k
C-6 - 24.8 k
F-6 - 24.2 k
C-4 - 28.1 k
F-4 - 24.2 k
F-3.1 - 12.0 k


EXCEPT @ GRID F.. ALL COLUMNS
WILL BE 14.8-24.

WITH KL 13.0 ALLOWABLE

COL LOAD IS 93.0 k.

THIS SATISFIES ALL CONDITIONS






$$\frac{3.26}{4} = .8150 \text{ KIPS PER COL.}$$

$$.8150 \times 11.5 = 9.37 \text{ K' MOMENT}$$

$$\frac{9.37 \times 12 \times 1000}{21600} = 5.2 \text{ K/IN S3'}$$

$$W8x31 \times 27.5 = 5.2 \text{ COLUMNS OK}$$




HORZ. FORCES & DIAG. BRACING.

7.26 KIPS @ C-7 TO E-7

12.23 @ E-2 TO E-3

6.10 @ A-1 TO A-2

14.64 @ D.1-1 TO E-1



DIAG. BRACES. $A_4 \cdot 3/8 \cdot 1.5 \square'' \quad \frac{26.13}{1.5} = 17.42 \text{ ksi} < 24$
BRACES O.K.


COLUMN UPLIFT. 21.65 w/ $4 \cdot 3/4$ EPOXY ANCHORS:

PULLOUT TEST ON $3/4$ EPOXY ANCH. w/ $6 \cdot 1/2$ IN EMBEDMENT IS

24.2 KIPS. WITH A SAFETY FACTOR OF 4 TO 1

6 KIPS PER ANCHOR

$6 \text{ k} \times 4 = 24 > 21.65$ O.K.



DESKED LOADS (1990 BOCA NATIONAL BLDG CODE)


LIVE LOAD ... 100 PSF. (LIGHT MANUFACTURING - PAGE 246)

DEAD LOAD ... 20 PSF.

TOTAL ... 120 PSF.

TANKS FT1, FT2, & FT3 47,300 LBS. EACH (FILLED)


TANK FT4 25,300 LBS (FILLED)

LATERAL FORCES FOR EARTHQUAKE LOADS $V = 2.5 A_v I K C S W$ (PAGE 272) $A_v = .1$ (ZONE 1) (PAGE 273) $I = 1.0$ (TABLE 1113.1, PAGE 275) $K = 1.0$ (TABLE 1113.4.3, PAGE 278) $C = .12$ (PAGE 279) $S = 1.5$ (TABLE 1113.4.6, PAGE 281) $W = \text{WEIGHT}$ $V = 2.5 \times .1 \times 1.0 \times 1.0 \times .12 \times 1.5 \times W$ $V = .045 W$ 

BENCH GRID. A-1 TO B-1

(12/2.14)

UNBRACED LENGTH 3.1




$$M = 2.4 \times 3.08 = 7.4$$

FROM ASD 2.174 ALLOWABLE $M = 27.3 > 7.4$

BENCH GRID. A-2 TO B-2

(12/2.14)

UNBRACED LENGTH 3.1



$$M = 2.4 \times 3.08 = 10.2$$

$$M = 2.4 \times 4.50 = 11.4$$

$$M = 2.4 \times 3.08 = 11.9$$

$$M = 2.4 \times 2.37 = 10.2$$

FROM ASD 2.174 ALLOWABLE $M = 27.3 > 11.9$

Otis A Clark PE.


TEL NO. 405 878-0338

Mar 29, 95 9:09 P.11
PAGE 9

(W12, 35)

UNIFORM LATH 2'-11"


BEAM @ GRID B-2 TO D-2



$$\begin{aligned}
 M @ 1 &= 26.0 \times 2.21 = 46.4 \\
 M @ 2 &= 26.0 \times 5.13 - 20.4 \times 2.92 = 48.2 \\
 M @ 3 &= 26.0 \times 2.21 = 46.4
 \end{aligned}$$

FROM ASD 2.172 ALLOWABLE $M = 91.2 > 48.2$

BEAM @ GRID D-2 TO E-2



$$\begin{aligned}
 M @ 1 &= 26.4 \times 2.21 = 58.3 \\
 M @ 2 &= 26.4 \times 5.13 - 25.8 \times 2.92 = 60.1 \\
 M @ 3 &= 26.4 \times 2.21 = 58.3
 \end{aligned}$$


FROM ASD 2.173 ALLOWABLE $M = 66.8 > 60.1$

It's A Clark PE.

TEL NO. 405 878-0338

Mar 29, 95 9:10 P.12
Page 10

BEAM & GRID D.1-1 TO E-1 & D.1-3 TO E-3 (W/12x6)
(UNBOLTED LETH 2411)




$$M = 15.4 \times 6.7 = 10.3$$

$$M = 15.4 \times 3.59 - 12.9 \times 2.92 = 17.6$$

$$M = 11.0 \times 2.21 = 24.3$$

FROM ASD 2-173 ALLOWABLE $M = 66.4 > 24.3$

BEAM & GRID B-1 TO C-1 (W/12x19)
(UNBOLTED LETH 2411)



$$M = 6.4 \times 2.21 = 14.1$$

$$M = 6.4 \times 5.13 - 7.5 \times 2.92 = 10.9$$

$$M = 9.2 \times 6.7 = 6.2$$

FROM ASD 2-174 ALLOWABLE $M = 42.5 > 14.1$


Otis A Clark PE.

TEL NO. 405 878-0338

Mar 29, 95

9:10 P.13
PAGE 11

BEAM - GRID A-3 TO B-3




(11/12/14)
UNBRACED LETH 30

$$\begin{aligned} M_1 &= 4.4 \times 1.5 \\ M_2 &= 4.4 \times 3.75 - 1.5 \times 3.00 \\ M_3 &= 3.7 \times 5.14 - 1.9 \times 2.37 \\ M_4 &= 3.7 \times 2.37 \end{aligned}$$

FROM ASD 2.174 ALLOWABLE $M = 27.3 >$

BEAM - GRID A-5 TO A-7



(11/12/16)
UNBRACED LETH 310

$$\begin{aligned} M_1 &= 6.1 \times 3.35 \\ M_2 &= 6.1 \times 7.17 - 3.1 \times 3.82 \\ M_3 &= 6.2 \times 6.24 - 2.7 \times 3.35 \\ M_4 &= 6.2 \times 2.89 \end{aligned}$$

FROM ASD 2.172 ALLOWABLE $M = 76.2 > 31.9$

It's A Clark PE.

TEL NO. 405 878-0338


Mar 29, 95

9:11 P.14
Page 12

BEAM @ GRID A-3 TO A-5

W12x8

UNBRACED LENA 41.0




$$\begin{aligned}
 M_1 &= 8 \times 3.31 = 26.5 \\
 M_2 &= 8 \times 6.62 - 1.8 \times 3.31 = 22.0 \\
 M_3 &= 4.0 \times 7.96 - 2.2 \times 3.98 = 23.4 \\
 M_4 &= 4.0 \times 3.98 = 15.9
 \end{aligned}$$

FROM ASD 2.172 ALLOWABLE $M = 76.2 > 23.4$

BEAM @ GRID B-3 TO B-5

(W12x8)

UNBRACED LENA 41.0




$$\begin{aligned}
 M_1 &= 3 \times 3.31 = 9.93 \\
 M_2 &= 3 \times 6.62 - 3.3 \times 3.31 = 3.31 \\
 M_3 &= 3 \times 7.96 - 3.9 \times 3.98 = 4.12 \\
 M_4 &= 3 \times 3.98 = 11.94
 \end{aligned}$$

FROM ASD 2.172 ALLOWABLE $M = 76.2 > 41.2$

BEAM & GRID B-5 TO B-7

(12/2/26)

UNBRACED LETH. 3492




$$\begin{aligned}
 M @ 1 &= 6.9 \times 3.35 = 23.1 \\
 M @ 2 &= 6.9 \times 7.17 - 3.5 \times 3.82 = 36.1 \\
 M @ 3 &= 7.0 \times 6.24 - 3.8 \times 3.35 = 33.3 \\
 M @ 4 &= 7.0 \times 2.89 = 20.2
 \end{aligned}$$

FROM ASD 2-172 ALLOWABLE $M = 76.2 > 33.3$

CROSS BEAM UNDER FT. 1, 2, 3 (CL. PLACED) 5' 10" SPAN (12/2/26)

UNBRACED LETH. 160



$$\begin{aligned}
 M @ 1 &= 7.0 \times 1.42 = 9.9 \\
 M @ 2 &= 7.0 \times 2.92 - 6.7 \times 1.50 = 10.4 \\
 M @ 3 &= 7.0 \times 1.42 = 9.9
 \end{aligned}$$

FROM ASD 2-174 ALLOWABLE $M = 30.2 > 10.4$


It's A Clark PE.

TEL NO. 405 878-0338

Mar 29, 95 9:13 P.16
Page 14

BEAM - GRID C-3 TO C-4

(W12x32)



$$M @ 1 = 13.7 \times 1.87 = 25.6$$

$$M @ 2 = 13.7 \times 3.35 - 1.6 \times 1.48 = 43.5$$

$$M @ 3 = 13.7 \times 5.27 - 1.6 \times 4.0 - 8.4 \times 2.52 = 52.9$$

$$M @ 4 = 11.1 \times 6.19 - 3.3 \times 3.19 - 1.7 \times 2.21 = 54.4$$


$$M @ 5 = 11.1 \times 3.78 - 3.3 \times 1.78 = 40.9$$

$$M @ 6 = 11.1 \times 3.00 = 33.3$$

FROM ASD $\phi = 172$ ALLOWABLE $M = 91.2 > 54.4$

BEAM - GRID F-3 TO F-4, F-4 TO F6
F6 TO F-7

(W12x26)



$$M @ 1 = 9.2 \times 3.35 = 30.8$$

$$M @ 2 = 9.2 \times 3.35 = 30.8$$

FROM ASD $\phi = 172$ ALLOWABLE $M = 66.8 > 30.8$

Jtls A Clark PE.


TEL NO. 405 878-0338

Mar 29, 95 9:13 P.17
1 AUG 17

BEAM & GRID C-6 TO C-7

(W12x26)

UNBRACED LGTH 31.44




$$\begin{aligned} M_1 &= 9.0 \times 3.35 = 30.2 \\ M_2 &= 9.0 \times 7.17 - 8.4 \times 3.82 = 32.4 \\ M_3 &= 9.4 \times 3.35 = 31.5 \end{aligned}$$

FROM ASD 2.173 ALLOWABLE $M = 66.8 > 32.4$

BEAM & GRID C-4 TO C-6

(W12x26)

UNBRACED LGTH 31.44



$$\begin{aligned} M_1 &= 10.2 \times 3.35 = 34.2 \\ M_2 &= 10.2 \times 6.25 - 9.8 \times 2.90 = 35.3 \\ M_3 &= 10.8 \times 3.35 - 1.5 \times 1.43 = 34.0 \\ M_4 &= 10.8 \times 1.5 = 16.2 \end{aligned}$$


FROM ASD 2.173 ALLOWABLE $M = 66.8 > 35.3$

Otis A Clark PE.

TEL NO. 405 878-0338

Mar 29, 95 9:14 P.18
PAGE 16

BEAM UNDER EF. 4 (2 PLACES) (V12.2C)
UNBRACED LGTH. 5'10³/₄




$$M @ ① \& ④ = 8.1 \times 3.55 = 28.8$$

$$M @ ② \& ③ = 8.1 \times 4.63 - 49 \times 1.08 = 32.2$$

FROM ADS 2-173 ALLOWABLE $M = 66.8 > 32.2$

BEAM @ GRID B-3 TO C-3 (V12.35)



$$M @ ① = 12.8 \times 2.21 = 28.3$$

$$M @ ② = 12.8 \times 5.13 - 12.9 \times 2.92 = 28.0$$

$$M @ ③ = 25.6 \times 1.46 - 13.7 \times .79 = 26.4$$

$$M @ ④ = 25.5 \times .67 = 17.1$$

FROM ADS 2-172 ALLOWABLE $M = 91.2 > 28.3$


Otis A Clark PE.

TEL NO. 405 878-0338

Mar 29, 95

9:15 P.19
PAGE 1

CROSS BEND UNDER RF 4 (2 PLACES) 540 SPIN (48.18)
UNBRACED LETH 16




$$M = \textcircled{1} 4.3 \times 1.42 = 6.1$$

$$M = \textcircled{2} 4.3 \times 2.92 - 4.0 \times 1.56 = 6.6$$

$$M = \textcircled{3} 4.3 \times 1.42 = 6.1$$

FROM ASD 2.174 ALLOWABLE $M = 30.3 > 6.6$

BEND UNDER FLASH TANKS (6 PLACES) (412.26)
UNBRACED LETH 54034



$$M = \textcircled{1} \& \textcircled{6} = 12.9 \times 3.55 = 45.8$$

$$M = \textcircled{2} \& \textcircled{5} = 12.9 \times 4.63 - 7.0 \times 1.08 = 52.2$$

FROM ASD 2.173 ALLOWABLE $M = 66.8 > 52.2$

Clis A Clark PE.

TEL NO. 405 878-0338

BEAM - GRID E-2 TO E-3

(W8.24)

UNBRACED LETH 12.4

$$M = \frac{1.8 \times 12.33}{8} = 2.8 \text{ k'}$$

FROM ASD 2-174 ALLOWABLE $M = 38.3 > 2.8$

BEAM - GRID B-2 TO B-3

(W8.24)

UNBRACED LETH 12.4

$$M = \frac{3.6 \times 12.33}{8} = 5.5 \text{ k'}$$

FROM ASD 2-174 ALLOWABLE $M = 38.3 > 5.5$

BEAM - GRID B-1 TO B-2

(W8.24)

UNBRACED LETH 12.4

$$M = \frac{4.2 \times 12.33}{8} = 6.5 \text{ k'}$$

FROM ASD 2-174 ALLOWABLE $M = 38.3 > 6.5$

BEAM - GRID A-1 TO A-2

(W8.24)

UNBRACED LETH 12.4

$$M = \frac{2.4 \times 12.33}{8} = 3.7 \text{ k'}$$

FROM ASD 2-174 ALLOWABLE $M = 38.2 > 3.7$

BEAM - GRID A-5 TO B-5

(W8.24)

UNBRACED LETH 9.3

$$M = \frac{3.4 \times 9.25}{8} = 3.9$$

FROM ASD 2-174 ALLOWABLE $M = 38.3 > 3.9$

BEAM $7\frac{1}{2}$ SOUTH OF GRID B-7 TO C-7 (WB-10)
UNBRACED LTH $7\frac{1}{2}$

$$M = \frac{3.2 \times 7.25}{8} = 2.9 \text{ K'}$$

FROM ASD PAGE 2-175 ALLOWABLE $M = 11.5 > 2.9$

BEAM $6\frac{3}{4}$ NORTH OF GRID B-5 TO C-5 (WB-10)
UNBRACED LTH $7\frac{1}{2}$

$$M = \frac{3.2 \times 7.25}{8} = 2.9 \text{ K'}$$

FROM ASD 2-175 ALLOWABLE $M = 11.5 > 2.9$

BEAM $2\frac{1}{4}$ NORTH OF GRID B-5 TO C-5 (WB-10)
UNBRACED LTH $7\frac{1}{2}$

$$M = \frac{2.8 \times 7.25}{8} = 2.5 \text{ K'}$$

FROM ASD 2-175 ALLOWABLE $M = 11.5 > 2.5$

BEAM $3\frac{1}{4}$ SOUTH OF GRID B-5 TO C-5 (WB-10)
UNBRACED LTH $7\frac{1}{2}$

$$M = \frac{3.0 \times 7.25}{8} = 2.7 \text{ K'}$$

FROM ASD 2-175 ALLOWABLE $M = 11.5 > 2.7$

BEAM $6\frac{1}{2}$ SOUTH OF GRID B-5 TO C-5 (WB-10)
UNBRACED LTH $7\frac{1}{2}$

$$M = \frac{3.2 \times 7.25}{8} = 2.9 \text{ K'}$$

FROM ASD 2-175 ALLOWABLE $M = 11.5 > 2.9$

BEAM 2¹/₈ NORTH OF GRID A-5 TO B-5 (W8x10)
UNBRACED LETH 913

$$M = \frac{3.4 \cdot 9.25}{8} = 3.9 \text{ K'}$$

FROM ADS 2-175 ALLOWABLE $M = 9.0 > 3.9$

BEAM 6¹/₈ NORTH OF GRID A-5 TO B-5 (W8x10)
UNBRACED LETH 913

$$M = \frac{4.0 \cdot 9.25}{8} = 4.6 \text{ K'}$$

FROM ADS 2-175 ALLOWABLE $M = 9.0 > 4.6$

BEAM 7¹/₈ SOUTH OF GRID A-7 TO B-7 (W8x10)
UNBRACED LETH 913

$$M = \frac{4.2 \cdot 9.25}{8} = 4.9 \text{ K'}$$

FROM ADS 2-175 ALLOWABLE $M = 9.0 > 4.9$

BEAM 3¹/₄ SOUTH OF GRID A-7 TO B-7 (W8x10)

$$M = \frac{4.0 \cdot 9.25}{8} = 4.6 \text{ K'}$$

FROM ADS 2-175 ALLOWABLE $M = 9.0 > 4.6$

BEAM 3¹/₄ SOUTH OF GRID B-5 TO C-5 (W8x10)
UNBRACED LETH 713

$$M = \frac{3.2 \cdot 7.25}{8} = 2.9 \text{ K'}$$

FROM ADS 2-175 ALLOWABLE $M = 11.5 > 2.9$

Otis A Clark PE.

TEL NO. 405 878-0338

Mar 29, 95

9:18 P.23
PAGE 21

BEAM ~~GRID~~ D-2 TO D-3

(W1514)

UNBRACED LETH 1140

$$M = \frac{3.8 \times 11.83}{8} = 4.7 \text{ K'}$$

FROM ASD 2.175 ALLOWABLE $M = 20.75 > 4.7$

BEAM ~~GRID~~ D-1 TO D-2

(W1519)

UNBRACED LETH 1140

$$M = \frac{3.2 \times 12.5}{8} = 5.0 \text{ K'}$$

FROM ASD 2.175 ALLOWABLE $M = 17.0 > 5.0$

BEAM 34114 + 71112 NORTH OF GRID A-3 TO B-3 (W8110)

UNBRACED LETH 963

$$M = \frac{4.4 \times 9.25}{8} = 5.1 \text{ K'}$$

FROM ASD 2.175 ALLOWABLE $M = 9.0 > 5.1$

BEAM 6712 SOUTH OF GRID A-5 TO B-5 (W8110)

UNBRACED LETH 963

$$M = \frac{4.0 \times 9.25}{8} = 4.6$$

FROM ASD 2.175 ALLOWABLE $M = 9.0 > 4.6$

BEAM 3434 SOUTH OF GRID A-5 TO B-5 (W8110)

UNBRACED LETH 963

$$M = \frac{3.6 \times 9.25}{8} = 4.2$$

FROM ASD 2.175 ALLOWABLE $M = 9.0 > 4.2$

It's A Clark PE.

TEL NO. 405 878-0338

Mar 29, 95

9:19 P.24

PAGE 28

BEAM 3-1 & 6-2 WEST OF GRID B-1 TO B-2 (2 PLACES)

(W8.15) UNBRACED LETH 13'0"

$$M = \frac{4.8 \times 13}{8} = 7.8 \text{ K'}$$

FROM ASD 2.175 ALLOWABLE $M = 12.1 > 7.8$

BEAM 2-4 & 6-3 WEST OF GRID B-2 TO B-3 (W8.15)

UNBRACED LETH 13'0"

$$M = \frac{3.8 \times 13}{8} = 6.2 \text{ K'}$$

FROM ASD 2.175 ALLOWABLE $M = 12.1 > 6.2$

BEAM UNDER TANKS (8 PLACES) (W8.10)

UNBRACED LETH 8'11"

$$M = \frac{1.6 \times 5.9}{8} = 1.2 \text{ K'}$$

FROM ASD 2.175 ALLOWABLE $M = 15.6 > 1.2$

BEAM @ TANKS 3-6 & 8 SPAN (8 PLACES) (W8.10)

UNBRACED LETH 3'6.5"

$$M = \frac{1.2 \times 3.55}{8} = .5 \text{ K'}$$

FROM ASD 2.175 ALLOWABLE $M = 15.6 > .5$

BEAM - GRID A-7 TO B-7

(W8, 24)

UNBRACED LTH 9'3"

$$M = \frac{1.8 \times 9.25}{8} = 2.1 \text{ k'}$$

FROM ASD 2.174 ALLOWABLE $M = 38.3 > 2.1$

BEAM - GRID B-7 TO C-7

(W8, 24)

UNBRACED LTH 7'3"

$$M = \frac{1.4 \times 7.25}{8} = 1.3$$

FROM ASD 2.174 ALLOWABLE $M = 38.3 > 1.3$

BEAM - GRID B-5 TO C-5

(W8, 24)

UNBRACED LTH 7'3"

$$M = \frac{2.6 \times 7.25}{8} = 2.4 \text{ k'}$$

FROM ASD 2.174 ALLOWABLE $M = 38.3 > 2.4$

BEAM - GRID C-7 TO F-7

(W12, 26)

UNBRACED LTH 18'0"

$$M = \frac{3.6 \times 18.0}{8} = 8.1 \text{ k'}$$

$$M = \text{CANT. END.} = \frac{12.0 \times 5.45^2}{2} = 31.4 \text{ k'}$$

FROM ASD 2.174 ALLOWABLE $M = 31.4 > 8.1$

BEAM @ GRID C-6 TO F-6 & C-4 TO F-4 (W12x26)
UNBRACED LETH 18'0"

$$M = \frac{7.2 \times 18.04}{8} = 16.2 \text{ k'}$$

$$M_{\text{CONT}} = \frac{1.40 \times 5.45^2}{2} = 5.9 \text{ k'}$$

FROM ASD 2.174 ALLOWABLE $M = 31.4 > 16.2$

BEAM @ GRID C-3.1 TO F-3.1 (W12x26)
UNBRACED LETH 18'0"

$$M = \frac{6.6 \times 18.04}{8} = 14.9 \text{ k'}$$

$$M_{\text{CONT}} = \frac{2.0 \times 5.45^2}{2} = 3.0 \text{ k'}$$

FROM ASD 2.174 ALLOWABLE $M = 31.4 > 14.9$

BEAM = FILTER PRESSURE GRID C TO F (6PAGES) (W12x25)
UNBRACED LETH 18'0"

$$M = \frac{3.6 \times 18.04}{8} = 8.1 \text{ k'}$$

$$M_{\text{CONT}} = \frac{1.46 \times 5.45^2}{2} = 6.8 \text{ k'}$$

FROM ASD 2.174 ALLOWABLE $M = 31.4 > 8.1$

BEAM 711/2 # 341/4 NORTH OF GRID. B-3 TO C-3. (W8.10)
UNBRACED LETH 713

$$M = \frac{3.4 \times 7.25}{8} = 3.1 \text{ k'}$$

FROM ASD 2.175 ALLOWABLE $M = 11.5 > 3.1$

BEAM @ GRID E-1 TO E-2 (W8.10)
UNBRACED LETH 124

$$M = \frac{1.8 \times 11.33}{8} = 2.5$$

FROM ASD FROM 2.175 ALLOWABLE $M = 5.2 > 2.5$


BEAM 46.5 FT OF GRID A-3 TO A-2 (W8.10)
UNBRACED LETH 130

$$M = \frac{1.8 \times 13}{8} = 2.9 \text{ k'}$$

FROM ASD 2.175 ALLOWABLE $M = 4.8 > 2.9$

(18.15)


UNBROKEN LETH. dho



FROM ASD 2.175 ALLOWABLE $M = 23.6 > 6.6$

(wind)

LINEAR LCM 20



FROM ASD 2-174. ALLOWABLE $N = 29.8 > 14.4$


Jt1s A Clark PE.

TEL NO. 405 878-0338

Mar 29, 95 9:22 P. 29-28

(3 PAGES)

MEZZ BEAM B-3 TO C-3 & D-1.3 TO E-3 (WE15)
& E-1 TO D-1 UNDERG LATH 3'7"




$$M @ \textcircled{1} = 1.9 \times 1.54 = 2.9 \text{ k'}$$

$$M @ \textcircled{2} = 0.7 \times 3.58 = 2.5 \text{ k'}$$

FROM ASD 2-175 ALLOWABLE $M = 23.6 > 2.9$

MEZZ BEAM @ GRID D-2 TO E-2 (WE12.4)
UNDERG LATH 3'7"



$$M @ \textcircled{1} = 5.6 \times 1.54 = 8.6$$

$$M @ \textcircled{2} = 5.6 \times 5.12 - 5.12 \times 3.58 = 10.1$$

$$M @ \textcircled{3} = 4.7 \times 1.54 = 7.2$$

FROM ASD 2-174 ALLOWABLE $M = 27.6 > 10.1$

MEZZ BEAM C9-1 TO C9-2

(W8x15)

(UNBRACED LGTH 10'10")

$$M = \frac{3.6 \times 1267}{8} = 5.7 \text{ k'}$$

FROM ADS 2.175 ALLOWABLE $M = 14.0 > 5.7$ MEZZ BEAM D1-1 TO D1-2

(W8x15)

(UNBRACED LGTH 7'2")

$$M = \frac{5.2 \times 1267}{8} = 8.2 \text{ k'}$$

FROM ADS 2.175 ALLOWABLE $M = 21.0 > 8.2$ MEZZ BEAM 1 1/2 WEST OF C9 TO C9-2

(W8x15)

(UNBRACED LGTH 4'6")

$$M = \frac{4.2 \times 13}{8} = 6.8 \text{ k'}$$

FROM ADS 2.175 ALLOWABLE $M = 21.25 > 6.8$ MEZZ BEAM 3 1/2 EAST OF B1 TO B-2

(W8x15)

(4'6" UNBRACED LGTH)

$$M = \frac{5.6 \times 13}{8} = 9.1$$

FROM ADS 2.175 ALLOWABLE $M = 21.25 > 9.1$ MEZZ BEAM 1 1/2 EAST OF B2 TO B3

(W8x15)

(UNBRACED LGTH 7'2")

$$M = \frac{4.9 \times 13}{8} = 6.5$$

FROM ADS 2.175 ALLOWABLE $M = 21.0 > 6.5$

MEZZ BEAM @ GRID E-1 TO E-2 (W8.10)
R2 TO R3 & E2 TO E3

$$M = \frac{1.2 + 1.3}{8} \cdot 1.95 \text{ k}' \quad (\text{UNBRACED LETH } 13'0")$$

FROM ADS 2.15 ALLOWABLE $M = 4.0 > 1.95$

MEZZ BEAM @ GRID R1 TO R2 (W8.10)

(UNBRACED LETH 6'8")

$$M = \frac{2.6 + 1.3}{8} \cdot 4.2 \text{ k}'$$

FROM ADS PAGE 2.15 ALLOWABLE $M = 12.2 >$

MEZZ BEAM @ GRID C9-3 TO C9-2 & D1-3 TO D1-2

(W8.15) (UNBRACED LETH 7'2")

$$M = \frac{5.2 + 1.3}{8} \cdot 8.5 \text{ k}'$$

FROM ADS 2.15 ALLOW. $M = 21.2 > 8.5$

MEZZ BEAM 1/2" WEST OF E1 TO E2 & E2 TO E3 (W8.15)

(UNBRACED LETH 7'2")

$$M = \frac{4.0 + 1.3}{8} \cdot 6.5 \text{ k}'$$

FROM ADS 2.15 ALLOWABLE $M = 21.2 > 6.5$

Otis A Clark PE.

TEL NO. 405 878-0338

Mar 29, 95

9:25 P.32

PAGE 31

MEZZ BEAM 2-11 SPAN, 6 PLACES, 11.8x10

(2-11 UNBRACED LETH)

$$M = \frac{1.2 \times 2.92}{2} = 4.4'$$


FROM ADS 2-175 ALLOWABLE $M = 16.0 > 4$

MEZZ BEAM TANK OPENINGS (6 PLACES) (11.8x10)

(UNBRACED LETH 2-11)

$$M = \frac{6 \times 7.16}{4} = 1.1'$$

FROM ADS 2-175 ALLOWABLE $M = 16.0 > 1.1$



Otis A. Clark PE.

TEL NO. 405. 878-0338

Apr 03, 95 13:36 P.02

(REVISED)


COLUMNS ON 6" SLAB

Max. Cal Load Is At B.S - 17.6 KIPS

6" SLAB 4000 PSI Conc w/ #4 @ 12 IN. A STR.

ALLOWABLE M FOR FT. OF SLAB

$$As for Jd = 20 \times 14000 \times .85 \times 3 \times 12,240 \text{ " LBS.}$$



CHECK OF 2 WAY (PUNCHING) SHEAR

$$4 \times 16 \text{ " } \times 6 \text{ " } \times 1.1 \sqrt{4000} = 26.7 \text{ K} > 17.6 \text{ K O.K.}$$

REQUIRED MOMENT PER FT OF SLAB

$$\frac{2500 \times 11.5}{12} \times 11.5 = 9184 \text{ " LBS } < 12,240 \text{ " LBS. O.K.}$$


FROM ASD PAGE B-302 BEAM DIAG. #20

Otis A Clark PE.

TEL NO. 405 878-0338

Apr 03, 95 13:36 P.03

(REVISED)



$$3.26 \times 8150 \text{ KIPS PER COL}$$

4

$$8150 \times 11.5 = 9.37 \text{ K' MOMENT}$$


$$\frac{9.37 \times 12 \times 1000}{4 \times 600} = 5.2 \text{ K/IN S3'}$$

$$148.31 \times 27.5 = 4078.5 \text{ COLUMNS OK}$$

COMBINED LOADS

$$\frac{5.2}{27.5} + \frac{24.2}{149} = .3515 < 1 \text{ Cols: O.K.}$$

FROM ADD-331



Otis A Clark PE.

TEL NO. 405 878-0338

Apr 03, 95 13:37 P.04

Page 32

Horiz Forces @ NRC Max Col Load @ 82 = 7.1 k
D₂ 12.3 k
E₂ 5.9 k

Horiz Force @ Girder 2 = (7.1 + 12.3 + 5.9) x .045 = 1.14 k

1.14 38 k Horiz Force per Col
3

M₁ k Horiz Axis of Col = 38 x 12.25 = 4.66 k'

Rein S₂ = 4.66 x 12 259 < 5.63 OK
21.6

COMBINED LOADING

259 + 12.3 46 + 13 = 59 < 1
5.63 95


Cols. OK

Otis A. Clark, PE.

TEL NO. 405 878-0338

Apr 03, 95 13:38 P.05
PAGE 33

MOMENT CONT. @ COL CAP PLATES - Cols F3, F4, F5, F6



CAP PL. @ Cols F3, F4, F5, F6

FROM PROB. 5 MOMENT IS 9.37 k

$$FORCES @ FUS. \frac{9.37 \times 12}{(2 - 1.435)} = 14.86 \text{ k}$$

$$\Delta WELD @ PLANCHES 70.4 \times 2 = 140.8 > 14.86 \text{ o.k.}$$

$$\text{MAX TENSION @ BOLTS} \frac{9.37 \times 12}{6.75} = 16.66 \text{ k}$$

$$\frac{16.66}{2} = 8.33 \text{ PER BOLT} < 9.3 \text{ o.k.}$$

Foundation Design Analysis



March 27, 1995

Mr. Jim Richenbaugh
Black & Veatch Waste Science
4717 Grand Avenue, Suite 500
Kansas City, MO 64112

Re: USPCI Lone Mountain Facility
Subject: Waste Water Treatment Floor Structural Design

The concrete floors in the area where the mezzanine has been erected were poured as part of two different building expansions. The first expansion was poured in the spring of 1987 and was designed to be eighteen inches thick with two layers of 3/4 inch reinforcement bars tied on one foot centers and separated by twelve inches between the top and bottom mats. All reinforcement bars were kept within three inches of the slab's surfaces and were supported by concrete brick on a two inch layer of sand. This slab underlies the area that supports the Flash Tanks and EF4 and extends to the south edge of the filter press mezzanine.

The second expansion attaches to the north side of the first slab and was poured in November of 1987. It was poured around four existing boiler foundations that were 2 feet wide, 3 feet deep, and 24 feet long. The floor slab was poured six inches thick and used a layer of 1/2 inch reinforcement bars tied on one foot centers, supported on a concrete brick and a 2 inch layer of sand. This slab underlies the area supporting the filter presses.

Both slabs were poured using a 4000 psi concrete strength mix as verified by the core sample tested by Meyers Engineering of which a report has been sent to you earlier this week.

I hope this will provide the information you needed for the certification work now in progress.

Sincerely,

Lawson Fenton

Lawson Fenton
Project Manager

R. 170
Wayne, Oklahoma 73860-9622


Tel: 405/697-3500
Fax: 405/697-3596

Our Mission:

Provide the highest quality waste and by-product management services that consistently meet or exceed customer needs and regulatory requirements at competitive cost while enhancing shareholder value.

(12) — CONTAMINANT AREA NUMBER

--- LOCATION OF CORE




FMT: Final Water Treatment

LAYOUT OF WASTE VALLEY TREATMENT
BUILDING USED LONG MOUNTAIN HAZARDOUS
WASTE FACILITY VANDERBILT, OREGON

MOES

⑭ CONTAINMENT AREA NUMBER

← LOCATION OF CORE



AYOUT OF WASTE WATER TREATMENT
BUILDING USED LONG MOUNTAIN HAZARDOUS
WASTE FACILITY VANDERBILT UNIVERSITY


MERS
WASTEWATER TREATMENT
BUILDING AND WASTE

10/1/82
5/1/82

<u>Specimen</u>	<u>Diameter, In.</u>	<u>Drilled Length, In.</u>	<u>Capped Length, In.</u>	<u>Crushing Load, lbs.</u>	<u>L/D Correction Factor</u>	<u>Compressive Strength, psi</u>
PHT-1	3.75	5.5	5.7	32,440	0.96	2,810
PHT-2	3.75	5.5	4.9	47,200	0.93	3,980
PHT-3	3.75	6.5	4.5	41,400	0.93	3,490
PHT-4	3.75	7.5	4.6	60,700	0.93	5,110
PHT-5	3.75	7.0	7.1	43,000	0.99	3,860
PHT-6	3.75	6.5	4.1	57,100	0.88	4,550
PHT-7	3.75	7.0	5.8	43,800	0.96	3,810
PHT-8	3.75	6.0	5.8	74,800	0.96	6,480
PHT-9	3.75	5.0	5.5	33,900	0.96	2,950
PHT-10	3.75	6.0	4.7	72,500	0.93	6,100
PHT-11	3.75	6.0	5.6	55,720	0.96	4,840
PHT-12	3.75	6.0	6.6	65,600	0.98	5,800
PHT-13	3.75	5.0	5.3	68,700	0.94	5,850
PHT-14	3.75	5.0	5.3	80,200	0.95	6,900
PHT-15	3.75	6.0	5.1	60,200	0.97	5,290
FHT-1A	3.75	6.0	4.7	53,800	0.93	4,530
FHT-1B	3.75	11.0	6.0	50,800	0.97	4,460
FHT-2	3.75	22.0	7.0	30,740	0.99	2,760
*FHT-3	3.75	15.0	-	-	-	-
FHT-4	3.75	6.0	7.0	81,600	0.99	7,320
FHT-5	3.75	6.0	5.8	81,700	0.96	7,100
*FHT-6	3.75	19.0	-	-	-	-
*FHT-7	3.75	14.5	-	-	-	-
FHT-9	3.75	7.0	7.0	53,200	0.99	4,770

PHT - Pre-Water Treatment
FHT - Final Water Treatment

* Samples which we were not able to pull out of the hole.



CORE PLUG DETAIL

CORE PLUG DETAIL FOR
USPCI, LONE MOUNTAIN FACILITY
WAYNOKA, OKLAHOMA

Myers
ENGINEERING CORPORATION
Oklahoma City Oklahoma

JOB NO. 311
SCALE NTS
DRAWN DMC
DATE 6/23/97

1 SHEET
OF 1

REV. NO. 1 6-23-97 CHANGE FILL IN SOL. TO BENTONITE SAND PER GENE WALKER REQUEST.

OTIS A Clark PE.

TEL NO. 405 878-0338

OTIS A. CLARK PE.

Phone
(405) 878-0338

130 Bdwy. Bldg.
Suite 202
Shawnee, OK. 74801

To: USPCI
Lone Mountain Facility
Route 2, Box 180A
Waynoka, Okla. 73806

Attn: Lawson Fenton

March 28, 1995

The following is an investigation for the foundation support for the mezzanine platforms for the Wastewater Final Treatment Facility, and the calculations for the design of the beams, columns, and bracing for the structure. The design loads are per the 1990 BOCA National Building Code and are shown on page #7 of the following submittal.

COLUMN	LOAD, KIPS	FOUNDATION CONDITION	REMARKS
A-1	3.6	17" floor slab	OK (see page #2)
A-2	4.5		
A-3	8.4		
A-5	9.8	6" floor slab	OK (see page #1)
A-7	4.8		
B-1	14.3	17" floor slab	OK (see page #2)
B-2	36.3		
B-3	27.9		
B-5	17.6	6" floor slab	OK (see page #1)
B-7	8.5		
C-4	28.1	24" x 36" cont. ftg.	OK (see page #3)

C-6	24.8	24" x 36" cont.ftg.	OK (see page #3)
C-7	11.5	6" floor slab	OK (see page #1)
C.9-1	14.1	17" floor slab	OK (see page #2)
C.9-3	28.8		
D-2	62.9		
D.1-1	19.0		
D.1-3	19.9		
E-1	14.2		
E-2	34.1		
E-3	14.4		
F-3.1	12.0	6" floor slab	OK (see page #1)
F-4	24.2	24" x 36" cont. ftg.	OK (see page #3)
F-6	24.2		
F-7	12.1	6" floor slab	OK (see page #1)




COLUMNS ON 6" SLABS

Max. Cal. Load. Is at B.S. - 17.6 Kips.

6" SLAB, 4,000 PSI CONC. w/ #4 @ 12 IN. CTR.

ALLOWABLE M PER FT. OF SLAB

$$As fcsd = .20 \times 14,000 \times .85 \times 3 = 12,240 \text{ " LBS.}$$



CHECK OF 2 WAY (PUNCHING) SHEAR

$$4 \times 16" \times 6" \times 1.1 \sqrt{4000} = 26.7 \text{ K.} > 17.6 \text{ K. O.K.}$$

REQUIRED MOMENT PER FT. OF SLAB

$$\frac{2500 \times 11.5}{12} \times 11.5 = 6,888 \text{ " LBS.} < 12,240 \text{ " LBS. O.K.}$$

COLUMNS ON 17" SLABS W/ #6 @ 12" E.W. T & B

Max. Col. Load Is At GRID D-2 = 62.9 KIPS.

ALLOWABLE MOMENT IN SLAB

$$.44 \times 24000 \times .12 = 126,720 \text{ LB.} = 10.56 \text{ K'}$$

ALLOWABLE SOIL BEG. = 2500 * SWA WT .180 = 2320

$$\frac{62.9}{2.32} = 27.11 \text{ sq ft reqd. area} = 5.3 \text{ SQUARES}$$

2 WAY (PUNCHING) SHEAR $4 \times 27 \times 17 \times 1.1 \sqrt{4000}$
 $= 127.7 \text{ K} > 62.9 \text{ K} \dots \text{OK.}$

REQD MOMENT IN GRID BEAN

$$\frac{2.25 \times 2.32}{4} = 1.31 \text{ K' } < 10.56 \text{ K'}$$

OK.

COLUMNS ON 24" x 36" GRADE BEAM

MAX COL LOAD IS AT COL C-4 - 28.1 KIPS.

GRADE BEAM HAS 2 #6 @ TOP, CTR. & BOT
(ACCORDING TO LAWSON FORTON)

ALLOWABLE MOMENT IN GRADE BEAM (FIGURING T & B REIN.)

As f'd = $188 \times 24000 \times 30 = 637,600$ "LB. OR 52.8 K'

ALLOWABLE SOIL BRG 2500 - GB. WEIGHT 360 = 2140




$\frac{28.1 \text{ K}}{2140} \times 6' - 8" \text{ LENGTH OF GRADE BEAM TO SUPPORT SOIL}$

2140 x 2

READ MOMENT IN GRADE BEAM

$\frac{21.8 \text{ K} \times 6.67}{2} = 18.2 \text{ K} < 52.8 \text{ K} \quad \text{O.K.}$





Tank Leak Tests

HYDROSTATIC TEST RECORD

RECORD DATE: 8-8-95

VENDOR: SCOTT MANUFACTURING, INC.

CUSTOMER: USPCI-LONE MT. FACILITY

CUSTOMER: P.O. NO. 132

PROJECT: EVAPROATOR FLASH TANK NO. 3

W.O. NO.: 48709,10, & 11

LOCATION: WAYNOKA, OK.

JOB NO.: 499

TESTING PROCEDURE: WELDED STEEL TANKS FOR OIL STORAGE, API STANDARD 650, NINTH EDITION, JULY 1993, SECTION 5 - ERECTION, PARAGRAPH 5.3.6 TESTING OF THE SHELL, METHOD a.(1).

RESULTS: PRIOR TO SANDBLASTING AND PAINTING, EVAPORATOR FLASH TANK NO. 3 WAS FILLED WITH WATER UP TO THE SHELL AND FLUE CONNECTION. THE TANK WAS INSPECTED FREQUENTLY DURING THE FILLING OPERATION. WATER WAS HELD IN THE TANK FOR A PERIOD OF TWENTY FOUR HOURS. AFTER CAREFUL VISUAL INSPECTION NO LEAKS WERE VISIBLE IN ANY WELDED SHELL OR PIPE JOINTS.

REPORT NO 1

VENDOR INSPECTOR'S SIGNATURE



Hydrostatic Test Record

Customer: USPCI - Lone Mt. Facility
Project: Evaporation Flash Tank No.3
Location: Waynoka, OK

Test Start Date: 8/13/96 Test Start Time: 4:55 p.m.
Test Finish Date: 8/14/96 Test Finish Time: 8:30 a.m.

Test Procedure:

Fill evaporator feed tank to the manway with water.

Results:

There was no change in water level inside the feed tank. Visual inspection of tank indicated no water leaks.



Signature Geoffrey E. Brueggemann
Geoffrey E. Brueggemann, P.E.
Envirotech Services, Inc.

Date: 8/20/96

Piping Leak Tests

Piping Pressure Test

Customer: USPCI - Lone Mt. Facility

Project: Discharge piping from Filter Press Pump P83 to Filter Press 3.

Location: Waynoke, OK

Test Start Date 5/2/95 Test Start Time 1:20 p.m.

Test Finish Date 5/2/95 Test Finish Time 3:20 p.m.

Test Procedure:

Fill piping section between filter press pump P83 discharge to inlet of filter press FP3.
Apply water pressure to system up to 150 psig by hydro pump and hold this pressure for
minimum 2 hours.

Results:

Piping section was isolated from P83 by flange and FP3 by valve. System was pressured
up to 150 psig and held this pressure for 2 hours. No change in pressure gauge reading
was observed.

Witness

Ray [Signature]

Date: 5/2/95

Hydrostatic Test Record

Customer: USPCI - Lone Mt. Facility

Project: Suction pipe from Evaporator Flash Tank No. 3 to Pump P-5.

Location: Waynoka, OK

Test Start Date: 8/13/96 Test Start Time: 4:55 p.m.


Test Finish Date: 8/14/96 Test Finish Time: 8:30 a.m.

Test Procedure:

Prior to hydrostatic test on FT3, open bottom valve and flood suction piping to Pump P-5.

Results:

There was no change in water level inside the flash tank. Visual inspection of the suction piping between FT3 and Pump P-5 indicated no water leaks.



Signature Geoffrey E. Brueggemann
Geoffrey E. Brueggemann, P.E.
Envirotech Services, Inc.

Date: 8/20/96

Piping Pressure Test

Customer: USPCI - Lone Mt. Facility

Project: Discharge piping from Filter Press FP3 to suction side of Evaporation Feed Pump P-5.

Location: Waynoka, OK

Test Start Date: 8/13/96 Test Start Time: 11:15 a.m.

Test Finish Date: 8/13/96 Test Finish Time: 1:15 p.m.

Test Procedure:

Fill piping section between Filter Press FP3 discharge to suction side of Pump P-5. Apply water pressure to system up to 155 psig by hydro pump and hold this pressure for minimum 2 hours.

Results:

Piping section was isolated from Filter Press FP3 by flange and P-5 by valve. System was pressured up to 155 psig and held this pressure for 2 hours. No change in pressure gauge reading was observed.



Signature

Geoffrey E. Brueggemann
Geoffrey E. Brueggemann, P.E.
Envirotech Services, Inc.

Date: 8/20/96

Piping Pressure Test

Customer: USPCI - Lone Mt. Facility

Project: Discharge piping from Evaporation Feed Pump P-5 to suction side of Evaporation Heat Exchanger EU3.

Location: Waynoka, OK

Test Start Date: 8/14/96 Test Start Time: 9:20 a.m.

Test Finish Date: 8/14/96 Test Finish Time: 11:20 a.m.

Test Procedure:

Fill piping section between Pump P-5 discharge to suction side of EU3. Apply water pressure to system up to 235 psig by hydro pump and hold this pressure for minimum 2 hours.

Results:

Piping section was isolated from Pump P-5 by flange and EU3 by valve. System was pressured up to 235 psig and held this pressure for 2 hours. No change in pressure gauge reading was observed.



Signature Geoffrey E. Brueggemann
Geoffrey E. Brueggemann, P.E.
Envirotech Services, Inc.

Date: 8/20/96

Piping Pressure Test

Customer: USPCI - Lone Mt. Facility

Project: Discharge piping from Evaporator Heat Exchanger EU3 to suction side of Flash Tank FT3.

Location: Waynoka, OK

Test Start Date: 8/14/96 Test Start Time: 8:30 a.m.

Test Finish Date: 8/14/96 Test Finish Time: 10:30 a.m.

Test Procedure:

Fill piping section between EU3 discharge to suction side of FT3. Apply water pressure to system up to 225 psig by hydro pump and hold this pressure for minimum 2 hours.

Results:

Piping section was isolated from EU3 by flange and FT3 by valve. System was pressured up to 225 psig and held this pressure for 2 hours. No change in pressure gauge reading was observed.



Signature Geoffrey E. Brueggemann
Geoffrey E. Brueggemann, P.E.
Envirotech Services, Inc.

Date: 8/20/96

Piping Pressure Test

Customer: USPCI - Lone Mt. Facility

Project: Suction piping of Evaporator Flash Tank FT3 to suction side of Filter Press Pump P83.

Location: Waynoka, OK

Test Start Date: 8/29/96 Test Start Time: 8:30 a.m.

Test Finish Date: 8/29/96 Test Finish Time: 10:30 a.m.

Test Procedure:

Fill piping section between discharge side of FT3 and Pump P83. Apply water pressure to system of 50 psig by hydro pump and hold this pressure for minimum 2 hours.

Results:

Piping section was isolated from FT3 by valve and P83 by flange. System was pressured up to 50 psig and held this pressure for 2 hours. Visual inspection of all piping indicated no leaks.



Signature Geoffrey E. Brueggemann
Geoffrey E. Brueggemann, P.E.
Envirotech Services, Inc.

Date: Aug. 29, 1996



Tank Metallurgy



SML JOB INSPECTION FORM

W/O #: 48710 DATE: 8-8-95 INSPECTED BY: M. JORDANCUSTOMER: USPCI EVAPORATOR FLASH TANK NO.3
LONE MOUNTAIN FACILITY
WAYNOKA, OKLAHOMAINSPECTION CRITERIA PER: CUSTOMER: SMI: ☒INSPECTION: TANK AND PERTINENT PARTS TYPE INSPECTION: VISUAL, DIMENSIONAL, X-RAYDRAWING #: 499-1 THRU 10 LOCATION: IN SHOP AND PAINT AREABRIEF DESCRIPTION OF INSPECTION: ALL WELDS, DIMENSIONS AND ORIENTATIONS
CHECKED. 8-8-95 TANK WAS RAISED UPRIGHT AND HYDRO
TESTED. NO LEAKS FOUND. SEE X-RAY LOCATION MAP:
THREE SPOTS SHOT.PAINT: 11 MILS (TOTAL) INSIDE4 MILS (TOTAL) OUTSIDE

INSULATION, CLADDING, ASSEMBLY PER SPECIFICATIONS.

WASHERS WERE USED (BOTH SIDES) ON CONE BOLT UP.

MINOR PAINT TOUCH-UP WAS NEEDED (AFTER LOADED FOR SHIPPING)

WAS NOT DONE BECAUSE PAINTER DID NOT HAVE LEFT-OVER PAINT.

INSPECTION RESULTS:

CONFORMING: ☒

NON CONFORMING: _____

IF NON CONFORMING - CORRECTIONS IMPLEMENTED: _____

CORRECTIONS APPROVED

YES _____

NO _____

COPIES TO:

DATE:

BILL BASOM8-22-95

NAME

DATE:

M. Jordan
8-22-95

LUBBOCK LABS, INC.

SCOTT MANUFACTURING, INC.
P.O. BOX 10232
LUBBOCK, TEXAS 79408

DATE: 6-9-90

PHONE (806) 747-3393
210 PARIS
LUBBOCK, TEXAS 79401

WELDER AND WELDING OPERATOR QUALIFICATION TEST RECORD

Welder or welding operator's name BILL FISHER SS# 457-82-4797
Welding process GMAW Manual YES Semiautomatic --- Machine ---
Position 6 GR - T, K, Y CONNECTIONS UPHILL
(Flat, horizontal, overhead or vertical) — If vertical, state whether upward or downward)
In accordance with procedure specification no. SNI - 022
Material specification ASTM A 53 GRADE B
Diameter and wall thickness (if pipe) — otherwise, joint thickness
Thickness range this qualifies 2T = 1.012"

FILLER METAL

Specification no. SFA 5.20 Classification AWS E 71T-1 F no. ---
Describe filler metal (if not covered by AWS specification)

Is backing strip used? NO
Filler metal diameter and trade name 0.045" Flux for submerged arc or gas for gas metal arc or flux
FRONT 1 ARC cored arc welding CO² - 100%

VISUAL INSPECTION (9.25.1)

Appearance GOOD Undercut NONE Piping porosity NONE

Guided Bend Test Results N/A - SEE, AWS D1.1-90 5.3.2

Type	Result	Type	Result

Test conducted by Laboratory test no.
per Test date

Fillet Test Results N/A

Appearance Fillet size
Fracture test root penetration Maroonch
(Describe the location, nature, and size of any crack or tearing of the specimen.)
Test conducted by Laboratory test no.
per Test date

RADIOGRAPHIC TEST RESULTS

Film Identification	Results	Remarks	Film Identification	Results	Remarks
#8 BILL FISHER					
0-1	PASS		2-0	PASS	
1-2	PASS		PERMAN N.D.T. #5945		

Test witnessed by RON WIMBERLEY Test no. 06990-7
per Ron Wimberley

We, the undersigned, certify that the statements in this record are correct and that the welds were prepared and tested in accordance with the requirements of 5C or D of AWS D1.1, (1990) Structural Welding Code, year

Manufacturer or contractor SCOTT MFG. INC.
Authorized by RICK SCOTT

Date 6-9-90

Form E-4

ANSI/AWS D1.1-86

LUBBOCK LABS, INC.

SCOTT MANUFACTURING, INC.

Customer: P.O. BOX 10232
LUBBOCK, TEXAS 79408

PHONE (806) 747-3393
210 PARIS
LUBBOCK, TEXAS 79401

Date 10-16-93

Report of: WELDER AND WELDING OPERATOR QUALIFICATION TEST RECORD
Social Security no. 461-78-1423

Welder or welding operator's name WYNN CADEL Identification no. 275

Welding process ECAW Manual ***** Semiautomatic Machine

Position 3G VERTICAL : ALSO QUALIFIES FOR 1G FLAT, & 2G HORIZONTAL DOWNWARD

(Flat, horizontal, overhead or vertical — If vertical, state whether upward or downward)

In accordance with procedure specification no. S.M.I. CORTEN

Material specification ASTM A 242

Diameter and wall thickness (If pipe) — otherwise, joint thickness 0.375"
Thickness range this qualifies 0.125" to 0.75" ALSO QUALIFIES FILLET WELDS OF UNLIMITED

FILLER METAL

Specification no. AWS 5.29 Classification E 80T1-W F no.

Describe filler metal (If not covered by AWS specification)

Is backing strip used? YES

Filler metal diameter and trade name 0.045" Flux for submerged arc or gas for gas metal arc or flux
ALLOY RODS--DUAL SHIELD cored arc welding

VISUAL INSPECTION (9.25.1)

Appearance GOOD Undercut NONE Piping porosity NONE

Guided Bent Test Results

Type	Result	Type	Result
FACE 1	ACCEPTED		
ROOT 1	ACCEPTED		

Test conducted by RON WIMBERLEY Laboratory test no. 0101693-A
per Ron Wimberley Test date 10-16-93

N/A

Fillet Test Results

Appearance Fillet size

Fracture test root penetration Maroonch

(Describe the location, nature, and size of any crack or tearing of the specimen.)

Test conducted by Laboratory test no.

per Test date

N/A

RADIOGRAPHIC TEST RESULTS

Film Identification	Results	Remarks	Film Identification	Results	Remarks

Test witnessed by Test no.
per

We, the undersigned, certify that the statements in this record are correct and that the welds were prepared and tested in accordance with the requirements of 5C or D of AWS D1.1, (1992) Structural Welding Code.
year

Manufacturer or contractor SCOTT MANUFACTURING, INC.

Authorized by

Date 10-16-93

LUBBOCK LABS, INC.

Customer: SCOTT MANUFACTURING, INC.
P.O. BOX 10232
LUBBOCK, TEXAS 79408

PHONE (806) 747-3393
210 PARIS
LUBBOCK, TEXAS 79401

Date 6-9-90

Report of: WELDING PROCEDURE QUALIFICATION TEST RECORD

PROCEDURE SPECIFICATION
Material specification ASTM A-53, GRADE B, 8" Dia. Pipe
Welding process GMAW
Manual or machine MANUAL
Position of welding 6GR-T, K, Y CONNECTIONS
Filler metal specification SFA 5.20
Filler metal classification AWS E 71T-1
Weld metal grade ASTM A 53, GRADE B
Shielding gas CO₂ Flow rate 35-40 CFH
Single or multiple pass MULTIPLE
Single or multiple arc SINGLE
Welding current DIRECT/REVERSE
Welding progression UP HILL
Preheat temperature N/A
Postheat treatment N/A
Welder's name BILL FISHER
SS/457-82-4797
*Applicable when filler metal has no
AWS classification.

VISUAL INSPECTION (9.25.1)

Appearance GOOD
Undercut NONE
Piping porosity NONE

Test date 6-9-90
Witnessed by RON WIMBERLEY

GROOVE WELD TEST RESULTS

Tensile strength, psi
1. 92,800 - SWL FILE #2839901
2. 84,200 - SWL FILE #2839901

Guided-bend tests (2 root-, 2 face-, or 4 side-bend)

SIDE SIDE
S 1. SATISFACTORY 1. SATISFACTORY
S 2. SATISFACTORY 2. SATISFACTORY

Radiographic-ultrasonic examination

RT report no. PASS-PERMIAN N.D.T. #5945
UT report no. N/A

FILLET WELD TEST RESULTS N/A

Minimum size multiple pass Maximum size single pass
Macroetch Macroetch

1. _____ 3. _____ 1. _____ 3. _____
2. _____ 2. _____

All-weld-metal tension test

Tensile strength, psi _____
Yield point/strength, psi _____
Elongation in 2 in., % _____
Laboratory test no. 06990-7A

WELDING PROCEDURE

Pass no.	Electrode size	Welding current		Speed of travel
		Amperes	Volts	
1-6	0.045"	220	26	12-14

We, the undersigned, certify that the statements in this record are correct and that the test welds were prepared, welded, and tested in accordance with the requirements of SB of AWS D1.1, (1990) Structural Welding Code.

Procedure no. SMI-022 Manufacturer or contractor SCOTT MFG. INC.

Revision no. 6-09-90 Authorized by RICK SCOTT

Form E-2

Date 6-9-90

SCOTT MANUFACTURING INC.

Procedure Qualification Test Record (PQR)

<p>Variables</p> <p>Base metal <u>ASTM 500, GR:B / ASTM 500 GR:B</u></p> <p>Metal thickness <u>.188 / .188</u></p> <p>Conting <u>NONE</u></p> <p>Joint preparation <u>GRIND</u></p> <p>Dacking <u>SEE - JOINT DETAIL</u></p> <p>Position of welding <u>PLAT AND HORZ. (1F & 2F)</u></p> <p>Welding process <u>FLUX-CORED (FCAW)</u></p> <p>Manual, semiautomatic, or automatic <u>SEMI-AUTOMATIC</u></p> <p>*Filler metal spec. <u>ANS 5.20</u></p> <p>*Filler metal class <u>SFA 5.20 (E70T-1)</u></p> <p>*Weld metal grade <u>MILD STEEL (A-1)</u></p> <p>Electrical characteristics <u>D.C.R.P</u></p> <p>Mode of transfer <u>SPRAY</u></p> <p>Shielding gas/combination <u>75% Ar + 25% Co2</u></p> <p>Gas flow (CFH) <u>25 CFH</u></p> <p>Welder's name <u>C. CADDEL</u></p> <p>Welder's ID no. <u>275</u></p>	<p>PQR Number <u>#015</u></p> <p>WPS Number <u>#015A AND #015B</u></p> <p>Weld in butt joint visual exam results (see 3.4.1 or 8.4.1)</p> <table border="1"> <thead> <tr> <th></th> <th>A</th> <th>B</th> </tr> </thead> <tbody> <tr> <td>Fusion</td> <td>Accept</td> <td>Accept</td> </tr> <tr> <td>Penetration</td> <td>Accept</td> <td>Accept</td> </tr> <tr> <td>Reinforcement</td> <td>Accept</td> <td>Accept</td> </tr> <tr> <td>Porosity</td> <td>Accept</td> <td>Accept</td> </tr> <tr> <td>Undercut</td> <td>Accept</td> <td>Accept</td> </tr> <tr> <td>Cracks</td> <td>Accept</td> <td>Accept</td> </tr> </tbody> </table> <p>Fillet weld visual exam results (see 3.4.2 or 8.4.2)</p> <table border="1"> <tbody> <tr> <td>Fusion</td> <td>Accept</td> </tr> <tr> <td>Effective throat</td> <td>Accept</td> </tr> <tr> <td>Convexity</td> <td>Accept</td> </tr> <tr> <td>Porosity</td> <td>Accept</td> </tr> <tr> <td>Undercut</td> <td>Accept</td> </tr> <tr> <td>Cracks</td> <td>Accept</td> </tr> </tbody> </table>		A	B	Fusion	Accept	Accept	Penetration	Accept	Accept	Reinforcement	Accept	Accept	Porosity	Accept	Accept	Undercut	Accept	Accept	Cracks	Accept	Accept	Fusion	Accept	Effective throat	Accept	Convexity	Accept	Porosity	Accept	Undercut	Accept	Cracks	Accept
	A	B																																
Fusion	Accept	Accept																																
Penetration	Accept	Accept																																
Reinforcement	Accept	Accept																																
Porosity	Accept	Accept																																
Undercut	Accept	Accept																																
Cracks	Accept	Accept																																
Fusion	Accept																																	
Effective throat	Accept																																	
Convexity	Accept																																	
Porosity	Accept																																	
Undercut	Accept																																	
Cracks	Accept																																	

*See Definitions

Joining Procedure

Filler Metal Size	Welding Power		Speed of Travel	Joint Detail
	Current Range	Voltage Range		
FLUX-CORED .045	150 (I)	25 (V)	244 IPM (WIRE)	
NOTES:	1) FLARE-VEE WELDS-ONE PASS 2) FLARE-BEVEL WELDS-THREE PASSES.			


We, the undersigned, certify that the statements in this record are correct and that the test specimens were prepared, joined, and examined in accordance with the requirements of ANSI/AWS D9.1, Sheet Metal Welding Code, PER MIL STD 1261-C

Manufacturer or Contractor SCOTT MANUFACTURING INC.

Authorized by File Permitt
Date 7/26/94

WIR NO.	QUALITY DEPARTMENT-WELDING INSPECTION RECORD (WIR).			
NA				
PRINT *	PART NAME: WELDER'S QUALIFICATION TEST SPECIMEN I.D. # 275		weld description: <i>PER 015</i> WELDER'S QUALIFICATION	
NA	WELDER:	work station:	date	welding code
<i>WPS-015A</i> <i>WPS* PER QAP-1</i> <i>WPS015B</i>	C. Caddel	W.O.*	7-20-94	MIL-STD-1261C

WELDING CHARACTERISTICS

CHARACTERISTIC	ACCEPT	REJECT	DISCREPANCIES	NO OF WELDS INSPECT NO ACCEPT/REJT
POROSITY	X			
OVERLAP	X			
UNDERCUT	X			
USION	X			
SLAG INCLUS'S	NA			
	X			
<input checked="" type="checkbox"/> ACCEPTED	<input type="checkbox"/> REJECTED	<input type="checkbox"/> HOLD	<input type="checkbox"/> OTHER	INSPECTED BY/DATE <i>Plumsted 7/20/94</i>

VISUAL INSPECTION CRITERIA

FOR PRODUCTION WELDS: QAM 14.3.4

☐ reinspected ☐ accepted ☐ rejected

COMMENTS/
OBSERVATIONS: *FCAW MILDSTEEL*
FLAT & HORIZONTAL (1F & 2F)

REINSPECTED BY:

DATE:

PURCHASE ORDER # 37625

KOCHJOB NO.: 46794 <<<
Rep:KOCH ENGINEERING COMPANY INC
DIVMET® DIVISION

*** PACKING LIST ***

old To:
SCOTT MANUFACTURING INC
PO BOX 10232
JBBOCK
ACCOUNTS PAYABLE

TX 79408

Ship To:
SCOTT MANUFACTURING INC
FM 1585, 3/4 MILE EAST
HWY 62/82, WOLFORTH TX 79382

Date: 06/28/95

Customer Order No.: 37625

Scheduled Ship-Date: 7-21-94

Terms: NET 30


Ship Via: CENTRAL
Remarks:<<<< Collect
XXX <<<< Prepaid & Add
<<<< Freight Allowed

F.O.B. HOUSTON

	Item 1	Item 2	Item 3	Item 4	Item 5
QUANTITY	2				
DIAMETER	75.25				
SH THICKNESS	6.00				
SH MATERIAL	304				
SH STYLE	4310				
ID MATERIAL	304				
TOP & BOTTOM GRIDS	TB-S				
WAY SIZE					
CTIONS	6				
PK NUMBER					

of Crate(s):
e of Crate(s):
ss Wt. of Crate(s):

W.O.# JT-48709



T48709
37626

FORT WORTH F&D HEAD COMPANY
P. O. BOX 16477 — FORT WORTH, TEXAS 76162-0477

MILL TEST REPORT

CUSTOMER Scott Manufacturing, Inc.		CUSTOMER ORDER NO. PO# 37626		DATE 07-05-95					
CODE	QTY.	SIZE-OD	THK.	PLATE MFG.	HEAT NO.	SLAB NO.	MAT'L	HOT FORMED	COLD FORMED
JRG	1	75 1/4"OD. x Flanged & Dished Head 69 1/4"DR., 4 3/4"ICR., 2"SF.	3/8"NOM.	Geneva Steel	1A1009	.26-01	SA-516-70		X

FORT WORTH F & D HEAD COMPANY CERTIFIES THAT HEADS MANUFACTURED FROM MATERIAL REPRESENTED BY THIS REPORT COMPLY WITH ASME CODE SECTION II & SECTION VIII, DIVISION I. ALL HEADS COMPLY WITH UCS-79(d) & UG-81(a). NO SUBSEQUENT HEAT TREATMENT WAS PERFORMED.

WE CERTIFY THAT THIS IS A TRUE COPY OF THE ORIGINAL METALLURGICAL TEST CERTIFICATE NOW IN OUR FILES.

[Signature]
FORT WORTH F & D HEAD COMPANY



PG-21645



PG-4645

THIS IS TO CERTIFY THAT THE PRODUCT DESCRIBED HEREIN WAS MANUFACTURED, SAMPLED, TESTED AND/OR INSPECTED IN ACCORDANCE WITH THE SPECIFICATION AND FULFILLS REQUIREMENTS IN SUCH RESPECTS.

Edward J. Br. May
CORPORATE DIRECTOR, QUALITY
DATE 04-22-95


DATE 08-22-95

88057

01 MILL CERTIFIED T/R

PLATE
ASTM A516-90 GRADE 70 AND ASME SA516 1992 EDITION
1993 ADDENDA GRADE 70 PRESSURE VESSEL QUALITY WAVE DIE STAMP -
STENCIL ONLY

ITEM NO.	MATERIAL DESCRIPTION	QUANTITY	WEIGHT	HEAT NO.	TEST OR PECE IDENT	YIELD ST.	TENSILE ST.	ELONGATION %		% RED. OF AREA	REMARKS
								IN 2"	IN 4"		
03	STEEL 3750 84,0000 480,0000 JWG	5	21440#	1A1009	26-01 26-01 26-01 ***END OF DATA***	54.5 45.6 44.4	79.2 73.5 73.4	22.0 22.0 24.0			
<p>YIELD STRENGTH-TOTAL EXTENSION UNDER LOAD 0.5X</p> <p>HEAT NO. 1A1009 HEAT 25 130 007 007 39 01 01 02 004 3040 025 004 FINE GRAIN</p> <p>GENEVA STEEL COMPANY CERTIFIED ALL SMELTING, MELTING AND MANUFACTURING PROCESSES OCCURRED IN THE USA.</p> <p>***END OF DATA***</p> <p>5-25-65</p>											



№ 21 95 05:35PM RUSSIA METAL-STEEL TA 82-12-9

Экспорт Export

2251

1003003

Продавец (Экспортер)
Seller (Exporter)

AO

NLHK

398040 LIPETSK

PL. METALLURGOV, 2

Грузополучатель, адрес, страна:
Customer, Address, Country:

INTERNETAL GROUP LTD

Lot 1
Houston

export in USA

Железнодорожная накладная №
Railway Bill No

Вагон №
Freight Car No

42534081

ТОВАРОСОПРОВОДИТЕЛЬНЫЙ ДОКУМЕНТ №
Shipping document No
(СЕРТИФИКАТ КАЧЕСТВА)
Quality certificate
(ОТКРУЗОЧНАЯ СПЕЦИФИКАЦИЯ)
Shipping specification

94748

Контракт №
Contract No

98-29/92-4-157-32

от
from

Заказ-наряд №
Order-Naryad No

98-29/92-4-157-32

от
from

Разрешение на вывоз №
Export licence No

000 Лист № 1
Sheet No 1

Листов: 1
Sheets: 1

Заказ №
Order No

341381

94

Наименование и код товара
Description and code of goods

720822990

НТД (NTD)

Вид груза,
место, код

Количество
товара
Quantity

Hot-rolled carbon steel strip in coils

ASTM A-36

ГОСТ-ГОСТ
ТУ-ТУ

3

№ п.п. Item No	№ поз. Pos. No	Номера плавов Nos. of Heats	Группа (класс) прочности Group (class) of strength	Марка стали Grade of Steel	Размеры, мм Dimension, mm			Ед. изм. Инд. Unit Code	Номера мест Package Nos.	Масса (тн) Mass (tons)	
					толщина thickness	ширина width	длина length			брутто gross	нетто net
1	8	2412710			9.14	1524			657	14.91	14.90
2	8	2412710			9.14	1524		шт.	658	15.01	15.00
3	8	2412710			9.14	1524		Руп	659	14.81	14.80
										44.73	44.70

Химический состав, %
Chemical composition, %

Quality Characteristic of Goods
Composition, %

№ п.п. Item No	№ поз. Pos. No	Номера плавов Nos. of Heats	C x100	Mn x100	Si x100	P x1000	S x1000	Cr x100	Ni x100	Cu x100	Al x100
1	8	2412710	17	46	22	15	18	3	3	2	4.4

Механические свойства
Mechanical Properties

Технологические пробы
Technological tests

Твердость
Hardness

№ п.п. Item No	№ поз. Pos. No	Номера плавов Nos. of Lots	Предел прочности Ultimate strength	Предел текучести Yield limit	Удлинение Elongation	Ударная вязкость Impact viscosity	Холодная загиб Cold bend tests	Ударная вязкость после механического старения Impact toughness after Mechanical aging	Характер кромки Brim
----------------------	----------------------	----------------------------------	---	---------------------------------------	-------------------------	--	---	---	----------------------------

1 8 29759 488.0 353.0 40.0



ИНДЕКСНАЯ ТАМОЖЕНА

ГН
РОССИИ
022

ВЫПУСК РАЗРЕШ
Инспектор

Замечания:
Note: 760-800-смотки:570-610

Маркировка (marking)

Указанный в настоящем сертификате товар соответствует по качеству действующим в России стандартам, техническим условиям и может быть отгружен на экспорт.

It is hereby certified that the quality of goods mentioned in this certificate is in conformity with the Russia standards, specification and the goods may be exported.

Подпись
Signature
ОКД
М.П. 12/12/94
the representative of the shop
19 г.

STEEL AUTHORITY OF INDIA LTD

BHILAI STEEL PLANT

BHILAI, INDIA

No 5-47-0

MILL TEST CERTIFICATE

CERTIFICATE NO. JVTIC00269

DATE : 09-03-1993

1. BUYER'S NAME AND ADDRESS	METALL UND ADSTOFF A.G. BAHNHOFSTRASSE 10 CH-6300 ILS, SWITZERLAND	4. QUALITY	ASTM A-36
2. MATERIAL	PRIME HOT ROLLED, MILD STEEL PLATES	5. TOLERANCES	ASTM A-6 WITH S-14 END TEST
3. PROCESS OF MANUFACTURE OF STEEL	BASIC OXYGEN CONVERTER CONTINUOUS CAST KILLED STEEL	6. BILL OF LADING NUMBER	JVTIC00269 DATED 09-03-1993
		7. NAME OF VESSEL	N.V. STATE OF GUJARAT
		8. LOADING PORT	VISAKHAPATNAM/INDIA
		9. DISCHARGE PORT	HOUSTON PIER/U.S.A.

ITEM NUMBER

DIENSION IN INCHES : 3/8 X 96 X 240

LOT 303

N AND R REFERENCE NO. : 2.1225

THEORETICAL WEIGHT
PER PIECE IN KGS. : 1111

TEST RESULTS

HEAT NUMBER	NUMBER OF PIECES	CHEMICAL ANALYSIS (AS PER LADLE SAMPLE ANALYSIS)						MECHANICAL PROPERTIES			
		C	S	P	Mn	Si		YIELD POINT	TENSILE STRENGTH	% ELONGATION ON GL = 200 cm	END TEST
		X	X	X	X	X	IN N/sq.cm	IN N/sq.cm			1/2 T
73000	42	0.12	0.024	0.018	0.60	0.18	309 277	432 426	27 28		OK OK
73008	28	0.11	0.023	0.019	0.87	0.21	335 331	460 452	26 24		OK OK
73011	59	0.09	0.023	0.013	0.81	0.20	309 315	411 428	24 27		OK OK
73034	58	0.11	0.026	0.014	0.81	0.14	323 329	444 458	23 24		OK OK

STEEL AUTHORITY OF INDIA LIMITED

TEST RESULTS

HEAT NUMBER	NUMBER OF PIECES	CHEMICAL ANALYSIS (AS PER CADLE SAMPLE ANALYSIS)					MECHANICAL PROPERTIES			
		C	S	P	Mn	Si	YIELD POINT	TENSILE STRENGTH	% ELONGATION ON	BEND TEST
		%	%	%	%	%	IN N/sq.cm	IN N/sq.cm	BL. = 200 cm	1/2 T
73075	59	0.10	0.024	0.015	0.80	0.21	303 324	424 454	25 24	OK OK
73078	43	0.11	0.021	0.011	0.84	0.22	314 335	437 456	26 25	OK OK
73244	50	0.11	0.020	0.017	0.85	0.23	324 354	434 473	24 24	OK OK
73284	39	0.10	0.023	0.021	0.86	0.21	325 327	439 426	25 25	OK OK
73472	6	0.10	0.021	0.017	0.86	0.20	316 331	448 471	24 24	OK OK
73474	52	0.09	0.021	0.014	0.80	0.21	332 335	447 449	26 27	OK OK
73475	57	0.08	0.019	0.012	0.84	0.22	336 359	454 469	30 27	OK OK
73477	1	0.11	0.024	0.016	0.90	0.22	326 335	441 459	24 28	OK OK
73481	6	0.09	0.018	0.011	0.80	0.22	342 336	452 456	23 26	OK OK
73468	1	0.10	0.019	0.019	0.88	0.18	355 340	472 460	27 25	OK OK

NUMBER OF PIECES

301

TOTAL WEIGHT (METRIC TON)

556.611

CERTIFIED THAT THE MATERIAL IS IN ACCORDANCE WITH
ASTM A-36, 1989 EDITION AND ROLLING TOLERANCE ON
THICKNESS, WIDTH, LENGTH AND FLATNESS ACCORDING TO
ASTM A-6 MATERIAL HAVE SHEARED EDGES ON ALL FOUR SIDES.

FOR CHIEF METALLURGIST

Bhilai Steel Plant

"STEEL AUTHORITY OF INDIA LIMITED"

Date: 10.31 1985

COMMERCIAL BOND

7030

FILE COPY


PRODUCER: DONETSK IRON AND STEEL WORKS														TO WHOM IT MAY CONCERN	
MATERIAL: PRIME QUALITY, NEWLY PRODUCED, HOT ROLLED STEEL PLATES TO A 36.															
SIZE: 1/4 x 60 x 240														THEORETICAL WEIGHT: 0.463 MT	
No.	Heat number	C x100	Mn x100	Si x100	S x1000	P x1000	Cr x100	Ni x100	Cu x100	Tensile MPA	Yield MPA	Elongation % 50 / 250 mm	No of pieces	No of bundles	
1	8304 - 356	15	57	26	36	28	14	7	6	465 470 470 470	325 305 330 320	34 22 22,5 34	3	1	
2	8305 - 353	18	55	28	27	21	11	7	12	490 500 500 500	315 320 330 320	32 27 26 32	51	6	
3	8329 - 455	15	55	26	39	20	13	8	8	445 450 450 455	305 305 315 305	34 28 27 33	45	5	
4	8342 - 452	17	46	18	35	14	16	11	8	450 450 445 460	285 300 285 295	30 27 34 26	41	5	
5	8343 - 471	16	46	21	46	14	16	9	9	440 440 430 440	280 300 285 290	34 29 29,5 35	24	3	
6	7379 - 541	19	54	29	30	29	15	6	7	485 480 475 485	315 320 315 320	32 25,5 26,5 34	47	6	
7	7380 - 539	19	54	22	28	27	20	6	6	485 495 490 490	315 330 315 320	26 30 29 34	35	4	
8	3010 - 538	20	72	28	30	26	14	6	12	480 475 475 480	315 305 315 320	33 28 27 30	11	2	


FILE COPY

18	7341-467	23	62	25	27	19	7	6	520	335	34	48	6
19	7333-462	15	49	22	30	15	10	11	440	290	26.5	49	6
20	7343-451	14	58	25	38	25	13	9	465	300	34	57	7
21	7342-450	13	47	20	35	17	10	8	440	305	34	63	7
22	7339-468	16	54	20	33	18	15	70	460	310	27	39	5
23	8330-456	17	49	19	34	16	14	8	450	295	27	36	4
24	7384-544	18	57	29	30	20	11	10	490	320	36	45	5
25	7351-536	19	59	22	38	24	21	9	465	315	29	47	6
26	7363-537	17	57	21	43	24	13	9	475	320	34	9	1

FILE COPY

28	7383-543	18	62	25	28	19	11	7	8	445	295	30			6
										475	320	30			
										465	315	29			
										500	325	32	47		
										455	300	26			
										450	295	26			
										510	335	30			
29	7386-547	18	59	23	32	19	14	8	8	490	325	28	36		4
										490	320	23			
										490	340	23			
										500	335	26			
30	8368-548	15	49	18	35	14	12	6	8	465	310	32	53		6
										485	315	26			
										500	320	25			
										485	310	26			





YES ☒ NO ☐

6070

TT 48710

37693



ACEROS CORSA, S.A. DE C.V.

Apartado Postal 75-269 54180 México, D.F.

Tels.: 586-16-00 y 586-87-22

Telex 01776550 COSAME FAX 586-81-38

P.O.# 1-39970

Date: 25/01/95

P.O. R.C. GONX, 310789

COMMERCIAL METALS CO.

P.O. BOX 1046

DALLAS, TX. 75221-1046

Shipped to: A. MEJIA Y GOMEZ SARUDD, S.

Y/O ALFREDO RAMIREZ.

NUEVO LAREDO, LAREDO.

MILL TEST REPORT

ASTM A36

TESTED ASTM A6

Chemical

Mechanical Properties

Item	Size Material	Kgs.	No. of Lifts	No. of Pieces	Total Pes.	Heat No.	C	Mn	Si	S	P	Tensile PSI	Yield PSI	Elong. % (8")
1	FB 2"X3/8"X20'	15.754	8	85	680	9850	0.17	0.72	0.20	.029	.022	66,600	49,300	20.50
2	FB 2 1/2"X3/8"X20'	16.683	8	72	576	9816	0.23	0.60	0.25	.027	.015	68,300	50,600	22.50
3	FB 3"X3/8"X20'	29.197	14	60	840	9876	0.16	0.68	0.24	.050	.024	75,000	55,600	24.40
4	FB 2 1/2"X1/2"X20'	16.066	8	52	416	9990	0.20	0.74	0.20	.031	.020	70,300	52,100	22.90
5														
6														
7														
8														
9														
10														
11														
12														
13														

MELTED AND MANUFACTURED IN MEXICO

A - Equals Legs Angles

FB - Flat Bars

R - Rounds

ACEROS CORSA, S.A. DE C.V.

JUL 10 1995 09:43

WE HEREBY CERTIFY THAT THE FOLLOWING DATA
IS A TRUE COPY FROM TESTS PERFORMED IN OUR
LABORATORY.

CERTIFIED TEST REPORT

STRUCTURAL METALS, INC.
BOX 911, SEGUIN, TEXAS 78156-0911
210-372-8260

The following tests conform to the requirements
of the specifications listed.

QUALITY CONTROL MANAGER 2/21/95

S 170000
O INTSEL SOUTHWEST
L P O BOX 41041
D HOUSTON TX
77241

S 8000
H INTSEL SOUTHWEST
I MILL
P SEGUIN TX

SIN# 65140355
BOL NO 1589544244

HEAT NO	SECTION	O	SPECIFICATION	T #	YIELD PSI	TENSILE PSI	ELONG % IN	R.A. %	BEND TEST DIAM	DATE ROLLED	LB/FT
19359	20	20	ASTM A36-93a	1	50300	74000	32.0 B			010694	4.48
19359	40	40	ASTM A36-93a	1	50300	74000	32.0 B			010694	4.48
19809	40	40	ASTM A36-93a	1	54600	78400	31.0 B			020195	4.06

REMARKS: 100% MELTED AND MANUFACTURED IN THE USA AND FREE FROM MERCURY CONTAMINATION IN THE PROCESS

FOR ADDITIONAL COPIES
CALL ACCOUNTING
(210) 372-8225.



SCOTT Manufacturing, Inc.
Custom Metal Fabrication
P.O. Box 10232
Lubbock, Texas 79408-3232
(806) 747-3395
FAX (806) 866-4930

MAIL TO:
F.M. 1506, 3/4 Mile East of Hwy 62/82
Wolfforth, TX 79302

MAIL TO:
P.O. Box 10232
Lubbock, TX 79408-3232

SHIPPED TO

TO CITY

ADDRESS

PHONE

CONTACT

INSTRUCTIONS:

Send Invoice & Bill of Lading to
Scott Manufacturing, Inc.
P.O. Box 10232
Lubbock, TX 79408-3232

Date 7-5-95

QUANTITY	U/M	DESCRIPTION	PRICE PER U/M	TOTAL
1	✓	2" Sch 40 Pipe x 21' R/L A536RB	✓	
2		2 1/2" Sch 40 Pipe x 21' R/L A536RB	✓	
3		8" Sch 40 Pipe x 5' A536RB	✓	
4		4" Sch 80 Pipe x 2' A536RB	✓	
5	✓	3" Sch 80 Pipe x 6' A536RB	✓	
6		2" Sch 160 Pipe x 2 1/2' A536RB 1 1/2" x	✓	
7		10" Sch 40 Pipe x 2 1/2' A536RB	✓	
8				
9				
10				
11				
12				
13				
14				
15				
16				
17				

DELIVERY DATE

SHIP VIA

PREPAY & ADD ☐

PREPAID ☐

COD ☐

COLLECT ☐

White - Purchasing

TAX EXEMPT YES ☒ NO ☐

COST CODE

WORK ORDER #

PURCHASE ORDER #

6070

ST 48710

37748

Order No.: BYJ1623
Date: 1993-2-26
Customer: VAN LIEUEN PIPE AND TUBE CORP.
Product: SEAMLESS HOT FINISHED CARBON STEEL PIPE
Specification: API 5L GR.B
Standard: API 5L GR.B


検査証明書
INSPECTION CERTIFICATE

住友金属工業株式会社
SUMITOMO METAL INDUSTRIES, LTD.
WAKAYAMA STEEL WORKS (KANNAN)
250-100 Fushimi, Wakayama, Japan

品名 Item No.	規格 Spec.	寸法 Size	長さ Length	重量 Weight	検査項目 Inspection Item	機械的性質 Mechanical Properties		化学的性質 Chemical Properties		試験結果 Test Result	試験方法 Test Method	試験機 Test Machine	試験場所 Test Place	試験者 Tester	試験日 Test Date
						引張強さ Tensile Strength	降伏点 Yield Point	C	Mn						
MIN-MAX	2.375"	0.154"	20'	600	19920	420	60000	0.025	0.008	0.008	0.008	0.008	0.008	0.008	0.008
J311047	16 18 8022 7 1	16 18 8022 7 1	16 18 8022 7 1	16 18 8022 7 1	16 18 8022 7 1	16 18 8022 7 1	16 18 8022 7 1	16 18 8022 7 1	16 18 8022 7 1	16 18 8022 7 1	16 18 8022 7 1	16 18 8022 7 1	16 18 8022 7 1	16 18 8022 7 1	16 18 8022 7 1
J311164	15 22 8022 7 1	15 22 8022 7 1	15 22 8022 7 1	15 22 8022 7 1	15 22 8022 7 1	15 22 8022 7 1	15 22 8022 7 1	15 22 8022 7 1	15 22 8022 7 1	15 22 8022 7 1	15 22 8022 7 1	15 22 8022 7 1	15 22 8022 7 1	15 22 8022 7 1	15 22 8022 7 1
J312007	15 17 8022 7 1	15 17 8022 7 1	15 17 8022 7 1	15 17 8022 7 1	15 17 8022 7 1	15 17 8022 7 1	15 17 8022 7 1	15 17 8022 7 1	15 17 8022 7 1	15 17 8022 7 1	15 17 8022 7 1	15 17 8022 7 1	15 17 8022 7 1	15 17 8022 7 1	15 17 8022 7 1
J311047	17 18 8022 7 1	17 18 8022 7 1	17 18 8022 7 1	17 18 8022 7 1	17 18 8022 7 1	17 18 8022 7 1	17 18 8022 7 1	17 18 8022 7 1	17 18 8022 7 1	17 18 8022 7 1	17 18 8022 7 1	17 18 8022 7 1	17 18 8022 7 1	17 18 8022 7 1	17 18 8022 7 1

検査者: 山本 健一
検査日: 1993-2-26
検査場所: 住友金属工業株式会社
検査機: 住友金属工業株式会社

検査者: 山本 健一
検査日: 1993-2-26
検査場所: 住友金属工業株式会社
検査機: 住友金属工業株式会社



TURPIN PRODUCTS - 211 Sch 162 Homesites

TIME: 10:08 EST
USS, WDC, DEC 1962 - Department of State

[illegible]

ALL ORDERING INFO TO: 1-800-4-A-DRAPER INC.
 * 0517725 05 * R18819

PQ NUMBER
CLP/94/I96096-01

VEHICLE
LT8220

8000 TO ADDRESS

ADDRESS

ADDRESS

ADDRESS

MAIL TO ADDRESS
TYPE & FILLER CORPMAIL TO ADDRESS
TYPE & FILLER CORPMAIL TO ADDRESS
TYPE & FILLER CORPMAIL TO ADDRESS
TYPE & FILLER CORP

VENDOR PRODUCTS

VENDOR PRODUCTS

VENDOR PRODUCTS

VENDOR PRODUCTS

F O BOX 40878
HOUSTON TX 77240-0896

22 XL NG15NOH-

240-0856

055

1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	32	33	34	35	36	37	38	39	40	41	42	43	44	45	46	47	48	49	50	51	52	53	54	55	56	57	58	59	60	61	62	63	64	65	66	67	68	69	70	71	72	73	74	75	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	93	94	95	96	97	98	99	100
---	---	---	---	---	---	---	---	---	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	-----

PIPE CARBON SMLS STD PIPE API 5L-40TH EDITION DTD 11/1/92 GRADE B AND GRADE X42 ASTM A53-93A ASTM A106-93 GRADE B QUAD STENCIL ASME SA53-*1992 EDITION 1993 ADDENDUM ASME SA106-*1992 EDITION 1993

(CU+NI) OVER 15 BLK REG MILL COAT PE BEV 30 DEG MEETING ALL THE APPLICABLE REQUIREMENTS OF NACE STANDARD

MATERIAL	AS ROLLED	YIELD STRENGTH (MPa)	TENSILE STRENGTH (MPa)	ELONGATION (%)	REDUCTION OF AREA (%)	IMPACT (J)
		2.375 (60.325)	0.344 (8.737)			

TEST TYPE / FACILITY DESCRIPTION	TEST CODE	TEST DATE	TEST TIME	TEST RESULT	TEST UNIT	TEST LOCATION	TEST OPERATOR	TEST STATUS
STEEL CORROSION PROTECTION	S-001	1987	10/15	COAT THICKNESS	4000	MIL	J. J. HARRIS	PASS
				ADHESION	6000	LBS	J. J. HARRIS	PASS
CONCRETE STRENGTH	C-001	1987	10/15	CYLINDRICAL STRENGTH	3000	PSI	J. J. HARRIS	PASS
				SQUARE FOOTAGE	3000	SQ FT	J. J. HARRIS	PASS

LESS-46	31N137L/B	AA	0.750	47100	0.64	59.0	53.3	3000
400040	STB137L/B	AB	0.750	49100	0.65	38.0	52.7	3000

1

1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	32	33	34	35	36	37	38	39	40	41	42	43	44	45	46	47	48	49	50	51	52	53	54	55	56	57	58	59	60	61	62	63	64	65	66	67	68	69	70	71	72	73	74	75	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	93	94	95	96	97	98	99	100
---	---	---	---	---	---	---	---	---	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	-----

[illegible][illegible][illegible]

N89-248
PROD
.....
:13
T13 007 034 23
** END OF DATA THIS SHEET: *
.....

*CE IS BASED ON THE FOLLOWING EQUATIONS:

INSPECTION CERTIFICATE
 (TYPE B - W RECORD)
 ORDER NUMBER: DS1772S 03
 SHIPPING NO: R18819
 INVOICE NUMBER: CLP/94/196096-01
 Q&A: 2.375 (60.325) h (mm) WALL: 0.344 (8.737) h (mm)

ALL ORDERING AND SHIPPING INFORMATION
 ORDER NUMBER: DS1772S 03
 SHIPPING NO: R18819
 INVOICE NUMBER: CLP/94/196096-01
 Q&A: 2.375 (60.325) h (mm) WALL: 0.344 (8.737) h (mm)

PRODUCT IDENTIFICATION	FLAT	BEND	CRACK SIZE	LWY COLLAPSE	DR	TEST LOC	TEMP	SIZE	TEST COND	CHURRY WATSON IMPACT TESTING			HAZ - HAZ AFFECTED ZONE
										1	2	3	
L33348		OK											
N39348		OK					**						
END OF DATA THIS SHEET **													

TEST / INSPECTION		YES	NO	RESULTS / COMMENTS
FULL LENGTH VISUAL				
FULL LENGTH EM				
FULL LENGTH MF				
FULL LENGTH UT				
END AREA INSPECTION (PLAN END)				
SPECIAL END AREA (SEA) NIP				
FULL LENGTH DRIFT				

TESTING / INSPECTION INFORMATION		RESULTS / COMMENTS
B - BODY		
W - WELD		
HAZ - HAZ AFFECTED ZONE		

ADDITIONAL NOTES/COMMENTS

ALL MELTING AND MANUFACTURING TOOK PLACE IN THE USA. NO REPAIRS BY WELDING. NO MERCURY OR MERCURY COMPOUNDS ARE ADDED TO THE STEEL AND ALL MERCURY BEARING EQUIPMENT IS PROTECTED BY A DOUBLE BOUNDARY OF CONTAINMENT.

THIS IS TO CERTIFY THAT THE PRODUCT DESCRIBED HEREIN WAS MANUFACTURED, SUPPLIED, TESTED AND/OR INSPECTED IN ACCORDANCE WITH THE SPECIFICATION AND FULFILLS THE REQUIREMENTS IN SUCH RESPECTS.

PREPARED BY THE OFFICE OF: D.S. DASKOWSKI MGR. MET. & Q.A. USS TUBULAR PRODUCTS

DATE: 12/05/94

U.S. STEEL GROUP
A Unit of USX Corporation

TUBULAR PRODUCTS

METALLURGICAL TEST REPORT

WHS 09.16.02

THIS IS TO CERTIFY THAT THE PRODUCT DESCRIBED HEREIN WAS MFG., SAMPLED, TESTED, AND OR INSPD. IN ACCORDANCE WITH THE SPECIFICATION AND FULFILLS REQUIREMENTS IN SUCH RESPECTS.

APPROVED BY OFFICE OF:
D.S. DABKOWSKI MGR. MET. &
Q.A. USB TUBULAR PRODUCTS

U.S. STEEL GROUP
A Unit of USX Corporation

REQ. CONTRACT NO. _____

PURCHASE ORDER NO. _____

CLP 793/168848-01

INVOICE NO. _____

SHIPPER NO. _____

BILL ORDER NO. _____

SHIPPER NO. _____

DATE _____

SHIPPER NO. _____

DATE _____

SHIPPER NO. _____

DATE _____

USS TUBULAR PRODUCTS

VAN LEEUWEN PIPE & TUBE CORP.
ACCOUNTS PAYABLE
15333 HEMPSTEAD RD
HOUSTON TX 77040

VAN LEEUWEN PIPE & TUBE CORP.
ACCOUNTS PAYABLE
15333 HEMPSTEAD RD
HOUSTON TX 77040

MEETING ALL THE APPLICABLE REQUIREMENTS OF NACE STANDARD MR-01-75

DATE 106/02/92

SEP 10 1993

ITEM NO.	SIZE	WALL	MATERIAL DESCRIPTION	MATL	HEAT/LOT NO.	MK. WTNO. PSI	YIELD STR. PSI	TENSILE STR. PSI	ELONG. % IN 2"	QUICK WELDING IN.	PLAT
03	2 7/8	.203	ASTM A53-90B/A106-91 GR. B ASME SA53/SA106 89ED 91ADD API 5L GR. B/X42 40TH ED. DTD 11/92	SML	N67242	3000	48600	73500	37.0	3/4	OK
03	2 7/8	.203	ASTM A53-90B/A106-91 GR. B ASME SA53/SA106 89ED 91ADD API 5L GR. B/X42 40TH ED. DTD 11/92	SML	N67244	3000	48500	73200	35.0	3/4	OK

ITEM NO.	HEAT NO.	TYPE	C	M	P	S	B	D	W	H	Q	R	T	U	V	Y	N	L	ST	LO	D	Y	B	F	U	C
03	N67242	HEAT 18	104	D11	D11	010	24	D2	D2	D2	04	01	01	01	01	001										
03	N67242	PROD 19	107	D09	D13	013	24	D2	D2	D2	04	01	01	01	01	002										
03	N67244	HEAT 17	104	D11	D11	013	23	D2	D2	D2	04	01	01	01	01	001										
03	N67244	PROD 16	105	D08	D13	013	22	D2	D2	D2	04	01	01	01	01	001										
03	N67244	PROD 15	105	D08	D13	013	22	D2	D2	D2	04	01	01	01	01	001										
** END OF DATA THIS SHEET ***																										
MANUFACTURING TOOL: PLACE IN THE USA.																										
CE=37 HRB=78.0 CE=.36 HRB=78.0																										

END OF DATA THIS SHEET ***


ALL INFORMATION CONTAINED HEREIN IS UNCLASSIFIED EXCEPT WHERE SHOWN OTHERWISE

055-

EX 123.92

TUBES DE SAINT SAUVE		MATERIAU TEST REPORT	
11 277	11 277	PAGE 1	
11 277	11 277	REF. 25-12-277041	
<p>PROCESSEUR : MARCON KEYSTONE CORP -</p> <p>ORDER NO : H-144387 PO. 60-B-05310 08-04-92</p> <p>WELDED STEEL PIPE, NOT FINISHED MILL STEELING ROLLER</p> <p>SPECIFICATION: ASME B 31.3, 1.1, 1.2, 1.3, 1.4, 1.5, 1.6, 1.7, 1.8, 1.9, 2.0, 2.1, 2.2, 2.3, 2.4, 2.5, 2.6, 2.7, 2.8, 2.9, 3.0, 3.1, 3.2, 3.3, 3.4, 3.5, 3.6, 3.7, 3.8, 3.9, 4.0, 4.1, 4.2, 4.3, 4.4, 4.5, 4.6, 4.7, 4.8, 4.9, 5.0, 5.1, 5.2, 5.3, 5.4, 5.5, 5.6, 5.7, 5.8, 5.9, 6.0, 6.1, 6.2, 6.3, 6.4, 6.5, 6.6, 6.7, 6.8, 6.9, 7.0, 7.1, 7.2, 7.3, 7.4, 7.5, 7.6, 7.7, 7.8, 7.9, 8.0, 8.1, 8.2, 8.3, 8.4, 8.5, 8.6, 8.7, 8.8, 8.9, 9.0, 9.1, 9.2, 9.3, 9.4, 9.5, 9.6, 9.7, 9.8, 9.9, 10.0, 10.1, 10.2, 10.3, 10.4, 10.5, 10.6, 10.7, 10.8, 10.9, 11.0, 11.1, 11.2, 11.3, 11.4, 11.5, 11.6, 11.7, 11.8, 11.9, 12.0, 12.1, 12.2, 12.3, 12.4, 12.5, 12.6, 12.7, 12.8, 12.9, 13.0, 13.1, 13.2, 13.3, 13.4, 13.5, 13.6, 13.7, 13.8, 13.9, 14.0, 14.1, 14.2, 14.3, 14.4, 14.5, 14.6, 14.7, 14.8, 14.9, 15.0, 15.1, 15.2, 15.3, 15.4, 15.5, 15.6, 15.7, 15.8, 15.9, 16.0, 16.1, 16.2, 16.3, 16.4, 16.5, 16.6, 16.7, 16.8, 16.9, 17.0, 17.1, 17.2, 17.3, 17.4, 17.5, 17.6, 17.7, 17.8, 17.9, 18.0, 18.1, 18.2, 18.3, 18.4, 18.5, 18.6, 18.7, 18.8, 18.9, 19.0, 19.1, 19.2, 19.3, 19.4, 19.5, 19.6, 19.7, 19.8, 19.9, 20.0, 20.1, 20.2, 20.3, 20.4, 20.5, 20.6, 20.7, 20.8, 20.9, 21.0, 21.1, 21.2, 21.3, 21.4, 21.5, 21.6, 21.7, 21.8, 21.9, 22.0, 22.1, 22.2, 22.3, 22.4, 22.5, 22.6, 22.7, 22.8, 22.9, 23.0, 23.1, 23.2, 23.3, 23.4, 23.5, 23.6, 23.7, 23.8, 23.9, 24.0, 24.1, 24.2, 24.3, 24.4, 24.5, 24.6, 24.7, 24.8, 24.9, 25.0, 25.1, 25.2, 25.3, 25.4, 25.5, 25.6, 25.7, 25.8, 25.9, 26.0, 26.1, 26.2, 26.3, 26.4, 26.5, 26.6, 26.7, 26.8, 26.9, 27.0, 27.1, 27.2, 27.3, 27.4, 27.5, 27.6, 27.7, 27.8, 27.9, 28.0, 28.1, 28.2, 28.3, 28.4, 28.5, 28.6, 28.7, 28.8, 28.9, 29.0, 29.1, 29.2, 29.3, 29.4, 29.5, 29.6, 29.7, 29.8, 29.9, 30.0, 30.1, 30.2, 30.3, 30.4, 30.5, 30.6, 30.7, 30.8, 30.9, 31.0, 31.1, 31.2, 31.3, 31.4, 31.5, 31.6, 31.7, 31.8, 31.9, 32.0, 32.1, 32.2, 32.3, 32.4, 32.5, 32.6, 32.7, 32.8, 32.9, 33.0, 33.1, 33.2, 33.3, 33.4, 33.5, 33.6, 33.7, 33.8, 33.9, 34.0, 34.1, 34.2, 34.3, 34.4, 34.5, 34.6, 34.7, 34.8, 34.9, 35.0, 35.1, 35.2, 35.3, 35.4, 35.5, 35.6, 35.7, 35.8, 35.9, 36.0, 36.1, 36.2, 36.3, 36.4, 36.5, 36.6, 36.7, 36.8, 36.9, 37.0, 37.1, 37.2, 37.3, 37.4, 37.5, 37.6, 37.7, 37.8, 37.9, 38.0, 38.1, 38.2, 38.3, 38.4, 38.5, 38.6, 38.7, 38.8, 38.9, 39.0, 39.1, 39.2, 39.3, 39.4, 39.5, 39.6, 39.7, 39.8, 39.9, 40.0, 40.1, 40.2, 40.3, 40.4, 40.5, 40.6, 40.7, 40.8, 40.9, 41.0, 41.1, 41.2, 41.3, 41.4, 41.5, 41.6, 41.7, 41.8, 41.9, 42.0, 42.1, 42.2, 42.3, 42.4, 42.5, 42.6, 42.7, 42.8, 42.9, 43.0, 43.1, 43.2, 43.3, 43.4, 43.5, 43.6, 43.7, 43.8, 43.9, 44.0, 44.1, 44.2, 44.3, 44.4, 44.5, 44.6, 44.7, 44.8, 44.9, 45.0, 45.1, 45.2, 45.3, 45.4, 45.5, 45.6, 45.7, 45.8, 45.9, 46.0, 46.1, 46.2, 46.3, 46.4, 46.5, 46.6, 46.7, 46.8, 46.9, 47.0, 47.1, 47.2, 47.3, 47.4, 47.5, 47.6, 47.7, 47.8, 47.9, 48.0, 48.1, 48.2, 48.3, 48.4, 48.5, 48.6, 48.7, 48.8, 48.9, 49.0, 49.1, 49.2, 49.3, 49.4, 49.5, 49.6, 49.7, 49.8, 49.9, 50.0, 50.1, 50.2, 50.3, 50.4, 50.5, 50.6, 50.7, 50.8, 50.9, 51.0, 51.1, 51.2, 51.3, 51.4, 51.5, 51.6, 51.7, 51.8, 51.9, 52.0, 52.1, 52.2, 52.3, 52.4, 52.5, 52.6, 52.7, 52.8, 52.9, 53.0, 53.1, 53.2, 53.3, 53.4, 53.5, 53.6, 53.7, 53.8, 53.9, 54.0, 54.1, 54.2, 54.3, 54.4, 54.5, 54.6, 54.7, 54.8, 54.9, 55.0, 55.1, 55.2, 55.3, 55.4, 55.5, 55.6, 55.7, 55.8, 55.9, 56.0, 56.1, 56.2, 56.3, 56.4, 56.5, 56.6, 56.7, 56.8, 56.9, 57.0, 57.1, 57.2, 57.3, 57.4, 57.5, 57.6, 57.7, 57.8, 57.9, 58.0, 58.1, 58.2, 58.3, 58.4, 58.5, 58.6, 58.7, 58.8, 58.9, 59.0, 59.1, 59.2, 59.3, 59.4, 59.5, 59.6, 59.7, 59.8, 59.9, 60.0, 60.1, 60.2, 60.3, 60.4, 60.5, 60.6, 60.7, 60.8, 60.9, 61.0, 61.1, 61.2, 61.3, 61.4, 61.5, 61.6, 61.7, 61.8, 61.9, 62.0, 62.1, 62.2, 62.3, 62.4, 62.5, 62.6, 62.7, 62.8, 62.9, 63.0, 63.1, 63.2, 63.3, 63.4, 63.5, 63.6, 63.7, 63.8, 63.9, 64.0, 64.1, 64.2, 64.3, 64.4, 64.5, 64.6, 64.7, 64.8, 64.9, 65.0, 65.1, 65.2, 65.3, 65.4, 65.5, 65.6, 65.7, 65.8, 65.9, 66.0, 66.1, 66.2, 66.3, 66.4, 66.5,</p>			

3" x 70 ft

 TUBERIE DE SAINT SAUVEUR 11 877 872 3000 MAIN STREET - FREDERICK TEL: (224) 111-1111 1800 MAIN STREET		MATERIAL TEST REPORT		PAGE 2
PURCHASER : HARMON KEYSTONE CORP. ORDER NO : 1 H-14438 / P.O. 60-8-06510 08-04-92 (SEE V.P. 03025073)				
TENSILE TEST DIR. 1 LONGIT.		8000 TENSILE TYPE RECT. 3/4"		REF. 21-71-14438
MEAT 350134		Y.S. PSI 41000	T.M. PSI 53300	ELEVATION 1 (10.0 - 2") 41.5
PRODUCT ANALYSIS (CZ)				
HEAT 350134	C 0.13 0.15	SI 0.21 0.21	Mn 0.64 0.65	P 0.013 0.013
	S 0.006 0.006	CR 0.05 0.05	NI 0.01 0.01	CU 0.025 0.024
				V 0.000 0.000
OTHER TESTS : BATHYFACTORY				
HYDRAULIC TEST SURFACE & DIMENSIONAL FLATTERING TEST				
100% PASS P- 2500 PSI / 5000 PSI 100% PASS				
NO REPAIR BY MELTING HAS BEEN CARRIED OUT				
3				

3 SEE 80 JOURNAL

USX
A subsidiary of USX Corporation

FAIRFIELD WORKS
P.O. BOX 529
FAIRFIELD, ALABAMA 36064

HARMON/KEYSTONE CORP
P O BOX 791

160C3-0791

PIPE CARBON SMLS STD PIPE API 5L-40TH EDITION BTD 11/1992 GRADE B AND GRADE X42 A5TH A5C-90B ASTM A106-1991 GRADE B Q&M STENCIL CARBON EQUIVALENT ON HEAT ANALYSIS .40 MAX BASED ON C-MN OVER 5 + (CR+MU+V) OVER B + (CU+NI) OVER 15 MLK REB WILL COAT FE BEV 30 DEG

HARRISON/KEYSTONE CORP
109 BOORICH DR
PINSOM VALLEY AL 363

94128h 804489

B87908

W. J. S. X.
THERMOLUX PRODUCTS

⑤

PRODUCT DESCRIBED HEREIN WAS
 INSPECTION, SAMPLED, TESTED AND/
 OR INSPECTED IN ACCORDANCE
 WITH THE SPECIFICATION AND
 REQUIREMENTS IN

SUCH RESPECTS.
PREPARED BY THE OFFICE OF:
J.W. ZEONG - MANAGER, Q.A.
FAIRFIELD PIPE MILL

SPECIFICATION										TEST RESULTS										ANALYSIS									
MATERIAL					MECHANICAL					CHEMICAL					PHYSICAL					THERMAL					ELECTRICAL				
ITEM	DESCRIPTION	UNIT	VALUE	TEST METHOD	ITEM	DESCRIPTION	UNIT	VALUE	TEST METHOD	ITEM	DESCRIPTION	UNIT	VALUE	TEST METHOD	ITEM	DESCRIPTION	UNIT	VALUE	TEST METHOD	ITEM	DESCRIPTION	UNIT	VALUE	TEST METHOD					
1	YIELD STRENGTH	MPa	235	ASTM A370	1	ELONGATION	%	22	ASTM A370	1	TENSILE	MPa	475	ASTM A370	1	IMPACT	J	27	ASTM A370	1	HARDNESS	HR	150	ASTM A370					
2	TENSILE	MPa	475	ASTM A370	2	ELONGATION	%	22	ASTM A370	2	TENSILE	MPa	475	ASTM A370	2	IMPACT	J	27	ASTM A370	2	HARDNESS	HR	150	ASTM A370					
3	ELONGATION	%	22	ASTM A370	3	TENSILE	MPa	475	ASTM A370	3	IMPACT	J	27	ASTM A370	3	HARDNESS	HR	150	ASTM A370	3	YIELD STRENGTH	MPa	235	ASTM A370					
4	IMPACT	J	27	ASTM A370	4	HARDNESS	HR	150	ASTM A370	4	YIELD STRENGTH	MPa	235	ASTM A370	4	ELONGATION	%	22	ASTM A370	4	TENSILE	MPa	475	ASTM A370					
5	HARDNESS	HR	150	ASTM A370	5	YIELD STRENGTH	MPa	235	ASTM A370	5	ELONGATION	%	22	ASTM A370	5	TENSILE	MPa	475	ASTM A370	5	IMPACT	J	27	ASTM A370					

SPECIFICATION										TEST RESULTS										ANALYSIS									
MATERIAL					MECHANICAL					CHEMICAL					PHYSICAL					THERMAL					ELECTRICAL				
ITEM	DESCRIPTION	UNIT	VALUE	TEST METHOD	ITEM	DESCRIPTION	UNIT	VALUE	TEST METHOD	ITEM	DESCRIPTION	UNIT	VALUE	TEST METHOD	ITEM	DESCRIPTION	UNIT	VALUE	TEST METHOD	ITEM	DESCRIPTION	UNIT	VALUE	TEST METHOD					
1	YIELD STRENGTH	MPa	235	ASTM A370	1	ELONGATION	%	22	ASTM A370	1	TENSILE	MPa	475	ASTM A370	1	IMPACT	J	27	ASTM A370	1	HARDNESS	HR	150	ASTM A370					
2	TENSILE	MPa	475	ASTM A370	2	ELONGATION	%	22	ASTM A370	2	TENSILE	MPa	475	ASTM A370	2	IMPACT	J	27	ASTM A370	2	HARDNESS	HR	150	ASTM A370					
3	ELONGATION	%	22	ASTM A370	3	TENSILE	MPa	475	ASTM A370	3	IMPACT	J	27	ASTM A370	3	HARDNESS	HR	150	ASTM A370	3	YIELD STRENGTH	MPa	235	ASTM A370					
4	IMPACT	J	27	ASTM A370	4	HARDNESS	HR	150	ASTM A370	4	YIELD STRENGTH	MPa	235	ASTM A370	4	ELONGATION	%	22	ASTM A370	4	TENSILE	MPa	475	ASTM A370					
5	HARDNESS	HR	150	ASTM A370	5	YIELD STRENGTH	MPa	235	ASTM A370	5	ELONGATION	%	22	ASTM A370	5	TENSILE	MPa	475	ASTM A370	5	IMPACT	J	27	ASTM A370					

SPECIFICATION										TEST RESULTS										ANALYSIS									
MATERIAL					MECHANICAL					CHEMICAL					PHYSICAL					THERMAL					ELECTRICAL				
ITEM	DESCRIPTION	UNIT	VALUE	TEST METHOD	ITEM	DESCRIPTION	UNIT	VALUE	TEST METHOD	ITEM	DESCRIPTION	UNIT	VALUE	TEST METHOD	ITEM	DESCRIPTION	UNIT	VALUE	TEST METHOD	ITEM	DESCRIPTION	UNIT	VALUE	TEST METHOD					
1	YIELD STRENGTH	MPa	235	ASTM A370	1	ELONGATION	%	22	ASTM A370	1	TENSILE	MPa	475	ASTM A370	1	IMPACT	J	27	ASTM A370	1	HARDNESS	HR	150	ASTM A370					
2	TENSILE	MPa	475	ASTM A370	2	ELONGATION	%	22	ASTM A370	2	TENSILE	MPa	475	ASTM A370	2	IMPACT	J	27	ASTM A370	2	HARDNESS	HR	150	ASTM A370					
3	ELONGATION	%	22	ASTM A370	3	TENSILE	MPa	475	ASTM A370	3	IMPACT	J	27	ASTM A370	3	HARDNESS	HR	150	ASTM A370	3	YIELD STRENGTH	MPa	235	ASTM A370					
4	IMPACT	J	27	ASTM A370	4	HARDNESS	HR	150	ASTM A370	4	YIELD STRENGTH	MPa	235	ASTM A370	4	ELONGATION	%	22	ASTM A370	4	TENSILE	MPa	475	ASTM A370					
5	HARDNESS	HR	150	ASTM A370	5	YIELD STRENGTH	MPa	235	ASTM A370	5	ELONGATION	%	22	ASTM A370	5	TENSILE	MPa	475	ASTM A370	5	IMPACT	J	27	ASTM A370					

SPECIFICATION										TEST RESULTS										ANALYSIS									
MATERIAL					MECHANICAL					CHEMICAL					PHYSICAL					THERMAL					ELECTRICAL				
ITEM	DESCRIPTION	UNIT	VALUE	TEST METHOD	ITEM	DESCRIPTION	UNIT	VALUE	TEST METHOD	ITEM	DESCRIPTION	UNIT	VALUE	TEST METHOD	ITEM	DESCRIPTION	UNIT	VALUE	TEST METHOD	ITEM	DESCRIPTION	UNIT	VALUE	TEST METHOD					
1	YIELD STRENGTH	MPa	235	ASTM A370	1	ELONGATION	%	22	ASTM A370	1	TENSILE	MPa	475	ASTM A370	1	IMPACT	J	27	ASTM A370	1	HARDNESS	HR	150	ASTM A370					
2	TENSILE	MPa	475	ASTM A370	2	ELONGATION	%	22	ASTM A370	2	TENSILE	MPa	475	ASTM A370	2	IMPACT	J	27	ASTM A370	2	HARDNESS	HR	150	ASTM A370					
3	ELONGATION	%	22	ASTM A370	3	TENSILE	MPa	475	ASTM A370	3	IMPACT	J	27	ASTM A370	3	HARDNESS	HR	150	ASTM A370	3	YIELD STRENGTH	MPa	235	ASTM A370					
4	IMPACT	J	27	ASTM A370	4	HARDNESS	HR	150	ASTM A370	4	YIELD STRENGTH	MPa	235	ASTM A370	4	ELONGATION	%	22	ASTM A370	4	TENSILE	MPa	475	ASTM A370					
5	HARDNESS	HR	150	ASTM A370	5	YIELD STRENGTH	MPa	235	ASTM A370	5	ELONGATION	%	22	ASTM A370	5	TENSILE	MPa	475	ASTM A370	5	IMPACT	J	27	ASTM A370					

SPECIFICATION										TEST RESULTS										ANALYSIS									
MATERIAL					MECHANICAL					CHEMICAL					PHYSICAL					THERMAL					ELECTRICAL				
ITEM	DESCRIPTION	UNIT	VALUE	TEST METHOD	ITEM	DESCRIPTION	UNIT	VALUE	TEST METHOD	ITEM	DESCRIPTION	UNIT	VALUE	TEST METHOD	ITEM	DESCRIPTION	UNIT	VALUE	TEST METHOD	ITEM	DESCRIPTION	UNIT	VALUE	TEST METHOD					
1	YIELD STRENGTH	MPa	235	ASTM A370	1	ELONGATION	%	22	ASTM A370	1	TENSILE	MPa	475	ASTM A370	1	IMPACT	J	27	ASTM A370	1	HARDNESS	HR	150	ASTM A370					
2	TENSILE	MPa	475	ASTM A370	2	ELONGATION	%	22	ASTM A370	2	TENSILE	MPa	475	ASTM A370	2	IMPACT	J	27	ASTM A370	2	HARDNESS	HR	150	ASTM A370					
3	ELONGATION	%	22	ASTM A370	3	TENSILE	MPa	475	ASTM A370	3	IMPACT	J	27	ASTM A370	3	HARDNESS	HR	150	ASTM A370	3	YIELD STRENGTH	MPa	235	ASTM A370					
4	IMPACT	J	27	ASTM A370	4	HARDNESS	HR	150	ASTM A370	4	YIELD STRENGTH	MPa	235	ASTM A370	4	ELONGATION	%	22	ASTM A370	4	TENSILE	MPa	475	ASTM A370					
5	HARDNESS	HR	150	ASTM A370	5	YIELD STRENGTH	MPa	235	ASTM A370	5	ELONGATION	%	22	ASTM A370	5	TENSILE	MPa	475	ASTM A370	5	IMPACT	J	27	ASTM A370					

SPECIFICATION										TEST RESULTS										ANALYSIS									
MATERIAL					MECHANICAL					CHEMICAL					PHYSICAL					THERMAL					ELECTRICAL				
ITEM	DESCRIPTION	UNIT	VALUE	TEST METHOD	ITEM	DESCRIPTION	UNIT	VALUE	TEST METHOD	ITEM	DESCRIPTION	UNIT	VALUE	TEST METHOD	ITEM	DESCRIPTION	UNIT	VALUE	TEST METHOD	ITEM	DESCRIPTION	UNIT	VALUE	TEST METHOD					
1	YIELD STRENGTH	MPa	235	ASTM A370	1	ELONGATION	%	22	ASTM A370	1	TENSILE	MPa	475	ASTM A370	1	IMPACT	J	27	ASTM A370	1	HARDNESS	HR	150	ASTM A370					
2	TENSILE	MPa	475	ASTM A370	2	ELONGATION	%	22	ASTM A370	2	TENSILE	MPa	475	ASTM A370	2	IMPACT	J	27	ASTM A370	2	HARDNESS	HR	150	ASTM A370					
3	ELONGATION	%	22	ASTM A370	3	TENSILE	MPa	475	ASTM A370	3	IMPACT	J	27	ASTM A370	3	HARDNESS	HR	150	ASTM A370	3	YIELD STRENGTH	MPa	235	ASTM A370					
4	IMPACT	J	27	ASTM A370	4	HARDNESS	HR	150	ASTM A370	4	YIELD STRENGTH	MPa	235	ASTM A370	4	ELONGATION	%	22	ASTM A370	4	TENSILE	MPa	475	ASTM A370					
5	HARDNESS	HR	150	ASTM A370	5	YIELD STRENGTH	MPa	235	ASTM A370	5	ELONGATION	%	22	ASTM A370	5	TENSILE	MPa	475	ASTM A370	5	IMPACT	J	27	ASTM A370					

SPECIFICATION										TEST RESULTS										ANALYSIS									
MATERIAL					MECHANICAL					CHEMICAL					PHYSICAL					THERMAL					ELECTRICAL				
ITEM	DESCRIPTION	UNIT	VALUE	TEST METHOD	ITEM	DESCRIPTION	UNIT	VALUE	TEST METHOD	ITEM	DESCRIPTION	UNIT	VALUE	TEST METHOD	ITEM	DESCRIPTION	UNIT	VALUE	TEST METHOD	ITEM	DESCRIPTION	UNIT	VALUE	TEST METHOD					
1	YIELD STRENGTH	MPa	235	ASTM A370	1	ELONGATION	%	22	ASTM A370	1	TENSILE	MPa	475	ASTM A370	1	IMPACT	J	27	ASTM A370	1	HARDNESS	HR	150	ASTM A370					
2	TENSILE	MPa	475	ASTM A370	2	ELONGATION	%	22	ASTM A370	2	TENSILE	MPa	475	ASTM A370	2	IMPACT	J	27	ASTM A370	2	HARDNESS	HR	150	ASTM A370					
3	ELONGATION	%	22	ASTM A370	3	TENSILE	MPa	475	ASTM A370	3	IMPACT	J	27	ASTM A370	3	HARDNESS	HR	150	ASTM A370	3	YIELD STRENGTH	MPa	235	ASTM A370					
4	IMPACT	J	27	ASTM A370	4	HARDNESS	HR	150	ASTM A370	4	YIELD STRENGTH	MPa	235	ASTM A370	4	ELONGATION	%	22	ASTM A370	4	TENSILE	MPa	475	ASTM A370					
5	HARDNESS	HR	150	ASTM A370	5	YIELD STRENGTH	MPa	235	ASTM A370	5	ELONGATION	%	22	ASTM A370	5	TENSILE	MPa	475	ASTM A370	5	IMPACT	J	27	ASTM A370					

SPECIFICATION										TEST RESULTS										ANALYSIS									
MATERIAL					MECHANICAL					CHEMICAL					PHYSICAL					THERMAL					ELECTRICAL				
ITEM	DESCRIPTION	UNIT	VALUE	TEST METHOD	ITEM	DESCRIPTION	UNIT	VALUE	TEST METHOD	ITEM	DESCRIPTION	UNIT	VALUE	TEST METHOD	ITEM	DESCRIPTION	UNIT	VALUE	TEST METHOD	ITEM	DESCRIPTION	UNIT	VALUE	TEST METHOD					
1	YIELD STRENGTH	MPa	235	ASTM A370	1	ELONGATION	%	22	ASTM A370	1	TENSILE	MPa	475	ASTM A370	1	IMPACT	J	27	ASTM A370	1	HARDNESS	HR	150	ASTM A370					
2	TENSILE	MPa	475	ASTM A370	2	ELONGATION	%	22	ASTM A370	2	TENSILE	MPa	475	ASTM A370	2	IMPACT	J	27	ASTM A370	2	HARDNESS	HR	150	ASTM A370					
3	ELONGATION	%	22	ASTM A370	3	TENSILE	MPa	475	ASTM A370	3	IMPACT	J	27	ASTM A370	3	HARDNESS	HR	150	ASTM A370	3	YIELD STRENGTH	MPa	235	ASTM A370					
4	IMPACT	J	27	ASTM A370	4	HARDNESS	HR	150	ASTM A370	4	YIELD STRENGTH	MPa	235	ASTM A370	4	ELONGATION	%	22	ASTM A370	4	TENSILE	MPa	475	ASTM A370					
5	HARDNESS	HR	150	ASTM A370	5	YIELD STRENGTH	MPa	235	ASTM A370	5	ELONGATION	%	22	ASTM A370	5	TENSILE	MPa	475	ASTM A370	5	IMPACT	J	27	ASTM A370					

SPECIFICATION										TEST RESULTS										ANALYSIS									
MATERIAL					MECHANICAL					CHEMICAL					PHYSICAL					THERMAL					ELECTRICAL				
ITEM	DESCRIPTION	UNIT	VALUE	TEST METHOD	ITEM	DESCRIPTION	UNIT	VALUE	TEST METHOD	ITEM	DESCRIPTION	UNIT	VALUE	TEST METHOD	ITEM	DESCRIPTION	UNIT	VALUE	TEST METHOD	ITEM	DESCRIPTION	UNIT	VALUE	TEST METHOD					
1	YIELD STRENGTH	MPa	235	ASTM A370	1	ELONGATION	%	22	ASTM A370	1	TENSILE	MPa	475	ASTM A370	1	IMPACT	J	27	ASTM A370	1	HARDNESS	HR	150	ASTM A370					
2	TENSILE	MPa	475	ASTM A370	2	ELONGATION	%	22	ASTM A370	2	TENSILE	MPa	475	ASTM A370	2	IMPACT	J	27	ASTM A370	2	HARDNESS	HR	150	ASTM A370					
3	ELONGATION	%	22	ASTM A370	3	TENSILE	MPa	475	ASTM A370	3	IMPACT	J	27	ASTM A370	3	HARDNESS	HR	150	ASTM A370	3	YIELD STRENGTH	MPa	235	ASTM A370					
4	IMPACT	J	27	ASTM A370	4	HARDNESS	HR	150	ASTM A370	4	YIELD STRENGTH	MPa	235	ASTM A370	4	ELONGATION	%	22	ASTM A370	4	TENSILE	MPa	475	ASTM A370					
5	HARDNESS	HR	150	ASTM A370	5	YIELD STRENGTH	MPa	235	ASTM A370	5	ELONGATION	%	22	ASTM A370	5	TENSILE	MPa	475	ASTM A370	5	IMPACT	J	27	ASTM A370					

SPECIFICATION										TEST RESULTS										ANALYSIS									
MATERIAL					MECHANICAL					CHEMICAL					PHYSICAL					THERMAL					ELECTRICAL				
ITEM	DESCRIPTION	UNIT	VALUE	TEST METHOD	ITEM	DESCRIPTION	UNIT	VALUE	TEST METHOD	ITEM	DESCRIPTION	UNIT	VALUE	TEST METHOD	ITEM	DESCRIPTION	UNIT	VALUE	TEST METHOD	ITEM	DESCRIPTION	UNIT	VALUE	TEST METHOD					
1	YIELD STRENGTH	MPa	235	ASTM A370	1	ELONGATION	%	22	ASTM A370	1	TENSILE	MPa	475	ASTM A370	1	IMPACT	J	27	ASTM A370	1	HARDNESS	HR	150	ASTM A370					
2	TENSILE	MPa	475	ASTM A370	2	ELONGATION	%	22	ASTM A370	2	TENSILE	MPa	475	ASTM A370	2	IMPACT	J	27	ASTM A370	2	HARDNESS	HR	150	ASTM A370					
3	ELONGATION	%	22	ASTM A370	3	TENSILE	MPa	475	ASTM A370	3	IMPACT	J	27	ASTM A370	3	HARDNESS	HR	150	ASTM A370	3	YIELD STRENGTH	MPa	235	ASTM A370					
4	IMPACT	J	27	ASTM A370	4	HARDNESS	HR	150	ASTM A370	4	YIELD STRENGTH	MPa	235	ASTM A370	4	ELONGATION	%	22	ASTM A370	4	TENSILE	MPa	475	ASTM A370					
5	HARDNESS	HR	150	ASTM A370	5	YIELD STRENGTH	MPa	235	ASTM A370	5	ELONGATION	%																	

JUL 20 05 07:24 PM MK DENVER-40

Piping Metallurgy

06/16/1993 10:12 FROM TEXAS PIPE & SUPPLY

TO

1400241721 7103



QUANEX CORPORATION

HOUSTON, TEXAS

GULF STATES TUBE DIVISION ROSENBERG, TEXAS 77471

CST NUMBER	CUSTOMER ORDER NUMBER	DATE	QTY	COM	QTY	REFS	QTY	ACCOUNT NUMBER	US	UNIT
268768	75738	06/23/93	23	00	16	20	01	05712000000	FP	JTM

TEXAS PIPE & SUPPLY CO INC
2330 HOLMES ROAD

HOUSTON

TX

77051

TEXAS PIPE & SUPPLY CO INC

2330 HOLMES ROAD

HOUSTON

TX 77051

UNIT

XL CUST TRK - TR WITH SHIPMENT

ORDER	TYPE	FINISH	PER SPEC	DATE
ER SPEC	ROUND	HOT FINISH	PER SPEC	AUGUST 1993
			HF CARBON PIPE	08/31/93

SEAMLESS ASTM/ASME A/SA 106 B 90

EQUAL INSTRUCTIONS:

PLAIN ENDS - LACQUER COAT

ACCEPTABLE PER NACE MRD 175 TABLE 3

IN FOR 20' MIN LENGTHS

EN	QUANTITY	O.D.	I.D.	WALL	LENGTH	WT/LF	WEIGHT	
1	5.460'	2.300	1-1/2" SCH 40	.145 AVG	RAND 17' 24'	2.712	14.850	COG. 255 p.m. 5763'

MILL TEST REPORTS FURNISHED BY
TEXAS PIPE & SUPPLY CO. INC.
CUSTOMER *MTM*
CUSTOMER PO #

HEAT NO.	C	Mn	P	S	SI	NI	Cr	Mo	Cu	Pb	REMARKS
08173	.19	.73	.006	.011	.23	.10	.06	.02	.23		V .031
	.20	.76	.005	.013	.23	.10	.06	.02	.24		V .001
07598	.19	.77	.006	.014	.20	.09	.06	.02	.24		V .031
	.19	.76	.006	.015	.20	.09	.06	.02	.24		V .031

FLATTEN		FLARE	FLANGE	REV. FLATTEN	HYDRO TEST	SEND	EDDY CURRENT		
					2500 psi OK	OK			
HEAT NO.	ULT. STR. PSI	YIELD PSI	ELONG 2"	HARDNESS	HEAT NO.	ULT. STR. PSI	YIELD PSI	ELONG 2"	HARDNESS
08173	77900	50900	48.0						
07598	72900	48400	48.0						

THE MATERIAL HEREIN DESCRIBED HAS BEEN MANUFACTURED

SWORN TO AND SUBSCRIBED BEFORE ME THIS



HACKNEY, INC.

A DIVISION OF TRINITY INDUSTRIES
P.O. Box 568887 • 2525 Stemmons Freeway
Dallas, Texas 75356-8887 • (214) 634-2850

YOUR ORDER NUMBER	REFERENCE	CUSTOMER NO.	INVOICE NO.	INVOICE DATE	DATE SHIPPED
0099-002979	C139654	454634	819873	12/02/94	12/02/94

SHIPPED TO: M & M SUPPLY CO
PO BOX 548
DUNCAN OK 75533

SHIP TO: M & M SUPPLY
3923 OKLAHOMA AVE
HOODWARD, OK 73801

CERTIFIED TEST REPORT

ITEM		QUANTITY	DESCRIPTION/SPECIFICATION										HEAT CODE
36	6		8X6 STD CONC	A234-92A/SA234 WPB									XMP
37	2		A106B 48 / 88768	A234-92A/SA234 WPB									XLR
38	3		4X2 STD ECC	A234-92A/SA234 WPB									XLK
39	6		A106B 09 / X83447	A234-92A/SA234 WPB									LYH1
			6X4 STD ECC	A234-92A/SA234 WPB									
			A106B 09 / X83188	A234-92A/SA234 WPB									
			2 STD LR 45	A234-92A/SA234 WPB									
			A106B 09 / N86242	A234-92A/SA234 WPB									
STRESS RELIEVED AT 1200 °F													
CHEMICAL ANALYSIS													
CODE	C	Mn	P	S	Si	Cr	Mo	Cu	Ni	V	Nb		C.E. =
XMP	.19	.75	.010	.006	.34	.07	.02	.15	.08	.00	.00		.35
XLR	.18	.80	.012	.006	.24	.03	.01	.04	.01	.00	.00		.33
XLK	.18	.78	.012	.012	.25	.02	.01	.02	.01	.00	.00		.32
LYH1	.17	.81	.008	.007	.24	.04	.01	.01	.01	.00	.00		.32
CHARPY RESULTS													
PHYSICAL PROPERTIES													
HEAT CODE	TENSILE * KSI	YIELD KSI	% Elong. IN 2"	Hard- ness HB	Size, MM x 10 mm	Temp. °F	FOOT POUNDS		LATERAL EXPANSION		% SHEAR		
XMP	78.2 L	49.6	38.0	197									
XLR	71.3 L	45.1	42.3	197									
XLK	70.0 L	45.2	43.8	197									
LYH1	80.1 L	57.2	30.0	132									

* L = LONGITUDINAL, T = TRANSVERSE, R = ROUND, S = STRIP

HACKNEY is a domestic manufacturer, and these items conform to the following specifications as they apply:
FITTINGS: ASTM A234 WPB, ASME SA234 WPB, ANSI B16.9, B16.28, and NACE MR01-75.
FLANGES: ASTM A105 AND A516-70, ASME SA105, ANSI B16.5, and NACE MR01-75.
were heat treated as required by the applicable specification. They also conform to the requirements of Parts 192 and 195, Title 49, Code of Federal Regulations. All welded fittings are welded by certified welders to ASME Section VIII, Division 1, and 100% radiographically examined per Article 2, ASME Section V. All are in accordance with the requirements of Paragraph UG-117, Section VIII, Division 1, of the ASME Code. Hackney weld caps meet ASME Division 1, Section VIII Pressure Vessel Code Requirements, Paragraph UCS-79d. We certify these flanges and fittings capable of passing a hydrostatic test compatible with their rating, and that above figures are correct as contained in the records of the Company. Hardness testing and stamping are per NACE MR01-75.

THE TUBE GROUP

Subnex

TEXAS PIPE & SUPPLY CO. INC. ROSENBERG, TEXAS 77471

P.O.#81380

P.O. BOX 552
ROSENBERG, TEXAS 77471
(713) 342-5431
800-231-5024

ORDER NUMBER	CUSTOMER ORDER NUMBER	DATE	QTY	COM	DIV	MTLS	GRS	ACCOUNT NUMBER	US	FP	JNB
073539	81380	09/28/94	23	00	16	20	01	05712000000			

TEXAS PIPE & SUPPLY CO INC
2330 HOLMES ROAD
HOUSTON TX 77051

ROUTING	COL-CUST TRK-TR W/SHPT	PER SPEC	ROUND	HOT FINISH	PER SPEC	OCTOBER
SEAMLESS	ASTM/ASME A/SA 106 B 90	HF CARBON PIPE	10/31/94			

SPECIAL INSTRUCTIONS:
PLAIN ENDS - U.V.C. COAT
ACCEPTABLE PER NACE MRO 175 TABLE 3
AIM FOR 20' MIN. LENGTHS

ITEM	QUANTITY	O.D.	I.D.	WALL	LENGTH	WT/FT	WEIGHT	REMARKS
1	12,800'	1.315		.133 AVG	RAND 17' 24'	1.679	21,491	Comp. 589 pcc 12,548

MILL TEST REPORTS FURNISHED BY
TEXAS PIPE & SUPPLY CO. INC.
CUSTOMER
CUSTOMER PO#

HEAT NO.	C	Mn	P	S	Si	Fe	Cr	Mo	Cu	Pb	REMARKS
601244	.17	.67	.014	.012	.25	.07	.04	.01	.16		V .002
	.17	.67	.014	.012	.26	.07	.04	.02	.16		V .002
601174	.17	.71	.014	.016	.23	.08	.03	.02	.20		V .002
	.17	.70	.014	.017	.23	.09	.03	.02	.20		V .002

FLATTEN		FLARE	FLANGE	REV. FLATTEN	HYDRO TEST 2500 PSI CK	BEND CK	EDDY CURRENT			
HEAT NO.		ULT. STR. PSI	YIELD PSI	ELONG 2"	HARDNESS	HEAT NO.	ULT. STR. PSI	YIELD PSI	ELONG 2"	REMARKS
601244		67900	45900	48.0						
601174		70400	47900	50.0						

I CERTIFY THAT THE MATERIAL HEREIN DESCRIBED HAS BEEN MANUFACTURED IN ACCORDANCE WITH THE ORDERED SPECIFICATION AND THAT THIS TEST INFORMATION IS CORRECT AS CONTAINED IN THE RECORDS OF THE COMPANY.

ALZBRANCK

SWORN TO AND SUBSCRIBED BEFORE ME THIS 4th DAY OF OCTOBER 1994

NOTARY



HACKNEY, INC.

A DIVISION OF TRINITY INDUSTRIES
P.O. Box 568887 • 2525 Stemmons Freeway
Dallas, Texas 75356-8887 • (214) 634-2850

YOUR ORDER NUMBER	REFERENCE	CUSTOMER NO.	INVOICE NO.	INVOICE DATE	DATE SHIPPED
0099-002979	C139654	454634	819873	12/02/94	12/02/94

LD TO: H & M SUPPLY CO
PO BOX 548
DUNCAN OK 75533

SHIP TO: H & M SUPPLY
3923 OKLAHOMA AVE
HODDWARD, OK 73801

CERTIFIED TEST REPORT

ITEM		QUANTITY	DESCRIPTION/SPECIFICATION										HEAT CODE
1	24		2 150 RF WN STD	A105-93B/SA105	AS FORGED								0994EH
4	20		A105 26 / 494-3258	A105-93B/SA105	AS FORGED								0894CS
6	14		6 150 RF WN STD	A105-93B/SA105	AS FORGED								0694AM
8	8		A105 32 / 62367	A105-93B/SA105	AS FORGED								0894BV
			3 150 RF BLD	A105-93B/SA105	AS FORGED								
			A105 32 / 60633	A105-93B/SA105	AS FORGED								
			6 150# RF BLIND A105	A105-93B/SA105	AS FORGED								
			A105 32 / 62311	A105-93B/SA105	AS FORGED								
CHEMICAL ANALYSIS													
ITEM CODE	C	Mn	P	S	Si	Cr	Mo	Ni	Cu	V	Nb	CE	
0994EH	.20	.83	.024	.027	.27	.11	.02	.00	.00	.00	.00	.40	
0894CS	.21	.94	.009	.017	.23	.09	.02	.00	.00	.00	.00	.41	
0694AM	.20	.87	.008	.016	.22	.08	.02	.00	.00	.00	.00	.39	
0894BV	.20	.89	.014	.013	.21	.10	.02	.22	.08	.00	.00	.39	
CHARPY RESULTS													
PHYSICAL PROPERTIES													
HEAT CODE	TENSILE * KSI	YIELD KSI	% Elong. IN 2"	Hard- ness HB	Size MM x 10 mm	Temp. °F	FOOT POUNDS	LATERAL EXPANSION	% SHEAR				
0994EH	78.4	45.7	29.0	135									
0894CS	78.4	44.5	28.0	147									
0694AM	75.6	41.8	33.0	141									
0894BV	76.0	44.4	30.0	139									

*L = LONGITUDINAL, T = TRANSVERSE, R = ROUND, S = STRIP

HACKNEY is a domestic manufacturer, and these items conform to the following specifications as they apply:
FITTINGS: ASTM A234 WPB, ASME SA234 WPB, ANSI B16.9, B16.28 and NACE MR01-75.
FLANGES: ASTM A105 AND A516-70, ASME SA105, ANSI B16.5 and NACE MR01-75.

All items were heat treated as required by the applicable specification. They also conform to the requirements of Parts 192 and 195, Title 49, Code of Federal Regulations. All welded fittings are welded by certified welders to ASME Section VIII, Division 1, and 100% radiographically examined per Article 2, ASME Section V. All are in accordance with the requirements of Paragraph UG-11, Section VIII Division 1, ASME Code. Hackney weld caps meet ASME Division 1, Section VIII Pressure Vessel Code Requirements, Paragraph UCS-79d. We certify these flanges and fittings are capable of passing a hydrostatic test compatible with their rating, and that the above figures are correct as contained in the records of the Company. Hardness testing and stamping are per NACE MR01-75.



HACKNEY, INC.

A DIVISION OF TRINITY INDUSTRIES
P.O. Box 568887 • 2525 Stemmons Freeway
Dallas, Texas 75356-8887 • (214) 634-2850

YOUR ORDER NUMBER	REFERENCE	CUSTOMER NO.	INVOICE NO.	INVOICE DATE	DATE SHIPPED
0099-002979	C139654	454634	821782	12/16/94	12/16/94

TO: M & H SUPPLY CO
PO. BOX 548
DUNCAN, OK 75533

SHIP TO: M & H SUPPLY
3923 OKLAHOMA AVE
WOODWARD, OK 73801

CERTIFIED TEST REPORT

EM	QUANTITY	DESCRIPTION/SPECIFICATION	HEAT CODE
2	30	3 150 RF WN STD A105 26 / 494-3217 A105-93B/SA105 AS FORGED	0994EX
3	8	4 150 RF WN STD A105 04 / 8495H2021 A105-93B/SA105 AS FORGED	1194BQ
5	14	8 150 RF WN STD A105 32 / 63195 A105-93B/SA105 AS FORGED	1094BT
7	6	4 150 RF BLIND A105 26 / 494-3250 A105-93B/SA105 AS FORGED	1194DA

CODE	C	Mn	P	S	Si	Cr	Mo	Cu	Ni	V	Nb	CE
EX	.19	.90	.018	.023	.26	.07	.01	.34	.09	.00	.00	.39
1194BQ	.24	.98	.014	.025	.25	.09	.02	.27	.07	.00	.00	.45
1094BT	.19	.86	.007	.014	.23	.06	.02	.18	.08	.00	.00	.37
1194DA	.21	.91	.024	.024	.22	.14	.01	.28	.08	.00	.00	.42

HEAT CODE	TENSILE * KSI	YIELD KSI	% Elong. IN 2"	Hard- ness HB	Size MM x 10 mm	Temp. °F	FOOT POUNDS	LATERAL EXPANSION	% SHEAR
0994EX	73.5	41.0	32.0	141					
1194BQ	83.4	46.6	30.0	150					
1094BT	75.4	42.8	34.0	132					
1194DA	79.9	46.5	28.0	153					

* = LONGITUDINAL, T = TRANSVERSE, R = ROUND, S = STRIP

HACKNEY is a domestic manufacturer, and these items conform to the following specifications as they apply:
FITTINGS: ASTM A234 WPB, ASME SA234 WPB, ANSI B16.9, B16.28, and NACE MR01-75.
FLANGES: ASTM A105 AND A516-70, ASME SA105, ANSI B16.5, and NACE MR01-75.

If items were heat treated as required by the applicable specification. They also conform to the requirements of Parts 192 and 195, Title 49, Code of Federal Regulations. All welded fittings are welded by certified welders to ASME Section VIII, Division 1, and 100% radiographically examined per Article 2, ASME Section V. All are in accordance with the requirements of Paragraph UG-11, Section VII, Division 1 of the ASME Code. Hackney weld caps meet ASME Division 1, Section VIII Pressure Code Requirements, Paragraph UCS-79d. We certify these flanges and fittings capable of passing a hydrostatic test compatible with their rating, and that the above figures are correct as contained in the records of the Company. Hardness testing and stamping are per NACE MR01-75.



HACKNEY, INC.

A DIVISION OF TRINITY INDUSTRIES
P.O. Box 568887 • 2525 Stemmons Freeway
Dallas, Texas 75356-8887 • (214) 634-2850

YOUR ORDER NUMBER	REFERENCE	CUSTOMER NO.	INVOICE NO.	INVOICE DATE	DATE SHIPPED
0099-002979	C139654	454634	824237	01/12/95	01/12/95

SHIPPED TO: M & M SUPPLY CO
PO BOX 548
DUNCAN OK 75533

SHIP TO: M & M SUPPLY
3923 OKLAHOMA AVE
WOODWARD, OK 73801

CERTIFIED TEST REPORT

CERTIFIED TEST REPORT

U 414 (R 12/93)

ITEM		QUANTITY	DESCRIPTION/SPECIFICATION										HEAT CODE
12		6	4 150 RF SO A105 26 / 494-1178 AS FORGED A105-93B/SA105										0794BM
14		6	2 150 RF THRD A105 26 / 494-3254 AS FORGED A105-90A/SA105										0994DX
15		12	1 150 RF SH STD A105 LS 25545 AS FORGED A105-93B/SA105										1192DE
19		8	2 300 RF BLIND A105 26 / 494-3205 AS FORGED										0994DH

CHEMICAL ANALYSIS													
CODE	C	Mn	P	S	Si	Cr	Mo	Cu	Ni	V	Nb		CE
BM	.25	.97	.016	.028	.22	.07	.02	.37	.09	.00	.00		.46
0994DX	.20	.87	.017	.026	.28	.08	.02	.29	.09	.00	.00		.39
1192DE	.18	.98	.011	.021	.23	.09	.01	.20	.08	.02	.02		.39
0994DH	.22	.86	.015	.024	.19	.06	.02	.23	.09	.00	.00		.40

MECHANICAL PROPERTIES										CHARPY RESULTS		
HEAT CODE	TENSILE * KSI	YIELD KSI	% Elong. IN 2"	Hard- ness HB	Size MM x 10 mm	Temp. °F	FOOT POUNDS	LATERAL EXPANSION	% SHEAR			
0794BM	88.2	54.8	27.0	165								
0994DX	86.2	49.4	30.0	144								
1192DE	86.2	55.6	26.0	156								
0994DH	81.8	60.8	33.0	141								

BOUND S - STRIP

L = LONGITUDINAL, T = TRANSVERSE, R = ROUND, S = STRIP

HACKNEY is a domestic manufacturer, and these items conform to the following specifications as they apply:
FITTINGS: ASTM A234 WPB, ASME SA234 WPB, ANSI B16.9, B16.28, AND NACE MR01-75.
FLANGES: ASTM A105 AND AS16-70, ASME SA105, ANSI B16.5, AND NACE MR01-75.

All items were heat treated as required by the applicable specification. They also conform to the requirements of Parts 192 and 195, Title 49, Code of Federal Regulations. All welded fittings are welded by certified welders to ASME Section VIII, Division 1 of the ASME code. Hackney weld caps meet ASME Division 1, Section VIII Pressure Requirements, Paragraph UCS-79d. We certify these flanges and fittings capable of passing a hydrostatic test compatible with their rating, and that the above figures are correct as contained in the records of the Company. Hardness testing and stamping are per NACE MR01-75.



HACKNEY, INC.

A DIVISION OF TRINITY INDUSTRIES
P.O. Box 568867 • 2525 Stemmons Freeway
Dallas, Texas 75356-8867 • (214) 634-2850

YOUR ORDER NUMBER	REFERENCE	CUSTOMER NO.	INVOICE NO.	INVOICE DATE	DATE SHIP
0005-000190	C105278	454634	944862	04/15/93	04/15/93

SOLD TO: H. & M. SUPPLY CO.
PO BOX 548
DUNCAN, OK. 75533

SHIP TO: H. & M. SUPPLY
2512 N. 4TH
ENID, OK 73701

CERTIFIED TEST REPORT

ITEM		QUANTITY	DESCRIPTION/SPECIFICATION										HEAT CODE
6	2		10 STD WC	A234-92A/SA234 WPB									AZAZ
7	4		A516-70 TUSCL 421C088	A234-92A/SA234 WPB									KWS1
8	8		3X2-1/2 STD CONC	STRESS RELIEVED AT 1200 F									LAT1
9	2		A106B USS L40421	A234-92A/SA234 WPB									LA01
			4X2 STD CONC	STRESS RELIEVED AT 1200 F									
			A106B USS X46453	A234-92A/SA234 WPB									
			6X4 STD CONC	STRESS RELIEVED AT 1200 F									
			A106B NSS FX0054										
CODE		C	Mn	P	S	Si	Cr	Mo	Cu	Ni	V	Nb	Fe
AZAZ		.26	1.12	.020	.010	.22	.03	.00	.01	.02	.00	.00	.46
KWS1		.18	1.02	.011	.004	.25	.05	.01	.15	.01	.00	.00	.37
LAT1		.17	.78	.010	.005	.23	.03	.01	.01	.01	.00	.00	.31
LA01		.15	.65	.008	.004	.22	.07	.02	.17	.08	.00	.00	.29

MECHANICAL PROPERTIES										RESULTS	
HEAT CODE	TENSILE * KSI	YIELD KSI	% Elong. IN 2"	Hardness HB	Size MM x 10 mm	Temp. °F	FOOT POUNDS	LATERAL EXPANSION	SHEAR		
AZAZ	85.0 T	58.8	33.0	197							
KWS1	72.8 L	47.2	31.0	130							
LAT1	76.9 L	49.1	31.0	115							
LA01	68.5 L	47.9	30.0	117							

* L = LONGITUDINAL, T = TRANSVERSE

AZAZ, KWS1, LAT1, LA01 CONFORM TO THE REQUIREMENTS OF NACE MR0175-92

Items were heat treated in accordance with the requirements of the specification to which they were manufactured.

We hereby certify that the products covered by this report comply with the applicable requirements of ASTM and/or ASME specifications, as noted for each item.

We hereby certify that the above figures are correct, as contained in the records of the Company.

Shirley L. L. L.



HACKNEY, INC.

A DIVISION OF TRINITY INDUSTRIES
P.O. Box 568887 • 2525 Stemmons Freeway
Dallas, Texas 75356-8887 • (214) 634-2850

YOUR ORDER NUMBER	REFERENCE	CUSTOMER NO.	INVOICE NO.	INVOICE DATE	DATE SHIP
0099-000662	C114322	454634	966462	09/22/93	09/22/93

LD TO: M & M SUPPLY CO
PO BOX 548
DUNCAN, OK 75533

SHIP TO: M & M SUPPLY
201 SE 3RD.
LINDSAY, OK 73052

CERTIFIED TEST REPORT

ITEM	QUANTITY	DESCRIPTION/SPECIFICATION	HEAT CODE
9	12	8 STD WC A516-70 TUSCL: 5872530 A234-92A/SA234 WPB	AZDF
10	8	3X2 STD CONC. A106E 09 / L60626 A234-92A/SA234 WPB STRESS RELIEVED AT 1200 F	LKE1
11	6	6X4 STD CONC. A106B USS U42761 A234-92A/SA234 WPB STRESS RELIEVED AT 1200 F	C59D
13	12	3 STD LR 90 A106E 09 / L60626 A234-92A/SA234 WPB STRESS RELIEVED AT 1200 F	LKE1

CODE	C	Mn	P	S	Si	Cr	Mo	Cu	Ni	V	Nb	C.E.
F	.25	1.02	.019	.013	.21	.03	.00	.05	.03	.00	.00	.43
LKE1	.18	.80	.011	.006	.26	.04	.01	.02	.02	.00	.00	.33
C59D	.17	.77	.010	.008	.23	.03	.01	.01	.01	.00	.00	.31
LKE1	.18	.80	.011	.006	.26	.04	.01	.02	.02	.00	.00	.33

HEAT CODE	TENSILE * KSI	YIELD KSI	% ELONG IN 2"	Hard- ness HB	Size MM x 10 mm	Temp °F	FOOT POUNDS	LATERAL EXPANSION	% SHEAR
AZDF	82.2	56.8	29.0	197					
LKE1	70.3	44.4	26.0	123					
C59D	70.6	52.8	28.0	118					
LKE1	70.3	44.4	26.0	123					

L = LONGITUDINAL, T = TRANSVERSE

LKE1, C59D, LKE1 CONFORM TO THE REQUIREMENTS OF NACE MR0175-92

Items were heat treated in accordance with the requirements of the applicable specifications and/or ASME specifications, as noted for each item.
We hereby certify that the above figures are correct, as contained in the test report.

John L. Flannery



Secondary Containment Corrosion Protection



Tank Corrosion Protection

INTERIOR COATING SYSTEM

SURFACE PREPARATION

SSPC-SP 5 "WHITE METAL BLAST CLEANING," 2.0-3.0 MILS SURFACE PROFILE.

PRIME COAT

APPLY BY SPRAY TO ALL INTERIOR SURFACES, ONE COAT OF PLASITE 7156 HI-RESISTANT HEAVY BUILD PROTECTIVE COATING, IVORY, AT A DRY FILM THICKNESS OF NOT LESS THAN 5.0 MILS. A MINIMUM DRYING TIME OF 12 HOURS AT 70° SHALL BE ALLOWED BEFORE APPLICATION OF THE FINISH COAT.

WELD AND SEAM STRIPE COAT

APPLY BY HIGH QUALITY BRUSH, ONE COAT OF PLASITE 7156 HI-RESISTANT HEAVY BUILD PROTECTIVE COATING, IVORY, TO ALL WELDS AND SEAMS.

FINISH COAT

APPLY BY SPRAY, TO ALL INTERIOR SURFACES, ONE FINISH COAT OF PLASITE 7156 HI-RESISTANT HEAVY BUILD PROTECTIVE COATING, LIGHT GRAY, AT A DRY FILM THICKNESS OF NOT LESS THAN 5.0 MILS. A MINIMUM DRYING TIME OF 7 DAYS AT 70° F SHALL ELAPSE AFTER COMPLETION OF THE INTERIOR PAINT SYSTEM BEFORE THE TANK CAN BE PLACED IN SERVICE.

TOTAL DRY FILM THICKNESS

THE TOTAL DRY FILM THICKNESS SHALL NOT BE LESS THAN 10.0 MILS. PER SSPC DRY FILM THICKNESS MEASURING STANDARD. ADDITIONAL FINISH COATS WILL BE APPLIED IN AREAS OF DEFICIENT THICKNESS.

EXTERIOR COATING SYSTEM

SURFACE PREPARATION

SSPC-SP10 "NEAR WHITE METAL BLAST CLEANING," 2.0-3.0 MILS SURFACE PROFILE.

PRIME COAT

APPLY BY SPRAY TO ALL EXTERIOR SURFACES. ONE COAT OF GLID-GUARD CORROSION RESISTANT H S EPOXY NO. 5466 SERIES, GRAY, AT A DRY FILM THICKNESS OF NOT LESS THAN 3.0 MILS.



TECHNICAL BULLETIN



7156
March 1993
(Replaces May 1985)

PLASITE 7156 HI-RESISTANT HEAVY BUILD PROTECTIVE COATING

TYPE: A water-resistant epoxy coating polymerized with an amine adduct-type curing agent.

INTENDED USE: Primarily as a tank lining for water, including low conductivity deionized or distilled water at elevated temperatures, as well as use with brines and petroleum processes. Designed and laboratory confirmed for immersion in demineralized water at 250°F.

FOR INDUSTRIAL USE ONLY!

GOVERNMENT AGENCY ACCEPTANCE: Meets the requirements of the U.S. Food and Drug Administration, 21 CFR 175.300.

Accepted by the U.S. Department of Agriculture for surfaces which contact potable water and for incidental food contact. Accepted by the U.S. Environmental Protection Agency for surfaces which contact potable water.

NSF REQUIREMENT GUIDE - PLASITE 7156 is certified by the National Sanitation Foundation (NSF) to Standard 61 for potable water up to 180°F when the following requirements are met. PLASITE 71 Thinner, up to a maximum of 15%, must be used for thinning purposes. Prior to placing the lining in service it must be force cured at 200°F metal temperature for four hours.

CHEMICAL RESISTANCE: Excellent resistance to waters and brines at elevated temperatures. Refer to **CHEMICAL RESISTANCE** on Page 2.

TEMPERATURE RESISTANCE: Dry film basis is 400°F for short periods. Continuous immersion temperatures depend on particular reagent and temperatures.

SURFACE PREPARATION: Steel surfaces shall be prepared by blasting to white metal since this coating is intended for use in immersion service. Refer to Page 3 for details on **SURFACE PREPARATION**.

APPLICATION: PLASITE 7156 is formulated for use as a spray applied coating. Refer to **SPRAY EQUIPMENT** on Page 4.

COLORS: Ivory; Light gray. Special colors are available but may not be suitable for food service. Consult PLASITE Technical Service Department.

FILM THICKNESS PER COAT: A 5 to 6 mil film is produced in one multi-pass spray coat. A total film thickness of 10 to 12 mils is required for immersion service.

COVERAGE: 850 mil ft²/gallon $\pm 2\%$ (theoretical). For estimating purposes, 57 ft²/gallon will produce a 10 to 12 mil DFT film (20% loss included). Two multi-pass spray coats will produce the 10 to 12 mil DFT film recommended for immersion service.

DRYING TIME: Surface will normally be tack free in 2 hours at 70°F.

CURING TIME: 7 days at 70°F to 90°F; 20 days at 30°F to 50°F. Consult laboratory for possible difference in resistance of coating when curing at the lower temperatures. Refer to Page 2 for force curing.

PHYSICAL SPECIFICATIONS

PIGMENTS: Titanium dioxide, inerts and tinting colors.

SOLIDS: 74% $\pm 2\%$ by weight; 53% $\pm 2\%$ by volume.

POT LIFE: Approximately 8 to 10 hours at 70°F.

SHELF LIFE: 24 months at 70°F. Material in stock should be turned upside down every 3 months.

SPRAY VISCOSITY: At 70°F, 17 ± 5 seconds Ford Cup #4.

SHIPPING WT.: Approximately 13.5 lbs./gallon.

average, 1000 cycles, Taber CS-17 Wheel, 1000 Gr. Wt. Ivory Color.

***SURFACE HARDNESS:** Konig Pendulum Hardness of 113 seconds; (Glass Standard = 250 seconds) ASTM Method D4366-84.

THERMAL SHOCK: Unaffected in 5 cycles, minus 70°F to plus 212°F.

GLOSS: 7.0 at 60°.

***ABRASIVE RESISTANCE:** 75.3 milligrams loss. ***NOTE:** Above tests were conducted on film cured at 150°F.

VOLATILE ORGANIC COMPOUNDS CONTENT COATING AS SUPPLIED (ASTM METHOD D2369)

THINNED 10% BY VOLUME
WITH PLASITE 71 THINNER

COLOR	Lbs./Gal.	Grams/Liter	*Lbs./Gal	*Grams/Liter
Ivory	3.06 $\pm 2\%$	368 $\pm 2\%$	3.39 $\pm 2\%$	406 $\pm 2\%$
Lt. Gray	3.12 $\pm 2\%$	374 $\pm 2\%$	3.45 $\pm 2\%$	413 $\pm 2\%$

*Determined theoretically by using ASTM Method test results.

WISCONSIN PROTECTIVE COATINGS CORP.
614 Elizabeth Street
P.O. Box 8147
Green Bay, WI 54308-8147
414-437-6561

Represented by:

ZONE OF USAGE

A ZONE: This would include immersion service for process and storage vessels. A film thickness of 10 to 12 mils required.

CHEMICAL RESISTANCE

The following list of laboratory tests is an indication of the range of chemical resistance. These tests consist of 1" x 5" mild steel test panels coated to a film thickness of 12 mils. The panels are one-half immersed in the solution at noted temperatures for a period of six months with no effect on the coating.

WATERS		ALKALIES		MISCELLANEOUS	
Demineralized	250°F	50% Sodium Hydroxide	150°F	50% Sodium Chlorate	150°F
Sea Water	212°F	50% Magnesium Hydroxide	100°F	Crude Oil	210°F
		25% Sodium Hydroxide	150°F	Ethylene Glycol	100°F
		10% Calcium Hydroxide	150°F		

NOTE: Although the chemical tests indicated show that PLASITE 7156 is unaffected by immersion as listed, it is not meant to imply an express guarantee in actual service. The service is dependent upon proper application and actual operating conditions and it is recommended that users confirm adaptability of the product for a specific use by their own tests. PLASITE 7156 is not suitable for service in corrosive acids or oxidizing service for continuous immersion.

THINNERS

The following thinners are recommended:

PLASITE 71 Thinner — a medium-fast thinner to be used under most conditions (above 50°F).

PLASITE 20 Thinner — a fast thinner to be used when applying at lower temperatures (below 50°F).

The amounts of thinner required will vary depending on air and surface temperatures and application equipment. Normal application temperatures and conditions will require addition of approximately 10% by volume with approximately 5% additional thinner added for each 5° of increased temperature. Airless spray equipment and above normal temperatures require additional thinning.

It is recommended that the amount of thinner included on each order amount to approximately 20% of the coating order.

PRIMERS

PLASITE 7104 inhibitive primer is available for use in special applications such as pre-priming of blasted steel surfaces prior to final fabrication or erection and prior to application of final topcoats. The propriety of such a system should be determined by consulting plant laboratory or by prior experience or testing.

PLASITE 7104 Primer is applied at a spreading rate of 206 ft²/gallon for a 3 mil DFT (20% loss included). The PLASITE 7156 Coating, for ZONE A Service, is normally intended for use as a self-priming system with a separate primer not required.

PLASITE 7104 Primer is NOT recommended for potable water service.

CURING

1. For immersion service, complete curing will normally take place in 7 days at 70°F, 14 days at 50°F, or 20 days at 30°F to 50°F. As ventilation and other factors affect the time/cure of coatings, additional time allowance is recommended at any temperature if cure time is questioned. When exposure is severe, force curing is recommended to obtain maximum resistance.
2. With adequate ventilation, when applying at temperatures between 30°F and 50°F, coating surfaces will normally be tack free in 16 to 24 hours; between 50°F and 70°F, 2 to 16 hours.
3. Force curing at elevated temperature is desirable for certain exposures. Where coating is to be subjected to immersion in taste sensitive solutions, it is recommended that the curing temperature be at 200°F for 4 hours. In order to ensure the complete removal of solvent and odor, force curing is recommended when coating is to be used in potable water and food material service.
4. Listed below are a few force curing schedules that may be used for time and work planning. When applying at temperatures of 30°F to 60°F, allow 16 to 24 hours air dry time prior to raising the metal temperature to the force curing temperature. When applying at temperatures above 60°F to 70°F, allow 2 to 5 hours air dry time. After the appropriate air dry period, raise metal temperature approximately 30°F each 30 minutes until the desired force curing metal temperature is reached.

METAL TEMPERATURE °F	CURING TIME	METAL TEMPERATURE °F	CURING TIME
130	18 Hours	170	3½ Hours
140	10 Hours	180	2½ Hours
150	6 Hours	190	2 Hours
160	4½ Hours	200	1¾ Hours

Final cure may be checked by exposing coated surface to ethyl alcohol for ten minutes. If no dissolving and only minor softening of film occurs, the curing can be considered complete. The film will reharden after exposure if cured.

SURFACE PREPARATION

STEEL

Immersion Service (Zone A as described under ZONE OF USAGE).

1. All sharp edges shall be ground to produce a radius and all imperfections, such as, skip welds, delaminations, scabs, slivers and slag, shall be corrected prior to abrasive blasting. Skip welds shall be welded solid.
2. Degrease surface prior to sandblasting. Organic solvents, alkaline solutions, steam, hot water with detergents or other systems that will completely remove dirt, oil, grease, etc. may be used. Used tanks may require additional decontamination.
3. The surface shall be blasted to an SSPC-SP5 or NACE No. 1 white metal surface using a Venturi blast nozzle supplied with 80 to 100 psi. An anchor pattern or "tooth" in the metal shall correspond to approximately 20 to 25% of the total film thickness of the coating.
4. Contaminated grit shall not be used for the finish work.
5. The blasting media used shall be a natural abrasive, or steel grit, or slag grit (similar or equal to BLACK BEAUTY®). These abrasives shall be sharp with a hard-cutting surface, properly graded, dry, and of best quality. The media shall be of proper size to obtain the specified anchor pattern and shall be free of objectionable contaminants.
6. The anchor pattern shall be sharp and no evidence of a polished surface is allowed.
7. Remove all traces of grit and dust with a vacuum cleaner or by brushing. Care must be taken to avoid contaminating the surface with fingerprints or from detrimental material on the workers' clothes.
8. The surface temperature shall be maintained at a minimum of 5° above the dew point to prevent oxidation of the surface. The coating shall be applied within the same day that the surface has been prepared.

When utilized, inhibitive primer should be applied as soon as possible after surface preparation.

NOTE: The above specification numbers are from Steel Structure Painting Council Surface Preparation Specifications, 4516 Henry Street, Suite 301, Pittsburgh, PA 15213-3728 and National Association of Corrosion Engineers, P.O. Box 218340, Houston, TX 77218.

CONCRETE

Immersion Service (Zone A as described under ZONE OF USAGE).

All concrete surfaces require whip blasting with No. 50 grit for immersion service. Fully cured concrete must be blasted to provide a hard, firm, clean and neutral surface for coating. All concrete surfaces must be filled and sealed with PLASITE 9028M1 or PLASITE 9028M2, applied in accordance with appropriate PLASITE bulletin. All surface imperfections, "bug holes," etc. must be completely repaired before application of PLASITE 7156. PLASITE 9028M1 or PLASITE 9028M2 are not recommended for food or potable water service. Ref. Force Curing recommendation for taste sensitive solutions.

ALUMINUM

Surface shall be clean and grease free with a blast produced anchor pattern or "tooth" as described earlier under "STEEL." In addition, the blasted surface shall be given a chemical treatment such as:

ALODINE® 1200S available from
Parker & Amchem
32100 Stephenson Highway
Madison Heights, MI 48071
(800) 521-1355

IRIDITE® 14-2 produced by
Allied-Kelite Division of
Witco Corporation
2701 Lake Street
Melrose Park, IL 60160
(800) 323-9784

OAKITE® CRYSCOAT 747LTS Plus
OAKITE® CRYSCOAT ULTRASEAL
Produced by Oakite Products
50 Valley Road
Berkeley Heights, NJ 07922
(908) 464-6900
Canada: (416) 791-1628

SPRAY APPLICATION

1. All spray equipment should be thoroughly cleaned and the hose, in particular, should be free of old paint film and other contaminants.
2. Use standard production type spray guns:

GUN	FLUID	AIR
DeVilbiss JGA-503	E	797
Binks #18	66-SS	63-PB
Graco P800	04	02
3. When airless spray equipment is used, the recommended liquid pressure is 1500 to 1800 psi with tip size from .015" to .021". Thinning requirements are more than for conventional spray.

BRUSH APPLICATION

A high quality brush should be used.

READ THIS NOTICE!!

SAFETY AND MISCELLANEOUS EQUIPMENT

1. For tank lining work, it is recommended that the operator

EQUIPMENT

provide himself with clean coveralls and rubber soled shoes and observe good personal hygiene. Certain personnel may be sensitive to various types of resins which may cause dermatitis.

2. THE SOLVENT IN THIS COATING IS FLAMMABLE AND CARE AS DEMANDED BY GOOD PRACTICE, OSHA, STATE AND LOCAL SAFETY CODES, ETC. MUST BE FOLLOWED CLOSELY. Keep away from heat, sparks and open flame and use necessary safety equipment, such as, air mask, explosion-proof electrical equipment, non-sparking tools and ladders, etc. Avoid contact with skin and breathing of vapor or spray mist. When working in tanks, rooms and other enclosed spaces, adequate ventilation must be provided. Refer to PLASITE Bulletin PA-3. Keep out of the reach of children.
3. CAUTION - Read and follow all caution statements on this product technical bulletin, material safety data sheet and container label for this product.

MIXING

The catalyst is in a separate container and measured for the coating unit supplied. Thoroughly mix the pigments. After the pigment and liquid is thoroughly mixed, add the measured liquid catalyst slowly and mix completely with the coating. The coating should stand approximately 30 minutes after the catalyst has been thoroughly mixed.

APPLICATION PROCEDURE

SPRAY GUN

1. Air supply shall be uncontaminated. Adjust air pressure to approximately 50 lbs. at the gun and provide 5 to 10 lbs. of pot pressure. Adjust spray gun by first opening liquid valve and then adjusting air valve to give an 8" to 12" wide spray pattern with best possible atomization.
2. Apply a "mist" bonding pass.
3. Allow to dry approximately one minute but not long enough to allow film to completely dry.
4. Apply crisscross multi-passes maintaining an even continuous wet appearing film. This technique will enable a 10 to 12 mil wet film (approximately 5 to 6 mils DFT) to be applied per multi-pass coat.
5. OVERCOAT TIME will vary both with temperature and ventilation. Will normally require 8 to 12 hours at 70°F for enclosed spaces with additional time needed if coating is being applied at lower temperatures. Remove all overspray by dry brushing or scraping if required.

6. By repeating Step No. 4 a homogeneous film of 10 to 12 mils is obtained.
7. Equipment must be thoroughly cleaned immediately after use with PLASITE thinner to prevent the setting of the coating.

NOTE: All welds, pits and rough metal areas should be coated by brush prior to spray application.

BRUSH APPLICATION

(Recommended for small areas and repairs only)

1. Apply a very light crisscross brush coat.
2. Allow to dry for approximately 5 minutes.
3. Apply a heavy coat using crisscross brush pattern. "Flow" the coating on rather than try to "brush out."
4. Allow to dry tack-free.
5. Repeat Steps 3 and 4 until sufficient film thickness is obtained. Normally a film thickness of 2½ to 3 mils can be obtained per coat by this method.

INSPECTION

Degree of surface preparation shall conform to appropriate specifications as outlined in SURFACE PREPARATION section. Film thickness of each coat and total dry film thickness of coating system shall be determined with a non-destructive magnetic gauge properly calibrated.

Refer to PLASITE Bulletin PA-3, Section 3, for inspection requirements.

This bulletin provides standard information on the coating and application procedure. Since varying conditions may not be covered, consult your local sales representative or PLASITE Technical Service Department for further information.

METRIC COMPARISONS

$$1 \text{ mil} = .001" = 25.4 \text{ microns}$$

$$1 \text{ U.S. gallon} = 3.785 \text{ liters}$$

$$1 \text{ sq. ft.} \times 0.0929 = \text{sq. meters}$$

$$^{\circ}\text{C} = \frac{5(^{\circ}\text{F} - 32)}{9}$$

**Glidden****PROTECTIVE MAINTENANCE COATINGS DATA**

For Industrial Use and Professional Application Only
Rust Inhibitive Polyamide Epoxy Coating

**GLID-GUARD® Corrosion Resistant HS
Epoxy No. 5465 Series**

For Interior-Exterior Metal

Read Label and Material Safety Data Sheet Prior to Use.
See other cautions on last page. DSF1-0690

PRODUCT DESCRIPTION

GLID-GUARD Corrosion Resistant HS Epoxy is a low VOC, high solids, two package polyamide epoxy coating intended for direct application to interior and exterior metal. It is rust inhibitive and resistant to moisture and many chemicals. The product's excellent penetrating properties result in superior adhesion.

This product is an excellent choice for application to metal when surface preparation is limited to Hand Tool or Power Tool Cleaning. It is also suitable for use as a high build intermediate coat in heavy-duty industrial systems and may be used as a topcoat when the color and sheen are acceptable.

Like most epoxy coatings, GLID-GUARD Corrosion Resistant HS Epoxy will chalk and lose gloss on exposure to direct sunlight but will maintain excellent film integrity and continue to provide excellent protection to the substrate.

PRODUCTS AVAILABLE

GLID-GUARD Corrosion Resistant HS Epoxy Red No. 5465 (Component A)
GLID-GUARD Corrosion Resistant HS Epoxy Gray No. 5466 (Component A)
GLID-GUARD Corrosion Resistant HS Epoxy White No. 5467 (Component A)
GLID-GUARD Corrosion Resistant HS Epoxy Aluminum Mastic No. 5468 (Component B)
GLID-GUARD Corrosion Resistant HS Epoxy Curing Agent No. 5469 (Component B)

NOTE: Refer to Protective Maintenance Coatings Data sheet Section 8 No. 29 for detailed information on Aluminum Mastic No. 5468.

TYPICAL USES

Ideal for use as a primer and intermediate build coat on storage tanks, structural steel, machinery and equipment in the food processing industries, chemical industries, petroleum refineries, paper mills, marine structures, mining industries, waste water treatment facilities, and general industrial buildings.

PRODUCT ADVANTAGES

- Low VOC
- Rust inhibitive
- Tolerates surface moisture during application
- Long term flexibility—does not become brittle with age
- Hard, tough film
- Free of toxic amine curing agents
- Excellent alkali and solvent resistance
- High film build
- Protection in fresh or salt water immersion
- Lead and chromate free
- Simple 1 to 1 mixing ratio

SERVICE CONDITIONS

Do not use for potable water or direct food contact service. Do not use on unprimed wood or unprimed gypsum wallboard. Do not use on surfaces that may be subjected to severe abrasion.

Will withstand 250°F. continuous and 300°F. intermittent dry heat. The color may change as these limits are approached, but the film will remain intact.

REGULATORY RESTRICTIONS

The application VOC of this product may be restricted by law in some locations. Application VOC is increased by thinning with solvent. If the application VOC is restricted to 420 gm/liter (3.5 lbs./gal.), thinning must not exceed 7% by volume (9 fl.oz./gal.) with GLID-GUARD Epoxy Solvent No. 5568. If the application VOC is restricted to 450 gm/liter (3.75 lbs./gal.) or higher or is not restricted, thinning with up to 10% (12 fl.oz./gal.) is permissible.

TECHNICAL DATA

All data shown is for a mixed (converted) gallon unless otherwise noted

- *Product No.—5467/5469
- Generic Type—Polyamide epoxy
- Color—White
- Gloss—Approximately 30 @ 60°
- Percent Solids by Weight—71% ± 1%
- Percent Solids by Volume—54% ± 1%
- Theoretical Coverage per 1.0 dry mil (1.9 mils wet)—866 sq.ft./gallon
- **Recommended Film Build/Coverage (theoretical, unreduced)
 - Minimum—3.0 mils dry (5.5 mils wet) 289 sq.ft./gallon
 - Typical—5.0 mils dry (9.5 mils wet) 173 sq.ft./gallon
 - Maximum—8.0 mils dry (15.0 mils wet) 108 sq.ft./gallon(wet mil figures rounded to the nearest 0.5 mil)

When computing working coverage, allow for application losses, surface irregularities, any solvent addition, etc.

- Percent Vehicle (Solids) by Weight—28% ± 1%
- Percent Pigment by Weight—43% ± 1%
- Percent Solvent by Weight—29% ± 1%
- Viscosity—95-100 KU
- Weight per Gallon—11.1 lbs.
- Flash Point (Closed Cup)—Base No. 5467—46°F. Curing Agent No. 5469—43°F.
- VOC—3.24 lbs/gallon (388 gm/liter) unreduced

- 3.48 lbs/gallon (417 gm/liter) reduced 7% by volume with No. 5568
- 3.56 lbs/gallon (427 gm/liter) reduced 10% by volume with No. 5568

- Drying Time (70°F., 50% Relative Humidity)
 - Touch—1-2 hours
 - Handle—7 hours
 - Recoat—7 hours
 - Full Cure—7 days

- Reduction Solvent—GLID-GUARD Epoxy Solvent No. 5568 (10% maximum)
- Clean-Up Solvent—GLID-GUARD Epoxy Solvent No. 5568 or MEK
- Type of Cure—Converted
- Mixing Ratio (Base/Curing Agent) by Volume—1 to 1
- Induction Before Use—30 minutes @ material temperatures > 70°F.
- 60 minutes @ material temperatures 60°-70°F.

- Pot Life—4 hours @ 70°F.
- Tinting—DO NOT TINT

*Compositional data for other products in this series may differ slightly.
**As measured over the peaks of any surface projections or blast profile.

28

Epoxy—For Interior-Exterior/GLID-GUARD® Corrosion Resistant HS Epoxy

THE GLIDDEN COMPANY
August 1991

Corrosion Resistant

GLID-GUARD Corrosion Resistant HS Epoxy (Continued)

MATERIAL PREPARATION

Do not add unspecified curing agents or solvents or mix with other paints. Do not tint.

Thoroughly mix the selected GLID-GUARD Corrosion Resistant HS Epoxy (Component A) and Corrosion Resistant HS Epoxy Curing Agent No. 5469 (Component B) separately, then combine the two components in equal parts by volume using power agitation. If agitation equipment is not explosion proof, provide good ventilation to prevent build up of vapors. Allow the combined material to stand 30 minutes before use. Extend this induction (standing) time to 60 minutes if the surface or material temperature is 60°–70°F. After the induction period has elapsed, add up to 10% by volume GLID-GUARD Epoxy Solvent No. 5568 (12 fluid ounces per gallon of combined material) if necessary for application and mix thoroughly (see "Regulatory Restrictions" above). Pot life is 4 hours at 70°F., less at higher temperatures.

SURFACE PREPARATION

All surfaces should be clean, dry and free of all contaminants.

Metal Surfaces

Ferrous Metal

Surface preparation is dependent upon service conditions as follows:

TYPE A—AGGRESSIVELY CORROSIVE

This exposure is an area characterized by aggressive chemical fumes, mists or dusts or other chemical contaminants that combine with high humidity and condensed moisture to corrode zinc at rates greater than one mil per year. The need to limit air pollution and protect personnel generally confines chemical concentrations of such an aggressive nature to within a radius of about 50 yards from the source of contamination. For Type A environments and all immersion exposures, White Metal Blast Cleaning (SSPC-SP5-82 and SSPC-SP-COM) is recommended. For splash and spillage, Near-White Blast Cleaning (SSPC-SP10-82 and SSPC-SP-COM) is satisfactory.

TYPE C—CORROSIVE

This exposure is less destructive than Type A exposure and is characterized by moderately aggressive chemical fumes, mists, or dusts that combine with moisture and high humidity to corrode zinc at rates less than one mil per year. Type A exposure may, in many instances, become Type C exposure outside of a radius of about 50 yards from the source of contamination for a limited further distance. For Type C environments, Near-White Blast Cleaning (SSPC-SP10-82 and SSPC-SP-COM) is recommended.

TYPE M—MODERATE

This exposure is generally outdoors and is characterized by normal atmospheric weathering and/or light or moderate concentrations of chemical fumes that combine with humidity and condensed moisture to corrode carbon steel at rates less than three mils per year. Zinc in this exposure is virtually free of corrosion. Light to moderate chemical fume concentrations in indoor areas without excessive humidity may produce similar conditions. For Type M environments, Commercial Blast Cleaning (SSPC-SP6-82 and SSPC-SP-COM) is recommended. Where exposure is normal weathering only, Brush-Off Blast Cleaning (SSPC-SP7-82 and SSPC-SP-COM), Power Tool Cleaning (SSPC-SP3-82 and SSPC-SP-COM), or Hand Tool Cleaning (SSPC-SP2-82 and SSPC-SP-COM) will provide excellent service.

TYPE P—PROTECTED (ARCHITECTURAL)

In this category, surfaces are generally indoors and are not subjected to high humidity or chemical contaminants that will attack paint or steel. For Type P environments, Brush-Off Blast Cleaning (SSPC-SP7-82 and SSPC-SP-COM), Power Tool Cleaning (SSPC-SP3-82 and SSPC-SP-COM), or Hand Tool Cleaning (SSPC-SP2-82 and SSPC-SP-COM) will provide the sound substrate needed for proper adhesion.

Galvanized and Aluminum

Sandblasting is unnecessary. Remove oil, grease, dirt, dust and chemical contaminants using the prescribed cleaning methods.

Poured Concrete

Verify that all surface projections have been leveled. Remove all oils, grease, dust, dirt and chemical contaminants with the prescribed cleaning methods. Remove weak or powdery surfaces by acid etching or brush abrasive blasting. Dull very smooth concrete by similar means. Prime with this product thinned 10% by volume with GLID-GUARD Epoxy Solvent No. 5568 (see "Regulatory Restrictions" above).

Previously Painted Surfaces

The performance of this coating over previously painted surfaces is directly influenced by the type, age and condition of the old finish. For best results in immersion situations, completely remove any old coating and prepare as for new surfaces. For non-immersion service, remove all blistered, loose or peeling old coating. Hard or glossy finishes should be dulled by sanding or other abrasive means. Apply to a test area; if wrinkling or lifting occurs after overnight drying, remove the old coating.

APPLICATION

Do not apply when air or substrate temperature is below 60°F.

For best appearance, primary application should be by airless or conventional spray. Use brush or roller application for small areas only—flow and leveling will be limited. Spray application is required to obtain 5.0 mils dry in a single coat. Application by brush or roller will limit the film thickness to 3.0-4.0 mils dry per coat.

SPRAY APPLICATION

Airless Spray

Glidden equipment is specified.

Gun: ASM 400 Fluid Tip: 315-619

Pump: GLIDDEN 500™, GLIDDEN 750™, GLIDDEN 750GE™, GLIDDEN FORMULA ONE™

Pressure: 2000-2500 psi

NOTE: All pumps must be kept well away from areas where vapors from this product may collect.

Conventional Spray

Gun: Binks Model 18, Binks 2001, or equivalent

Needle: Binks Model 63A or equivalent

Fluid Nozzle: Binks Model 63PB or equivalent

Air Cap: Binks Model 63B or equivalent

COVERAGE

Typical coverage (calculated, unreduced) is 173 sq. ft./gallon at 5.0 mils dry (9.5 mils wet). Minimum film thickness is 3.0 mils dry (5.5 mils wet) 289 sq. ft./gallon, maximum is 8.0 mils dry (15.0 mils wet) 108 sq. ft./gallon. All wet mil figures are rounded to the nearest 0.5 mil. When computing working coverage, allow for application losses, surface irregularities, any solvent addition, etc.

DRYING

Dries to touch in 1-2 hours, to handle in 7 hours, to recoat in 7 hours, to full cure in 7 days at 70°F., 50% relative humidity. Allow longer drying times under cooler or more humid conditions.

CLEAN-UP

Clean all equipment immediately after use with GLID-GUARD Epoxy Solvent No. 5568 or methyl ethyl ketone.

TOPCOATS

SOLVENT EPOXY FINISHES

GLID-GUARD Corrosion Resistant HS Epoxy No. 5465/5469 series

GLID-GUARD Chemical Resistant Epoxy No. 5240/5242 series

GLID-GUARD High Solids Epoxy No. 5430/5434 series

GLID-GUARD⁺ DURAMASTER™ High Solids Epoxy No. 5295/5299 series

GLID-GUARD⁺ METALLITE™ High Build Epoxy No. 5475/5476

GLID-GUARD Cold Cure Epoxy No. 5281/5265

GLID-GUARD Coal Tar Epoxy No. 5270/5271

GLID-GUARD Hi-Build Coal Tar Epoxy No. 5273/5274

GLID-GUARD⁺ GLID-TILE™ Epoxide No. 5550/5552 series

NU-PON⁺ COTE Color Coat No. 7240/7200 series

WATER-BORNE EPOXY FINISHES

GLID-GUARD Acrylic Epoxy No. 5277/5278

GLID-GUARD Amine-Adduct Epoxy No. 5585/5586 series

POLYURETHANE FINISHES

GLID-THANE™ ONE Moisture Cured Polyurethane No. 6100 series

GLID-THANE II Acrylic Polyurethane No. 6200/6252 series

GLID-GUARD High Solids Acrylic/Polyester Urethane No. 5410/5414 series

SOLVENT VINYL FINISHES





GLID-GUARD Double Build Vinyl No. 5514

GLID-GUARD⁺ VINYL-COTE™ High Build No. 5522


WATER-BORNE ACRYLIC FINISHES

LIFEMASTER™ PRO Hi Performance Acrylic No. 6900 series

LIFEMASTER PRO HB Acrylic No. 5440 series



Piping Corrosion Protection





The Sherwin-Williams Company
Cleveland, OH 44115

Kem Kromik Universal Metal Primer—B50Z Series

Description

Kem Kromik Universal Metal Primer is a low VOC, modified alkyd resin primer designed for use over iron and steel substrates. Can be used as a "universal" primer under high performance topcoats and is also suitable as a "barrier" coat over conventional coatings which would normally be attacked by strong solvents in high performance coatings.

Characteristics

Color: Brown, Off White, and Buff

Coverage:
Recommended: 204-273 sq. ft./gal.
6-8 mils wet; 3-4 mils dry

Theoretical, no loss: 816 sq. ft./gal. @ 1.0 mil dry

Curing Mechanism: Oxidation

Drying Schedule: (temperature & humidity dependant)
@ 6 mils wet, 50% R. H. and:

	@ 40°F	@ 77°F	@ 110°F
To Touch:	2 hours	30 minutes	15 minutes
Tack Free:	2½ hours	1 hour	20 minutes
To Recoat with:			
alkyds	2½ hours	1 hour	45 minutes
epoxy	36 hours	16 hours	16 hours
urethane	36 hours	16 hours	16 hours

Finish: 0-10 units @ 85°

Flash Point: 80°F (Pensky-Martens Closed Cup)

Solvent: Xylene

Vehicle Type: Phenolic Alkyd

VOC: 415 grams/liter; 3.45 lbs./gal.

Volume Solids: 51 ± 2%

Weight Solids: 72 ± 2%

Weight per Gallon: 12.5 ± .35 lbs

Meets the performance requirements, not necessarily composition, of Federal Specification: TT-P-664D

Application

Application Conditions

Temperature (air, surface, material): 40-120°F
(surface temp. at least 5°F above dew point)

Relative humidity: 85% maximum.

Brush: No reduction required. Use a natural bristle brush.

Roller: No reduction required. Use a 3/8" woven nap with phenolic core.

Airless spray:

Pressure: 1800-3000 psi

Tip: .015" - .019"

Hose: 1/4" I.D.

Filter: 60 mesh

Reduction: normally no reduction required

Conventional spray:

Specifications

Substrate	Surface Preparation (See pages 2 through 6)
Steel	SSPC SP2/ SW-14

2 topcoats are recommended over all primers/substrates.

Suggested topcoats	Page
A-100 Exterior Latex Finishes	24-26
Corothane II Satin Polyurethane	32
DTM Acrylic Coatings	24
Heavy Duty Epoxy	49
Hi-Bild Aliphatic Polyurethane	50
Hi-Solids Polyurethane	53
Industrial Enamel	54
Industrial Enamel HS	55
Metatex Semi-Gloss Coating	64
ProlMar Interior & Exterior Alkyd & Latex Topcoats	73-95
Sher-Tile Epoxy	100
Silver-Brite Aluminum	102
Tile-Clad High Solids Epoxy	108
Water Based Catalyzed Epoxy	111

Performance Specifications

Physical Properties:

Abrasion Resistance (ASTM D4060, 1000 cycles)	250 mg
Direct Impact (ASTM G14)	70 inch lbs.
Dry Heat Resistance (ASTM D2485)	200° F
Elcometer Adhesion (ASTM D4541)	260 psi
Exterior Durability (with chalk)	Good
Flexibility (ASTM D522, 180° bend)	1/4" mandrel
Moisture Condensation Resistance (ASTM D4585)	500 hrs.
Pencil Hardness (ASTM D3383)	H
Salt Fog Resistance (ASTM B117)	500 hours
Thermal Shock (ASTM C22-6)	5 cycles

Resistance Guide:

(Resistance to fumes, splash and spillage - not immersion-ASTM D3912).

Acid Salt Solutions	Moderate
Aliphatic Hydrocarbons	Moderate
Alkalies	Not recommended
Aromatic Hydrocarbon Solvents	Light
Chlorinated Solvents	Not recommended
Fresh Water	Moderate
Salt Water	Moderate
Glycol ethers, alcohols, formaldehyde	Moderate
Oils (cutting, vegetable, lubricating)	Severe
Organic Acids	Light
Oxygenated Solvents	Not recommended

STORAGE

Warning: All Dudick products classified by DOT labels as either white, yellow or red labels, must not be mixed or stored together as an explosive reaction can occur. All products should be stored in a cool, dry area away from open flames, sparks or other hazards.

When properly stored in their original, unopened containers, Primer 67/67C components have a one year shelf life.

SAFETY

M.S.D.S - Sheets must always be read before using products. Primer 67/67C are intended for application by experienced, professional personnel. Dudick Inc. can supply supervision to help determine that the surface has been properly prepared, the ingredients correctly mixed, and the materials properly and safely applied.

If materials are to be applied by your own personnel or by a third party contractor, please be sure that they are aware of the following safety precautions:

- Exposure to resins and hardeners through direct skin contact and/or inhalation may cause severe dermatitis reactions in some people. Cleanliness of the skin and clothing is critical and must be of paramount concern.
- Fumes are flammable and heavier than air. Proper ventilation should be maintained to minimize breathing of concentrated fumes.
- Suitable respirators should be used during application.
- Safety glasses, gloves, and suitable protective clothing must be worn at all times during application.
- If contact with hardeners occurs, remove any clothing involved and flush the skin with flowing water. Discard the clothing. Do not attempt to wash and reuse it. Primer liquids can be removed with S-10 Cleaning Solvent, MEK, or lacquer thinner. **DO NOT USE ACETONE.**

- Keep open flames and sparks away from the area where materials are being mixed and applied.

- If a rash occurs, remove the individual from the work area and seek a physician's care for dermatitis.

- In case of eye contact, flush with water for at least 15 minutes and consult a physician.

- If swallowed, do not induce vomiting; call a physician immediately.

Note:

Dudick Inc. ("Dudick") warrants all goods of its manufacture to be as represented in its catalogs and that the application of its products by its employees or sub-contractors shall be performed in a workmanlike manner. Dudick's obligation under this warranty shall be the repair to and replacement of any applications which its examination shall disclose to be defective. Dudick makes no warranty concerning the suitability of its product for application to any surface, it being understood that the goods have been selected and the application ordered by the purchaser. **DUDICK INC. MAKES NO WARRANTY, EXPRESS OR IMPLIED, THAT THE GOODS SHALL BE MERCHANTABLE OR THAT THE GOODS ARE FIT FOR ANY PARTICULAR PURPOSE. THE WARRANTY OF REPAIR OR REPLACEMENT SET FORTH HEREIN IS EXCLUSIVE AND IN LIEU OF ALL OTHER WARRANTIES ARISING BY LAW OR OTHERWISE; AND DUDICK INC. SHALL NOT BE LIABLE FOR INCIDENTAL OR CONSEQUENTIAL DAMAGES, INCLUDING BUT NOT LIMITED TO LOST PROFITS, DOWN TIME, DAMAGES TO PROPERTY OF THE PURCHASER OR OTHER PERSONS, OR DAMAGES FOR WHICH THE PURCHASER MAY BE LIABLE TO OTHER PERSONS, WHETHER OR NOT OCCASIONED BY DUDICK'S NEGLIGENCE.** This warranty shall not be extended, altered or varied except by written instrument signed by Dudick and Purchaser.

Primer 67/67C

100% SOLIDS. MOISTURE-TOLERANT EPOXY PRIMER for

Dudick Incorporated

1818 Miller Parkway
Streetsboro, Ohio 44241

Dudick Inc.

1818 Miller Parkway
Streetsboro, Ohio 44241

(216) 562-1970
(216) 562-7638 FAX

Primer 67/67C

100 % SOLIDS, MOISTURE-TOLERANT
EPOXY PRIMER FOR STEEL AND
CONCRETE 3-4 MILS (0.1 mm)

RECOMMENDED APPLICATIONS

Concrete Substrates
Steel Substrates
Primer for Epoxy and Urethane
Floor Toppings, Linings, Coatings and Grout

PHYSICAL PROPERTIES

Tensile Strength ASTM C-307	2,000 - 2,500 PSI
Tensile Elongation ASTM C-307	12-25 %
Adhesion to Concrete ASTM D-4541	Cohesive Failure of concrete
Adhesion to Steel ASTM D-4541	2,200-2,500 PSI
Electrical Properties NFPA #99, ASTM F-150	< 25,000 ohms

SPECIFICATIONS

Primer shall be 3-4 mils thick, 100% solids bisphenol A epoxy cured with an amine adduct as manufactured by Dudick Inc. Primer 67 shall be brush, roller or spray applied in accordance with the manufacturer's recommended practices. Primer 67C must be spray or roller applied.

PRIMER 67

Primer 67 is designed to prevent abrasive-blasted steel from developing rust bloom prior to the application of a Dudick coating or lining system. For maximum performance all steel surfaces should be primed, but primer may not be needed for mild, non-immersion service. Concrete, however, must always be primed to aid in the "wetting out" required for good adhesion.

PRIMER 67C - CONDUCTIVE PRIMER

Primer 67C is a 100% solids, two component epoxy primer designed to be used over concrete whenever the coating or lining system must be spark tested.

ESTIMATING QUANTITIES AND ORDER BILL OF MATERIAL

SQUARE FEET PER GALLON		
	CONCRETE	STEEL
Primer 67	150-200	250-300
Primer 67C	100-150	—

Quantities shown are for estimating purposes only. Actual field usage may vary. Primer 67/67C are available in 1 and 2 gallon units.

APPLICATION INSTRUCTIONS

SURFACE PREPARATION

Metal: Surfaces must be abrasive blasted to an appropriate finish.

Immersion and heavy spillage service: White Metal SSPC SP-5 or NACE #1, 3.0 mil minimum profile.

Heavy, non-immersion service (i.e. fumes and spillage): Near white SSPC SP-10 or NACE #2, 2.0 mil minimum profile.

Atmospheric service: Commercial SSPC SP-6 or NACE #3, 2.0 mil minimum profile.

Concrete: Concrete must be abrasive blasted or etched with muriatic acid (Solution of 1 part 20° Be HCl and 1 part water) to remove surface laitance and other contaminants. Concrete must be free of curing compounds and form release agents. Surface texture should be similar to 40-60 grit sandpaper. The prepared surface should have a minimum tensile strength of 250 PSI per ASTM D-4541.

All concrete substrates must be checked for moisture prior to product application using the Plastic Sheet Test, ASTM D-4263.

Additional surface preparation will be required if a 40-60 grit texture is not achieved and the surface laitance not completely removed after a single application of acid or with the first mechanical preparation procedure.

Abrasive blasting removes laitance, exposing honeycombs or voids beneath the surface which must be filled with Scratch Coat 100. (Refer to separate product bulletin)

APPLICATION SPECIFICATIONS

Substrate temperature for both concrete and metal must be between 50°F and 110°F.

Relative humidity must not exceed 90%.

Substrate temperature must be 5°F above the Dew Point.

PRIMER 67/67C MIX RATIOS:

Primer 67
Component A 1 gal.
Component B 1 gal.

Primer 67C
Component A 1 gal.
Component B 95 fl. oz.

*Pre-mix primer 67C Component A for 1-2 minutes to disperse the conductive fillers prior to adding the correct amount of Component B.

Primer 67C must be spray or roller applied. Use brush application for small touch-up or repair work only.

The pot life of the mixed Primer 67/67C will depend on the temperature. To prevent material waste and avoid damage to equipment, do not open and mix more material than can be used according to the following table:

PRIMER 67/ 67C POT LIFE

TEMPERATURE	POT LIFE
50°F	90 min.
75°F	60 min.
90°F	30 min.

At 75° F the pot life and thin film cure of Primer 67 can be decreased by the addition of Accelerator #1 as follows:

Ozs./Accelerator #1 per mixed gal. Primer 67	Pot Life	Thin Film Cure
3-4	36 min.	4 hrs.
6-7	15 min.	2 hrs.

Using 7 ounces of accelerator #1 per mixed gallon of Primer 67, the thin film cure @ 40° F is reduced to 8 hours.

PRIMING

Metal: Mix the pre-measured units of Component A with Component B. Prime all metal surfaces to be coated with Primer 67 at 3-4 mils WFT.

Concrete: Mix the pre-measured units of Component A with Component B. Prime all concrete surfaces to be coated with either Primer 67 or 67C at 3-4 mils WFT. The basecoat may be applied over primer that is "tacky". Do not allow the primer to puddle.

Important - With all epoxies after priming and before each additional coat, examine the surface for amine blush (oily film). If present, remove by washing with warm water and detergent.

Cure Cycle for Primer 67/67C:

Temperature	Minimum Recoat Time	Maximum Recoat Time
50°F	12 hrs.	8 Days
75°F	6-8 hrs.	5 Days
90°F	4-5 hrs.	3 Days

To optimize intercoat adhesion, we recommend application of the basecoat while the primer is tacky. If this is not possible, the above recoat times must be observed. Exposure of the primer to direct sunlight will considerably shorten the recoat times. If recommended recoat times are exceeded, consult a Dudick Representative; sanding or abrasive blasting may be required before the coating, lining or floor topping can be applied.

CLEANING

Use S-10 Cleaning Solvent to clean tools and equipment. **DO NOT USE ACETONE.**

SHIPPING

Primer 67/67C Component A's are non-regulated plastic liquids. Primer 67/67C Component B's are flammable corrosives with a flash point of 106°F (Setaflash) and carry both a red warning label and a black and white warning label. S-10 Cleaning Solvent is a flammable liquid with a flash point of 52°F (PMCC) and carries a red warning label.

Dudick Inc.

Dudick Incorporated
Corrosion-Proof Products
1818 South Wason Drive
Streetsboro, Ohio 44241
218-562-1870
FAX No. 218-562-7838

Protecto-Coat 200

ELASTOMERIC, SPRAY APPLIED, ENVIRONMENTALLY SAFE, URETHANE COATING. 40-60 MILS (1-1 1/2 mm)

Protecto-Coat 200 is a high solids aromatic polyurethane coating with superior elongation. It is especially suited to bridge cracks in concrete.

RECOMMENDED APPLICATIONS

Secondary Containment Areas	Spent Liquor Storage Tanks
Process Floors	Food Processing
Railroad Tank Cars	Pharmaceutical
Underground Pipes & Tanks - Exterior	Breweries
Thickener Tanks & Mechanisms	Structural Steel

CHEMICAL RESISTANCE

Protecto-Coat 200 provides a tough, durable surface and will withstand splash and spills of many inorganic and organic acids as well as alkalis. Also resistant to aliphatic solvents.

PHYSICAL PROPERTIES

Protecto-Coat 200	40 Mil Basecoat	20 Mil Topcoat
Tensile Strength (PSI) ASTM C307	2,400-2,600	2,200-2,500
Elongation*	225% to 250%	50 to 60%
Shore D Hardness	40-45	65-70
Abrasion Resistance CS 17 wheels/1000 cycles x 1000 gm load	10 mg weight loss	32 mg weight loss
Solids by Volume	80%	100%

*At 60% elongation the chemical resistant topcoat begins to surface crack while the basecoat will continue to elongate to 250% extension.

SPECIFICATIONS

Coating shall be 40-60 mils thick, 80-100% solids aromatic urethane resin, consisting of 2 basecoats and a topcoat of 20 mils each, manufactured by Dudick, Inc. Materials shall be brush-, roller- or spray- applied in accordance with manufacturer's recommended practices.

THE PROTECTO-COAT 200 SYSTEM

The Protecto-Coat 200 system uses a moisture tolerant primer and two or three coats of elastomeric thermosetting urethane resins to protect concrete and steel.

Primer 67 is designed to prevent abrasive-blasted steel from developing rust bloom prior to the application of a Protecto-Coat System. For maximum performance, all steel surfaces should be primed, but primer may not be needed for mild, non-immersion service. Concrete, however, must always be primed to aid in the "wetting out" required for good bonding.

Protecto-Coat 200 is applied in three coats by brush, roller or spray. The elastomeric basecoat is applied in two 25 mil applications to achieve a nominal 40 mils DFT. The chemical resistant topcoat is applied in a single 20 mil application. Total thickness shall be a nominal 60 mils.

Post-It™ brand fax transmittal memo 7871		# of pages >
To	Commonwealth	
Ca.	Co.	
Dept.	Phone #	
Fax #	Fax #	

697-3592

Mid-America

ESTIMATING QUANTITIES AND ORDER BILL OF MATERIAL

SQUARE FEET PER GALLON		
	CONCRETE	STEEL
Primer 67	150-200	250-300
Protecto-Coat 200		
2 Base Coats Actual 35-40 mil DFT	25	25
Top Coat Actual 15-20 mil DFT	60	60
S-10 Solvent	500	500

Quantities shown are for estimating purposes only. Actual field usage may vary.

APPLICATION INSTRUCTIONS

SURFACE PREPARATION

Metal: For immersion service, abrasive blast to a white metal finish and a 2-4 mil minimum profile according to SSPC 5 or NACE No. 1. For fume or splash service, abrasive blast to a near-white metal finish according to SSPC 10 or NACE No. 2. Atmospheric service: Commercial SSPC 6 or NACE No. 3.

Concrete: Concrete must be abrasive-blasted or etched with muriatic acid (solution of 1 part 20° Be HCl and 1 part water) to remove surface laitance and other contaminants. Concrete must be free of curing compounds and form release agents. Surface texture should be similar to 40-60 grit sandpaper. The prepared surface should have a tensile strength of between 250 and 300 PSI per ASTM D4541.

Additional surface preparation will be required if a 40-60 grit texture is not achieved and the surface laitance not completely removed after a single application of acid or with the first mechanical preparation procedure.

If, after abrasive blasting, honeycombs/voids appear on the concrete, these have to be filled with a suitable material. Contact a Dudick representative for this information.

Recommended application temperatures should be between 40°F and 90°F substrate temperature. Do not apply Protecto-Coat 200 over concrete exposed to direct sunlight during the warming trend of the concrete as measured by surface temperature. To do so may lead to blistering, pinholes, or wrinkling in the coating due to outgassing of air in the concrete and high substrate temperatures. Wait for a definite downturn or cooling trend within the concrete as again measured by surface temperature. If this is not possible consult a Dudick representative for alternatives such as double priming.

PRIMING

Metal: For maximum performance, prime all steel surfaces with Primer 67, mixed with appropriate amount of hardener to 3-4 mils. For mild non-immersion service, priming of steel may be omitted.

Concrete: Concrete must be primed to aid in the "wetting out" required for good bonding. Mix Component A with Component B in the premeasured units for 2-3 minutes and apply by brush, roller, or spray. We recommend the basecoat be applied over slightly tacky or tack-free primer. Do not allow the primer to puddle.

Protecto-Coat 200 Mix Ratio:

Protecto-Coat 200 Basecoat	
Component A*	1 Gallon
Component B*	54 fl. ozs.

*Premeasured units by weight

Protecto-Coat 200 Topcoat

Protecto-Coat 200 Top Coat Comp. A*	1 Gal.
Component B*	54 fl. oz.

*Premeasured quantities by weight

BASECOAT

Add appropriate amount of hardener for each gallon of Protecto-Coat Liquid and mix thoroughly until uniform color is achieved. Apply a 25 mil wet (20 mil DFT) basecoat using spray, brush or roller. Allow basecoat application to cure to at least a "firm" or slightly "tacky" feel before applying the second 25 mil wet (20 mil DFT) basecoat. Brush or roller may require several coats to achieve desired thickness.

Protecto-Coat 200

Elastomeric, Spray Applied, Environmentally Safe, Urethane Coat

Dudick Incorporated
Corrosion-Proof Products

Horizontal surfaces may be basecoated in one application by applying 50 mils wet (40 mil DFT) in a single coat.

TOPCOAT

Add appropriate amount of hardener for each gallon of Protecto-Coat Liquid and mix thoroughly until a uniform color is achieved. Apply a 20-mil-thick topcoat using spray, brush or roller.

Cure Cycle for Protecto-Coat 200

TEMPERATURE	RECOAT TIME	CURE TIME
50°	48 Hrs.	96 Hrs.
70°	24 Hrs.	48 Hrs.
90°	16 Hrs.	36 Hrs.

If these recoat times are exceeded, consult a Dudick representative; sanding or abrasive blasting may be required before the next coat. Recoat times are dramatically reduced when the coating is exposed to direct sunlight.

Single Component Airless Spray Equipment — Graco King 45-to-1 spray pump or equivalent. Use Graco Golden Mastik Gun or Graco No. 207945 Gun with airless adapter equipped with a Reverse-A-Clean tip and a tip size between .035-.041. Spray hose should be 1/2" or 3/8" ID. Available inlet pressure must be a minimum of 100 psl.

Brush or roller application may require additional coats to meet specified dry film thickness.

Pot life of the opened and mixed Protecto-Coat 200 will depend on the temperature at the work site. To prevent material waste and avoid damage to equipment, do not open and mix more material than can be used according to the following table:

TEMPERATURE	POT LIFE
50°F	120 Min.
75°F	60 Min.
90°F	45 Min.

Do not attempt to store mixed material. Residual material should be properly disposed of at the end of each work period.

Where immersion service is required, spark test the coating with a 5,000 to 7,000 volt AC spark tester. Mark and repair all pinholes. Use Protecto-Coat liquid mixed with the appropriate amount of hardener. Retest only the repairs.

CLEANING

Use S-10 Solvent to clean tools and equipment.

SHIPPING

Protecto-Coat 200 Topcoat A and B and Protecto-Coat 200 Basecoat A are classified as plastic liquids and are non-regulated.

Protecto-Coat 200 Basecoat B is combustible. Primer 67 Component B is corrosive and carries a black and white warning label. Primer 67 Component A is classified as a plastic liquid and is nonregulated, while S-10 Cleaning Solvent is red label liquid with a flash point of 52°F (PMCC).

STORAGE

Warning: All Dudick products classified by DOT labels as either white, yellow or red labels must not be mixed or stored together as an explosive reaction may occur.

When stored in a cool and dry location, Protecto-Coat 200 ingredients have a one-year shelf life. Exposure to excessive heat may cause premature gelling and reduce working time.

SAFETY

M.S.D.S. - Sheets must always be read before using products. Protecto-Coat Systems are intended for application by experienced, professional personnel. Dudick Inc. can supply Protecto-Coat systems supervision to help determine that the surface has been properly prepared, the ingredients correctly mixed, and the materials properly and safely applied.

Protecto-Coat 200

Elastomeric Spray Applied, Environmentally Safe, Urethane Coat

Dudick Incorporated
Corrosion-Proof Products

Mid America Printers, Inc. 400 200 200

If Protecto-Coat materials are to be applied by your own personnel or by a third-party contractor, please be sure that they are aware of the following safety precautions:

- Exposure to resins and hardeners may cause severe dermatitis reactions in some people. Cleanliness of the skin and clothing is critical and must be of paramount concern.
- Safety glasses, gloves and suitable protective clothing must be worn at all times during application.
- Suitable respirators should be used.
- If contact with hardeners occurs, remove any clothing involved and wash the skin with large amounts of water. Discard the clothing. Do not attempt to wash and reuse it. Protecto-Coat liquid may be washed off with S-10 Cleaning Solvent, MEK liquid, or laquer thinner.
- Fumes are flammable and heavier than air. Proper ventilation should be maintained to minimize breathing of concentrated fumes.
- If a rash or dermatitis occurs, remove the individual from the work area and seek a physician's care for dermatitis.
- Keep open flames and sparks away from the area where toppings are being mixed and applied.
- In case of eye contact, wash with water for at least 15 minutes and consult a physician. If swallowed, do not induce vomiting; call a physician immediately.

Note:

Dudick Inc. ("Dudick") warrants all goods of its manufacture to be as represented in its catalogs and that the application of its products by its employees or sub-contractors shall be performed in a workmanlike manner. Dudick's obligation under this warranty shall be the repair to and replacement of any applications which its examination shall disclose to be defective. Dudick makes no warranty concerning the suitability of its product for application to any surface, it being understood that the goods have been selected and the application ordered by the purchaser. DUDICK INC. MAKES NO WARRANTY, EXPRESS OR IMPLIED, THAT THE GOODS SHALL BE MERCHANTABLE OR THAT THE GOODS ARE FIT FOR ANY PARTICULAR PURPOSE. THE WARRANTY OF REPAIR OR REPLACEMENT SET FORTH HEREIN IS EXCLUSIVE AND IN LIEU OF ALL OTHER WARRANTIES ARISING BY LAW OR OTHERWISE; AND DUDICK INC. SHALL NOT BE LIABLE FOR INCIDENTAL OR CONSEQUENTIAL DAMAGES, INCLUDING BUT NOT LIMITED TO LOST PROFITS, DOWN TIME, DAMAGES TO PROPERTY OF THE PURCHASER OR OTHER PERSONS, OR DAMAGES FOR WHICH THE PURCHASER MAY BE LIABLE TO OTHER PERSONS, WHETHER OR NOT OCCASIONED BY DUDICK'S NEGLIGENCE. This warranty shall not be extended, altered or varied except by written instrument signed by Dudick and Purchaser.

Protecto-Coat 200

Elastomeric, Spray Applied, Environmentally Safe, Urethane Coat-

Dudick Incorporated
Corrosion-Proof Products

1818 South Wason Drive
Streetsboro, Ohio 44241
(12-91)

Waste Analysis

08/28/94 16:24 214 727 9686

ANACHEM

001/004

Treated
 slowdown



ANACHEM INC.

8 Prestige Circle, Suite 104 • Allen, Texas 75002
214/727-9003 • FAX # 214/727-9686 • 1-800-966-1186

Customer Name: USPCI
Date Received: August 17, 1994 at 11:10:45
Date Reported: August 26, 1994
Submission #: 9408000203
Project: HEAT EXCHANGERS

SAMPLES The submission consisted of 1 sample with sample I.D. shown in the attached data table.

TESTS The sample listed in the attached result pages was analyzed for:

- * ALKALINITY, TOTAL (EPA 310.1)
- * ANION/CATION RATIO (CALCULATION)
- * CALCIUM/Ca (EPA 215.1)
- * CHLORIDE (EPA 300.6)
- * CYANIDE, TOTAL (EPA 335.2)
- * HARDNESS, TOTAL (BASED ON AAS/ICP)
- * ICP SCAN (EPA 200.7)
- * IRON/Fe (EPA 236.1)
- * MAGNESIUM/Mg (EPA 242.1)
- * MICROWAVE DIGESTION (EPA 3015)
- * pH (EPA 150.1)
- * POTASSIUM/K (EPA 200.7)
- * SILICA (EPA 370.1)
- * SODIUM/Na (EPA 273.1)
- * SPECIFIC CONDUCTANCE (EPA 120.1)
- * SULFATE (EPA 375.4)
- * TDS-TOTAL DISSOLVED SOLIDS (EPA 160.1)
- * TSS-TOTAL SUSPENDED SOLIDS (EPA 160.2)

Distribution Of Reports
2-Bruce Patterson of USPCI
Ph. (405) 697-3500 Fax (405) 697-3592

Respectfully Submitted,
Anachem, Inc.

C.E. Newton, Ph.D.
Chemist

Submission #: 9408000203 lms

NOTE: Submitted material will be retained for 60 days unless notified or consumed in analysis. Material determined to be hazardous will be returned or a \$20 disposal fee will be assessed. Our letters and reports are for the exclusive use of the client to whom they are addressed. The use of our name must receive our prior written approval. Our letters and reports apply to the sample tested and/or inspected, and are not necessarily indicative of the qualities of apparently identical or similar materials.

Page 1 of 4

08/20/04 10:25 214 727 0090

ANACHEM

002/004

Client Name: USPCI
 Submission #: 9408000203
 Project Name: HEAT EXCHANGERS
 Report Date: 08/26/94

Client Sample #: TREATED EXHAUST BLOWOFF

Laboratory ID #: 35372 Matrix: Liquid
 Sample Container: 3xGallon Plastic
 Sampling Location: Not listed on the chain of custody.
 Sampling Date: Not listed on the chain of custody.
 Temperature (Celsius): 21

ALKALINITY, TOTAL (EPA 310.1)

Analyte	Results(mg/l)	Det. Limit
Total Alkalinity	7600	1

ANION/CATION RATIO (CALCULATION)

Analyte	Results(%)	Det. Limit
Anion/Cation Ratio	1.00	0

CALCIUM / Ca (EPA 216.1)

Analyte	Results(mg/l)	Det. Limit
Calcium	30.2	0.01

CHLORIDE (EPA 300.6)

Analyte	Results(mg/l)	Det. Limit
Chloride	145000	0.1

CYANIDE, TOTAL (EPA 335.2)

Analyte	Results(mg/l)	Det. Limit
Total Cyanide	23.9	0.20

TURBIDITY, TOTAL (BASED ON AAS/ICP)

Analyte	Results(mg/l)	Det. Limit
Turbidity, Calculated	1500	

ICP SCAN (EPA 200.7)

Analyte	Results(mg/l)	Det. Limit
Silver	<0.0120	0.0120
Cadmium	0.072	0.0014
Chromium	0.112	0.0146
Copper	0.286	0.0046
Cobalt	1.38	0.0028
Lead	0.362	0.042
Manganese	0.034	0.0004
Nickel	0.925	0.0049
Antimony	<0.0246	0.0246
Thallium	0.286	0.056
Zinc	0.031	0.0031
Arsenic	32.6	0.044
Selenium	2.61	0.026
Aluminum	2.96	0.107
Barium	0.152	0.045
Beryllium	<0.0011	0.0011
Molybdenum	31.2	0.0069
Tin	<0.023	0.023
Titanium	<0.017	0.017
Vandium	0.139	0.0037
Silicon	4.09	0.015
Strontium	1.33	0.0013
Lithium	12	0.001

IRON / Fe (EPA 236.1)

Analyte	Results(mg/l)	Det. Limit
Iron	5.09	0.03

MAGNESIUM / Mg (EPA 242.1)

Analyte	Results(mg/l)	Det. Limit
Magnesium	31.7	0.01

08/20/94 16:25 214 727 0680

ANACHEM

12/003/004

Client Name: USPCI
Submission #: 9408000203
Project Name: HEAT EXCHANGERS
Report Date: 08/26/94

pH (EPA 150.1)

Analyte
pH For Liquid

Results(---)
7.5

Det. Limit
0

POTASSIUM/K (EPA 200.7)

Analyte
Potassium

Results(mg/l)
12300

Det. Limit
0.010

SILICA (EPA 370.1)

Analyte
Silicon Dioxide/Silica

Results(mg/l)
100

Det. Limit
2

SODIUM/Na (EPA 273.1)

Analyte
Sodium

Results(mg/l)
105000

Det. Limit
0.01

SPECIFIC CONDUCTANCE (EPA 120.1)

Analyte
Specific Conductance

Results(umhos/cm)
78900

Det. Limit
1

SULFATE (EPA 375.4)

Analyte
Sulfate

Results(mg/l)
30200

Det. Limit
1

TDS-TOTAL DISSOLVED SOLIDS (EPA 160.1)

Analyte
Total Dissolved Solids

Results(mg/l)
299000

Det. Limit
1

TOTAL SUSPENDED SOLIDS (EPA 160.2)

Analyte
Total Suspended Solids

Results(mg/l)
1440

Det. Limit
1

08/26/94

16:26

TS214 727 9086

ANACHEM

00047004

Report to: USPCI
Lab Number: 9408000203
Page 4 of 4

Project: Heat Exchangers

QUALITY CONTROL DATA

<u>ANALYTE</u>	<u>DATE ANALYZED</u>	<u>SPIKE VOL</u>	<u>STAND. DEV.</u>	<u>COEFF. OF VAR %</u>	<u>REC1%</u>	<u>REC2%</u>
Hardness, Calc.	8/19/94	----	0	0	96	---
Total Alkalinity	8/19/94	----	5.7	0.7	100	---
Silica	8/25/94	----	0	0	100	---
Sulfate	8/19/94	----	0.31	1.2	100	---
Chloride	8/25/94	----	178	8	100	---
T.S.S.	8/18/94	----	181	10	99	98
Total Cyanide	8/25/94	----	0	0	109	---

 $\text{Standard Deviation} = (\sum x^2 - (\sum x)^2 / n) / (n - 1)$ $\text{Coefficient of Variability \%} = (\text{S.D.} / \text{Avg.}) \times 100$ $\text{Recovery \%} = [(\text{spiked-unsiked}) / \text{expected}] \times 100$

ICP SCAN INFORMATION

Note:

ICP scans are very general in nature and do not include precise calibration or quality control. The process is intended as a screening procedure to identify very high metal concentrations.

Project: Heat Exchangers

Report to: USPCI
Report Number: 9407000227
Page 4 of 4

QUALITY CONTROL DATA

<u>ANALYTE</u>	<u>DATE ANALYZED</u>	<u>SPIKE VOL</u>	<u>STAND. DEV.</u>	<u>COEFF. OF VAR %</u>	<u>REC1/%</u>	<u>REC2/%</u>
Mercury	7/20/94	---	0.141	2.0	102	99
Total Alkalinity	7/26/94	---	0	0	100	---
T.D.S.	7/28/94	995	304	0.1	96	96
Silicon Dioxide/ Silica	8/1/94	---	0	0	100	---
Sulfate	8/1/94	---	5	2.4	99	---
Chloride	7/26/94	500	2.1	1.1	100	99
Hardness, Calcium	8/1/94	---	±4.2	1.1	110	100
T.S.S.	7/21/94	298	0.7	0	98	95

Standard Deviation = $(x1-x2)/1.414$

Coefficient of Variability % = $(S.D./Avg.) \times 100$

Recovery % = $[(\text{spiked}-\text{unspiked})/\text{expected}] \times 100$

ICP SCAN INFORMATION

Note: ICP scans are very general in nature and do not include precise calibration or quality control. The process is intended as a screening procedure to identify very high metal concentrations.

Client Name: USPCI
Submission#: 9407000227
Client Name: HEAT EXCHANGERS
Date: 08/04/94

Evaporator
Blowdown

Client Sample #: EV #1
Laboratory ID #: 33964 Matrix: Liquid
Sample Container: 2 Liter Plastic Bottle
Sampling Location: Not listed on the chain of custody.
Sampling Date: Not listed on the chain of custody.

XP SCAN (EPA 6010)

Analyte	Results(mg/l)	Det. Limit
Aluminum	333	
Barium	2.4	
Bismuth	0.166	
Bromine	0.514	
Copper	1.76	
Cobalt	97.6	
Iron	12600	
Potassium	0.242	
Sodium	41.7	
Magnesium	0.264	
Manganese	136000	
Mercury	35.4	
Nickel	0.336	
Antimony	0.198	
Thallium	0.264	
Zinc	52.2	
Arsenic	4.5	
Selenium		
Aluminum		
Barium		
Strontium	67.2	
Lithium		
Vanadium	3.1	
Silicon	1	
Strontium	22.4	

MERCURY DIGESTION (EPA 7470)
Date of Mercury Digestion: 07/20/94

MERCURY/Hg BY COLD VAPOR (EPA 245.1)

Analyte	Results(mg/l)	Det. Limit
Mercury	0.002	

Client Sample #: EV #2
Laboratory ID #: 33965 Matrix: Liquid
Sample Container: 2x2 Liter Plastic Bottle
Sampling Location: Not listed on the chain of custody.
Sampling Date: Not listed on the chain of custody.

ALKALINITY, TOTAL (EPA 310.1)

Analyte	Results(mg/l)	Det. Limit
Total Alkalinity	18900	1

ANION / CATION RATIO (CALCULATION)

Analyte	Results	Det. Limit
Anion/Cation Ratio	1.08	0

BICARBONATE ALKALINITY (EPA 310.1)

Analyte	Results(mg/l)	Det. Limit
Bicarbonate Alkalinity	23100	1

CALCIUM / Ca (EPA 200.7)

Analyte	Results(mg/l)	Det. Limit
Calcium	735	0.001

Name: USPCI
Session#: 9407000227
Name: HEAT EXCHANGERS
Date: 08/04/94

BICARBONATE ALKALINITY (EPA 310.1)

Analyte: bicarbonate Alkalinity

Results(mg/l)
<1

Det. Limit
1

CHLORIDE (EPA 300.6)

Analyte: chloride

Results(mg/l)
176000

Det. Limit
0.1

CYANIDE, TOTAL (EPA 335.2)

Analyte: total Cyanide

Results(mg/l)
<0.02

Det. Limit
0.02

IRON (EPA 200.7)

Analyte: iron

Results(mg/l)
112

Det. Limit
0.013

MAGNESIUM (EPA 200.7)

Analyte: magnesium

Results(mg/l)
222

Det. Limit
0.030

PHOSPHORUS (EPA 150.1)

Analyte: phosphorus For Liquid

Results(---)
13

Det. Limit
0

POTASSIUM (EPA 200.7)

Analyte: potassium

Results(mg/l)
17400

Det. Limit
0.010

SILICA (EPA 370.1)

Analyte: Silica/Silica

Results(mg/l)
400

Det. Limit
2

SODIUM (EPA 200.7)

Analyte: sodium

Results(mg/l)
150000

Det. Limit
0.001

SPECIFIC CONDUCTANCE (EPA 120.1)

Analyte: specific Conductance
THIS IS A CALCULATED VALUE; THE MATRIX OF THE
SAMPLE PRECLUDED THE USE OF A CONDUCTIVITY
PROBE DUE TO OILY COATING; THE CALCULATED VALUE
ASSUMES INFINITE DILUTION OF THE SAMPLE.)

Results(umhos/cm)
840000

Det. Limit
1

SPECIFIC GRAVITY (USP 841)

Analyte: specific Gravity

Results
1.31

Det. Limit
1

SULFATE (EPA 375.4)

Analyte: Sulfate

Results(mg/l)
55300

Det. Limit
1

TDS-TOTAL DISSOLVED SOLIDS (EPA 160.1)

Analyte: Total Dissolved Solids

Results(mg/l)
417000

Det. Limit
1

TSS-TOTAL SUSPENDED SOLIDS (EPA 160.2)

Analyte: Total Suspended Solids

Results(mg/l)
6780

Det. Limit
1

Project: Heat Exchangers

Report to: USPCI
Number: 9407000227
Page 4 of 4

QUALITY CONTROL DATA

<u>ANALYTE</u>	<u>DATE ANALYZED</u>	<u>SPIKE VOL</u>	<u>STAND. DEV.</u>	<u>COEFF. OF VAR %</u>	<u>REC1/%</u>	<u>REC2/%</u>
Mercury	7/20/94	---	0.141	2.0	102	99
Total Alkalinity	7/26/94	---	0	0	100	---
T.D.S.	7/28/94	995	304	0.1	96	96
Silicon Dioxide/ Silica	8/1/94	---	0	0	100	---
Sulfate	8/1/94	---	5	2.4	99	---
Chloride	7/26/94	500	2.1	1.1	100	99
Hardness, Calcium	8/1/94	---	±4.2	1.1	110	100
T.S.S.	7/21/94	298	0.7	0	98	95

Standard Deviation = $(x1-x2)/1.414$

Coefficient of Variability % = $(S.D./Avg.) \times 100$


Recovery % = $[(\text{spiked-unspiked})/\text{expected}] \times 100$

ICP SCAN INFORMATION


Note:

ICP scans are very general in nature and do not include precise calibration or quality control. The process is intended as a screening procedure to identify very high metal concentrations.



Tank Drawings



NOTE: SEE SHEET 2 FOR HORIZONTAL
AND VERTICAL SHELL SEAM
FIT UP AND WELDING



QTY.	ITEM	DWG. NO.
3	SHELL R.	1
1	1" THICK FLUE W/ 2" INSUL.	1
1	3/4" x 75-1/4" O.D. FLANGED & DISHED HEAD, STANDARD TYPE, A516 STEEL	1
8	CRANE HOOKS	1
1	1/2" BASE PLATE	2
3	REINFORCING R. (RE-R)	3
3	SHELL MANHOLE - 30" Ø	4
1	BOTTOM MANHOLE - 20" Ø	5
3	DAVIT	6
1	NAME PLATE & BRACKET	7
1	INFLUENT INTERNAL DETAIL	8



NOZZLE NO.	SIZE	LOCATION	ORIENTATION TO NORTH	DIST. FROM CENTER OF TANK OR ABOVE FLOOR ELEVATION	DESCRIPTION
1	30"	SIDEWALL	225°	9'-3"	MANWAY
2 +	20"	BOTTOM	135°	1'-9"	MANWAY
3	8"	BOTTOM	180°	CENTER	EFFLUENT
4	4"	SIDEWALL	0°	9'-4"	OVERFLOW
5	3"	SIDEWALL	22.5°	15'-6"	LEVEL GAUGE (FOAM DETECTOR)
6	3"	SIDEWALL	67.5°	9'-0"	HIGH LEVEL ALARM
7	8"	SIDEWALL	180°	14'-0"	INFLUENT
8	3"	SIDEWALL	112.5°	5'-6"	LEVEL GAUGE
9 **	3"	SIDEWALL	112.5°	11'-6"	LEVEL GAUGE
10	2"	SIDEWALL	157.5°	5'-6"	SIGHT GLASS
11 **	2"	SIDEWALL	157.5°	11'-6"	SIGHT GLASS
12	3"	SIDEWALL	90°	8'-0"	FUTURE
13 **	3"	SIDEWALL	112.5°	15'-6"	PRESS. GAUGE
14	3"	SIDEWALL	67.5°	6'-0"	LOW LEVEL ALARM
15	3"	SIDEWALL	315°	6'-0"	FUTURE
16 *	30"	SIDEWALL	225°	17'-8"	MANWAY
17 *	30"	SIDEWALL	45°	17'-8"	MANWAY
18 **	4"	SIDEWALL	0°	15'-4"	OVERFLOW
19	3"	SIDEWALL	22.5°	13'-6"	FUTURE
20	10"	SIDEWALL	270°	15'-0"	VIEWPORT

* FABRICATOR TO VERIFY LOCATION WITH USPCI TO AVOID PIPING INTERFERENCE.

+ HINGE BOTTOM MANWAY TO ALLOW COVER PLATE TO SWING OPEN TOWARD THE TANK SHELL AWAY FROM THE TANK CENTER.

** PROVIDE A SPLASH DEFLECTOR PER SHEET 8


SHELL R SCHEDULE

RING NO.	THICK.*	HEIGHT	NO. OF SHEETS AT LENGTH PER RING
1	3/8"	60"	1 AT 237 1/2"
2	3/8"	96"	1 AT 237 1/2"
3	3/8"	90"	1 AT 237 1/2"

* 1/8" CORROSION ALLOWANCE ADDED

REVISIONS			SCOTT MANUFACTURING, INC.		
NO.	DATE	BY	P.O. BOX 10232, LUBBOCK, TEXAS 79408		
1	6/23/95	RJT	EVAPORATOR FLASH TANK NO. 3		
2	8/1/95	RJT	USPCI, WAYNOKA, OK		
3			DRAWN BY	R&T	SCALE NONE
4			CHK'D BY	RJT	DATE 6/7/95
5			DRAWING NAME	499-1.DWG	APP'D. BY
					JOB NO. 95025
					499-1

NOTE: SEE SHEET 2 FOR HORIZONTAL
AND VERTICAL SHELL SEAM
FIT UP AND WELDING



QTY.	ITEM	DWG. NO.
3	SHELL R.	1
1	$\frac{1}{4}$ " THICK FLUE W/ 2" INSUL.	1
1	$\frac{3}{4}$ " x 75 $\frac{1}{2}$ " O.D. FLANGED & DISHED	1
	HEAD, STANDARD TYPE, A516 STEEL	
8	CRANE HOOKS	1
1	$\frac{1}{2}$ " BASE PLATE	2
3	REINFORCING R. (RE-R)	3
3	SHELL MANHOLE - 30" ϕ	4
1	BOTTOM MANHOLE - 20" ϕ	5
3	DAVIT	6
1	NAME PLATE & BRACKET	7
1	INFLUENT INTERNAL DETAIL	8

TANK SHELL


SPOT 1
6" LONG @ 120° VERT. SEAM

X-RAY
LOCATION MAP

7-13-95

SPOT 2
"T" SEAM

SPOT 3
6" LONG ON
HORZ. SEAM



PLAN ORIENTATION

NOZZLE NO.	SIZE	LOCATION	ORIENTATION TO NORTH	DIST. FROM CENTER OF TANK OR ABOVE FLOOR ELEVATION	DESCRIPTION
1	30"	SIDEWALL	225°	9'-3"	MANWAY
2 +	20"	BOTTOM	135°	1'-9"	MANWAY
3	8"	BOTTOM	180°	CENTER	EFFLUENT
4	4"	SIDEWALL	0°	9'-4"	OVERFLOW
5	3"	SIDEWALL	22.5°	15'-6"	LEVEL GAUGE (FOAM DETECTOR)
6	3"	SIDEWALL	67.5°	9'-0"	HIGH LEVEL ALARM
7	8"	SIDEWALL	180°	14'-0"	INFLUENT
8	3"	SIDEWALL	112.5°	5'-6"	LEVEL GAUGE
9 **	3"	SIDEWALL	112.5°	11'-6"	LEVEL GAUGE
10	2"	SIDEWALL	157.5°	5'-6"	SIGHT GLASS
11 **	2"	SIDEWALL	157.5°	11'-6"	SIGHT GLASS
12	3"	SIDEWALL	90°	8'-0"	FUTURE
13 **	3"	SIDEWALL	112.5°	15'-6"	PRESS. GAUGE
14	3"	SIDEWALL	67.5°	6'-0"	LOW LEVEL ALARM
15	3"	SIDEWALL	315°	6'-0"	FUTURE
16 *	30"	SIDEWALL	225°	17'-8"	MANWAY
17 *	30"	SIDEWALL	45°	17'-8"	MANWAY
18 **	4"	SIDEWALL	0°	15'-4"	OVERFLOW
19	3"	SIDEWALL	22.5°	13'-6"	FUTURE
20	10"	SIDEWALL	270°	15'-0"	VIEWPORT

* FABRICATOR TO VERIFY LOCATION WITH USPCI TO AVOID PIPING INTERFERENCE.

+ HINGE BOTTOM MANWAY TO ALLOW COVER PLATE TO SWING OPEN TOWARD THE TANK SHELL AWAY FROM THE TANK CENTER.




** PROVIDE A SPLASH DEFLECTOR PER SHEET 8

SHELL R SCHEDULE

RING NO.	THICK.*	HEIGHT	NO. OF SHEETS PER RING AT LENGTH
1	$\frac{3}{8}$ "	60"	1 AT 237 $\frac{1}{2}$ "
2	$\frac{3}{8}$ "	96"	1 AT 237 $\frac{1}{2}$ "
3	$\frac{3}{8}$ "	90"	1 AT 237 $\frac{1}{2}$ "



* $\frac{1}{8}$ " CORROSION ALLOWANCE ADDED

REVISIONS			SCOTT MANUFACTURING, INC.		
NO	DATE	BY	P.O. BOX 10232, LUBBOCK, TEXAS 79458		
1	6/23/95	RJT	EVAPORATOR FLASH TANK NO. 3		
2			USPCI, WAYNOKA, OK		
3			DRAWN BY R&T	SCALE NONE	JOB NO. 9508E
4			CHKD BY RJT	DATE 6/7/95	DRAWING NO.
5			DRAWING NAME 499-1.DWG	APP'D. BY	499-1



ONE $\frac{1}{4}$ " TELLTALE HOLE IN REINFORCING PLATE. HOLE SHALL BE LOCATED ON HORIZONTAL CENTERLINE AND HAVE STD. PIPE THREADS.




USE	NOMINAL DIAMETER D	T	ROLL RADIUS	A	B	R	A'	B'	QUANTITY
SHELL MANHOLE	30"	$\frac{3}{8}$ "	SHELL RADIUS	62"	31"	$13\frac{1}{2}$ "			2
VIEWPORT	$21\frac{1}{2} \times 10\frac{7}{8}$	$\frac{3}{8}$ "	SHELL RADIUS	46"	36"		$10\frac{3}{4}$ "	$5\frac{7}{16}$ "	1
INFLUENT	8"	$\frac{3}{8}$ "	SHELL RADIUS	19"	$8\frac{3}{4}$ "	$4\frac{3}{8}$ "			1



REVISIONS			SCOTT MANUFACTURING, INC.	
NO	DATE	BY	P.O. BOX 10232, LUBBOCK, TEXAS 79408	
1	6/23/95	RJT	REINFORCING PLATE DETAILS	
2	8/1/95	RJT	WAYNOKA, OK	
3			DRAWN BY R&T	SCALE NONE
4			CHECK'D BY RJT	DATE 6/7/95
5			QUANTITY 1400-3.0M2	APPROVED BY 499-3


95085

499-3







COVER PLATE - $\frac{1}{2}$ " R
(1 REQUIRED)

FLANGE RING - $\frac{1}{2}$ " R
(1 REQUIRED)



REVISIONS			SCOTT MANUFACTURING, INC.		
NO	DATE	BY	P.O. BOX 10232, LUBBOCK, TEXAS 79408		
1			BOTTOM MANHOLE - 20" DIA.		
2			WAYNOKA, OK		
3			QUANT. BY	R&T	SIZE 1 1/2" = 1'-0"
4			CHK'D. BY	PIT	DATE 6/7/02
5			DRAWING NAME		APP'D. BY
			488-S, DMC		95026
					DRAWING NO.
					449-3

Ancillary Equipment Drawings



REVISIONS			SCOTT MANUFACTURING, INC.		
NO	DATE	BY	P.O. BOX 10232, LUBBOCK, TEXAS 79408		
1			DAVIT DETAIL		
2			WAYNOKA, OK		
3			DRAWN BY R&T	SCALE NONE	JOB NO. 95085
4			CHECKED BY RJT	DATE 6/7/95	DRAWING NO.
5			DRAWING NAME	APPROVED BY	499-6

SILVER LETTERS

BLACK BACKGROUND

1" DIA. HOLES

BLACK LETTERS

SILVER BACKGROUND

OWNER TO PROVIDE

1" DIA. HOLES

1" PLATE

API STANDARD 650

APPENDIX A, J, & M YEAR COMPLETED 1995

EDITION 8-1988 REVISION NUMBER 4

NOMINAL DIAMETER 6.333' NOMINAL HEIGHT 31'

NOMINAL CAPACITY 2981 GAL DESIGN LIQUID LEVEL 13.833'

DESIGN SPECIFIC GRAVITY 1.5 MAXIMUM OPERATING TEMP. 300° F


DESIGN PRESSURE ATM PARTIAL STRESS RELIEF NA

MANUFACTURER'S SERIAL NO. 499-3 PURCHASER'S TANK NO.


FABRICATED BY SCOTT MANUFACTURING, INC.

ERECTED BY

SHELL COURSE	MATERIAL
20.5'	0.375, A36
-	
-	
-	



SIDE VIEW




FRONT VIEW

NAME PLATE BRACKET


(1 REQUIRED)


(4) - 1/8" DIA. DRIVE SCREW RIVETS REQUIRED



NAME PLATE
(1 REQUIRED)






REVISIONS			SCOTT MANUFACTURING, INC.		
NO	DATE	BY	P.O. BOX 10232, LUBBOCK, TEXAS 79408		
1	6/23/95	RJT	NAME PLATE AND BRACKET WAYNOKA, OK		
2			DRAWN BY	R&T	SCALE NONE JOB NO. 95086
3			CHK'D BY	RJT	DATE 6/7/95 DRAWING NO.
4			DRAWING NAME	499-7, DWG	APP'D BY 499-7
5					









REVISIONS			SCOTT MANUFACTURING, INC.		
NO	DATE	BY	P.O. BOX 10232, LUBBOCK, TEXAS 79408		
1	6/23/95	RJT	MIST ELIMINATOR FRAME		
2			USPCI, WAYNOKA, OK		
3			CHART BY	R&T	SCALE NONE
4			CHK'D BY	RJT	DATE 6/7/95
5			DRAWING NAME	499-10.DWG	APP'D. BY
			DUC NO. 95086		
			DRAWING NO. 499-10		



Secondary Containment Drawings





SECTION T-6

ASSESSMENT OF WASTERWATER STORAGE TANK T-6 CLEAN HARBORS' WAYNOKA FACILITY

For:




Prepared by:



August 2018

18176.00



Contents

1. INTRODUCTION.....	3
2. TANK SYSTEM DESCRIPTION	3
3. PRIMARY TANK VESSEL	3
3.1 GENERAL DESCRIPTION OF WASTEWATER STORAGE TANK (T6).....	3
3.2 DESIGN STANDARDS.....	4
3.3 HAZARDOUS CHARACTERISTICS OF WASTES STORED.	4
3.4 EXISTING CORROSION PROTECTION.	5
3.5 DOCUMENTED AGE OF TANK.	5
3.6 RESULT OF LEAK TESTS.	5
3.7 EXISTING DATA AVAILABLE.	5
3.8 STRUCTURAL CALCULATION.	5
3.9 COMPARISON TO ACTUAL STRUCTURE TO THEORETICAL VALUES.	6
4. SECONDARY CONTAINMENT SYSTEM	8
4.1 GENERAL DESCRIPTION OF SECONDARY CONTAINMENT.....	8
4.2 DESIGN STANDARDS.....	8
4.3 HAZARDOUS CHARACTERISTICS OF WASTES STORED.....	8
4.4 EXISTING CORROSION PROTECTION.	8
4.5 DOCUMENTED AGE OF THE CONTAINMENT AREA.	9
4.6 RESULT OF LEAK TESTS.	9
4.7 EXISTING AVAILABLE DATA.	9
4.8 STRUCTURAL CALCULATIONS.....	9
4.9 COMPARISON OF ACTUAL STRUCTURE THEORETICAL VALUES.	10
4.10 CALCULATION OF EXISTING CAPACITY.....	10
5. FOUNDATION AND SHELL SETTLEMENT ANALYSIS	10
6. ANCILLARY EQUIPMENT.....	11
6.1 MANWAYS.....	11
6.2 STAIRWAY AND PLATFORM.	11
6.3 NOZZLE FLANGES.	11
6.4 LOAD LINES.	11
6.5 LEAK DETECTION SYSTEM.....	11
7. CONCLUSIONS	12
7.1 PRIMARY AND SECONDARY TANK USE.	12
7.2 LIFE EXPECTANCY.	12
8. RECOMMENDATIONS	12
8.1 COMPATIBLE STORAGE.	12
8.2 CONTROL LIQUID HEIGHT.....	12
8.3 DRAINAGE CONTROL.	12
8.4 ROUTINE INSPECTIONS.....	12
8.5 CORROSION PROTECTION.	13
9. CERTIFICATION	14

LIST OF FIGURES:

- FIGURE 1.** INTERIOR WALL SCHEMATIC
- FIGURE 2.** TANK THICKNESS MEASUREMENTS (WITH COATING)
- FIGURE 2a.** TANK THICKNESS MEASUREMENTS OF CORROSIVE FLOOR PITS
- FIGURE 2b.** TANK THICKNESS MEASUREMENTS OF STRIPPED FLOOR

LIST OF APPENDICES:

- APPENDIX A.** TANK SYSTEM VOLUME AND WEIGHT CALCULATIONS
- APPENDIX B.** PRIMARY & SECONDARY TANK THICKNESS CALCULATIONS
- APPENDIX C.** AS-BUILT PLANS
- APPENDIX D.** SECONDARY CONTAINMENT VOLUME CALCULATIONS
- APPENDIX E.** STRUCTURAL SUPPORT CALCULATIONS
- APPENDIX F.** TANK SYSTEM MEASUREMENT AND SETTLEMENT CALCULATIONS

1. INTRODUCTION

Envirotech Engineering and Consulting, Inc. performed professional engineering services for producing the following inspection and assessment of the T-6 Wastewater Storage Tank at the Lone Mountain Facility at Waynoka, Oklahoma and which is operated by Clean Harbors Environmental Services, Inc. Inspections were performed by Envirotech on May 21st, June 5th and August 23, 2018. The inspections and assessments were performed for the purpose of fulfilling the recommended update of the previous reported assessment by Envirotech in September of 2013.

The inspections included visual and sonic measurement of steel plate thicknesses of the walls and floors of the tank. Data and calculations from the previous assessment are included in this report and its appendices since Tank T-6 has demonstrated insignificant changes such that remains consistent with that data.

2. TANK SYSTEM DESCRIPTION


Wastewater Storage Tank (T6) is an on-ground wastewater storage tank installed in 1987. This tank has stored both raw leachate and treated wastewater (concentrate and sludge) in the past. The tank is vertical in position and cylindrical in shape. The tank is completely open to the atmosphere for evaporation purposes. Wastewater Storage Tank T6 is located in the central portion of the Lone Mountain Facility. A stairway, platform and walkway are located on the east side of the tank. The tank employs a tape float gage for liquid level measurement.

Wastewater Storage Tank (T6) is enveloped by a larger steel tank. The second steel tank is for the purpose of secondary containment. The annular tank space between the sides of the inner and outer tank is large enough for persons to enter and perform inspections. The distance between the bottoms of the inner and outer tank is only approximately 12-in. and is filled with pea gravel; therefore entry for direct inspection is impossible directly underneath the primary tank. Therefore, inspection of the secondary floor was evaluated under the gravel between the walls of the two tanks. This was considered adequate representation of the secondary floor.

3. PRIMARY TANK VESSEL

3.1 General Description of Wastewater Storage Tank (T6).

Wastewater Storage Tank (T6) consists of circular steel tank with an inside wall diameter of 100-ft. The tank has a maximum operating volume of 1,409,994.96-gal. (see *Appendix A – Tank System Volume and Weight Calculations*). The tank walls were initially constructed with three courses of steel plates. The first or bottom course was constructed of 5/16-in. A-36 steel. The second and third courses were constructed of 1/4 in. A-36 steel. This is shown in Figure 1. The bottom the tank was



Interior Wall Schematic

Clean Harbors Tank T-6 Inspection

013266-00

SE/NE Section 33, Township 23 North, Range 15 West
Indian Meridian, Wrayoka, Major County

Figure 1



ENVIROTECH
ENGINEERING & CONSULTING, INC.

2500 North 11th Street - End, Oklahoma 73201
Phone (580) 224-8780, Fax (580) 237-4302
T.A. #1560 - Expiration Date: 6-30-2020
www.envirotechconsulting.com

constructed of 1/4-in. A-36 steel. A pea gravel base filter detection system is located directly under the tank.

Wastewater Storage Tank (T6) was assessed to determine if the unit remained adequately designed with sufficient structural strength and compatibility with the waste to be stored. To conduct the assessment, the contents of the tank were removed and the tank was thoroughly washed and cleaned.

The Tank T-6 was opened for inspection by Clean Harbors personnel who managed the confined entry requirements. The principal inspection was performed on May 21, 2018 by Envirotech personnel. Follow-up inspections were performed on June 5th and August 23rd, 2018 to obtain additional thickness information needed to complete this report.

The inspection included inspecting regular locations inside the lower wall levels between the tank walls. Inspection of the interior walls and floor as well as the exterior wall surfaces were also measured for metal thickness. Note that the secondary wall is constructed the same except the middle plate has a design thickness of 0.3125 inches. Envirotech performed a visual inspection and ultrasonic thickness measurement survey of the entire tank bottom as well as the first course and bottom section of the second course of the tank shell. The upper section of the tank was not tested because storage had not and would not occur at that height. The black tank coating was visually observed to be in tact without noticeable damage to its surface. Steel thickness readings are shown on Figure 2 regarding the interior wall surface of the primary tank, the exterior wall of the secondary tank, and floor thickness measurements of the primary and secondary tank floors.

It will be mentioned at this time that the secondary walls and floor section were also inspected at the same time. The results of that inspection are reported in section 4 of this report. The wall section thickness of the outer wall is similar to the primary tank except the middle section is constructed with 0.3125-inch steel plate. The secondary tank floor thickness was measured at the area between the tank walls and results indicated adequate thickness of steel exists at those locations. No history or other information suggests the secondary floor has experienced measureable degradation.


3.2 Design Standards.

Original tank structure calculations located in *Appendix B* were performed to compare the existing tank to those sections that were applicable in the American Petroleum Institute Standard 650 – 1988 Edition API-650 – (New Tank Standards) and API 653-1992 (Tank Inspection, Repair, Alteration and Reconstruction) where applicable. Those calculations can be found in *Appendix B* of this report. The tank was earlier reported to have been constructed by Maloney Crawford of Tulsa, Oklahoma and the design drawings indicated that the tank was fabricated and erected in accordance with API Standard 650.

3.3 Hazardous Characteristics of Wastes Stored.

The wastes which are treated in this tank have the following characteristics:

Wastewater, Wastewater Concentrate and Leachate



NOTE: All thickness measurements are after coating



Tank Thickness Measurements
Clean Harbors Tank T-6 Inspection
 013266-00

SE/NE Section 33, Township 23 North, Range 8 West
 Indian Meridian, Wayne County, Oklahoma



2500 North 11th Street - Enid, Oklahoma 73701
 Phone (580) 234-8780, Fax (580) 237-4302
 C.A. #1980 - Expiration Date 6-30-2020
 www.envirotechconsulting.com

pH (4-13)
N > 6
Temperature = Ambient to 210° F

The hazardous characteristics of the waste treated in this tank were previously examined and it was determined that the pH and normality levels of the waste were the primary areas of concern. This was to determine the applicability of a corrosion allowance for the tank material type and thickness.

3.4 Existing Corrosion Protection.

Visual inspection of the primary tank revealed that the inside of the tank had been previously coated with coal tar epoxy coating. It was reported by Clean Harbors that the tank interior was recently sandblasted to prepare the surface for re-coating with a new layer of coal tar epoxy.

The exterior of the tank (between the outer secondary and inner primary wall) was inspected during the confined space entry. There is no coating on the interior surface, however the steel wall material appeared rust-coated but in good condition.

3.5 Documented Age of Tank.

This tank was erected and installed in 1987. The tank is 31-years old.

3.6 Result of Leak Tests.

A leak test has not been performed upon this vessel and is not required since the interior of the primary tank was inspected.

3.7 Existing Data Available.

Diameter of Tank	100-ft.
Height	24-ft.
(Maximum Operating Level)	19-ft.
Material	A36 (Design)
Wall Thickness First Course	.3125-in.
Wall Thickness Second Course	.25-in.
Wall Thickness Third Course	.25-in.
Specific Gravity	1.3
Operating Temperature	Ambient
Maximum Volume	188,502-c.f.
Seismic Zone	1

3.8 Structural Calculation.

The required thickness of the primary tank first course tank wall (as per API 653 – 1992) was calculated to be 0.3771-in., if the tank were filled to capacity (24-ft.) with material having a specific gravity of 1.3. This required thickness is greater than the original measured average thickness of 0.3154-in and

therefore would not over stress the tank. The table below presents allowable tank fluids heights for specific gravities ranging from 1.0 – 1.3. *Appendix B* (Primary Tank Wall Thickness Calculations) presents detailed calculations for the three courses of primary tank based on specific gravity of 1.3 and a 19-ft. maximum fluid level. Also see section 3.9 regarding maximum liquid level.

ALLOWABLE FLUID HEIGHTS	
Sp. Gr.	Fluid Height (ft)
1.0	24
1.1	22
1.2	21
1.3	19

3.9 Comparison to Actual Structure to Theoretical Values.

WALL THICKNESS COMPARISON			
	Calculated Minimum Thickness	Measured Thickness (Note 1)	Thickness Meets Standard
1 st Course	0.3087-in.*	0.3600-in.	Yes
2 nd Course	0.2130-in.*	0.2800-in.	Yes
3 rd Course	0.2130-in.*	See Note 2	See Note 2


*Based on a specific gravity of 1.3 of a fluid height of 19-ft.

Notes:

1. Evaluated combined metal and coating.
2. 3rd course not measured since liquid level not planned to extend high enough to impact the surface as reported by Clean Harbors and visually observed by Envirotech.

BOTTOM THICKNESS COMPARISON		
	Measured Thickness	Minimum Thickness (per API 650)
Bottom	0.190 – 0.250	0.2360-in.

During the initial tank inspection on May 21, 2018, Envirotech noted that significant corrosion had occurred primarily in the south end of the tank. During their second inspection on June 5, 2018, Envirotech observed several spot locations of corrosion which were ground to a flat surface to accommodate measurements that revealed the net remaining floor thickness was about 0.220 inches (see figure 2a). Since the cause and period of time could not be determined, it was recommended to replace the affected metal flooring. This was also based on APR 653 which states that minimum floor thickness is 0.010 inches for a tank without secondary containment. Even though this tank has such containment, use of the 0.010 inch criteria was considered an appropriate engineering factor of safety. Clean Harbors elected to continue with sandblasting the floor and the Envirotech engineer



NOTE:

Roman Numerals denote calibration points
Floor thickness measurements are before coating

Page 2 of 8



Tank Thickness Measurements
Clean Harbors Tank T-6 Inspection
Figure 2a
013266-00

SE/NE Section 33, Township 23 North, Range 15 West,
Indian Meridian, Wayne County, Oklahoma



ENVIROTECH

2500 North 11th Street - Enid, Oklahoma 73701
Phone (580) 234-8780, Fax (580) 237-4302
C.A. #1960 - Expiration Date: 6-30-2020
www.envirotechconsulting.com

provided additional floor thickness data. It was demonstrated that the original floor is 0.250 inches thick (see Figure 2b). It was also demonstrated that corrosion was about 0.060 inches deep resulting in a floor thickness of about 0.190 inches due to corrosion. Envirotech then reported to Clean Harbors that coating may progress since the tank bottom had adequate thickness. See photos below.



Pit depth of dime.




Corrosion pitting.



Corrosion.




Corrosion.



Corrosive pit depth of dime.



Corrosive pit depth of dime.



Area of Corrosion

Rev. 2/05



Tank Thickness Measurements
Clean Harbors Tank T-6 Inspection
 Figure 2b
 013266-00

SE/NE Section 33, Township 23 North, Range 16 West
 Indian Meridian, Wagon Mound, Mayr County



ENVIROTECH

2500 North 11th Street - Enid, Oklahoma 73701
 Phone (580) 234-8780, Fax (580) 237-4302
 C.A. #1960 - Expiration Date: 6-30-2020
www.envirotechconsulting.com

4. SECONDARY CONTAINMENT SYSTEM

4.1 General Description of Secondary Containment

(The following information is provided by 1997 tank inspection report).

The secondary containment system consists of an outer tank shell 108-ft. in diameter. The outer shell height is 24-ft. The tank walls were constructed using three course of steel plates which were welded together. The first and second courses were constructed of 5/16-in. A-36 steel while the third course was constructed of 1/4-in. A-36 steel. The tank bottom was constructed of 1/4-in. A-36 steel.

Initially, the tank was built on a native soil pad with a crushed rock layer of approximately 6-in. The tank pad was elevated and surface drainage moved away from the tank. Over time, the area around the tank had filled in to the point that surface water stood around the tank after rainfall events. The impact is that standing water under the tank may enhance bottom corrosion. This has been minimized through ongoing maintenance to create drainage away from the base of the tank as visually observed by Envirotech in the current inspection. A 12-in. layer of pea gravel was installed between the secondary containment tank floor and the primary tank floor and acts as a leak detection and collection system. This is demonstrated in the as-built plans in *Appendix C*.

4.2 Design Standards.

The tank was earlier reported as constructed by Maloney Crawford of Tulsa, Oklahoma. The design drawings indicated that the tank was fabricated and erected in accordance with API Standard 650 at that time.

4.3 Hazardous Characteristics of Wastes Stored.

The wastes which are treated in the primary tank have the following characteristics:

Wastewater, Wastewater Concentrate and Leachate
pH (4-13)
N > 6
Temperature = Ambient to 210° F

The hazardous characteristics of the waste treated in the primary tank were previously examined and it was determined that the pH and normality levels of the waste were primary areas of concern. This was to determine the applicability of a corrosion allowance for the containment system material type and thickness.

4.4 Existing Corrosion Protection.

The interior of the tank was inspected during the confined space entry. There is no coating on the interior surface, however the material appeared in good condition. The exterior of the tank is painted with an epoxy paint as corrosion protection.

4.5 Documented Age of the Containment Area.

The secondary containment vessel was erected in 1987 thus making the containment system 31-years old.

4.6 Result of Leak Tests.

No leak tests have been performed.

4.7 Existing Available Data.

Diameter of Tank	108-ft.
Height	24-ft.
(Maximum Operating Level)	19-ft.
Material	A36 (Design)
Wall Thickness First Course	.3125-in.
Wall Thickness Second Course	.3125-in.
Wall Thickness Third Course	.25-in.
Specific Gravity	1.3
Operating Temperature	Ambient
Seismic Zone	1

4.8 Structural Calculations.

The required thickness of the secondary containment was previously determined to be a function of the specific gravity of the fluid and the corresponding fluid height in the primary vessel. Based on the Allowable Fluid Heights presented in Section 3-8, the maximum fluid heights that would be experienced in the secondary containment, range from 16-ft. to 20-ft. (see *Appendix D – Secondary Containment Volume Calculations*). The calculated minimum thicknesses associated with these fluid heights and specific gravities are presented below:

Maximum Fluid Height (ft)	Specific Gravity of Fluid	Calculated Minimum Thickness – 1 st Course (inches)
16.0	1.3	0.2841
20.0	1.0	0.2784

Appendix B (Secondary Tank wall Thickness Calculations) presents detailed calculations based on a maximum fluid height of 16-ft. and a fluid specific gravity of 1.3. Note that under these conditions, fluid would never reach the third course of the secondary containment. *Appendix B* does however present a thickness calculation for the third course based on the 20-ft. maximum fluid height and specific gravity of 1.0.

A seismic design check was performed pursuant to API 650. Both the overturning moment and shell compression calculations indicate the tank being stable (see *Exhibit E – Structural Support Calculations*.)

A wind loading check was performed pursuant to API 650. These calculations indicate the tank is stable. (see *Exhibit E – Structural Support Calculations*.)

4.9 Comparison of Actual Structure Theoretical Values.

WALL THICKNESS COMPARISON			
	Calculated Minimum Thickness	Measured Thickness	Thickness Meets Standard
1 st & 2 nd Course	0.2841-in.	0.3300-in.	Yes
3 rd Course	0.108-in.	0.2870-in.	Yes

BOTTOM THICKNESS COMPARISON		
	Measured Thickness	Minimum Thickness (per API 650)
Bottom	0.221	0.2500-in.

4.10 Calculation of Existing Capacity.

The secondary containment vessel envelopes the primary tank. If the primary tank leaks, the contents would flow into the secondary vessel and the hydraulic grade lines between the two tanks would equalize thus containing the contents of the primary tank.

5. FOUNDATION AND SHELL SETTLEMENT ANALYSIS

The total weight of tank systems was previously calculated to be 8,372-tons. (see *Appendix A – Tank System Volume and Weight Calculations*). The weight of the tank system is distributed equally over the entire area of the secondary containment tank bottom. This yields a foundation loading of 1827.79-psf. Although no foundation investigation was performed prior to the construction of the T6 tank system, other work and investigation on the Lone Mountain site have resulted in allowable soil loading in excess of 2500-psf.

The foundation loading attributable to resistance of an overturning moment as a result of seismic forces, was calculated to be 601.00-psf, again well below the 2500-psf limit (see *Appendix E – Structural Support Calculations Shell Compression*).

During the tank inspection, elevation measurements were taken at eight (8) points around the circumference of the tank to determine if settlement was occurring. The maximum out-of-plane settlement was computed pursuant to API 653 *Appendix B* and compared with the settlement found from the elevation measurements. The maximum allowable settlement was computed to be 0.42-ft. and the maximum measured settlement was found to be 0.23-ft (see *Appendix F – Tank System Measurements and Settlement Calculations*).

6. ANCILLARY EQUIPMENT

6.1 Manways.

Located in both the primary and secondary tanks are manways with a neck diameter of 24-in. The center of the manways are located approximately 30-in. from the bottom of the tanks. The manways are secured with flange plates 2-ft. 8-in. in diameter which are held in place with 8 7/8-in. dia. Bolts. Both manways were visually inspected by Envirotech Services, Inc. and found in good condition.

6.2 Stairway and Platform.

Affixed to the exterior of secondary containment tank is a metal access stairway that leads from the ground to a platform located at the top of the tank. The stairway and platform are bolted to brackets which are welded to the tank.

Located on the interior of the primary tank is a vertical steel ladder which connects to welded brackets on the side of the tank. The condition of the stairway, platform, ladder and attachment bracket all appear good.

6.3 Nozzle Flanges.

Six (6) nozzle flanges are located around the perimeter walls of both the primary and secondary tanks (see *Diagrams T-6 In* and *T-6 Out* in *Appendix B*). The sizes of the nozzles range from 2-in. to 8-in. in diameter. Nozzles designs are such that piping may be connected to the interior and exterior sections resulting in a piping linkage from the interior of the primary tank to the exterior of the secondary tank. Currently all nozzles are blanked off, and no piping connects the interior and exterior tanks. All of the nozzles were visually inspected by Envirotech Services, Inc. and found in good condition.

6.4 Load Lines.

Load lines were not in place during the inspection and therefore are not included in this assessment.

6.5 Leak Detection System.

Leak detection for the tank system is provided by a network of four (4) collection boxes located equidistant around the perimeter of the secondary containment tank. If a leak occurs in either the bottom or sides of the primary tank, the fluid should travel through the gravel pack and end up at one of the four (4) collection boxes. The fluid then passes under the lip of the gravel stop section of the collection box, found in the interior of the secondary containment tank, and enters the leak detection

pipng which transports it to the exterior of the tank. The exterior piping is blanked with a gate valve and contains a sight glass for inspection purposes. The exterior piping, the gate valve and the sight glass are all contained within a secondary containment vault which is located on the exterior of the tank.

7. CONCLUSIONS

7.1 Primary and Secondary Tank Use.

The primary and secondary tanks were assessed in this document pursuant to API 650-88 and API 653-2009 where applicable. The tank vessels, at the time of the inspection, were determined appropriate for use with the present waste stream at given densities, chemical, and physical characteristics as verified by Clean Harbors Environmental Services, Inc. It was noted that the primary tanks operating height should be restricted based on the apparent and reported maximum height as visually observed and regarding specific gravity of the fluid and its associated height restriction in Section-3.8.

7.2 Life Expectancy.

Based on the information presented and fluid height restriction noted, the useful life of the tanks is estimated to be an additional 15-ys. However, corrosion of the interior tank shall be carefully observed to preempt internal steel lining failure do to corrosion. Repair of the floor plates may be required if corrosion continues as noted in this report.

8. RECOMMENDATIONS

8.1 Compatible Storage.

Clean Harbors should continually insure compatibility with the waste and densities stored in the tank.

8.2 Control Liquid Height.

Maintain a management system or alarm to ensure that the fluid height does not exceed that specified in Section-3.8 of the report.

8.3 Drainage Control.

Maintain site work around the perimeter of the tank to direct storm water away from the tank.

8.4 Routine Inspections.


Monthly visual inspections of the tank exterior should be conducted. This inspection should include each of the four (4) sight glasses associated with the leak detection system. If routine and preventative measures results in the tank being empty, consideration should be given to making periodic interior inspection.

8.5 Corrosion protection.


Continue routine painting of the tank exterior.

9. CERTIFICATION

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including possibility of fine and imprisonment for known violations.


Ron Erdman, P.E.
License No. OK12502

8-28-2018
Date



CA1960
6-30-2020

Appendix A

T6, Wastewater Storage Tank

TANK SYSTEM VOLUME AND WEIGHT CALCULATIONS

DIMENSIONS:

Geometry:	Cylindrical	
Diameter (Primary Tank):	100.00	Feet
Diameter (Secondary Tank):	108.00	Feet
Height:	24.00	Feet
Operating Height:	19.00	Feet
Bottom:	Flat	

PRIMARY TANK VOLUME

Maximum Volume =	188,502.00	C.F.
Operating Volume =	149,230.75	C.F.

Total Primary Tank Volume =	188,502.00	C.F.
	1,409,994.96	Gal.

TANK SYSTEM WEIGHTS

CONTENTS S.G.	1.30	
DENSITY	81.12	LB/C.F.

WEIGHT OF PRIMARY TANK CONTENTS	7,645.64	TONS
---------------------------------	----------	------

TANK WEIGHT - PRIMARY TANK

SURFACE AREA CALCULATIONS

Tank Bottom =	7,854.25	S.F.
Tank Wall = Cir*h	7,540.08	S.F.
Total Surface Area:	15,394.33	S.F.

TANK WEIGHT CALCULATIONS

Steel Thickness:		
Bottom =	0.2500	inches
Tank Wall (1st. course) =	0.3125	inches
Tank Wall (2nd. & 3rd. Courses) =	0.2500	inches
Volume of Steel:		
Bottom =	163.63	C.F.
Tank Wall =	170.16	C.F.
Density of Steel =	490.00	LB/C.F.

TOTAL PRIMARY TANK WEIGHT	81.76	TONS
---------------------------	-------	------

T6, Wastewater Storage Tank

TANK SYSTEM VOLUME AND WEIGHT CALCULATIONS

TANK WEIGHT - SECONDARY TANK

SURFACE AREA CALCULATION:

Tank Bottom =	9,161.20	S.F.
Tank Wall =	8,144.29	S.F.
Total Surface Area	17,305.48	S.F.

TANK WEIGHT CALCULATION:

Steel Thickness:		
Bottom =	0.2500	inches
Tank Wall (1st & 2nd Courses)	0.3125	inches
Tank Wall (3rd. Course)	0.2500	inches
Volume of Steel:		
Bottom =	190.86	C.F.
Tank Wall =	197.97	C.F.
Density of Steel =	490.00	LB/C.F.

TOTAL SECONDARY TANK WEIGHT	95.26	TONS
-----------------------------	-------	------

Volume of pea gravel bed	9,161.20	C.F.
Density of pea gravel	120.00	LB/C.F.

TOTAL PEA GRAVEL WEIGHT	549.67	TONS
-------------------------	--------	------

TOTAL TANK SYSTEM WEIGHT	8,372.35	TONS
--------------------------	----------	------

Foundation Loading	1827.79	psf
--------------------	---------	-----

Appendix B

**T6, Wastewater Storage Tank
PRIMARY TANK WALL THICKNESS**

DIMENSIONS:

Geometry:	Cylindrical	
Diameter:	100.00	feet
Height:	19.00	feet
Specific Gravity:	1.3	
Normal Operating temperature:	Ambient	

FIRST COURSE

Thickness (t) = $(2.6 \cdot H \cdot 1 \cdot D \cdot S.G.) / (s \cdot E)$

s = Allowable Design Stress = 24,708 psi

E = Joint Efficiency = 100%

Calculated Thickness (t) = 0.2462 inches

Corrosion Allowance = 0.0625 inches

Calculated Required Wall Thickness 1st Course 0.3087 inches

Measured Thickness (ultrasonic) 0.3154 inches

Safety Factor 1.02

SECOND AND THIRD COURSES

Thickness (t) = $(2.6 \cdot H \cdot D \cdot S.G.) / (s \cdot E)$

Height (second course) 11.00 feet

s = Allowable Design Stress = 24,708 psi

E = Joint Efficiency = 100%

Thickness (t) = 0.1505 inches

Corrosion Allowance = 0.0625 inches

Calculated Required Wall Thickness 2nd Course 0.2130 inches

Measured Thickness (ultrasonic) 0.2490 inches

Safety Factor 1.14

T6, Wastewater Storage Tank
SECONDARY TANK WALL THICKNESS CALCULATIONS

DIMENSIONS:

Geometry:	Cylindrical	
Diameter:	108.00	feet
Height:	16.00	feet
Specific Gravity:	1.3	
Normal Operating temperature:	Ambient	

FIRST AND SECOND COURSE

$$\text{Thickness (t)} = (2.6 \cdot H \cdot 1 \cdot D \cdot S.G.) / (s \cdot E)$$

$$s = \text{Allowable Design Stress} = 24,708 \text{ psi}$$

$$E = \text{Joint Efficiency} = 100\%$$

$$\text{Calculated Thickness (t)} = 0.2216 \text{ inches}$$

$$\text{Corrosion Allowance} = 0.0625 \text{ inches}$$

$$\text{Calculated Required Wall Thickness 1st Course} = 0.2841 \text{ inches}$$

$$\text{Measured Thickness (ultrasonic)} = 0.3154 \text{ inches}$$

$$\text{Safety Factor} = 1.11$$

THIRD COURSE

$$\text{Thickness (t)} = (2.6 \cdot H \cdot D \cdot S.G.) / (s \cdot E)$$

$$\text{Height (third course)} = 4.00 \text{ feet}$$

$$s = \text{Allowable Design Stress} = 24,708 \text{ psi}$$

$$E = \text{Joint Efficiency} = 100\%$$

$$\text{Thickness (t)} = 0.0455 \text{ inches}$$


$$\text{Corrosion Allowance} = 0.0625 \text{ inches}$$

$$\text{Calculated Required Wall Thickness 3rd Course} = 0.1080 \text{ inches}$$

$$\text{Measured Thickness (ultrasonic)} = 0.2490 \text{ inches}$$

$$\text{Safety Factor} = 1.57$$

Appendix C



PRELIMINARY


Case No.	Case Name	Form	Qty	Description	Unit No.	Value
1	1	1	1	SHIELD	55415	4.1
2	2	1	1	BOTTOM	59229	4.1
3	3	1	1	INSIDE LADDER	591	4.1
4	4	1	1	28" SWELL MANNING	582	4.1
5	5	1	1	6" SF SWELL NORM. w/ FEEL HOLE	51	4.1
6	6	1	1	4" SF SWELL NORM. w/ FEEL HOLE	30	4.1
7	7	1	1	3" SF SWELL NORM. w/ FEEL HOLE	19	4.1
8						
9						
10						
11						
12						
13						
14						
15						
16						
17						
18						
19						
20						
21						
22						
23						
24						
25						
26						
27						
28						
29						
30						
31						
32						
33						
34						
35						
36						
37						
38						
39						
40						
41						
42						
43						
44						
45						
46						
47						
48						
49						
50						
51						
52						
53						
54						
55						
56						
57						
58						
59						
60						
61						
62						
63						
64						
65						
66						
67						
68						
69						
70						
71						
72						
73						
74						
75						
76						
77						
78						
79						
80						
81						
82						
83						
84						
85						
86						

[illegible]

APPROVAL
☐ APPD. W/O COMMENT
☐ APPD. AS NOTED
 DATE _____
 BY _____

RETURN TO:
 MAIONEY-CRAWFORD, INC.
 ATTN: DON COLLINS
 P.O. BOX 659 TULSA, OKLA. 74101-0659

THIS DRAWING IS THE PROPERTY OF MALONEY-CRAWFORD INC.
THIS DRAWING OR COPIES THEREOF ARE NOT TO BE USED IN ANY
WAY WITHOUT PERMISSION FROM MALONEY-CRAWFORD INC.

MALONEY  CRAWFORD INC. TULSA, OKLAHOMA REPRESENTING TALE		QUANTITY <u>100</u> DATE <u>8-25-57</u> REGULATION OF _____ CATEGORY OF _____ APPROVED BY _____ AUTHORITY _____	
FOR <u>100' DIA x 30' PRIMARY</u> <u>CONTAINMENT TANK</u>		PROJECT <u>SMELL</u> FOR <u>100' DIA x 30' PRIMARY</u> <u>CONTAINMENT TANK</u>	

[illegible]

Appendix D

ENVIROTECH SERVICES, INC.
2500 North 11th Street
P.O. Box 6029
ENID, OKLAHOMA 73702
(405) 234-8780 FAX (405) 237-4302

JOB APPENDIX G - SECONDARY CONT
SHEET NO. VOLUME CALCS. OF _____
CALCULATED BY T-L Assessment DATE _____
CHECKED BY _____ DATE _____
SCALE _____

Volume of Secondary Containment

Scenario #1 - Primary Tank Height = 24-ft
 $Sp\ GR = 1.0$

$$V_p = V_{\text{Primary Tank}} = (100^2) \left(\frac{\pi}{4} \right) (24) = 188,502 \text{ ft}^3$$

$$V_s = V_{\text{secondary Containment Tank}} = (109^2 - 100^2) \left(\frac{\pi}{4} \right) (24) = 35,457 \text{ ft}^3$$

In the event of a Primary Tank failure, fluid will equalize at the following height (H):

$$(109^2) \left(\frac{\pi}{4} \right) H \cong V_p$$

$$H \cong \frac{V_p}{(109^2) \left(\frac{\pi}{4} \right)} = \frac{188,502}{(109^2) \left(\frac{\pi}{4} \right)} = \boxed{20.2\text{-ft}}$$

SCENARIO #2 - Primary Tank Height = 19-ft
 $Sp\ GR = 1.3$

$$H \cong \frac{(100^2) \left(\frac{\pi}{4} \right) (19)}{(109^2) \left(\frac{\pi}{4} \right)} = \boxed{14\text{-ft}}$$

Appendix E

T6 Wastewater Storage Tank
STRUCTURAL SUPPORT CALCULATIONS

DIMENSIONS		
Tank Diameter =	100.00	ft.
Total Height =	24.00	ft.
Weight of Tank (Steel) =		lbs
Tank First Coarse Thickness =	0.3125	in.
Tank Bottom Thickness =	0.25	in.

SEISMIC DESIGN CHECK

OVERTURNING MOMENT

Zone Coefficient (Z):	0.1875	
Essential Facilities Factor (I):	1.0	
Lateral Earthquake Force Coeff. (C1):	0.24	
D/H:	4.17	
k Factor:	0.68	
Site Amplification Factor (S):	1.2	
Natural Period of First Sloshing (T):	6.8	
Lateral Earthquake Force Coeff. (C2):	0.035	
Weight of Tank Shell (Ws):	83,386.00	lbs.
Total Weight of Tank Contents (Wt):	15,291,282.24	lbs.
W1/Wt:	0.285	
W2/Wt:	0.67	
Weight of Effective Mass of Contents That Moves in Unison with the Tank Shell (W1):	4,358,015	lbs.
Weight of Effective Mass in First Sloshing (W2):	10,245,159.10	lbs.
Ht from Btm of Shell to Centroid of Shell (Xs)	12	ft.
X1/H:	0.375	
Ht. from Btm to the Centroid of Lateral Seismic Force (X1):	9	ft.
X2/H:	0.54	
Ht. from Btm to the Centroid of Lateral Seismic Force (X2):	12.96	ft.

T6 Wastewater Storage Tank
STRUCTURAL SUPPORT CALCULATIONS

$$\text{Overturning Moment (M)} = Z * I * (C1 * Ws * Xs + C1 * W1 * X1 + C2 * W2 * X2)$$

$$\text{Overturning Moment (M)} = 2,637,208.48 \quad \text{lbs}$$

Weight of tank to resist overturning moment: W_L

$$W_L = 7.9 * t_b * (F_{by} * S.G. * H)^{0.5} =$$

$$\text{Thickness of bottom plate (t}_b\text{)} = 0.25 \quad \text{inches}$$

$$\text{Minimum specified yeild of bottom plate (F}_{by}\text{)} = 36,000 \quad \text{psi}$$

$$\text{Design specific gravity (S.G.)} = 1.3$$

$$W_L = 2093.13 \quad \text{lb/ft. circum}$$

$$1.25 * SG * H * D = 3900.00$$

$$W_L < 1.25 * SG * H * D \quad \text{OK!}$$

$$M / D^2 (W_t + W_L)$$

$$W_t = Ws / 3.1417 * D = 265.42$$

$$M / D^2 (W_t + W_L) = 0.112$$

$$M / D^2 (W_t + W_L) = 0.112 < 0.785 \quad \text{therefore the tank is stable.}$$

SHELL COMPRESSION

Maximum longitudinal compressive force (b):

$$b = W_t + (1.273 * M / D^2) = 601.13 \quad \text{lb / ft. circum}$$

$$\text{Maximum longitudinal compressive stress (b/12t)} = 160.30 \quad \text{psi}$$

$$S.G. * H * D^2 / t^2 = 3,194,880.00$$

$$S.G. * H * D^2 / t^2 > 10^6 \quad \text{therefore}$$

Maximum allowable compressive stress (F_a):

$$F_a = 10^6 * t / D = 3125 \quad \text{psi}$$

$$b/12t < F_a \quad \text{therefore shell compression is OK.}$$

T6 Wastewater Storage Tank
STRUCTURAL SUPPORT CALCULATIONS

WIND LOADING CHECK

M_{max} must be less than or equal to $.66*(WD)/2$

where

W = Shell weight available to resist uplift (lbs) 83,386.00 lbs

D = Tank diameter (ft) 100 ft.

M = Overturning moment = PW * Area (projected) * H1

H1 = Height from the ground to the centroid of the tank shell 12 ft

Pw = Wind Pressure (18 psf for up to 100 MPH winds on cylinder)

$M_{max} =$ 2,780,923 ft - lbs.

M = 518,400 ft - lbs.

$M < M_{max}$ therefore the tank is stable.

Appendix F

T6, Wastewater Storage Tank

TANK SYSTEM MEASUREMENT AND SETTLEMENT CALCULATIONS

ELEVATION MEASUREMENT

Pt. 1
 Pt. 2
 Pt. 3
 Pt. 4
 Pt. 5
 Pt. 6
 Pt. 7
 Pt. 8
 BM

Permissible Out of Plane Deflexion

$$S < (L^2 * Y * 11) / (2 * (E * H))$$

S = Permissible Deflexion (ft.)

L = Arc length between points (ft.)

Y = Yeild Strength (psi)

E = Young's modulus (psi)

H = tank height (ft.)


42.41	ft.
36,000	psi
30×10^6	psi
24	ft.

$L^2 * Y * 11 / (2 * (E * H)) =$	0.49	ft.
----------------------------------	------	-----

From the graph S =	0.23	ft.
-------------------------	------	-----

23 < 49 therefore settlement is acceptable


T6 WASTEWATER STORAGE TANK



POINT NUMBER	ELEVATION
1	1394.45
2	1394.22
3	1394.25
4	1394.38
5	1394.38
6	1394.25
7	1394.35
8	1394.40



FIELD WORK 10-28-2013



JIVIDENS LAND SURVEY Co., INC.

1210 19TH STREET / P.O. BOX 943
WOODWARD, OKLAHOMA 73802

Phone 580-256-7174 - Fax 580-256-3424
roger@jvidenslandsurvey.com mike@jvidenslandsurvey.com

FOR:
ENVIROTECH
2500 N. 11TH STREET
ENID, OK 73701

JOB
609-13

DATE OF PLAT
10-29-2013

SCALE
1"=20'

SHEET
1 OF 1

DRAWN BY
D.W.K.

OKLA. CA #2064, EXP. 06/30/2015
KANSAS CA #143, EXP. 12/31/2014

SECTION UT1

(OUT OF SERVICE)

SECTION 113

ASSESSMENT OF UNLOADING TANK No.1 (UT1) LONE MOUNTAIN HAZARDOUS WASTE FACILITY U.S.P.C.I. WAYNOKA, OKLAHOMA

A. TANK VESSEL DESCRIPTION

Unloading Tank No.1 is an existing small steel aboveground unloading tank located in the pretreatment Truckwash Building of the Lone Mountain Hazardous Waste Facility. Unloading Tank No.1 and a portion of the ancillary equipment are located together in a concrete containment area.

B. PRIMARY TANK VESSEL

1. General Description

Unloading Tank No.1 is being assessed to determine if the unit is adequately designed with sufficient structural strength, and compatibility with the waste to be stored or treated. Unloading Tank No.1 is an aboveground tank used for the unloading and transfer of caustic liquids. The tank is horizontal in position. The tank is supported by four C5x9 steel columns on concrete foundations. The tank is vented through hatch on top of the tank. The temperature of the tank varies with the temperature of the truck unloading (approximately ambient).

Effluent piping is located from the pretreatment building to the caustic tanks.

2. Design Standards.

Structure calculations were performed to compare the existing tank and supports to those sections that are applicable in the American Petroleum Institute Standard 650 - 1988 edition (API-650) and the American Institute of Steel Construction (AISC) Manual of Steel Construction (8th Edition). Appendix A of API 650 was utilized for the design standard due to the small diameter of this vessel. These calculations can be found in the Appendix A of this assessment. The tank was originally built to AWWA D-100-84 standards with ATSM-A-36 Steel.

3. Hazardous Characteristics of Wastes Stored

The wastes which are stored in this tank have the following characteristics:

Untreated wastes pH (4 - 13)

N > 1

Temperature = Ambient

The hazardous characteristics of the waste stored in this tank were examined. It was determined that the pH and normality levels of the waste are the primary areas of concern. This is to determine the applicability of a corrosion allowance for the tank material type and thickness.

4. Existing Corrosion Protection

The tank has been coated with Anchor Paints TAR GARD BLACK. This is a coal tar epoxy paint. The specifications for this paint can be found in Appendix H of this report. This paint has been rated excellent for chemical resistance to Alkalis. The inside and out are coated with this material. It should be noted that when thickness calculations were compared a 1/16" corrosion allowance was used.

5. Documented Age of Tank

This tank was installed in June of 1991. The tank was manufactured just prior to installation therefore the tank age is 1 year.

6. Result of Leak Tests

The tank was hydrostatically tested prior to being put into service and no leaks were found. In addition the tank has been monitored during use and no leaks have been discovered.

7. Existing Data Obtained

Tank Dimensions	See Appendix G of this Assessment
Material	A36 steel
* Wall Thickness	0.188
Volume	159 cf.
Specific gravity of waste	1.5 (Provided by USPCI)
Temperature	Ambient
Seismic Zone	1

* A complete and exhaustive ultrasonic thickness corrosion survey has been completed, the results of which can be found in Appendix F of this assessment.

8. Calculation of Existing Foundation Loading

Total Weight of Tank and Contents = 7.21 tons

Detailed calculations reflecting the volume and weight of the tank are found in Appendix A of this assessment. The minimum required foundation thickness and steel reinforcement are included in Appendix E of this assessment.

9. Required Structural Calculation

The calculated required wall thickness for this tank is 0.2371 inches. This thickness includes 0.0625 inches added for corrosion allowance. This corrosion allowance is based on a best engineering estimate taking into account the materials being treated and a 20 year design life. (See Appendix A of this assessment for detailed calculations or required wall thickness and structural analysis of the tank support system.) As mentioned previously this tank is supported by four C5x9 steel column supports. Detailed structural calculations of these supports are shown in Appendix A of this assessment. The support legs were found to be adequate given the present loading conditions.

10. Comparison of Actual Structure to Theoretical Values

Wall Thickness Comparison

Calculated Required Wall Thickness	0.2371"
Minimum Required Wall Thickness By API-650-88	0.1875"
Measured Wall Thickness	0.188"

As mentioned previously the calculated required thickness includes a 0.0625" corrosion allowance, however a corrosion allowance of 0.0129" is all that is provided due to the measured wall thickness of only 0.188".

C. SECONDARY CONTAINMENT SYSTEM

1. General Description of Secondary Containment

The secondary containment system is designed and operated to prevent any migration of wastes or liquids out of the system. This tank is located within a containment area inside the Truckwash building and consists of a reinforced concrete base floor area with vertical concrete sidewalls. All associated piping is aboveground. The area is inspected on a daily basis. There is a large sump located in the East end of this area.

At the time of inspection the concrete area was withstanding daily operations, and routine climatic conditions. The foundation walls and base are mass poured in place. No cracks from compression or uplift were visually apparent.

The containment area and tanks are visually monitored on a daily basis for leaks. A sump pump and drain are located in the containment area. The floor is sloped to the sump to collect any drainage or spills. Any released tank contents or surface runoff will drain on top of the sloped concrete to the sump area. The accumulated liquids are then removed and pumped to the wastewater pretreatment area within a maximum of 24 hours.

2. Design Standards.

Design drawings for this area were obtained and used as a reference. It should be noted that these are design drawings and not as built drawings. The structural capacity of the foundation and walls were compared to those sections that are applicable in the API-650-88 and the American Concrete Institute (ACI 318-89/318r-89) and these calculations were used as a guide in verifying the ability of the system to contain hazardous waste.

3. Hazardous Characteristics of Wastes Stored

The wastes which are treated in the primary tank have the following characteristics:

Untreated waste pH (4 - 13)

N > 1

Temperature = Ambient

The hazardous characteristics of the waste treated in the primary tank were examined. It was determined that the pH and normality levels of the waste are the primary areas of concern. This is to determine the applicability of a corrosion allowance for the containment system material type and thickness.

4. Existing Corrosion Protection

The concrete containment area and sump pump have been coated with Dudick Protecto-coat 800/900. This impermeable coating is compatible with the present waste stream for this tank vessel. The coating was installed in 1991 by Mid-America Painters of Woodward, OK. See Appendix H of this report for detailed information on this coating.

5. Documented Age of The Containment Area

The secondary containment system was constructed and installed in 1987 thus making the containment system 5 years old.

6. Result of Leak Tests

A visual inspection of the containment area was performed and from this inspection there were no cracks or breaks in the impermeable coating, therefore it would be adequate to contain any leaks or spills. The area is inspected on daily basis checking for leaks from the primary tank.

7. Existing Data Obtained

Dimensions	See Drawings
Wall Height	See Drawings
Material	Concrete
Gross Volume	1210.38 c.f.
Thickness	8"

See Appendix G of this assessment for a detailed layout and cross sections of the secondary containment. Also included in Appendix D of this assessment are detailed calculations of the gross volumes the containment area.

8. Calculation of Existing Capacity

Containment Capacity Available (CCA)

CCA = Gross Volume - Volume of items in the containment - Volume of rainfall.

See the Appendix D of this assessment for detailed calculations of the available containment volume. The containment capacity available = 1209.21 c.f.

9. Required Volume

Containment Capacity Required (CCR)

CCR = Volume of Largest Tank in the secondary containment

Volume of Largest Tank = 159 c.f.(UT1)

10. Comparison of Available Volume to Required Volume

Containment Capacity Comparison

Containment Capacity Required =	159 c.f.
Secondary Containment Volume Available =	1209 c.f.
Excess Containment Volume =	1050 c.f.

CCA > CCR Adequate Capacity (under normal operating conditions) is available.

D. CONCLUSIONS

1. Primary Tank Vessel

The tank vessel at the time of inspection was fit for use with the present waste stream at given densities, chemical and physical characteristics as verified by USPCI. The useful life of the steel tank would be estimated at 19 years if the current waste stream is maintained. This useful life was determined by using a design life of 20 years less the period that the tank has been in use at the USPCI Lone Mountain Facility.

2. Secondary Containment System

The secondary containment area at the time of inspection was fit for use, if the present waste stream at given densities and chemical and physical characteristics as verified by USPCI were released from the primary tank. The useful life of the concrete containment area is estimated at 15 years. This useful life was determined by using a design life of 20 years less the period that the tank has been in use at the USPCI Lone Mountain Facility. There did not seem to be any extensive corrosion or deterioration of the secondary containment area.

E. RECOMMENDATIONS

The following repairs or modifications should be made:

1. Primary Tank

The tank should be checked periodically with ultrasonic testing procedures to establish a verified limit of corrosion. USPCI should continually insure compatibility with the waste and densities stored. Daily inspections should be continued to detect any visual corrosion or defects.

2. Secondary Containment


The secondary containment should be checked periodically for any deterioration and structural integrity. USPCI should continually insure compatibility with the waste and densities stored.

3. Routine Inspections

When routine and preventative measures are to be completed, the tank should be cleaned and internally inspected to determine any interior defects or corrosion. Continued routine painting and coating of tanks on the interior and exterior, and routine inspection is recommended.


F. CERTIFICATION

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.



E.E Myers
Date: 1/20/93

Engineer
Title



APPENDIX A

The following appendices have been combined into one appendix:

- Appendix A
- Appendix B
- Appendix C
- Appendix E

These appendices were combined due to the fact that the original design calculations were prepared by Gauger Engineering. The calculations included in this appendix are those that were prepared by Gauger Engineering.

USPCI - CAUSTIC UNLOADING # 1

WEIGHT & CAPACITY OF TANK

$$\text{INSIDE DIAMETER OF END SECTION} = 4.958'$$

$$\text{AREA OF HALF CIRCLE} = \frac{\pi D^2}{4 \times 2} = \frac{\pi (4.958)^2}{8} = 9.655'$$

$$\text{AREA OF CENTER SECTION} = 4.958 \times 4 = 19.833'$$

$$\text{TOTAL INSIDE PLAN AREA} = 2 \times 9.655 + 19.833 = 39.142'$$

$$\text{HEIGHT OF TANK BASE RING TO TOP RING} = 3'-8"$$

$$\text{VOLUME} = 3.667 \times 39.141 = 143.532 \text{ Cu. Ft.}$$

$$\text{VOLUME OF END CONE} = H \times A \times \frac{1}{3}$$

$$= .479 \times 9.655 / 3 = 1.542 \text{ Cu. Ft.}$$

$$\text{VOLUME OF CENTER BASE SECTION} = H \times A \times \frac{1}{2}$$

$$= .479 \times 4 \times 4.958 / 2 = 4.75 \text{ Cu. Ft.}$$

$$\text{TOTAL VOLUME TO TOP RING (OVERFLOW)}$$

$$= 143.532 + 2 \times 1.542 \times 4.75 = 151.369 \text{ Cu. Ft.}$$

$$= 1132.24 \text{ GAL.}$$

(USE FOR LOAD DESIGN)

$$\text{TOTAL VOLUME OF BASE SLOPE}$$

$$1.542 \times 2 + 4.75 = 7.834 \text{ Cu. Ft.}$$

$$= 58.6 \text{ GAL.}$$

$$\text{VOLUME OF UNIT DEPTH} = 7.48 \times 39.142$$

$$= 292.782 \text{ Gall./Ft.}$$

$$\text{WORKING (NET) VOLUME} = 1034.64 \text{ GAL.}$$

(BASED ON 4" FREEBOARD)

$$\begin{aligned}\text{TOTAL INSIDE VOL.} &= 1132.24 + 58.6 \\ &= 1190.84 \text{ GAL.}\end{aligned}$$

$$\begin{aligned}\text{SPECIFIC GRAVITY OF CONTENTS} &= 1.30 \\ \text{MAX. WT. FOR TANK DESIGN} &= 1132.24 \times 8.33 \times 1.30 \\ &= \underline{12265.4 \#}\end{aligned}$$

ESTIMATE OF DEAD WT.

5/16" PLATE	629 #
3/16" SHELL	440 #
3/16" TOP & BOT.	393 #
1" ROD	71 #
1/2" ROD	7 #
5" CHANNEL	356 #
2 x 2 x 3/16 L	116 #
BR	21 #
COLLAR	20 #
MISC. & WELD	97 #
	<hr/> 2150 #


$$\text{MAX. LOAD} = 14,415 \# \pm$$

$$\text{LEG. LOAD} = 3604 \# \text{ EACH.}$$

$$\text{BEARING PRESSURE} = 100 \text{ PSI}$$

END SHELL ANALYSIS

Hoop Tension




Max. Hydro. Press. @ Bottom

$$3.67 \times 21.12 / 12 = 24.79 \text{ PSI}$$

$$T = \frac{24.19 \times 60}{2} = 743 \text{ } ^\circ/\text{h}$$

CAUTIVE SUPPORT FORCES



WEIGHTS

CONTENTS @ 21.12 PCF

Half cyl. $\lambda = \frac{\pi (4.96)^2}{2 \times 4} = 9.65 \text{ m}^2$

$$W_c = 9.65 \times 3.67 \times 81.12$$

$$= 2873 \text{ \# CYLINDER}$$

$$W_B = 9.65 \times 5 \times .35 \times 61.12$$
$$= 130^k$$

CONTENTS 3003 #.

TANK WT. $\frac{1}{4} R = 10.2 \frac{\#}{\text{sq'}}$

Top or Bottom ::

$$9.65 \times 10.2 = 99^{\#}$$

SWELL

$$.5\pi \times 9.67 / 2 \times 10.2 = 294^{\circ}$$

உறையூர் அங்குலம்

$$5\pi \times 2.44 \doteq 39^{\circ}$$

Total wt = 3534* L+D

CENTROID OF LOAD

$$\bar{x} = \frac{4 \times 2.5}{2\pi} = 1.061'$$


Moment of Load

$$\begin{aligned} M &= 3534 \times 1.061 \\ &= 3750' \# \text{ TOTAL} \\ &= 1875' \# / \text{SIDE} \end{aligned}$$

Unit Forecasts

$$F = \frac{1875 \times 12}{\frac{442}{6}} = 70 \frac{3}{11}$$

COMBINED FORCES ON END SHELLS




REQUIRED SHELL THICKNESS

$$T = \frac{673}{15000} = .04'' + \frac{1}{16} = .11''$$

USE MIN. $\frac{3}{16}''$

CLAM SHELL BOTTOM (DIVIDED)



$$\alpha = \tan^{-1} \frac{2.5}{.5} = 78.69^\circ$$

$$A_{\text{area}} = \pi \times \frac{5^2}{4} = 19.63 \text{ ft}^2$$

TOTAL LOAD ON BASE CIRCLES

$$F = 19.63 \times [3.667 + \frac{1}{2}(.5)] \times 1.3 \times 62.4 = 6106 \text{ \#}$$

$$\text{SHEAR @ CORNER WELD} = \frac{6106}{5\pi \times 12} = 32.4 \text{ \#/ft}$$

$$\text{RADIAL FORCE @ CORNER} = \frac{32.4}{\tan \alpha} = 159 \text{ \#/ft}$$


$$\text{PRINCIPAL TANGENTIAL (RAY)} = \sqrt{32.4^2 + 159^2} = 163 \text{ \#/ft}$$

CORNER REINF. ANGLE

$$C = 359 \times 20 = 4770^* \text{ COMPRESSION}$$

AREA OF ANGLE REQUIRED

$$A = \frac{4770}{15000} = .32 \quad 2 \times 2 \times \frac{3}{16} L = .44 \text{ " OK}$$




MAX. WELD FORCE $159^{\#}/\text{in}$

Fillet welds @ $.4 \times .707 \times 36000$
 $= 10180^{\#}/\text{in}$ WELD LEG.

$$L = \frac{159}{10180} = .02^{\#} \text{ USE } \frac{3}{16}^{\#}$$

CENTRAL TANK SHELL

CONTINUITY ANALYSIS OF PLATES




JOINT COORD.

JOINT	X	Y
1	-30	50
2	-30	38
3	-30	26
4	-30	16
5	-30	6
6	-15	3
7	0	0
8	15	3
9	30	6
10	30	16
11	30	26
12	30	38
13	30	50

MEMBERS

1	1	2
2	2	3
3	3	4
4	4	5
5	5	6
6	6	7
7	7	8
8	8	9
9	9	10
10	10	11
11	11	12
12	12	13
13	5	9



GAUGER ENGINEERING CO.
1306 E. 13TH. STREET
TULSA, OKLAHOMA

CAUSTIC UNLOADING TANK SHEET CONTINUITY ANALYSIS
USFC1 LONE MOUNTAIN FACILITY

I C R O S A F E --- STRUCTURAL ANALYSIS BY FINITE ELEMENTS
Version: SAFE2STA (2-D) Rel. 3.0 5/26/1991 2:49:24

SIZE OF THE STRUCTURE

Number of nodes	:	13
Number of materials	:	1
Number of beams	:	12
Number of beam end releases	:	0
Number of plates	:	0
Number of fasteners	:	0
Number of primary loadcases	:	1
Number of superposition loadcases	:	0
Number of restrained degrees of freedom	:	6

COORDINATES

Node	Coordinate X	Coordinate Y
1	-.300000E+02	.500000E+02
2	-.300000E+02	.280000E+02
3	-.300000E+02	.260000E+02
4	-.300000E+02	.160000E+02
5	-.300000E+02	.600000E+01
6	-.150000E+02	.300000E+01
7	.000000E+00	.000000E+00
8	.150000E+02	.300000E+01
9	.300000E+02	.600000E+01
10	.300000E+02	.160000E+02
11	.300000E+02	.260000E+02
12	.300000E+02	.380000E+02
13	.300000E+02	.500000E+02

MATERIAL PROPERTIES

Material	Young's modulus	Poisson's ratio	Specific weight
1	.290000E+08	.300000E+00	.000000E+00

AM DATA

am	I	J	Length	Area	M. Inertia	Material
1	1	2	.12000E+02	.30000E+01	.15600E-01	1
2	2	3	.12000E+02	.30000E+01	.15600E-01	1
3	3	4	.10000E+02	.30000E+01	.15600E-01	1
4	4	5	.10000E+02	.30000E+01	.15600E-01	1
5	5	6	.15297E+02	.30000E+01	.15600E-01	1
6	6	7	.15297E+02	.30000E+01	.15600E-01	1
7	7	8	.15297E+02	.30000E+01	.15600E-01	1
8	8	9	.15297E+02	.30000E+01	.15600E-01	1
9	9	10	.10000E+02	.30000E+01	.15600E-01	1
10	10	11	.10000E+02	.30000E+01	.15600E-01	1
11	11	12	.12000E+02	.30000E+01	.15600E-01	1
12	12	13	.12000E+02	.30000E+01	.15600E-01	1

IMARY LOADCASES

adcase name :
 adcase number : 1
 mber of loaded nodes : 0
 of loaded beams : 12
 of loaded plates : 0
 avity loads factor : .00000E+00

AM LOADS

am	Loading direction	End Distributed Loads
1	Local Y axis	.000000E+00 -.676000E+01
2	Local Y axis	-.676000E+01 -.135200E+02
3	Local Y axis	-.135200E+02 -.191500E+02
4	Local Y axis	-.191500E+02 -.247900E+02
5	Local Y axis	-.247900E+02 -.264800E+02
6	Local Y axis	-.264800E+02 -.281700E+02
7	Local Y axis	-.281700E+02 -.264800E+02
8	Local Y axis	-.264800E+02 -.247900E+02
9	Local Y axis	-.247900E+02 -.191500E+02
10	Local Y axis	-.191500E+02 -.135200E+02
11	Local Y axis	-.135200E+02 -.676000E+01
12	Local Y axis	-.676000E+01 .000000E+00

EMENT RESTRAINTS

fe	Type of restraint	Displacement
1	Translation along X axis	.000000E+00
2	Translation along X axis	.000000E+00
3	Translation along Y axis	.000000E+00
4	Translation along X axis	.000000E+00
5	Translation along Y axis	.000000E+00
13	Translation along X axis	.000000E+00

SOLUTION SUMMARY

Number of degrees of freedom : 39 (39 in RAM and 0 on disk)
 Bandwidth : 6
 Number of loadcases : 1

RESULTS FOR LOADCASE 1 :

NODE DISPLACEMENTS

Node	U	V	Omega
1	.00000E+00	.00000E+00	-.45278E-01
2	-.47052E+00	.00000E+00	-.27578E-01
3	-.56789E+00	.00000E+00	.12611E-01
4	-.30193E+00	.00000E+00	.36131E-01
5	.00000E+00	.00000E+00	.12750E-01
6	-.16627E-01	-.84828E-01	-.34803E-02
7	.17353E-17	-.33853E-02	.10361E-16
8	.16627E-01	-.84828E-01	.34803E-02
9	.00000E+00	.00000E+00	-.12750E-01
10	.30193E+00	.00000E+00	-.36131E-01
11	.56789E+00	.00000E+00	-.12611E-01
12	.47052E+00	.00000E+00	.27578E-01
13	.00000E+00	.00000E+00	.45278E-01

MEMBER CORNER FORCES

Member	I	J	FX1	FY1	MZ1	FX2	FY2	MZ2
1	1	2	.11842E+03	.00000E+00	-.30287E-12	-.77864E+02	.00000E+00	.12534E+04
2	2	3	.77864E+02	.00000E+00	-.12534E+04	.43816E+02	.00000E+00	.15334E+04
3	3	4	-.43816E+02	.00000E+00	-.15334E+04	.20717E+03	.00000E+00	.32233E+03
4	4	5	-.20717E+03	.00000E+00	-.32233E+03	.42687E+03	.00000E+00	-.28040E+04
5	5	6	-.17664E+04	.79440E+03	.28040E+04	.18433E+04	-.40987E+03	.84418E+03
6	6	7	-.18433E+04	.40987E+03	-.84418E+03	.19253E+04	.18733E-11	-.17040E+04
7	7	8	-.19253E+04	.28169E-12	.17040E+04	.18433E+04	.40987E+03	.84418E+03
8	8	9	-.18433E+04	-.40987E+03	-.84418E+03	.17664E+04	.79440E+03	-.28040E+04
9	9	10	-.42687E+03	.00000E+00	.28040E+04	.20717E+03	.00000E+00	.32233E+03
10	10	11	-.20717E+03	.00000E+00	-.32233E+03	.43816E+02	.00000E+00	.15334E+04
11	11	12	-.43816E+02	.00000E+00	-.15334E+04	-.77864E+02	.00000E+00	.12534E+04
12	12	13	.77864E+02	.00000E+00	-.12534E+04	-.11842E+03	.00000E+00	.47073E-13

AM LOADS AND STRESSES

am	I	J	FX1	SX1	FX2	SX2	SH1
	EM1	BM2					
1	1	2	.00000E+00	.00000E+00	.00000E+00	.00000E+00	-.11842E+03
287E-12							-.77864E+02
2	2	3	.00000E+00	.00000E+00	.00000E+00	.00000E+00	-.77864E+02
534E+04							.43816E+02
3	3	4	.00000E+00	.00000E+00	.00000E+00	.00000E+00	.43816E+02
334E+04							.20717E+03
4	4	5	.00000E+00	.00000E+00	.00000E+00	.00000E+00	.20717E+03
233E+03							.42687E+03
5	5	6	.18879E+04	.62931E+03	.18879E+04	.62931E+03	-.43255E+03
040E+04							-.40406E+02
6	6	7	.18879E+04	.62931E+03	.18879E+04	.62931E+03	-.40406E+02
18E+03							.37759E+03
7	7	8	.18879E+04	.62931E+03	.18879E+04	.62931E+03	-.37759E+03
40E+04							.40406E+02
8	8	9	.18879E+04	.62931E+03	.18879E+04	.62931E+03	.40406E+02
418E+03							.43255E+03
9	9	10	.00000E+00	.00000E+00	.00000E+00	.00000E+00	-.42687E+03
04							-.20717E+03
10	10	11	.00000E+00	.00000E+00	.00000E+00	.00000E+00	-.20717E+03
23E+03							-.43816E+02
11	11	12	.00000E+00	.00000E+00	.00000E+00	.00000E+00	-.43816E+02
534E+04							.77864E+02
12	12	13	.00000E+00	.00000E+00	.00000E+00	.00000E+00	.77864E+02
34E+04							.11842E+03
							.47073E-13

INTERNAL FORCES AND REACTIONS

de	Coordinate X	Coordinate Y	FX	FY	MZ
1	-.300000E+02	.500000E+02	.11842E+03 Reaction	.00000E+00	-.30287E-12
2	-.300000E+02	.380000E+02	.26853E-05	.00000E+00	.89746E-05
3	-.300000E+02	.260000E+02	-.11294E-05	.00000E+00	-.12568E-04
4	-.300000E+02	.160000E+02	.45927E-05	.00000E+00	-.23346E-05
5	-.300000E+02	.600000E+01	-.13396E+04 Reaction	.79440E+03 Reaction	.10962E-03
6	-.150000E+02	.300000E+01	.71504E-05	-.28610E-05	-.14251E-04
7	.000000E+00	.000000E+00	-.16691E-04	.21550E-11	.74037E-05
8	.150000E+02	.300000E+01	.71504E-05	.28610E-05	-.14251E-04
9	.300000E+02	.600000E+01	.13396E+04 Reaction	.79440E+03 Reaction	.10962E-03
10	.300000E+02	.160000E+02	.45927E-05	.00000E+00	-.23346E-05
11	.300000E+02	.260000E+02	-.11294E-05	.00000E+00	-.12568E-04
12	.300000E+02	.380000E+02	.26853E-05	.00000E+00	.89746E-05
13	.300000E+02	.500000E+02	-.11842E+03 Reaction	.00000E+00	.47073E-13

CENTRAL TANK SHELL

SIDE PLATE



3'-8"

3'-8"



PRESSURE:

$$3.667 \times 1.3 \times 62.4$$

$$= 298 \text{ #/ft}^2$$

$$q = 2.07$$

2.07 PSI

REF: TO TIMOSHENKO, WOINOWSKY KRIEGER
THEORY OF PLATES & SHELLS

RATIO OF SIDES

$$\frac{b}{a} = 1.0$$

FROM TABLES

$$\beta = .0264$$

$$\beta_1 = .0245$$

$$M_x = \beta q a^2$$

$$M_y = \beta_1 q a^2$$

$$= .0264 \times 2.07 \times 44^2$$

$$= .0245 \times 2.07 \times 44^2$$

$$= 105.8 \text{ #/in}^2$$

$$= 98.18 \text{ #/in}^2$$

$$\text{SECTION MODULUS} = \frac{b t^2}{6}$$


$$S = .167 t^2 = \frac{M}{\sigma} = \frac{105.8}{15000} = .0071$$

$$t = \sqrt{\frac{.0071}{.167}} = .2055 \text{ SIMPLY SPON}$$

$$\frac{105.8}{105.8 + 98.18} = 52\%$$

BOTTOM PLATE

SIMPLE SUPPORTED CASE



$$\begin{aligned} q &= 4.0 \times 1.3 \times 62.4 \\ &= 324.5 \text{ PSF} \\ &= 2.25 \text{ PSI} \end{aligned}$$

RATIO OF SIDES

$$\frac{b}{a} = \frac{44}{30} = 1.467 \approx 1.5$$

FROM TABLE @ & R

$$\begin{aligned} \beta &= .0812 \\ M_x &= \beta q a^2 \\ &= .0812 \times 2.25 \times 30^2 \\ &= 164.4 \text{ "*/"} \end{aligned}$$

$$\begin{aligned} \beta_1 &= .0498 \\ M_y &= \beta_1 q a^2 \\ &= .0498 \times 2.25 \times 30^2 \\ &= 100.85 \text{ "*/"} \end{aligned}$$

BUILT IN SUPPORTS CASE


@ & PLATE

$$\begin{aligned} M_x &= .0368 \times 2.25 \times 30^2 & M_y &= .0203 \times 2.25 \times 30^2 \\ &= 74.52 \text{ "*/"} & &= 41.11 \text{ "*/"} \end{aligned}$$

@ & EDGE

$$\begin{aligned} M_x &= -.0757 \times 2.25 \times 30^2 & M_y &= -.0570 \times 2.25 \times 30^2 \\ &= -153.3 \text{ "*/"} & &= -115.43 \text{ "*/"} \end{aligned}$$

CENTRAL TANK SHELL



STATIC MOMENT

$$844 + \frac{2804 + 1704}{2} = 3098 \text{ "}/$$

$$= 258.17 \text{ "}/$$

LOAD RATIO FOR THIS DIRECTION = 52%

$$M_s = .52 \times 258.17 = 134.24 \text{ "}/ > 105.6 \text{ OK}$$


$$M_b = .52 \times 2804 / 12 = 121.5 \text{ "}/$$

$$S = \frac{M}{\sigma} = \frac{t^2}{6} = \frac{121.5}{15000}$$

$$t = .22" + 1/16 = .283 < 5/16 \text{ USE } 5/16 \text{ PL}$$

clips:

For Frame Design Assume All Loads Carried On Frame
Plates Totally Supported By Frame



(10) STRENGTH

$$\frac{L}{r} = \frac{74.4}{.62} = 120$$

1 1/2" ϕ STD PIPE

$$\Delta = .799$$


$$\frac{L}{r} = \frac{60}{.50} = 120$$

$$\frac{P}{2} = .5 \quad E = 1.00$$

$$\Delta = .785$$

$$F_c = 10.28$$

$$.785 \times 10.28 = 8.07 \quad \text{OK}$$




$$S_x = \frac{4183}{15000} = .2789$$

$$S_y = .45 \quad \text{OK}$$

(1002)

$$\frac{5912}{15000} = .3941 < .45 \quad \text{OK}$$



GAUGER ENGINEERING CO.
1306 E. 13TH. STREET
TULSA, OKLAHOMA

ANALYSIS OF CAUSTIC UNLOADING TANK SUPPORT FRAME
USPCI LONE MOUNTAIN FACILITY

C R O S A F E --- STRUCTURAL ANALYSIS BY FINITE ELEMENTS
Version: SAFE2STA (2-D) Rel. 3.0 5/06/1991 2:34:31

E OF THE STRUCTURE

ber of nodes	:	11
ber of materials	:	1
ber of beams	:	14
ber of beam end releases	:	0
ber of plates	:	0
ber of fasteners	:	0
ber of primary loadcases	:	1
ber of superposition loadcases	:	0
ber of restrained degrees of freedom	:	4

E COORDINATES

	Coordinate X	Coordinate Y
1	.000000E+00	.000000E+00
2	.000000E+00	.800000E+01
3	.000000E+00	.300000E+02
4	.000000E+00	.520000E+02
5	.600000E+02	.000000E+00
6	.600000E+02	.800000E+01
7	.600000E+02	.300000E+02
8	.600000E+02	.520000E+02
9	.300000E+02	.580000E+02
0	.300000E+02	.800000E+01
1	.300000E+02	.200000E+01

ERIAL PROPERTIES

e	Young's modulus	Poisson's ratio	Specific weight
1	.290000E+08	.250000E+00	.283600E+00

.AM DATA

eam	I	J	Length	Area	M. Inertia	Material
1	1	2	.80000E+01	.52800E+01	.24700E+01	1
2	2	3	.22000E+02	.26400E+01	.63200E+00	1
3	3	4	.22000E+02	.26400E+01	.63200E+00	1
4	5	6	.80000E+01	.52800E+01	.24700E+01	1
5	6	7	.22000E+02	.26400E+01	.63200E+00	1
6	7	8	.22000E+02	.26400E+01	.63200E+00	1
7	4	9	.30594E+02	.17800E+01	.17800E+01	1
8	8	9	.30594E+02	.17800E+01	.17800E+01	1
9	4	8	.60000E+02	.75000E+00	.30000E-01	1
10	2	8	.74404E+02	.75000E+00	.30000E-01	1
11	10	2	.30000E+02	.17800E+01	.17800E+01	1
12	10	6	.30000E+02	.17800E+01	.17800E+01	1
13	11	2	.30594E+02	.93800E+00	.30000E-02	1
14	11	6	.30594E+02	.93800E+00	.30000E-02	1

PRIMARY LOADCASES

Loadcase name : TOTAL LD
 Loadcase number : 1
 Number of loaded nodes : 3
 Number of loaded beams : 6
 Number of loaded plates : 0
 Gravity loads factor : .0000E+00

BE LOADS

Beam	FX	FY	MZ
4	.000000E+00	-.193000E+04	.000000E+00
8	.000000E+00	-.193000E+04	.000000E+00
9	.000000E+00	-.500000E+03	.000000E+00

EAM LOADS

eam	Loading direction	End Distributed Loads
2	Local Y axis	.495000E+02 .247800E+02
3	Local Y axis	.247800E+02 .000000E+00
5	Local Y axis	-.495000E+02 -.247800E+02
6	Local Y axis	-.247800E+02 .000000E+00
13	Local Y axis	.563300E+02 .495000E+02
14	Local Y axis	-.563300E+02 -.495000E+02

MOVEMENT RESTRAINTS

Node	Type of restraint	Displacement
1	Translation along X axis	.000000E+00
1	Translation along Y axis	.000000E+00
5	Translation along X axis	.000000E+00
5	Translation along Y axis	.000000E+00

SOLUTION SUMMARY

number of degrees of freedom : 33 (33 in RAM and 0 on disk)
 bandwidth : 30
 number of loadcases : 1

=====

SOLUTIONS FOR LOADCASE 1 : TOTAL LD

=====

DE DISPLACEMENTS

de	U	V	Omega
1	.00000E+00	.00000E+00	-.24664E-03
2	.16727E-02	-.19634E-03	-.13333E-03
3	-.17304E-01	-.82295E-03	.22602E-03
4	-.14835E-02	-.14491E-02	-.89290E-03
5	.00000E+00	.00000E+00	.23742E-03
6	-.15939E-02	-.19634E-03	.12476E-03
7	.17868E-01	-.82304E-03	-.25533E-03
8	.25216E-02	-.14493E-02	.88565E-03
9	.54921E-03	-.15342E-01	.33061E-05
10	.36830E-04	-.21374E-02	.23056E-05
11	.36830E-04	-.32055E-01	.23056E-05

RAM CORNER FORCES


ram	1	3	FX1	FY1	MZ1	FX2	FY2	MZ2
1	1	2	-.25219E+03	.37675E+04	-.14559E-11	.25219E+03	-.37675E+04	.20175E+04
2	2	3	.82491E+03	.21789E+04	-.59127E+04	-.78308E+01	-.21789E+04	-.23169E+04
3	3	4	.78308E+01	.21789E+04	.23169E+04	.26475E+03	-.21789E+04	.14420E+04
4	5	6	.25219E+03	.37675E+04	.97033E-12	-.25219E+03	-.37675E+04	-.20175E+04
5	6	7	-.82628E+03	.21792E+04	.59445E+04	.91991E+01	-.21792E+04	.23152E+04
6	7	8	-.91931E+01	.21792E+04	-.23152E+04	-.26338E+03	-.21792E+04	-.14136E+04
7	4	9	.12089E+04	.24888E+03	-.14156E+04	-.12089E+04	-.24888E+03	.16289E+04
8	8	9	-.12089E+04	.25112E+03	.13486E+04	.12089E+04	-.25112E+03	-.16289E+04
9	4	8	-.14736E+04	-.19202E-01	-.26452E+02	.14736E+04	.19202E-01	.25300E+02
10	2	8	.13683E+01	.19310E+01	.15904E+02	-.13683E+01	-.19310E+01	.39749E+02
10	10	2	-.28147E+04	.79343E+00	.22260E+03	.28147E+04	-.79343E+00	-.24641E+03
10	10	6	.28147E+04	-.79343E+00	-.22260E+03	-.28147E+04	.79343E+00	.19880E+03
11	11	2	.42107E+04	.13113E-02	-.41283E+04	-.38932E+04	.15874E+04	.41257E+04
14	11	6	-.42107E+04	-.13113E-02	.41283E+04	.38932E+04	.15875E+04	-.41258E+04

4 LOADS AND STRESSES

m	I	J	FX1	SX1	FX2	SX2	SH1
	BM1	BM2					
1	1	2	-.37674E+04	-.71353E+03	-.37674E+04	-.71353E+03	-.25219E+03
59E-11	.20175E+04						
2	2	3	-.21789E+04	-.82533E+03	-.21789E+04	-.82533E+03	.82491E+03
27E+04	-.23169E+04						.78308E+01
3	3	4	-.21789E+04	-.82533E+03	-.21789E+04	-.82533E+03	.78308E+01
69E+04	.14420E+04						-.26475E+03
4	5	6	-.37674E+04	-.71353E+03	-.37674E+04	-.71353E+03	.25219E+03
33E-12	-.20175E+04						.25219E+03
5	6	7	-.21792E+04	-.82546E+03	-.21792E+04	-.82546E+03	-.82628E+03
45E+04	.23152E+04						-.91991E+01
6	7	8	-.21792E+04	-.82546E+03	-.21792E+04	-.82546E+03	-.91991E+01
52E+04	-.14136E+04						.26238E+03
7	4	9	-.12342E+04	-.69337E+03	-.12342E+04	-.69337E+03	-.69728E+01
56E+04	.16239E+04						-.69728E+01
8	8	9	-.12346E+04	-.69361E+03	-.12346E+04	-.69361E+03	.91635E+01
36E+04	-.16229E+04						.91635E+01
9	4	8	.14736E+04	.19648E+04	.14736E+04	.19648E+04	.19202E-01
38E-02	.25300E+02						.19202E-01
10	2	8	-.22453E+01	-.29938E+01	-.22453E+01	-.29938E+01	-.74798E+00
04E+02	.39749E+02						-.74798E+00
1	10	2	-.28147E+04	-.15813E+04	-.28147E+04	-.15813E+04	.79343E+00
50E+03	-.24641E+03						.79343E+00
2	10	6	-.28147E+04	-.15813E+04	-.28147E+04	-.15813E+04	.79343E+00
50E+03	.19880E+03						.79343E+00
3	11	2	.41289E+04	.44018E+04	.41289E+04	.44018E+04	.82578E+03
33E+04	.41257E+04						-.79311E+03
4	11	6	.41289E+04	.44018E+04	.41289E+04	.44018E+04	.82578E+03
33E+04	-.41258E+04						.79311E+03

E INTERNAL FORCES AND REACTIONS

e	Coordinate X	Coordinate Y	FX	FY	MZ
1	.000000E+00	.000000E+00	-.25219E+03 Reaction	.37674E+04 Reaction	-.14559E-11
2	.000000E+00	.800000E+01	.77631E-04	.10779E-03	.25467E-03
3	.000000E+00	.300000E+02	.16276E-06	-.15219E-04	-.33749E-04
4	.000000E+00	.520000E+02	-.41231E-04	.39184E-07	-.40558E-04
5	.600000E+02	.000000E+00	.25219E+03 Reaction	.37674E+04 Reaction	.97033E-12
6	.600000E+02	.800000E+01	-.77631E-04	.44798E-04	-.31623E-03
7	.600000E+02	.300000E+02	.32194E-06	-.66327E-04	-.98007E-04
8	.600000E+02	.520000E+02	.45378E-05	-.52525E-05	-.41468E-04
9	.300000E+02	.580000E+02	-.39668E-04	.63653E-05	.16168E-04
0	.300000E+02	.800000E+01	.34592E-04	-.12366E-07	.31206E-05
1	.300000E+02	.200000E+01	.62372E-04	.46881E-10	-.69368E-04



PHONE 582-1144

STRUCTURAL CIVIL ENGINEERS
1308 EAST 13th STREET TULSA, OKLAHOMA 74120

June 3, 1991

Mr. Gene Walker
Environmental Engineer
USPCI Inc. Lone Mountain Facility
Route 2, Box 180 A
Waynoka, Oklahoma 73860

Caustic Unloading Tank #1
Pretreatment Washdown Area

Dear Mr. Walker

The several items which were incomplete on my visit of May 30, 1991 have been satisfactorily completed at this time. Those items were concerned with touchup repainting, and completion of the ancillary piping to the pump location.

The leak test of the system was performed today and upon careful inspection, no leaks were detected.

This letter is to certify that the Caustic Unloading Tank #1 was installed in a manner that no structurally adverse conditions were produced in accordance with 40 CFR 264.192(b).

If there are questions please call at your convenience.

Sincerely,

A handwritten signature in cursive script that reads "Fred N. Gauger".

Fred N. Gauger H.S.C.E.
Registered Professional Engineer
Oklahoma #5823




GORE-TEX® JOINT SEALANT INSTALLATION INSTRUCTIONS

on the flanges. Dirt and scale provide leakage paths.


Lubricate the bolts and the underside of the nuts. Heavy graphite and oil mixture will do, but for maximum clamping force use Teflon pipe thread grease. Threads should be well formed and free running. Lubricating the threads doubles the clamping force.

Apply the Joint Sealant on the flange toward the inside of the gasket sealing area so that a width of overlap about equal to half the width of Joint Sealant on the outside as shown. Firmly press the Joint




Sealant in place as you go. The adhesive stripe will hold the Joint Sealant in position. The placement of the Joint Sealant is important because it makes a very thin gasket which spreads wider as the bolts are torqued. Flanges, especially blind flanges, tend appreciably when the bolts are torqued and might come together without adequately compressing the gasket if it were placed further toward the inside.

4. Complete the seal by crossing the ends near a bolt hole. Cross one end over the other about 1" and cut.




For the few critical applications where the extra bulk at the crossover could cause trouble, lap the ends as shown:



5. Assemble the flanged joint and torque the bolts as follows:
 - a. Run up all nuts finger tight.
 - b. Develop the required bolt stress in a minimum of three about equal steps, following a tightening up sequence as shown. Joint Sealant is highly compressible, but has little resilience, so gradual tightening is necessary to form a gasket of uniform thickness. Use a torque wrench if it is available.

Torquing Sequences



W. L. GORE & ASSOCIATES, INC.

100 AIRPORT RD. • P.O. BOX 1010 • ELKTON, MD 21921 • PHONE: 301/392-3200

Section 113 - Appendix D

UT1, Unloading Tank No.1

SECONDARY CONTAINMENT VOLUME CALCULATIONS

<u>Area No. 1 West End</u>	
Length =	34.50 feet
Width =	8.50 feet
Height = $(0.24 + (0.54 - 0.24/2))$	0.39 feet
Surface Area =	293.25 S.F.
Volume =	114.37

<u>Area No. 2 East End</u>	
Length =	61.50 feet
Width =	34.50 feet
Height = $(0.2 + (0.54 - 0.2/2))$	0.37 feet
Surface Area =	2121.75 S.F.
Volume =	785.05

<u>Sump South End</u>	
Length =	29.33
Width =	3.75
Height = $(0.5 + (3.66 - 0.5/2))$	2.08
Surface Area =	110.00
Volume =	228.80

<u>Sump North End</u>	
Length =	6.58
Width =	3.75
Height = $(3 + (3.66 - 3/2))$	3.33
Surface Area =	24.68
Volume =	82.17

Gross Area =	Area 1 - Area 2 =	2549.67 S.F.
Gross Volume =	Area * Height =	1210.38 C.F.

<u>Volumes of Items of Displacement **</u>		
1. Pipe Supports (9)		1.00 C.F.
2. Steel Pump Base		0.17 C.F.
Total volume to deduct for items in containment area =		1.17 C.F.

Subtraction for volume of rainfall

This entire area is covered and will not receive any rain

TOTAL AVAILABLE VOLUME = Gross Volume - Subtractions =	1210.38 C.F.
Items of displacement	-1.17 C.F.
Volume of rainfall	0.00 C.F.

TOTAL AVAILABLE VOLUME	1209.21 C.F.
	OR
	9044.92 Gal.

REPORT OF UT THICKNESS INSPECTION

TESTED FOR: USPCI
LONG MOUNTAIN

PROJECT: CORROSION
SURVEY

DATE: 7-13-92

OUR REPORT NO.: 10

Client Order Number:		Lab Number:		Location: <u>UT-1</u>																																																																																																													
Test Method Standard: <u>QC UT-S</u>		Acceptance Standard: <u>QC UT S</u>		Scanning Method: <u>RANDOM</u>																																																																																																													
UT UNIT		Manufacturer <u>KBA</u>																																																																																																															
<input type="checkbox"/> A-Scan		Model <u>DME</u>																																																																																																															
<input checked="" type="checkbox"/> Direct Readout		Serial No. <u>103162</u>																																																																																																															
<input type="checkbox"/> A-Scan and Direct Readout																																																																																																																	
CALIBRATION BLOCK		Size <u>.100-.500 STEP</u>																																																																																																															
ID Number: <u>01</u>		Material Type: <u>STEEL</u>																																																																																																															
SEARCH UNIT		Size <u>.625</u> Frequency <u>5 MHZ</u>																																																																																																															
<input type="checkbox"/> Single Element		Serial No. <u>E08931</u>																																																																																																															
<input checked="" type="checkbox"/> Dual Element																																																																																																																	
<table border="1"> <thead> <tr> <th colspan="6">Measurements</th> </tr> </thead> <tbody> <tr><td>1</td><td>.186</td><td>18</td><td>.313</td><td>35</td><td>52</td></tr> <tr><td>2</td><td>.189</td><td>19</td><td>.322</td><td>36</td><td>53</td></tr> <tr><td>3</td><td>.187</td><td>20</td><td>.318</td><td>37</td><td>54</td></tr> <tr><td>4</td><td>.188</td><td>21</td><td>.184</td><td>38</td><td>55</td></tr> <tr><td>5</td><td>.187</td><td>22</td><td>.187</td><td>39</td><td>56</td></tr> <tr><td>6</td><td>.186</td><td>23</td><td>.188</td><td>40</td><td>57</td></tr> <tr><td>7</td><td>.326</td><td>24</td><td>.186</td><td>41</td><td>58</td></tr> <tr><td>8</td><td>.331</td><td>25</td><td>.184</td><td>42</td><td>59</td></tr> <tr><td>9</td><td>.191</td><td>26</td><td>.189</td><td>43</td><td>60</td></tr> <tr><td>10</td><td>.195</td><td>27</td><td>.184</td><td>44</td><td>61</td></tr> <tr><td>11</td><td>.189</td><td>28</td><td>.186</td><td>45</td><td>62</td></tr> <tr><td>12</td><td>.188</td><td>29</td><td>.186</td><td>46</td><td>63</td></tr> <tr><td>13</td><td>.188</td><td>30</td><td>.192</td><td>47</td><td>64</td></tr> <tr><td>14</td><td>.189</td><td>31</td><td>.186</td><td>48</td><td>65</td></tr> <tr><td>15</td><td>.193</td><td>32</td><td></td><td>49</td><td>66</td></tr> <tr><td>16</td><td>.188</td><td>33</td><td></td><td>50</td><td>67</td></tr> <tr><td>17</td><td>.318</td><td>34</td><td></td><td>51</td><td>68</td></tr> </tbody> </table>						Measurements						1	.186	18	.313	35	52	2	.189	19	.322	36	53	3	.187	20	.318	37	54	4	.188	21	.184	38	55	5	.187	22	.187	39	56	6	.186	23	.188	40	57	7	.326	24	.186	41	58	8	.331	25	.184	42	59	9	.191	26	.189	43	60	10	.195	27	.184	44	61	11	.189	28	.186	45	62	12	.188	29	.186	46	63	13	.188	30	.192	47	64	14	.189	31	.186	48	65	15	.193	32		49	66	16	.188	33		50	67	17	.318	34		51	68
Measurements																																																																																																																	
1	.186	18	.313	35	52																																																																																																												
2	.189	19	.322	36	53																																																																																																												
3	.187	20	.318	37	54																																																																																																												
4	.188	21	.184	38	55																																																																																																												
5	.187	22	.187	39	56																																																																																																												
6	.186	23	.188	40	57																																																																																																												
7	.326	24	.186	41	58																																																																																																												
8	.331	25	.184	42	59																																																																																																												
9	.191	26	.189	43	60																																																																																																												
10	.195	27	.184	44	61																																																																																																												
11	.189	28	.186	45	62																																																																																																												
12	.188	29	.186	46	63																																																																																																												
13	.188	30	.192	47	64																																																																																																												
14	.189	31	.186	48	65																																																																																																												
15	.193	32		49	66																																																																																																												
16	.188	33		50	67																																																																																																												
17	.318	34		51	68																																																																																																												
<p>Diagram</p> <p><u>SEE DRWG. # UT-1</u></p> <p><u>* NOTE: THESE READINGS TAKEN WITH PAINT REMOVED.</u></p>																																																																																																																	
Technician: <u>A. SHARLEE</u> Level:			Technician: <u>J. Brooks</u> Level: <u>II</u>																																																																																																														

P.S.I.

Tank Number UT-1

Date 7-13-92

30	29	28	27	26
31		Hatch	25	
24	2	4	6	
23	1	3	5	
I Beam		I Beam		
	7	8	10	12
	9	11	13	15
I Beam		I Beam		
	19	20	22	
I Beam		I Beam		
	21	22	23	24

North

West

South





East

P.S.I.

Tank Number UT- 1Date 7 / 14 / 92


	0.186	29	0.186	57	0.	85	0.	113	0.	141	0.	168	0.
	0.189	30	0.192	58	0.	86	0.	114	0.	142	0.	169	0.
	0.187	31	0.186	59	0.	87	0.	115	0.	143	0.	170	0.
	0.188	32	0.	60	0.	88	0.	116	0.	144	0.	171	0.
	0.187	33	0.	61	0.	89	0.	117	0.	145	0.	172	0.
	0.186	34	0.	62	0.	90	0.	118	0.	146	0.	173	0.
	0.326	35	0.	63	0.	91	0.	119	0.	147	0.	174	0.
	0.331	36	0.	64	0.	92	0.	120	0.	148	0.	175	0.
	0.191	37	0.	65	0.	93	0.	121	0.	149	0.	176	0.
0	0.195	38	0.	66	0.	94	0.	122	0.	150	0.	177	0.
1	0.189	39	0.	67	0.	95	0.	123	0.	151	0.	178	0.
2	0.188	40	0.	68	0.	96	0.	124	0.	152	0.	179	0.
3	0.188	41	0.	69	0.	97	0.	125	0.	153	0.	180	0.
	0.189	42	0.	70	0.	98	0.	126	0.	154	0.	181	0.
5	0.193	43	0.	71	0.	99	0.	127	0.	155	0.	182	0.
6	0.188	44	0.	72	0.	100	0.	128	0.	156	0.	183	0.
	0.318	45	0.	73	0.	101	0.	129	0.	157	0.	184	0.
9	0.313	46	0.	74	0.	102	0.	130	0.	157	0.	185	0.
9	0.322	47	0.	75	0.	103	0.	131	0.	158	0.	186	0.
10	0.318	48	0.	76	0.	104	0.	132	0.	159	0.	187	0.
11	0.184	49	0.	77	0.	105	0.	133	0.	160	0.	188	0.
12	0.187	50	0.	78	0.	106	0.	134	0.	161	0.	189	0.
13	0.188	51	0.	79	0.	107	0.	135	0.	162	0.	190	0.
4	0.186	52	0.	80	0.	108	0.	136	0.	163	0.	192	0.
5	0.184	53	0.	81	0.	109	0.	137	0.	164	0.	193	0.
6	0.189	54	0.	82	0.	110	0.	138	0.	165	0.	194	0.
7	0.184	55	0.	83	0.	111	0.	139	0.	166	0.	195	0.
8	0.186	56	0.	84	0.	112	0.	140	0.	167	0.	196	0.

APPENDIX G
Drawings



RECORD DRAWING

USPCI A Subsidiary of Union Pacific Corporation		USPCI LONE MOUNTAIN FACILITY WATNOKA, OKLAHOMA		Myers MECHANICAL CONTRACTORS 1001 N. W. 10th St., Suite 100 Oklahoma City, Oklahoma 73106 (405) 755-4332		(UT) UNLOADING TANK NO. 1 TANK DETAIL	
DATE 12-15-82	DRAWN JCS	CHECKED JCS	IN CHARGE JCS	SCALE 1" = 4'-0"	SHEET NO. 1	TOTAL SHEETS 1	OF



REVISIONS	
NO.	DESCRIPTION

USPCI
A Subsidiary of
Union Pacific Corporation

USPCI
LOVE MOUNTAIN FACILITY
WAYNOKA, OKLAHOMA


Myers
ENGINEERING CONSULTANTS
1001 N. STEPHENS BLVD., SUITE 200
OKLAHOMA CITY, OKLAHOMA 73102
(405) 755-4315

(UTT) UNLOADING TANK NO. 1
CONTAINMENT AREA DETAIL

JOB NO.	201
SCALE	AS SHOWN
DRAWN	CRS
CHECKED	
DATE	10-11-82
BY	

UNLOADING TANK NO. 1 (UT1)
SECTIONS "A" - "A"

SCALE	1:10
DRAWN	10/5/57
CHECKED	



RECORD DRAWING

[illegible]

(UT1) UNLOADING TANK NO. 1
CONTAINMENT AREA ELEVATIONS