



OKLAHOMA DRINKING WATER

LEAD TESTING

IN PUBLIC SCHOOLS & CHILD CARE FACILITIES

District: INCA Community Services

School: Davis Head Start

Sampling Dates: 8/29/2024, 3/24/2026

Status: Completed Sampling

RESULTS

Below are the results from the first and second rounds of testing of drinking water for lead that was conducted at INCA Community Services - Davis Head Start. The initial sampling event occurred on August 29, 2026. The resampling event occurred on March 24, 2026.

In the initial sampling, five (5) outlets were tested resulting in a total of ten (10) samples being sent to the lab.

- Three (3) samples had no detectable level of lead.
- Four (4) samples had a low detection of lead between 1.0 and 14.9 µg/L.
- Three (3) samples had a high detection of lead equal to or above 15.0 µg/L.

In the resampling, five (5) outlets were tested resulting in a total of ten (10) samples being sent to the lab.

- Five (5) samples had no detectable level of lead.
- Five (5) samples had a low detection of lead between 1.0 and 14.9 µg/L.
- Zero (0) samples had a high detection of lead equal to or above 15.0 µg/L.

The table below shows all sample results. Sample results are in micrograms per liter, shown as µg/L. For more information on how to read this report, please see our **Results Interpretation Fact Sheet**.

Sample ID	Outlet Description	First Draw (µg/L)	Flush (µg/L)	Remedial Action	First Draw (µg/L)	Flush (µg/L)
		Initial Sampling			Resampling	
Non-Detect (<1.0 µg/L)						
1-1-KIT-KF2	Kitchen faucet in facility kitchen; sprayer attachment	<1.0	<1.0	N/A	N/A	N/A
1-1-KIT-KF1	Kitchen faucet in facility kitchen; standard faucet	<1.0	1.6	Install Reverse Osmosis System	<1.0	<1.0
1-1-EHB-BF1	Bathroom faucet in HeadStart Bathroom	2.5	1.9	Install Reverse Osmosis System	<1.0	<1.0
1-1-EH-CF2	Classroom faucet in Early HeadStart room; sprayer attachment	57.0	14.5	Not used for consumption	N/A	N/A
Low Detection (1.0 - 14.9 µg/L)						
1-1-EH-CF1	Classroom faucet in Early HeadStart room; standard faucet- RIGHT	83.5	114.0	Install Reverse Osmosis System	1.8	1.1

Sample ID	Outlet Description	First Draw (µg/L)	Flush (µg/L)	Remedial Action	First Draw (µg/L)	Flush (µg/L)
		Initial Sampling			Resampling	
1-1-HS-CF1	Classroom faucet near washer/dryer stack	N/A	N/A		2.4	<1.0
1-1-EH-CF3	Classroom faucet in Early Head start room; standard faucet- LEFT	N/A	N/A		1.4	2.8