OKLAHOMA DRINKING WATER
LEAD TESTING
IN PUBLIC SCHOOLS & CHILD CARE FACILITIES

INCA Milburn Head Start Post Remediation Sampling Results

Samples outlined in this report were collected under the Oklahoma Lead in Schools and Child Care Program (LWSC) on 10/09/2026 from 206 W Grand Ave, Milburn, OK 73450.

See below for an overview of the outlet descriptions noted in the results report:

Outlet Type Code Key:
DW: Drinking Water Fountain
WC: Water Cooler With Chiller Unit
CF: Classroom Faucet
KF: Kitchen Faucet
BF: Bathroom Faucet
NS: Nurse Office Sink
RA: Refrigerator Appliance
OF: Outdoor Faucet
IM: Ice Machine

Water Cooler Definition: A machine that is connected to the building's water supply for a continuous supply of water and to electricity to run a refrigeration unit to cool the incoming water.

Drinking Fountain Definition: A machine that is connected to the building's water supply for a continuous supply of water.

#	Outlet ID	Building #	Floor #	Room # / Name	Outlet Type Code	Water Cooler Make and Model	Comments	PR First Draw Result Final (ppb)	PR Flush Draw Result Final (ppb)	PR Sample Date(s)	PR Action Needed ?	Remediation Action Taken
1	16R-5	1	1	108	CF		Single faucet	4.5 ppb	<1 ppb	10/09/2026 07:30	Remediation Recommended	
2	16R-1	1	1	103	CF		Single faucet	2.7 ppb	<1 ppb	10/09/2026 07:30	Remediation Recommended	
3	16R-7	1	1	Left restroom	BF		Single faucet	<1 ppb	<1 ppb	10/09/2026 07:30	No Further Action	
4	16R-3	1	1	110	CF		Single faucet	<1 ppb	<1 ppb	10/09/2026 07:30	No Further Action	
5	16R-6	1	1	108	DW		Bubbler	<1 ppb	<1 ppb	10/09/2026 07:30	No Further Action	
6	16R-8	1	1	Right restroom	BF		Single faucet	<1 ppb	<1 ppb	10/09/2026 07:30	No Further Action	