



OKLAHOMA DRINKING WATER

LEAD TESTING

IN PUBLIC SCHOOLS & CHILD CARE FACILITIES

La Petite Academy Initial Sampling Results

Samples outlined in this report were collected under the Oklahoma Lead in Schools and Child Care Program (LWSC) on 06/04/2026 from 1424 SW 104th St., Oklahoma City, OK 73159.

See below for an overview of the outlet descriptions noted in the results report:

Outlet Type Code Key:

CF: Classroom Faucet

KF: Kitchen Faucet

BF: Bathroom Faucet

NS: Nurse Office Sink

RA: Refrigerator Appliance

OF: Outdoor Faucet

IM: Ice Machine

DW: Drinking Water Fountain

WC: Water Cooler With Chiller Unit

Water Cooler Definition: A machine that is connected to the building's water supply for a continuous supply of water and to electricity to run a refrigeration unit to cool the incoming water.

Drinking Fountain Definition: A machine that is connected to the building's water supply for a continuous supply of water.

#	Outlet ID	Building #	Floor #	Room # / Name	Outlet Type Code	Water Cooler Make and Model	Comments	Initial First Draw Result Final (ppb)	Initial Flush Draw Result Final (ppb)	Initial Sample Date(s)	Action Needed?	Remediation Action Taken
1	1716-9	1	1	School aged	CF		Left side of room closets to kid cubbies, right faucet, under teacher cabinet	1.12 ppb	<1 ppb	06/04/2026 06:45	Remediation Recommended	
2	1716-1	1	1	Infant room	CF		Right side faucet, farthest from door	<1 ppb	<1 ppb	06/04/2026 06:45	No Further Action	
3	1716-2	1	1	Infant room	CF		Left side faucet, closest to door	<1 ppb	<1 ppb	06/04/2026 06:45	No Further Action	
4	1716-3	1	1	Early pre school	CF		Left side, between bathrooms	<1 ppb	<1 ppb	06/04/2026 06:45	No Further Action	
5	1716-4	1	1	Early pre school	CF		Right side, between bathrooms	<1 ppb	<1 ppb	06/04/2026 06:45	No Further Action	
6	1716-5	1	1	Kitchen	KF		3 compartment, left wall	<1 ppb	<1 ppb	06/04/2026 06:45	No Further Action	
7	1716-6	1	1	School age	CF		Left side, under teacher cabinet	<1 ppb	<1 ppb	06/04/2026 06:45	No Further Action	
8	1716-7	1	1	School aged	CF		Right side, under teacher cabinet	<1 ppb	<1 ppb	06/04/2026 06:45	No Further Action	

[illegible]