



OKLAHOMA DRINKING WATER

LEAD TESTING

IN PUBLIC SCHOOLS & CHILD CARE FACILITIES

Tupelo Head Start Initial Sampling Results

Samples outlined in this report were collected under the Oklahoma Lead in Schools and Child Care Program (LWSC) on 09/04/2026 from 200 S. 7th Ave., Tupelo, OK 74572.

See below for an overview of the outlet descriptions noted in the results report:

Outlet Type Code Key:

CF: Classroom Faucet

KF: Kitchen Faucet

BF: Bathroom Faucet

NS: Nurse Office Sink

RA: Refrigerator Appliance

OF: Outdoor Faucet

IM: Ice Machine

DW: Drinking Water Fountain

WC: Water Cooler With Chiller Unit

Water Cooler Definition: A machine that is connected to the building's water supply for a continuous supply of water and to electricity to run a refrigeration unit to cool the incoming water.

Drinking Fountain Definition: A machine that is connected to the building's water supply for a continuous supply of water.

#	Outlet ID	Buildin g #	Floor #	Room # / Name	Outlet Type Code	Water Cooler Make and Model	Comments	Initial First Draw Result Final (ppb)	Initial Flush Draw Result Final (ppb)	Initial Sample Date(s)	Action Needed?	Remediation Action Taken
1	1756-2	1	1	Bathroom	BF		Bathroom to the left- Left sink	1.2 ppb	<1 ppb	09/04/2026 07:00	Remediation Recommended	
2	1756-4	1	1	Bathroom	BF		Bathroom to the right- Left sink	<1 ppb	1.2 ppb	09/04/2026 07:00	Remediation Recommended	
3	1756-1	1	1	Classroom	WC	EZFS8_1A	In the classroom to the right when we enter	<1 ppb	<1 ppb	09/04/2026 07:00	No Further Action	
4	1756-3	1	1	Bathroom	BF		Bathroom to the left- Right Sink	<1 ppb	<1 ppb	09/04/2026 07:00	No Further Action	
5	1756-5	1	1	Bathroom	BF		Bathroom to the right- Right sink	<1 ppb	<1 ppb	09/04/2026 07:00	No Further Action	