



OKLAHOMA DRINKING WATER

LEAD TESTING

IN PUBLIC SCHOOLS & CHILD CARE FACILITIES

Kickapoo Head Start Initial Sampling Results

Samples outlined in this report were collected under the Oklahoma
Lead in Schools and Child Care Program (LWSC) on 07/21/2026
from 10543 OK-102, Mcloud, OK 74851.

See below for an overview of the outlet descriptions noted in the results report:

Outlet Type Code Key:

CF: Classroom Faucet

KF: Kitchen Faucet

BF: Bathroom Faucet

NS: Nurse Office Sink

RA: Refrigerator Appliance

OF: Outdoor Faucet

IM: Ice Machine

DW: Drinking Water Fountain

WC: Water Cooler With Chiller Unit

Water Cooler Definition: A machine that is connected to the building's water supply for a continuous supply of water and to electricity to run a refrigeration unit to cool the incoming water.

Drinking Fountain Definition: A machine that is connected to the building's water supply for a continuous supply of water.

#	Outlet ID	Building #	Floor #	Room # / Name	Outlet Type Code	Water Cooler Make and Model	Comments	Initial First Draw Result Final (ppb)	Initial Flush Draw Result Final (ppb)	Initial Sample Date(s)	Action Needed?	Remediation Action Taken
1	1767-6	1	1	Bathroom	BF		Classroom B bathroom in the back to the left	3.26 ppb	<1 ppb	07/21/2026 07:00	Remediation Recommended	
2	1767-5	1	1	Bathroom	BF		Classroom B bathroom in the back to the right	2.9 ppb	<1 ppb	07/21/2026 07:00	Remediation Recommended	
3	1767-13	1	1	Bathroom	BF		Classroom A bathroom sink to the left bottom	2.37 ppb	<1 ppb	07/21/2026 07:00	Remediation Recommended	
4	1767-10	1	1	Classroom	CF		Classroom C sink in the back to the right	1.78 ppb	<1 ppb	07/21/2026 07:00	Remediation Recommended	
5	1767-14	1	1	Bathroom	BF		Classroom A bathroom sink in the center	1.39 ppb	<1 ppb	07/21/2026 07:00	Remediation Recommended	
6	1767-16	1	1	Classroom	CF		Classroom A sink to the right	1.14 ppb	<1 ppb	07/21/2026 07:00	Remediation Recommended	
7	1767-8	1	1	Bathroom	BF		Classroom C bathroom sink in the center	1.11 ppb	<1 ppb	07/21/2026 07:00	Remediation Recommended	
8	1767-7	1	1	Bathroom	BF		Classroom C bathroom sink to the left bottom	1.09 ppb	<1 ppb	07/21/2026 07:00	Remediation Recommended	
9	1767-1	1	1	Kitchen	KF		Kitchen faucet in front	<1 ppb	<1 ppb	07/21/2026 07:00	No Further Action	
10	1767-2	1	1	Kitchen	KF		Dishwashing section in the back	<1 ppb	<1 ppb	07/21/2026 07:00	No Further Action	

[illegible]