



OKLAHOMA DRINKING WATER

LEAD TESTING

IN PUBLIC SCHOOLS & CHILD CARE FACILITIES

Cherokee Nation Pryor Head Start Pryor Ehs I & II Initial Sampling Results

Samples outlined in this report were collected under the Oklahoma
Lead in Schools and Child Care Program (LWSC) on 06/18/2026
from 3343 W 530 RD , Pryor, OK 74361.

See below for an overview of the outlet descriptions noted in the results report:

Outlet Type Code Key:

CF: Classroom Faucet

KF: Kitchen Faucet

BF: Bathroom Faucet

NS: Nurse Office Sink

RA: Refrigerator Appliance

OF: Outdoor Faucet

IM: Ice Machine

DW: Drinking Water Fountain

WC: Water Cooler With Chiller Unit

Water Cooler Definition: A machine that is connected to the building's water supply for a continuous supply of water and to electricity to run a refrigeration unit to cool the incoming water.

Drinking Fountain Definition: A machine that is connected to the building's water supply for a continuous supply of water.

#	Outlet ID	Buildin g #	Floor #	Room # / Name	Outlet Type Code	Water Cooler Make and Model	Comments	Initial First Draw Result Final (ppb)	Initial Flush Draw Result Final (ppb)	Initial Sample Date(s)	Action Needed?	Remediation Action Taken
1	1814-1	1	1	Kitchen	KF		2 compartment faucet	<1 ppb	<1 ppb	06/18/2026 06:35	No Further Action	
2	1814-2	1	1	Kitchen	KF		1 compartment faucet	<1 ppb	<1 ppb	06/18/2026 06:35	No Further Action	
3	1814-3	1	1	Kitchen	IM		Small ice machine	<1 ppb		06/18/2026 06:35	No Further Action	
4	1814-4	1	1	Kitchenette	CF		2 compartment faucet, left of fridge	<1 ppb	<1 ppb	06/18/2026 06:40	No Further Action	
5	1814-5	1	1	Kitchenette	CF		2 compartment faucet, right of fridge	<1 ppb	<1 ppb	06/18/2026 06:40	No Further Action	