



OKLAHOMA DRINKING WATER

LEAD TESTING

IN PUBLIC SCHOOLS & CHILD CARE FACILITIES

Cherokee Nation Head Start - Jay I & Jay II Initial Sampling Results

Samples outlined in this report were collected under the Oklahoma
Lead in Schools and Child Care Program (LWSC) on 07/21/2026
from 935 E Melton Drive, Jay, OK 74346.

See below for an overview of the outlet descriptions noted in the results report:

Outlet Type Code Key:

CF: Classroom Faucet

KF: Kitchen Faucet

BF: Bathroom Faucet

NS: Nurse Office Sink

RA: Refrigerator Appliance

OF: Outdoor Faucet

IM: Ice Machine

DW: Drinking Water Fountain

WC: Water Cooler With Chiller Unit

Water Cooler Definition: A machine that is connected to the building's water supply for a continuous supply of water and to electricity to run a refrigeration unit to cool the incoming water.

Drinking Fountain Definition: A machine that is connected to the building's water supply for a continuous supply of water.

#	Outlet ID	Building #	Floor #	Room # / Name	Outlet Type Code	Water Cooler Make and Model	Comments	Initial First Draw Result Final (ppb)	Initial Flush Draw Result Final (ppb)	Initial Sample Date(s)	Action Needed?	Remediation Action Taken
1	1816-8	1	1	Kitchen	KF		2 compartment faucet, front of kitchen	3.74 ppb	<1 ppb	07/21/2026 07:14	Remediation Recommended	
2	1816-10	1	1	Kitchen	KF		Pot filler, right of oven	2.8 ppb	<1 ppb	07/21/2026 07:30	Remediation Recommended	
3	1816-9	1	1	Kitchen	KF		1 compartment faucet, middle kitchen	1.36 ppb	<1 ppb	07/21/2026 07:14	Remediation Recommended	
4	1816-3	1	1	Between 106 and 107	WC	ELKAY EZ H2O EZSTL8WS_1G	Left fountain	<1 ppb	<1 ppb	07/21/2026 07:14	No Further Action	
5	1816-1	1	1	Between 106 and 107	WC	ELKAY EZ H2O EZSTL8WS_1G	Right bottle filler	<1 ppb	<1 ppb	07/21/2026 07:14	No Further Action	
6	1816-4	1	1	108	CF		Tall faucet, right side of classroom	<1 ppb	<1 ppb	07/21/2026 07:14	No Further Action	
7	1816-2	1	1	Between 106 and 107	WC	ELKAY EZ H2O EZSTL8WS_1G	Right fountain	<1 ppb	<1 ppb	07/21/2026 07:14	No Further Action	
8	1816-5	1	1	108	CF		Left of fridge	<1 ppb	<1 ppb	07/21/2026 07:14	No Further Action	
9	1816-7	1	1	109	CF		Right of fridge	<1 ppb	<1 ppb	07/21/2026 07:14	No Further Action	
10	1816-6	1	1	109	CF		Tall faucet, left side of classroom	<1 ppb	<1 ppb	07/21/2026 07:14	No Further Action	
11	1816-12	1	1	Breakroom	CF		Single faucet	<1 ppb	<1 ppb	07/21/2026 07:37	No Further Action	

[illegible]