



OKLAHOMA DRINKING WATER

LEAD TESTING

IN PUBLIC SCHOOLS & CHILD CARE FACILITIES

Wauhillau Ehs I & II Initial Sampling Results

Samples outlined in this report were collected under the Oklahoma Lead in Schools and Child Care Program (LWSC) on 07/22/2026 from 1001 Lenape Drive, Nowata, OK 74048.

See below for an overview of the outlet descriptions noted in the results report:

Outlet Type Code Key:

CF: Classroom Faucet

KF: Kitchen Faucet

BF: Bathroom Faucet

NS: Nurse Office Sink

RA: Refrigerator Appliance

OF: Outdoor Faucet

IM: Ice Machine

DW: Drinking Water Fountain

WC: Water Cooler With Chiller Unit

Water Cooler Definition: A machine that is connected to the building's water supply for a continuous supply of water and to electricity to run a refrigeration unit to cool the incoming water.

Drinking Fountain Definition: A machine that is connected to the building's water supply for a continuous supply of water.

#	Outlet ID	Building #	Floor #	Room # / Name	Outlet Type Code	Water Cooler Make and Model	Comments	Initial First Draw Result Final (ppb)	Initial Flush Draw Result Final (ppb)	Initial Sample Date(s)	Action Needed?	Remediation Action Taken
1	1858-8	1	1	Kitchen	KF		Pot filler, right of oven	1.07 ppb	<1 ppb	07/22/2026 08:21	Remediation Recommended	
2	1858-1	1	1	Between 107 and 106	WC	ELKAY EZ H2O EZSTL8WS_1G	Right bottle filler	<1 ppb	<1 ppb	07/22/2026 08:21	No Further Action	
3	1858-9	1	1	Kitchen	IM	SCOTSMAN	Single ice machine	<1 ppb		07/22/2026 08:21	No Further Action	
4	1858-7	1	1	Kitchen	KF		1 compartment faucet	<1 ppb	<1 ppb	07/22/2026 08:21	No Further Action	
5	1858-2	1	1	Between 107 and 106	WC	ELKAY EZ H2O EZSTL8WS_1G	Right fountain	<1 ppb	<1 ppb	07/22/2026 08:21	No Further Action	
6	1858-4	1	1	108	CF		Left of 108.3	<1 ppb	<1 ppb	07/22/2026 08:21	No Further Action	
7	1858-5	1	1	109	CF		Right of 109.3	<1 ppb	<1 ppb	07/22/2026 08:21	No Further Action	
8	1858-3	1	1	Between 107 and 106	WC	ELKAY EZ H2O EZSTL8WS_1G	Left fountain	<1 ppb	<1 ppb	07/22/2026 08:21	No Further Action	
9	1858-6	1	1	Kitchen	KF		2 compartment faucet	<1 ppb	<1 ppb	07/22/2026 08:21	No Further Action	