



OKLAHOMA DRINKING WATER

LEAD TESTING

IN PUBLIC SCHOOLS & CHILD CARE FACILITIES

Delta Head Start - Purcell Initial Sampling Results

Samples outlined in this report were collected under the Oklahoma Lead in Schools and Child Care Program (LWSC) on 01/03/2026 from 715 SOUTH 4TH, Purcell, OK 73080.

See below for an overview of the outlet descriptions noted in the results report:

Outlet Type Code Key:

CF: Classroom Faucet

KF: Kitchen Faucet

BF: Bathroom Faucet

NS: Nurse Office Sink

RA: Refrigerator Appliance

OF: Outdoor Faucet

IM: Ice Machine

DW: Drinking Water Fountain

WC: Water Cooler With Chiller Unit

Water Cooler Definition: A machine that is connected to the building's water supply for a continuous supply of water and to electricity to run a refrigeration unit to cool the incoming water.

Drinking Fountain Definition: A machine that is connected to the building's water supply for a continuous supply of water.

#	Outlet ID	Building #	Floor #	Room # / Name	Outlet Type Code	Water Cooler Make and Model	Comments	Initial First Draw Result Final (ppb)	Initial Flush Draw Result Final (ppb)	Initial Sample Date(s)	Action Needed?	Remediation Action Taken
1	1875-4	1	1	Early headstart B	BF		Only Bathroom faucet	3.67 ppb	<1 ppb	1/3/2026 6:45:00 AM	Remediation Recommended	
2	1875-1	1	1	Early headstart B	CF		Single compartment food prep sink on other side of baby changing area	2.88 ppb	<1 ppb	1/3/2026 6:45:00 AM	Remediation Recommended	
3	1875-5	1	1	Early headstart A	CF		Farthest back from door single compartment	1.59 ppb	<1 ppb	1/3/2026 6:45:00 AM	Remediation Recommended	
4	1875-6	1	1	Early headstart A	CF		Farthest from entry door single faucet, sprayer	1.18 ppb	<1 ppb	1/3/2026 6:45:00 AM	Remediation Recommended	
5	1875-3	1	1	Early headstart B	CF		Single compartment outside of bathroom	<1 ppb	<1 ppb	1/3/2026 6:45:00 AM	No Further Action	
6	1875-2	1	1	Early headstart B	CF		Single compartment food prep sink on other side of baby changing, sprayer	<1 ppb	<1 ppb	1/3/2026 6:45:00 AM	No Further Action	
7	1875-11	1	1	1	KF		Single compartment right of 3 compartment	<1 ppb	<1 ppb	1/3/2026 7:00:00 AM	No Further Action	

