OKLAHOMA DRINKING WATER
LEAD TESTING
IN PUBLIC SCHOOLS & CHILD CARE FACILITIES

Epworth Christian Day School
Initial Sampling Results

Samples outlined in this report were collected under the Oklahoma Lead in Schools and Child Care Program (LWSC) on 10/16/2026 from 420 W Iowa, Chickasha, OK 73018.

See below for an overview of the outlet descriptions noted in the results report:

Outlet Type Code Key:
CF: Classroom Faucet
KF: Kitchen Faucet
BF: Bathroom Faucet
NS: Nurse Office Sink
RA: Refrigerator Appliance
OF: Outdoor Faucet
IM: Ice Machine
DW: Drinking Water Fountain
WC: Water Cooler With Chiller Unit

Water Cooler Definition: A machine that is connected to the building's water supply for a continuous supply of water and to electricity to run a refrigeration unit to cool the incoming water.

Drinking Fountain Definition: A machine that is connected to the building's water supply for a continuous supply of water.

#	Outlet ID	Building #	Floor #	Room # / Name	Outlet Type Code	Water Cooler Make and Model	Comments	Initial First Draw Result Final (ppb)	Initial Flush Draw Result Final (ppb)	Initial Sample Date(s)	Action Needed?	Remediation Action Taken
1	1928-1	1	1	101	CF		Sink in the back	<1 ppb	<1 ppb	10/16/2026 06:30	No Further Action	
2	1928-2	1	1	102	DW		WF to the right of the sink	<1 ppb	<1 ppb	10/16/2026 06:30	No Further Action	
3	1928-3	1	1	103	DW		WF to the right of the sink	<1 ppb	<1 ppb	10/16/2026 06:30	No Further Action	
4	1928-4	1	1	Big Classroom	CF		CF next to the kitchen	<1 ppb	<1 ppb	10/16/2026 06:30	No Further Action	
5	1928-9	1	1	105	CF		Cold water not running	<5 ppb	<1 ppb	10/16/2026 06:30	No Further Action	
6	1928-8	1	1	106	DW		WF to the right of the sink	<1 ppb	<1 ppb	10/16/2026 06:30	No Further Action	
7	1928-7	1	1	107	DW		WF to the right	<1 ppb	<1 ppb	10/16/2026 06:30	No Further Action	
8	1928-5	1	1	Kitchen	KF		Sink in the Back	<1 ppb	<1 ppb	10/16/2026 06:30	No Further Action	
9	1928-6	1	1	Kitchen	KF		Sink in the Front	<1 ppb	<1 ppb	10/16/2026 06:30	No Further Action	