



OKLAHOMA DRINKING WATER

LEAD TESTING

IN PUBLIC SCHOOLS & CHILD CARE FACILITIES

Greater Okla City Ymca Initial Sampling Results

Samples outlined in this report were collected under the Oklahoma Lead in Schools and Child Care Program (LWSC) on 05/20/2026 from 1 NW 4TH, Oklahoma City, OK 73102.

See below for an overview of the outlet descriptions noted in the results report:

Outlet Type Code Key:

CF: Classroom Faucet

KF: Kitchen Faucet

BF: Bathroom Faucet

NS: Nurse Office Sink

RA: Refrigerator Appliance

OF: Outdoor Faucet

IM: Ice Machine

DW: Drinking Water Fountain

WC: Water Cooler With Chiller Unit

Water Cooler Definition: A machine that is connected to the building's water supply for a continuous supply of water and to electricity to run a refrigeration unit to cool the incoming water.

Drinking Fountain Definition: A machine that is connected to the building's water supply for a continuous supply of water.

| # | Outlet ID | Building # | Floor # | Room # / Name | Outlet Type Code | Water Cooler Make and Model | Comments | Initial First Draw Result Final (ppb) | Initial Flush Draw Result Final (ppb) | Initial Sample Date(s) | Action Needed? | Remediation Action Taken |
|---|-----------|------------|---------|-------------------------|------------------|-----------------------------|---|---------------------------------------|---------------------------------------|------------------------|-------------------------|--------------------------|
| 1 | 1958-6 | 1 | 1 | Wobblers way | CF | | Single compartment, right side | 1.15 ppb | <1 ppb | 05/20/2026 05:00 | Remediation Recommended | |
| 2 | 1958-1 | 1 | 1 | Adventure ally | CF | | Single compartment in connecting hallway to other classroom | <1 ppb | <1 ppb | 05/20/2026 05:00 | No Further Action | |
| 3 | 1958-2 | 1 | 1 | Explore expressway | CF | | 2 compartment in connecting hallway to other room | <1 ppb | <1 ppb | 05/20/2026 05:00 | No Further Action | |
| 4 | 1958-3 | 1 | 1 | Right or janitors room | WC | Halsey Taylor | Single water cooler, in hallway | <1 ppb | <1 ppb | 05/20/2026 05:00 | No Further Action | |
| 5 | 1958-4 | 1 | 1 | Left of electrical room | WC | Halsey Taylor | Single water cooler, in hallway | <1 ppb | <1 ppb | 05/20/2026 05:00 | No Further Action | |
| 6 | 1958-5 | 1 | 1 | Wobblers way | CF | | 2 compartment left side | <1 ppb | <1 ppb | 05/20/2026 05:00 | No Further Action | |
| 7 | 1958-7 | 1 | 1 | Outside wobblers way | WC | Halsey Taylor | Single, outside classroom | <1 ppb | <1 ppb | 05/20/2026 05:00 | No Further Action | |
| 8 | 1958-8 | 1 | 1 | Outside mechanical room | WC | Halsey Taylor | Single, in hallway right of mechanical room | <1 ppb | <1 ppb | 05/20/2026 05:00 | No Further Action | |
| 9 | 1958-9 | 1 | 1 | Crawlers cove | CF | | 2 compartment in connecting hallway of rooms | <1 ppb | <1 ppb | 05/20/2026 05:00 | No Further Action | |

