



OKLAHOMA DRINKING WATER

LEAD TESTING

IN PUBLIC SCHOOLS & CHILD CARE FACILITIES

Big Five Head Start # 1,# 2 Initial Sampling Results

Samples outlined in this report were collected under the Oklahoma
Lead in Schools and Child Care Program (LWSC) on 07/31/2026
from 1502 N.1ST, Durant, OK 74701.

See below for an overview of the outlet descriptions noted in the results report:

Outlet Type Code Key:

CF: Classroom Faucet

KF: Kitchen Faucet

BF: Bathroom Faucet

NS: Nurse Office Sink

RA: Refrigerator Appliance

OF: Outdoor Faucet

IM: Ice Machine

DW: Drinking Water Fountain

WC: Water Cooler With Chiller Unit

Water Cooler Definition: A machine that is connected to the building's water supply for a continuous supply of water and to electricity to run a refrigeration unit to cool the incoming water.

Drinking Fountain Definition: A machine that is connected to the building's water supply for a continuous supply of water.

#	Outlet ID	Building #	Floor #	Room # / Name	Outlet Type Code	Water Cooler Make and Model	Comments	Initial First Draw Result Final (ppb)	Initial Flush Draw Result Final (ppb)	Initial Sample Date(s)	Action Needed?	Remediation Action Taken
1	2022-1	1	1	Kitchen	KF		2 compartment faucet	2.41 ppb	<1 ppb	07/31/2026 07:12	Remediation Recommended	
2	2022-2	1	1	Room 1	CF		Single faucet	<1 ppb	<1 ppb	07/31/2026 07:12	No Further Action	
3	2022-4	1	1	Room 2	CF		Single faucet	<1 ppb	<1 ppb	07/31/2026 07:12	No Further Action	
4	2022-3	1	1	Room 1, bathroom	BF		Single faucet	<1 ppb	<1 ppb	07/31/2026 07:12	No Further Action	
5	2022-5	1	1	Room 2, bathroom	BF		Single faucet	<1 ppb	<1 ppb	07/31/2026 07:12	No Further Action	