



OKLAHOMA DRINKING WATER

LEAD TESTING

IN PUBLIC SCHOOLS & CHILD CARE FACILITIES

Scott, Glenda Initial Sampling Results

Samples outlined in this report were collected under the Oklahoma Lead in Schools and Child Care Program (LWSC) on 06/24/2026 from 8341 NW 109TH, Oklahoma City, OK 73162.

See below for an overview of the outlet descriptions noted in the results report:

Outlet Type Code Key:

CF: Classroom Faucet

KF: Kitchen Faucet

BF: Bathroom Faucet

NS: Nurse Office Sink

RA: Refrigerator Appliance

OF: Outdoor Faucet

IM: Ice Machine

DW: Drinking Water Fountain

WC: Water Cooler With Chiller Unit

Water Cooler Definition: A machine that is connected to the building's water supply for a continuous supply of water and to electricity to run a refrigeration unit to cool the incoming water.

Drinking Fountain Definition: A machine that is connected to the building's water supply for a continuous supply of water.

#	Outlet ID	Building #	Floor #	Room # / Name	Outlet Type Code	Water Cooler Make and Model	Comments	Initial First Draw Result Final (ppb)	Initial Flush Draw Result Final (ppb)	Initial Sample Date(s)	Action Needed?	Remediation Action Taken
1	205-3	1	1	Hall bathroom	BF			<1 ppb	<1 ppb	6/24/2026 5:30:00 AM	No Further Action	
2	205-1	1	1	Kitchen sink	KF				<1 ppb		No Further Action	
3	205-2	1	1	Kitchen refrigerator	RA				<1 ppb		No Further Action	
4	205-4	1	1	Back bathroom, left	BF			<1 ppb		6/24/2026 5:30:00 AM	No Further Action	
5	205-5	1	1	Back bathroom, right	BF			<1 ppb	<1 ppb	6/24/2026 5:30:00 AM	No Further Action	