



OKLAHOMA DRINKING WATER  
**LEAD TESTING**  
IN PUBLIC SCHOOLS & CHILD CARE FACILITIES

## CTSA EARLY CHILDHOOD CENTER Initial Sampling Results

Samples outlined in this report were collected under the Oklahoma Lead in Schools and Child Care Program (LWSC) on 09/25/2025 from 1535 N McKinley Ave, Shawnee, OK 74801.

See below for an overview of the outlet descriptions noted in the results report:

Outlet Type Code Key:

CF: Classroom Faucet

KF: Kitchen Faucet

BF: Bathroom Faucet

NS: Nurse Office Sink

RA: Refrigerator Appliance

OF: Outdoor Faucet

IM: Ice Machine

DW: Drinking Water Fountain

WC: Water Cooler With Chiller Unit

Water Cooler Definition: A machine that is connected to the building's water supply for a continuous supply of water and to electricity to run a refrigeration unit to cool the incoming water.

Drinking Fountain Definition: A machine that is connected to the building's water supply for a continuous supply of water.

#	Outlet ID	Building #	Floor #	Room # / Name	Outlet Type Code	Water Cooler Make and Model	Comments	Initial First Draw Result Final (ppb)	Initial Flush Draw Result Final (ppb)	Initial Sample Date(s)	Action Needed?	Remediation Action Taken
1	2140-7	1	1	Early headstart 2	BF		Right bathroom faucet	<1 ppb	4.31 ppb	09/25/2025 06:00	Remediation Recommended	
2	2140-4	1	1	Early headstart 1	CF		Single compartment, right, closest to back of room	<1 ppb	<1 ppb	09/25/2025 06:00	No Further Action	
3	2140-5	1	1	Early headstart 2	CF		Silver Single compartment outside of bathroom	<1 ppb	<1 ppb	09/25/2025 06:00	No Further Action	
4	2140-2	1	1	Kitchen	KF		Single compartment right of 3 compartment	<1 ppb	<1 ppb	09/25/2025 06:00	No Further Action	
5	2140-1	1	1	Kitchen	KF		Silver 3 compartment	<1 ppb	<1 ppb	09/25/2025 06:00	No Further Action	
6	2140-8	1	1	Early headstart 3	CF		Silver single compartment outside of bathroom	<1 ppb	<1 ppb	09/25/2025 06:00	No Further Action	
7	2140-10	1	1	Early headstart 3	BF		Right bathroom faucet	<1 ppb	<1 ppb	09/25/2025 06:30	No Further Action	
8	2140-9	1	1	Early headstart 3	BF		Left bathroom faucet	<1 ppb	<1 ppb	09/25/2025 06:00	No Further Action	
9	2140-6	1	1	Early headstart 2	BF		Left bathroom faucet	<1 ppb	<1 ppb	09/25/2025 06:00	No Further Action	
10	2140-11	1	1	Early headstart 4	CF		Silver single compartment outside bathroom	<1 ppb	<1 ppb	09/25/2025 06:30	No Further Action	
11	2140-12	1	1	Early headstart 4	BF		Left bathroom faucet	<1 ppb	<1 ppb	09/25/2025 06:30	No Further Action	

#	Outlet ID	Building #	Floor #	Room # / Name	Outlet Type Code	Water Cooler Make and Model	Comments	Initial First Draw Result Final (ppb)	Initial Flush Draw Result Final (ppb)	Initial Sample Date(s)	Action Needed?	Remediation Action Taken
12	2140-13	1	1	Early headstart 4	BF		Right bathroom faucet	<1 ppb	<1 ppb	09/25/2025 06:30	No Further Action	
13	2140-14	1	1	Headstart 3	CF		Silver single compartment outside bathroom	<1 ppb	<1 ppb	09/25/2025 06:30	No Further Action	
14	2140-15	1	1	Headstart 3	BF		Left bathroom faucet	<1 ppb	<1 ppb	09/25/2025 06:30	No Further Action	
15	2140-20	1	1	Headstart 1	CF		Silver single compartment outside bathroom	<1 ppb	<1 ppb	09/25/2025 06:30	No Further Action	
16	2140-17	1	1	Headstart 2	CF		Silver single compartment outside bathroom	<1 ppb	<1 ppb	09/25/2025 06:30	No Further Action	
17	2140-18	1	1	Headstart 2	BF		Left bathroom faucet	<1 ppb	<1 ppb	09/25/2025 06:30	No Further Action	
18	2140-19	1	1	Headstart 2	BF		Right bathroom faucet	<1 ppb	<1 ppb	09/25/2025 06:30	No Further Action	
19	2140-16	1	1	Headstart 3	BF		Right bathroom faucet	<1 ppb	<1 ppb	09/25/2025 06:30	No Further Action	
20	2140-24	2	1	Headstart 4	CF		Silver faucet outside bathroom	<1 ppb	<1 ppb	09/26/2025 07:00	No Further Action	
21	2140-23	1	1	Playroom	CF		Silver single compartment	<1 ppb	<1 ppb	09/26/2025 07:00	No Further Action	
22	2140-22	1	1	Headstart 1	BF		Right bathroom faucet	<1 ppb	<1 ppb	09/26/2025 07:00	No Further Action	
23	2140-25	2	1	Headstart 4	BF		Single faucet	<1 ppb	<1 ppb	09/26/2025 07:00	No Further Action	

#	Outlet ID	Building #	Floor #	Room # / Name	Outlet Type Code	Water Cooler Make and Model	Comments	Initial First Draw Result Final (ppb)	Initial Flush Draw Result Final (ppb)	Initial Sample Date(s)	Action Needed?	Remediation Action Taken
24	2140-21	1	1	Headstart 1	BF		Left bathroom faucet	<1 ppb	<1 ppb	09/25/2025 06:30	No Further Action	
25	2140-28	2	1	Childcare 1	CF		Single compartment outside bathroom	<1 ppb	<1 ppb	09/26/2025 07:00	No Further Action	
26	2140-27	2	1	Childcare 2	BF		Single compartment	<1 ppb	<1 ppb	09/26/2025 07:00	No Further Action	
27	2140-26	2	1	Childcare 2	CF		Single silver	<1 ppb	<1 ppb	09/26/2025 07:00	No Further Action	
28	2140-29	2	1	Childcare 1	BF		Single compartment	<1 ppb	<1 ppb	09/26/2025 07:00	No Further Action	
29	2140-3		1	Early headstart 1	CF		Single compartment, left, closest to room door	<1 ppb	<1 ppb	09/25/2025 06:00	No Further Action	