



OKLAHOMA DRINKING WATER

LEAD TESTING

IN PUBLIC SCHOOLS & CHILD CARE FACILITIES

Redbird Early Headstart Initial Sampling Results

Samples outlined in this report were collected under the Oklahoma
Lead in Schools and Child Care Program (LWSC) on 06/17/2026
from 215 W Ash Street, Stilwell, OK 74960.

See below for an overview of the outlet descriptions noted in the results report:

Outlet Type Code Key:

CF: Classroom Faucet

KF: Kitchen Faucet

BF: Bathroom Faucet

NS: Nurse Office Sink

RA: Refrigerator Appliance

OF: Outdoor Faucet

IM: Ice Machine

DW: Drinking Water Fountain

WC: Water Cooler With Chiller Unit

Water Cooler Definition: A machine that is connected to the building's water supply for a continuous supply of water and to electricity to run a refrigeration unit to cool the incoming water.

Drinking Fountain Definition: A machine that is connected to the building's water supply for a continuous supply of water.

#	Outlet ID	Buildin g #	Floor #	Room # / Name	Outlet Type Code	Water Cooler Make and Model	Comments	Initial First Draw Result Final (ppb)	Initial Flush Draw Result Final (ppb)	Initial Sample Date(s)	Action Needed?	Remediation Action Taken
1	2147-2	1	1	Kitchen	KF		1 compartment, across from oven	1.83 ppb	<1 ppb	6/17/2026 6:50:00 AM	Remediation Recommended	
2	2147-9	1	1	109	CF		Across from changing table	1.76 ppb	1.08 ppb	6/17/2026 8:00:00 AM	Remediation Recommended	
3	2147-10	1	1	109	CF		Left of fridge	1.7 ppb	<1 ppb	6/17/2026 8:00:00 AM	Remediation Recommended	
4	2147-7	1	1	108	CF		Across from changing table	1.39 ppb	<1 ppb	6/17/2026 7:50:00 AM	Remediation Recommended	
5	2147-8	1	1	108	CF		Right of fridge	1.2 ppb	<1 ppb	6/17/2026 7:50:00 AM	Remediation Recommended	
6	2147-4	1	1	Between 106 and 107	WC	MURDOCK	Right bottle filler	<1 ppb	<1 ppb	6/17/2026 7:40:00 AM	No Further Action	
7	2147-5	1	1	Between 106 and 107	WC	MURDOCK	Right fountain	<1 ppb	<1 ppb	6/17/2026 7:40:00 AM	No Further Action	
8	2147-6	1	1	Between 106 and 107	WC	MURDOCK	Left fountain	<1 ppb	<1 ppb	6/17/2026 7:40:00 AM	No Further Action	
9	2147-1	1	1	Kitchen	KF		2 compartment, front of kitchen	<1 ppb	<1 ppb	6/17/2026 6:50:00 AM	No Further Action	
10	2147-3	1	1	Kitchen	IM	MANITOWO C D570	Left of oven	<1 ppb		6/17/2026 6:50:00 AM	No Further Action	