



OKLAHOMA DRINKING WATER

LEAD TESTING

IN PUBLIC SCHOOLS & CHILD CARE FACILITIES

Dibble Head Start Initial Sampling Results

Samples outlined in this report were collected under the Oklahoma Lead in Schools and Child Care Program (LWSC) on 02/10/2026 from 100 Old Town Main Street, Dibble, OK 73031.

See below for an overview of the outlet descriptions noted in the results report:

Outlet Type Code Key:

CF: Classroom Faucet

KF: Kitchen Faucet

BF: Bathroom Faucet

NS: Nurse Office Sink

RA: Refrigerator Appliance

OF: Outdoor Faucet

IM: Ice Machine

DW: Drinking Water Fountain

WC: Water Cooler With Chiller Unit

Water Cooler Definition: A machine that is connected to the building's water supply for a continuous supply of water and to electricity to run a refrigeration unit to cool the incoming water.

Drinking Fountain Definition: A machine that is connected to the building's water supply for a continuous supply of water.

#	Outlet ID	Building #	Floor #	Room # / Name	Outlet Type Code	Water Cooler Make and Model	Comments	Initial First Draw Result Final (ppb)	Initial Flush Draw Result Final (ppb)	Initial Sample Date(s)	Action Needed?	Remediation Action Taken
1	2459-2	1	1	Kitchen, separate room right of entrance	KF		3 compartment sink far right	8.74 ppb	<1 ppb	2/10/2026 6:00:00 AM	Remediation Recommended	
2	2459-11	2	1	Head start building	WC	ELKAY EZFSTL8_1D	Right side, bottom cooler Between men and women's restrooms closest to room 21	<1 ppb	<1 ppb	2/10/2026 6:15:00 AM	No Further Action	
3	2459-8	1	1	Cafeteria/ concession open area	WC	ELKAY EZFS8_1F	Right side, bottom cooler closest to room 119	<1 ppb	<1 ppb	2/10/2026 6:10:00 AM	No Further Action	
4	2459-9	2	1	Head start building	WC	ELKAY	Between men and women's restrooms closest to room 21	<1 ppb	<1 ppb	2/10/2026 6:15:00 AM	No Further Action	
5	2459-10	2	1	Head start building	BF	ELKAY EZH20	Right side, top bottle filler Between men and women's restrooms closest to room 21	<1 ppb	<1 ppb	2/10/2026 6:15:00 AM	No Further Action	
6	2459-7	1	1	Cafeteria/ concession open area	BF	ELKAY EZH20	Right side, Top bottle filler closest to room 119	<1 ppb	<1 ppb	2/10/2026 6:10:00 AM	No Further Action	
7	2459-6	1	1	Cafeteria/ concession open area	WC	ELKAY EZFS8_1F	Left side cooler closest to kitchen	<1 ppb	<1 ppb	2/10/2026 6:10:00 AM	No Further Action	

