



OKLAHOMA DRINKING WATER

LEAD TESTING

IN PUBLIC SCHOOLS & CHILD CARE FACILITIES

WOODWARD HEAD START Initial Sampling Results

Samples outlined in this report were collected under the Oklahoma Lead in Schools and Child Care Program (LWSC) on 09/17/2025 from 813 Madison, Woodward, OK 73801.

See below for an overview of the outlet descriptions noted in the results report:

Outlet Type Code Key:

CF: Classroom Faucet

KF: Kitchen Faucet

BF: Bathroom Faucet

NS: Nurse Office Sink

RA: Refrigerator Appliance

OF: Outdoor Faucet

IM: Ice Machine

DW: Drinking Water Fountain

WC: Water Cooler With Chiller Unit

Water Cooler Definition: A machine that is connected to the building's water supply for a continuous supply of water and to electricity to run a refrigeration unit to cool the incoming water.

Drinking Fountain Definition: A machine that is connected to the building's water supply for a continuous supply of water.

#	Outlet ID	Building #	Floor #	Room # / Name	Outlet Type Code	Water Cooler Make and Model	Comments	Initial First Draw Result Final (ppb)	Initial Flush Draw Result Final (ppb)	Initial Sample Date(s)	Action Needed?	Remediation Action Taken
1	2507-1		1	Early Head Start sink on kitchen counter	CF			8.33 ppb	6.74 ppb	9/17/25 6:23	Remediation Recommended	
2	2507-5		1	Classroom 3 Handwashing sink	CF			2.34 ppb	6.92 ppb	9/17/25 7:10	Remediation Recommended	
3	2507-2		1	Early Head Start Handwashing sink	CF			2.33 ppb	6 ppb	9/17/25 6:26	Remediation Recommended	
4	2507-10		1	Kitchen Small sink next to washer and dryer	KF			1.97 ppb	10.6 ppb	9/17/25 6:44	Remediation Strongly Suggested	
5	2507-12		1	Kitchen Sprayer	KF			1.79 ppb	1.14 ppb	9/17/25 6:30	Remediation Recommended	
6	2507-16		1	East Student Bathroom, left	BF			1.62 ppb	6.29 ppb	9/17/25 6:39	Remediation Recommended	
7	2507-11		1	Kitchen three bay sink	KF			1.47 ppb	<1 ppb	9/17/25 6:42	Remediation Recommended	
8	2507-17		1	East Student Bathroom, right	BF			1.26 ppb	5.01 ppb	9/17/25 7:20	Remediation Recommended	
9	2507-3		1	Classroom 1 Handwashing sink	CF			1.2 ppb	3.66 ppb	9/17/25 7:03	Remediation Recommended	
10	2507-13		1	Faculty Bathroom handwashing sink	BF			1.08 ppb	1.83 ppb	9/17/25 6:33	Remediation Recommended	
11	2507-4		1	Classroom 2 Handwashing sink	CF			<1 ppb	4.04 ppb	9/17/25 7:08	Remediation Recommended	
12	2507-14		1	West Student Bathroom, left	BF			<1 ppb	1.94 ppb	9/17/25 6:35	Remediation Recommended	

