



OKLAHOMA DRINKING WATER

LEAD TESTING

IN PUBLIC SCHOOLS & CHILD CARE FACILITIES

Pathfinder Llc Initial Sampling Results

Samples outlined in this report were collected under the Oklahoma
Lead in Schools and Child Care Program (LWSC) on 08/11/2026
from 8061 E 106th PI, Tulsa, OK 74133.

See below for an overview of the outlet descriptions noted in the results report:

Outlet Type Code Key:

CF: Classroom Faucet

KF: Kitchen Faucet

BF: Bathroom Faucet

NS: Nurse Office Sink

RA: Refrigerator Appliance

OF: Outdoor Faucet

IM: Ice Machine

DW: Drinking Water Fountain

WC: Water Cooler With Chiller Unit

Water Cooler Definition: A machine that is connected to the building's water supply for a continuous supply of water and to electricity to run a refrigeration unit to cool the incoming water.

Drinking Fountain Definition: A machine that is connected to the building's water supply for a continuous supply of water.

#	Outlet ID	Building #	Floor #	Room # / Name	Outlet Type Code	Water Cooler Make and Model	Comments	Initial First Draw Result Final (ppb)	Initial Flush Draw Result Final (ppb)	Initial Sample Date(s)	Action Needed?	Remediation Action Taken
1	2734-5	1	1	Toddler 2	DW		Front of classroom, bubbler	3.64 ppb	3.23 ppb	08/11/2026 06:05	Remediation Recommended	
2	2734-19	1	1	Tiny Tot 2	DW		Front of classroom, bubbler	1.29 ppb	<1 ppb	08/11/2026 06:17	Remediation Recommended	
3	2734-47	1	1	Kitchen	KF		2 Compartment faucet	1.15 ppb	<1 ppb	08/11/2026 05:57	Remediation Recommended	
4	2734-15	1	1	Transitional Preschool 1	CF		Front of classroom, right faucet	1.13 ppb	<1 ppb	08/11/2026 06:17	Remediation Recommended	
5	2734-32	1	1	Imagination Station	WC	ELKAY EZFS8_1E	Single fountain	<1 ppb	<1 ppb	08/11/2026 06:34	No Further Action	
6	2734-34	1	1	Main entrance	WC	ELKAY EZFSTL8_1F	Right fountain	<1 ppb	<1 ppb	08/11/2026 06:48	No Further Action	
7	2734-33	1	1	Main entrance	WC	ELKAY EZFSTL8_1F	Left fountain	<1 ppb	<1 ppb	08/11/2026 06:34	No Further Action	
8	2734-35	1	1	School Age Pre-K	CF		Left faucet	<1 ppb	<1 ppb	08/11/2026 06:48	No Further Action	
9	2734-31	1	1	Pre-K 1	DW		Single bubbler	<1 ppb	<1 ppb	08/11/2026 06:34	No Further Action	
10	2734-36	1	1	School Age Pre-K	CF		Right faucet	<1 ppb	<1 ppb	08/11/2026 06:48	No Further Action	
11	2734-38	1	1	School age room left hallway	WC	ELKAY EZFSTL8_1F	Across from bowling alley	<1 ppb	<1 ppb	08/11/2026 06:48	No Further Action	
12	2734-37	1	1	School Age Pre K	DW		Single bubbler	<1 ppb	<1 ppb	08/11/2026 06:48	No Further Action	
13	2734-40	1	1	School age room, right back classroom	WC	ELKAY EZFSTL8_1F	Behind culinary room	<1 ppb	<1 ppb	08/11/2026 06:48	No Further Action	
14	2734-39	1	1	Gym	WC	ELKAY EZFSTL8_1F	Single faucet	<1 ppb	<1 ppb	08/11/2026 06:48	No Further Action	

#	Outlet ID	Building #	Floor #	Room # / Name	Outlet Type Code	Water Cooler Make and Model	Comments	Initial First Draw Result Final (ppb)	Initial Flush Draw Result Final (ppb)	Initial Sample Date(s)	Action Needed?	Remediation Action Taken
15	2734-42	1	1	Preschool 1	CF		Left faucet	<1 ppb	<1 ppb	08/11/2026 06:48	No Further Action	
16	2734-43	1	1	Preschool 1	CF		Right faucet	<1 ppb	<1 ppb	08/11/2026 06:48	No Further Action	
17	2734-45	1	1	Kitchen	KF		3 Compartmen t, left faucet	<1 ppb	<1 ppb	08/11/2026 05:55	No Further Action	
18	2734-41	1	1	Culinary	WC	ELKAY EZSTL8_1F	Between restrooms	<1 ppb	<1 ppb	08/11/2026 06:48	No Further Action	
19	2734-44	1	1	Preschool 1	DW		Single bubbler	<1 ppb	<1 ppb	08/11/2026 06:48	No Further Action	
20	2734-46	1	1	Kitchen	KF		3 compartment, right faucet	<1 ppb	<1 ppb	08/11/2026 05:57	No Further Action	
21	2734-48	1	1	Outdoor playground	DW		Left side of building, first fountain	<1 ppb	<1 ppb	08/11/2026 05:57	No Further Action	
22	2734-27	1	1	Preschool 2	CF		Right faucet	<1 ppb	<1 ppb	08/11/2026 06:34	No Further Action	
23	2734-28	1	1	Preschool 2	DW		Single bubbler	<1 ppb	<1 ppb	08/11/2026 06:34	No Further Action	
24	2734-29	1	1	Pre-K 1	CF		Right faucet	<1 ppb	<1 ppb	08/11/2026 06:34	No Further Action	
25	2734-30	1	1	Pre-K 1	CF		Left faucet	<1 ppb	<1 ppb	08/11/2026 06:34	No Further Action	
26	2734-26	1	1	Preschool 2	CF		Left faucet	<1 ppb	<1 ppb	08/11/2026 06:34	No Further Action	
27	2734-25	1	1	Preschool 3	DW		Single bubbler	<1 ppb	<1 ppb	08/11/2026 06:34	No Further Action	
28	2734-24	1	1	Preschool 3	CF		Left faucet	<1 ppb	<1 ppb	08/11/2026 06:34	No Further Action	
29	2734-23	1	1	Preschool 3	CF		Right faucet	<1 ppb	<1 ppb	08/11/2026 06:34	No Further Action	
30	2734-22	1	1	Infant 1	DW		Single bubbler	<1 ppb	<1 ppb	08/11/2026 06:34	No Further Action	
31	2734-21	1	1	Infant 1	CF		Right faucet	<1 ppb	<1 ppb	08/11/2026 06:17	No Further Action	

#	Outlet ID	Building #	Floor #	Room # / Name	Outlet Type Code	Water Cooler Make and Model	Comments	Initial First Draw Result Final (ppb)	Initial Flush Draw Result Final (ppb)	Initial Sample Date(s)	Action Needed?	Remediation Action Taken
32	2734-20	1	1	Infant 1	CF		Left faucet	<1 ppb	<1 ppb	08/11/2026 06:17	No Further Action	
33	2734-18	1	1	Tiny Tot 2	CF		Front of classroom, right faucet	<1 ppb	<1 ppb	08/11/2026 06:17	No Further Action	
34	2734-17	1	1	Tiny Tot 2	CF		Front of classroom, left faucet	<1 ppb	<1 ppb	08/11/2026 06:17	No Further Action	
35	2734-16	1	1	Transitional Preschool 1	DW		Front of classroom, bubbler	<1 ppb	<1 ppb	08/11/2026 06:17	No Further Action	
36	2734-14	1	1	Transitional Preschool 1	CF		Front of classroom, left faucet	<1 ppb	<1 ppb	08/11/2026 06:17	No Further Action	
37	2734-13	1	1	Transitional Preschool 2	DW		Front of classroom, bubbler	<1 ppb	<1 ppb	08/11/2026 06:17	No Further Action	
38	2734-12	1	1	Transitional Preschool 2	CF		Front of classroom, left faucet	<1 ppb	<1 ppb	08/11/2026 06:17	No Further Action	
39	2734-11	1	1	Transitional Preschool 2	CF		Front of classroom, right faucet	<1 ppb	<1 ppb	08/11/2026 06:17	No Further Action	
40	2734-10	1	1	Transitional Preschool 3	CF		Front of classroom, left faucet	<1 ppb	<1 ppb	08/11/2026 06:17	No Further Action	
41	2734-9	1	1	Transitional Preschool 3	CF		Front of classroom, right faucet	<1 ppb	<1 ppb	08/11/2026 06:05	No Further Action	
42	2734-8	1	1	Transitional Preschool 4	DW		Front of classroom, bubbler	<1 ppb	<1 ppb	08/11/2026 06:05	No Further Action	
43	2734-7	1	1	Transitional Preschool 4	CF		Front of classroom, right faucet	<1 ppb	<1 ppb	08/11/2026 06:05	No Further Action	

[illegible]