



OKLAHOMA DRINKING WATER

LEAD TESTING

IN PUBLIC SCHOOLS & CHILD CARE FACILITIES

Aspen Creek Church Initial Sampling Results

Samples outlined in this report were collected under the Oklahoma Lead in Schools and Child Care Program (LWSC) on 03/11/2026 from 5100 S. Aspen Ave, Broken Arrow, OK 74011.

See below for an overview of the outlet descriptions noted in the results report:

Outlet Type Code Key:

CF: Classroom Faucet

KF: Kitchen Faucet

BF: Bathroom Faucet

NS: Nurse Office Sink

RA: Refrigerator Appliance

OF: Outdoor Faucet

IM: Ice Machine

DW: Drinking Water Fountain

WC: Water Cooler With Chiller Unit

Water Cooler Definition: A machine that is connected to the building's water supply for a continuous supply of water and to electricity to run a refrigeration unit to cool the incoming water.

Drinking Fountain Definition: A machine that is connected to the building's water supply for a continuous supply of water.

#	Outlet ID	Building #	Floor #	Room # / Name	Outlet Type Code	Water Cooler Make and Model	Comments	Initial First Draw Result Final (ppb)	Initial Flush Draw Result Final (ppb)	Initial Sample Date(s)	Action Needed?	Remediation Action Taken
1	2908-9	1	1	Mens bathroom, left	BF			5.3 ppb	<1 ppb	3/11/2026 5:45:00 AM	Remediation Recommended	
2	2908-10	1	1	Mens bathroom, right	BF			2.63 ppb	<1 ppb	3/11/2026 5:45:00 AM	Remediation Recommended	
3	2908-14	1	1	2 year old room bathroom	BF			<1 ppb	1.56 ppb	3/11/2026 5:45:00 AM	Remediation Recommended	
4	2908-3	1	1	Lobby bathroom, right	BF			1.4 ppb	<1 ppb	3/11/2026 5:45:00 AM	Remediation Recommended	
5	2908-4	1	1	Lobby kitchen, kitchen sink	KF			1.14 ppb	1.31 ppb	3/11/2026 5:45:00 AM	Remediation Recommended	
6	2908-13	1	1	Adults bathroom	BF			1.04 ppb	<1 ppb	3/11/2026 5:45:00 AM	Remediation Recommended	
7	2908-1	1	1	Entry/lobby fountain	WC	Elkay		<1 ppb	<1 ppb	3/11/2026 5:45:00 AM	No Further Action	
8	2908-2	1	1	Lobby bathroom, left	BF			<1 ppb	<1 ppb	3/11/2026 5:45:00 AM	No Further Action	
9	2908-5	1	1	Lobby kitchen, shorter sink	KF		Not hand wash only	<1 ppb	<1 ppb	3/11/2026 5:45:00 AM	No Further Action	
10	2908-6	1	1	Kitchen, sink against wall	KF		Not hand wash only	<1 ppb	<1 ppb	3/11/2026 5:45:00 AM	No Further Action	
11	2908-7	1	1	Kitchen, island sink	KF			<1 ppb	<1 ppb	3/11/2026 5:45:00 AM	No Further Action	
12	2908-8	1	1	Kitchen, ice machine	IM	Koolaire, scotsman		<1 ppb		3/11/2026 5:45:00 AM	No Further Action	
13	2908-11	1	1	Pre k bathroom	BF			<1 ppb	<1 ppb	3/11/2026 5:45:00 AM	No Further Action	

