



OKLAHOMA DRINKING WATER

LEAD TESTING

IN PUBLIC SCHOOLS & CHILD CARE FACILITIES

Tj'S Touch Of Joy Phase Iii Initial Sampling Results

Samples outlined in this report were collected under the Oklahoma Lead in Schools and Child Care Program (LWSC) on 06/24/2026 from 7749 NW 79th Place, Oklahoma City, OK 73132.

See below for an overview of the outlet descriptions noted in the results report:

Outlet Type Code Key:

CF: Classroom Faucet

KF: Kitchen Faucet

BF: Bathroom Faucet

NS: Nurse Office Sink

RA: Refrigerator Appliance

OF: Outdoor Faucet

IM: Ice Machine

DW: Drinking Water Fountain

WC: Water Cooler With Chiller Unit

Water Cooler Definition: A machine that is connected to the building's water supply for a continuous supply of water and to electricity to run a refrigeration unit to cool the incoming water.

Drinking Fountain Definition: A machine that is connected to the building's water supply for a continuous supply of water.

#	Outlet ID	Buildin g #	Floor #	Room # / Name	Outlet Type Code	Water Cooler Make and Model	Comments	Initial First Draw Result Final (ppb)	Initial Flush Draw Result Final (ppb)	Initial Sample Date(s)	Action Needed?	Remediation Action Taken
1	3076-11	1	1	Lions, bathroom	BF		Bathroom faucet	1.21 ppb	<1 ppb	6/24/2026 6:00:00 AM	Remediation Recommended	
2	3076-2	1	1	Front room, right	WC	Elkay		<1 ppb	<1 ppb	6/24/2026 6:00:00 AM	No Further Action	
3	3076-1	1	1	Front room, left	WC	Elkay		<1 ppb	<1 ppb	6/24/2026 6:00:00 AM	No Further Action	
4	3076-3	1	1	Jaguars class, main room	CF			<1 ppb	<1 ppb	6/24/2026 6:00:00 AM	No Further Action	
5	3076-6	1	1	Leopards, bathroom	BF		Bathroom faucet	<1 ppb	<1 ppb	6/24/2026 6:00:00 AM	No Further Action	
6	3076-5	1	1	Leopards, main room sink	CF			<1 ppb	<1 ppb	6/24/2026 6:00:00 AM	No Further Action	
7	3076-4	1	1	Jaguars, bathroom	BF		Bathroom faucet	<1 ppb	<1 ppb	6/24/2026 6:00:00 AM	No Further Action	
8	3076-7	1	1	Kitchen	KF		3 bay sink	<1 ppb	<1 ppb	6/24/2026 6:00:00 AM	No Further Action	
9	3076-8	1	1	Cubs	CF			<1 ppb	<1 ppb	6/24/2026 6:00:00 AM	No Further Action	
10	3076-9	1	1	Cheetahs, main room	CF			<1 ppb	<1 ppb	6/24/2026 6:00:00 AM	No Further Action	
11	3076-12	1	1	Cheetahs, bathroom	BF		Bathroom faucet	<1 ppb	<1 ppb	6/24/2026 6:00:00 AM	No Further Action	
12	3076-10	1	1	Lions, main room sink	CF			<1 ppb	<1 ppb	6/24/2026 6:00:00 AM	No Further Action	