OKLAHOMA DRINKING WATER
LEAD TESTING
IN PUBLIC SCHOOLS & CHILD CARE FACILITIES

Central Es
Post Remediation
Sampling Results

Samples outlined in this report were collected under the Oklahoma Lead in Schools and Child Care Program (LWSC) on 08/28/2026 from 123 Northwest Second Street, Moore, OK 73160.

See below for an overview of the outlet descriptions noted in the results report:

Outlet Type Code Key:
DW: Drinking Water Fountain
WC: Water Cooler With Chiller Unit
CF: Classroom Faucet
KF: Kitchen Faucet
BF: Bathroom Faucet
NS: Nurse Office Sink
RA: Refrigerator Appliance
OF: Outdoor Faucet
IM: Ice Machine

Water Cooler Definition: A machine that is connected to the building's water supply for a continuous supply of water and to electricity to run a refrigeration unit to cool the incoming water.

Drinking Fountain Definition: A machine that is connected to the building's water supply for a continuous supply of water.

#	Outlet ID	Building #	Floor #	Room # / Name	Outlet Type Code	Water Cooler Make and Model	Comments	PR First Draw Result Final (ppb)	PR Flush Draw Result Final (ppb)	PR Sample Date(s)	PR Action Needed?	Remediation Action Taken
1	3428-29	1	1	Room 19	CF			2.7 ppb	<1 ppb	08/28/2026 08:15	Remediation Recommended	
2	3428-31	1	1	Room 21	CF			18.5 ppb	<1 ppb	08/28/2026 08:15	Remediation Strongly Suggested	