



OKLAHOMA DRINKING WATER

LEAD TESTING

IN PUBLIC SCHOOLS & CHILD CARE FACILITIES

Central Es Initial Sampling Results

Samples outlined in this report were collected under the Oklahoma Lead in Schools and Child Care Program (LWSC) on 06/26/2026 from 123 Northwest Second Street, Moore, OK 73160.

See below for an overview of the outlet descriptions noted in the results report:

Outlet Type Code Key:

CF: Classroom Faucet

KF: Kitchen Faucet

BF: Bathroom Faucet

NS: Nurse Office Sink

RA: Refrigerator Appliance

OF: Outdoor Faucet

IM: Ice Machine

DW: Drinking Water Fountain

WC: Water Cooler With Chiller Unit

Water Cooler Definition: A machine that is connected to the building's water supply for a continuous supply of water and to electricity to run a refrigeration unit to cool the incoming water.

Drinking Fountain Definition: A machine that is connected to the building's water supply for a continuous supply of water.

#	Outlet ID	Building #	Floor #	Room # / Name	Outlet Type Code	Water Cooler Make and Model	Comments	Initial First Draw Result Final (ppb)	Initial Flush Draw Result Final (ppb)	Initial Sample Date(s)	Action Needed?	Remediation Action Taken
1	3428-31	1	1	Room 21	CF			23.5 ppb	1.46 ppb	6/26/2026 6:30:00 AM	Remediation Strongly Suggested	
2	3428-29	1	1	Room 19	CF			11 ppb	<1 ppb	6/26/2026 6:30:00 AM	Remediation Strongly Suggested	
3	3428-26	1	1	Room 17	CF			9.54 ppb	<1 ppb	6/26/2026 6:30:00 AM	Remediation Recommended	
4	3428-9	1	1	Room 13	CF			8.99 ppb	<1 ppb	6/26/2026 6:30:00 AM	Remediation Recommended	
5	3428-24	1	1	Room 18	CF			7.56 ppb	<1 ppb	6/26/2026 6:30:00 AM	Remediation Recommended	
6	3428-22	1	1	Room 15	CF			6.84 ppb	<1 ppb	6/26/2026 6:30:00 AM	Remediation Recommended	
7	3428-18	1	1	Kitchen, outside of office, right	KF			5.01 ppb	<1 ppb	6/26/2026 6:30:00 AM	Remediation Recommended	
8	3428-27	1	1	Room 17	DW		Bubbler	4.86 ppb	<1 ppb	6/26/2026 6:30:00 AM	Remediation Recommended	
9	3428-30	1	1	Room 22	DW		Bubbler/faucet	4.66 ppb	<1 ppb	6/26/2026 6:30:00 AM	Remediation Recommended	
10	3428-3	1	1	Outside of 250	WC	Elkay		3.55 ppb	4.31 ppb	6/26/2026 6:30:00 AM	Remediation Recommended	
11	3428-8	1	1	Room 11	CF			4.27 ppb	<1 ppb	6/26/2026 6:30:00 AM	Remediation Recommended	
12	3428-25	1	1	Room 18	DW		Bubbler	2.92 ppb	<1 ppb	6/26/2026 6:30:00 AM	Remediation Recommended	
13	3428-7	1	1	Room 12	CF			2.77 ppb	<1 ppb	6/26/2026 6:30:00 AM	Remediation Recommended	
14	3428-13	1	1	Cafeteria, middle left	WC			1.45 ppb	2.51 ppb	6/26/2026 6:30:00 AM	Remediation Recommended	
15	3428-15	1	1	Cafeteria, far right	WC			1.12 ppb	2.25 ppb	6/26/2026 6:30:00 AM	Remediation Recommended	

#	Outlet ID	Building #	Floor #	Room # / Name	Outlet Type Code	Water Cooler Make and Model	Comments	Initial First Draw Result Final (ppb)	Initial Flush Draw Result Final (ppb)	Initial Sample Date(s)	Action Needed?	Remediation Action Taken
16	3428-19	1	1	Kitchen, outside of office, left	KF			2.2 ppb	<1 ppb	6/26/2026 6:30:00 AM	Remediation Recommended	
17	3428-23	1	1	Room 15	DW		Bubbler	2.08 ppb	<1 ppb	6/26/2026 6:30:00 AM	Remediation Recommended	
18	3428-10	1	1	Room 14	CF			1.99 ppb	<1 ppb	6/26/2026 6:30:00 AM	Remediation Recommended	
19	3428-20	1	1	Room 16	CF			1.86 ppb	<1 ppb	6/26/2026 6:30:00 AM	Remediation Recommended	
20	3428-35	1	1	Outside of 15, middle right	WC	Elkay		1.52 ppb	1.61 ppb	6/26/2026 6:30:00 AM	Remediation Recommended	
21	3428-4	1	1	Outside of 10, left	WC	Elkay LZWSR_1B	Bottle filler, red filter status	1.22 ppb	1.32 ppb	6/26/2026 6:30:00 AM	Remediation Recommended	
22	3428-5	1	1	Outside of 10, left	WC	Elkay LZWSR_1B		1.21 ppb	<1 ppb	6/26/2026 6:30:00 AM	Remediation Recommended	
23	3428-37	1	1	Outside of 113, left	WC	Elkay		<1 ppb	1.12 ppb	6/26/2026 6:30:00 AM	Remediation Recommended	
24	3428-1	1	1	Front entrance	WC	Elkay		<1 ppb	1.02 ppb	6/26/2026 6:30:00 AM	Remediation Recommended	
25	3428-2	1	1	Outside of room 6	WC	Elkay		<1 ppb	<1 ppb	6/26/2026 6:30:00 AM	No Further Action	
26	3428-6	1	1	Outside of 10, right	WC	Elkay		<1 ppb	<1 ppb	6/26/2026 6:30:00 AM	No Further Action	
27	3428-12	1	1	Cafeteria, far left	WC	Elkay LZWSR_1D		<1 ppb	<1 ppb	6/26/2026 6:30:00 AM	No Further Action	
28	3428-14	1	1	Cafeteria, middle right	WC	Elkay		<1 ppb	<1 ppb	6/26/2026 6:30:00 AM	No Further Action	
29	3428-11	1	1	Cafeteria, far left	WC	Elkay LZWSR_1D	Bottle filler	<1 ppb	<1 ppb	6/26/2026 6:30:00 AM	No Further Action	
30	3428-17	1	1	Kitchen, center	KF			<1 ppb	<1 ppb	6/26/2026 6:30:00 AM	No Further Action	

[illegible]