OKLAHOMA DRINKING WATER
LEAD TESTING
IN PUBLIC SCHOOLS & CHILD CARE FACILITIES

# Irving Ms
# Initial Sampling Results

Samples outlined in this report were collected under the Oklahoma Lead in Schools and Child Care Program (LWSC) on 10/15/2026 from 125 Vicksburg Avenue, Norman, OK 73071.

See below for an overview of the outlet descriptions noted in the results report:

Outlet Type Code Key:
CF: Classroom Faucet
KF: Kitchen Faucet
BF: Bathroom Faucet
NS: Nurse Office Sink
RA: Refrigerator Appliance
OF: Outdoor Faucet
IM: Ice Machine
DW: Drinking Water Fountain
WC: Water Cooler With Chiller Unit

Water Cooler Definition: A machine that is connected to the building's water supply for a continuous supply of water and to electricity to run a refrigeration unit to cool the incoming water.

Drinking Fountain Definition: A machine that is connected to the building's water supply for a continuous supply of water.

| # | Outlet ID | Building # | Floor # | Room # / Name | Outlet Type Code | Water Cooler Make and Model | Comments | Initial First Draw Result Final (ppb) | Initial Flush Draw Result Final (ppb) | Initial Sample Date(s) | Action Needed? | Remediation Action Taken |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| 1 | 3480-1 | 1 | 1 | Across the library | WC | Elkay ezH2O | BF | <1 ppb | <1 ppb | 10/15/2026 05:00 | No Further Action | |
| 2 | 3480-2 | 1 | 1 | Across the library | WC | Elkay ezH2O | WF | <1 ppb | <1 ppb | 10/15/2026 05:00 | No Further Action | |
| 3 | 3480-3 | 1 | 1 | Across the gym | WC | Elkay ezH2O | BF | <1 ppb | <1 ppb | 10/15/2026 05:00 | No Further Action | |
| 4 | 3480-4 | 1 | 1 | Across the gym | WC | Elkay ezH2O | WF | <1 ppb | <1 ppb | 10/15/2026 05:00 | No Further Action | |
| 5 | 3480-5 | 1 | 1 | Cafeteria | WC | Elkay ezH2O | BF to the left | <1 ppb | <1 ppb | 10/15/2026 05:00 | No Further Action | |
| 6 | 3480-6 | 1 | 1 | Cafeteria | WC | Elkay ezH2O | WF to the left | <1 ppb | <1 ppb | 10/15/2026 05:00 | No Further Action | |
| 7 | 3480-7 | 1 | 1 | Cafeteria | WC | Elkay | WF to the right | <1 ppb | <1 ppb | 10/15/2026 05:00 | No Further Action | |
| 8 | 3480-8 | 1 | 1 | Across Room E4 | WC | Elkay | WF | <1 ppb | <1 ppb | 10/15/2026 05:00 | No Further Action | |
| 9 | 3480-9 | 1 | 1 | Next to Room E1 | WC | Elkay ezH2O | BF | <1 ppb | <1 ppb | 10/15/2026 05:00 | No Further Action | |
| 10 | 3480-10 | 1 | 1 | Next to Room E1 | WC | Elkay ezH2O | WF | <1 ppb | <1 ppb | 10/15/2026 05:00 | No Further Action | |
| 11 | 3480-11 | 1 | 1 | Next to Room S6 | WC | Elkay ezH2O | BF | <1 ppb | <1 ppb | 10/15/2026 05:00 | No Further Action | |
| 12 | 3480-12 | 1 | 1 | Next to Room S6 | WC | Elkay ezH2O | WF | <1 ppb | <1 ppb | 10/15/2026 05:00 | No Further Action | |
| 13 | 3480-13 | 1 | 1 | Across 6th grade bathroom | WC | Elkay ezH2O | BF to the left | <1 ppb | <1 ppb | 10/15/2026 05:00 | No Further Action | |
| 14 | 3480-14 | 1 | 1 | Across 6th grade bathroom | WC | Elkay ezH2O | WF to the left | <1 ppb | <1 ppb | 10/15/2026 05:00 | No Further Action | |
| 15 | 3480-15 | 1 | 1 | Across from 6th grade bathroom | WC | Elkay ezH2O | WF to the right | <1 ppb | <1 ppb | 10/15/2026 05:00 | No Further Action | |

| # | Outlet ID | Building # | Floor # | Room # / Name | Outlet Type Code | Water Cooler Make and Model | Comments | Initial First Draw Result Final (ppb) | Initial Flush Draw Result Final (ppb) | Initial Sample Date(s) | Action Needed? | Remediation Action Taken |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| 16 | 3480-16 | 1 | 1 | Across from 7th grade bathroom | WC | Elkay ezH2O | BF | <1 ppb | <1 ppb | 10/15/2026 05:00 | No Further Action | |
| 17 | 3480-17 | 1 | 1 | Across from 7th grade bathroom | WC | Elkay ezH2O | WF | <1 ppb | <1 ppb | 10/15/2026 05:00 | No Further Action | |
| | | | | | | | | | | | | |